

SEP 7 1960

Lvall E. Johnson, Chief,
Licensing Branch

Clifford K. Beck, Chief,
Hazards Evaluation Branch

Beck

CURTISS-WRIGHT REACTOR

We reviewed the proposed procedure to shut down the Curtiss-Wright research reactor for a period of one year. The facility will be on a standby basis during this period.

The procedures for the storage of the fuel elements and other radioactive materials as well as the periodical radiation monitoring system appears to be satisfactory and provides suitable protection for the public. We recommend the approval of the request.

OK

D-200

OFFICE ▶	HEB:DL&R	HEB:DL&R	HEB:DL&R			
SURNAME ▶	NGrossman	Hirst	CKBeck			
DATE ▶						