



UNIVERSITY OF WASHINGTON

OFFICE OF THE DEAN  
College of Engineering

July 23, 2003

Office of Nuclear Reactor Regulations  
Mail Stop OSE7  
US Nuclear Regulatory Commission  
Washington, DC 20555

Docket No. 50-139

Enclosed is the routine Annual Report for the period July 1, 2002 to June 30, 2003 in accordance with Section III. G.3 of Appendix A, Technical Specifications for Facility License No. R-73.

Please let me know if additional information is needed relative to this report.

Sincerely yours,

Denice Denton, Dean  
College of Engineering

MC:rb

Cc: NRC Region IV  
S. Addison, Environmental Health & Safety, Box 354400  
B. Pankow, Environmental Health & Safety, Box 354400

RECEIVED  
JUL 24 2003  
RADIATION SAFETY EH&S

Rec'd 3/31/04  
A020

**ANNUAL REPORT FROM THE  
UNIVERSITY OF WASHINGTON**

*Facility License R-73*

*Docket No. 50-139*

**A. Discussion of Changes Carried Out Pursuant to 10 CFR 50.59**

None.

**B. Radioactive Releases to the Environs**

1. Stack monitoring is no longer required.
2. There were no releases to the sanitary sewer during this period.

**C. Environmental Surveys Outside the Facility**

Survey meter surveys of retention tank area gave background readings.

**D. Significant Exposures (over 100 mrem for year)**

During the period July 2002 through June 2003 there were no significant exposures, i.e., over 100 mrem.

RECEIVED  
JUL 24 2003  
RADIATION SAFETY EH&S