

March 31, 2004

Mr. Bryce L. Shriver  
Senior Vice President  
and Chief Nuclear Officer  
PPL Susquehanna, LLC  
769 Salem Boulevard NUCSB3  
Berwick, PA 18603-0467

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2 - REQUEST FOR  
ADDITIONAL INFORMATION (RAI) - MINIMUM CRITICAL POWER RATIO  
SAFETY LIMITS (TAC NO. MC0837)

Dear Mr. Shriver:

In reviewing your application of September 16, 2003, the Nuclear Regulatory Commission staff has determined that additional information contained in the enclosure to this letter is needed to complete its review. We discussed this issue with your staff during a conference call on March 25, 2004. As we indicated during our conversation, we are enclosing a formal RAI. The enclosed questions have been revised from the draft RAI to exclude the questions that were answered during the conference call. As agreed to by your staff, we request you respond within 30 days of the date of this letter.

If you have any questions, please contact me at 301-415-1030.

Sincerely,

*/RA/*

Richard V. Guzman, Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-388

Enclosure: RAI

cc w/encl: See next page

March 31, 2004

Mr. Bryce L. Shriver  
Senior Vice President  
and Chief Nuclear Officer  
PPL Susquehanna, LLC  
769 Salem Boulevard  
Berwick, PA 18603-0467

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2 - REQUEST FOR  
ADDITIONAL INFORMATION (RAI) - MINIMUM CRITICAL POWER RATIO  
SAFETY LIMITS (TAC NO. MC0837)

Dear Mr. Shriver:

In reviewing your application of September 16, 2003, the Nuclear Regulatory Commission staff has determined that additional information contained in the enclosure to this letter is needed to complete its review. We discussed this issue with your staff during a conference call on March 25, 2004. As we indicated during our conversation, we are enclosing a formal RAI. The enclosed questions have been revised from the draft RAI to exclude the questions that were answered during the conference call. As agreed to by your staff, we request you respond within 30 days of the date of this letter.

If you have any questions, please contact me at 301-415-1030.

Sincerely,

*/RA/*

Richard V. Guzman, Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-388

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

Public OGC BBixler, RI THaung FAKstulewicz SWall  
PDI-1 R/F RLaufer MO'Brien ACRS RGuzman

Accession Number: ML040910361

OFFICE	PDI-1/PM	PDI-2/LA	SRXB/SC	PDI-1/SC
NAME	RGuzman	MO'Brien	FAkstulewicz	RLaufer
DATE	3/30/04	3/30/04	3/31/04	3/31/04

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION  
RELATING TO PROPOSED AMENDMENT TO REVISE  
MINIMUM CRITICAL POWER RATIO SAFETY LIMITS  
PPL SUSQUEHANNA, LLC  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2  
DOCKET NO. 50-388

The Nuclear Regulatory Commission staff is reviewing the proposed license amendment request to Facility Operating License No. NPF-22, relating to minimum critical power ratio safety limits (MCPRSL) dated September 16, 2003, and has found further clarification is needed as follows:

1. Provide a reference core loading pattern for Unit 2 Cycle 12 (U2C12) operation and a detailed description of the final core and fuel design to achieve a 24-month fuel reload cycle at the licensed rated power of 3489 MWt.
2. Identify the approved methodologies used in the U2C12 analysis and justify their applicability to the MCPRSL analysis for U2C12 operation. Also, identify the design documents (i.e. calculations) to support the proposed technical specification amendment, and provide a summary table or figure to show the number of rods that might experience boiling transition.
3. Provide a detailed description of the differences in calculating the mid-cycle U2C12 MCPRSL relative to the beginning-of-cycle U2C12 MCPRSL in terms of power distribution uncertainties and neutronic codes/methodologies used; and provide a detailed explanation of how the decrease in the MCPRSL is largely due to the incorporation of smaller power distribution uncertainties. Justify that the proposed MCPRSL reduction of 0.02 is conservative.

Enclosure

Susquehanna Steam Electric Station, Unit Nos. 1 and 2

cc:

Richard L. Anderson  
Vice President - Nuclear Operations  
PPL Susquehanna, LLC  
769 Salem Blvd., NUCSB3  
Berwick, PA 18603-0467

Dale F. Roth  
Manager - Quality Assurance  
PPL Susquehanna, LLC  
769 Salem Blvd., NUCSB2  
Berwick, PA 18603-0467

Aloysius J. Wrape, III  
General Manager - Nuclear Assurance  
PPL Susquehanna, LLC  
Two North Ninth Street, GENPL4  
Allentown, PA 18101-1179

Herbert D. Woodeshick  
Special Office of the President  
PPL Susquehanna, LLC  
634 Salem Blvd., SSO  
Berwick, PA 18603-0467

Terry L. Harpster  
General Manager - Plant Support  
PPL Susquehanna, LLC  
769 Salem Blvd., NUCSA4  
Berwick, PA 18603-0467

Bryan A. Snapp, Esq  
Assoc. General Counsel  
PPL Services Corporation  
Two North Ninth Street, GENTW3  
Allentown, PA 18101-1179

Robert A. Saccone  
General Manager - Nuclear Engineering  
PPL Susquehanna, LLC  
769 Salem Blvd., NUCSB3  
Berwick, PA 18603-0467

Supervisor - Document Control Services  
PPL Susquehanna, LLC  
Two North Ninth Street, GENPL4  
Allentown, PA 18101-1179

Rocco R. Sgarro  
Manager - Nuclear Regulatory Affairs  
PPL Susquehanna, LLC  
Two North Ninth Street, GENPL4  
Allentown, PA 18101-1179

Richard W. Osborne  
Allegheny Electric Cooperative, Inc.  
212 Locust Street  
P.O. Box 1266  
Harrisburg, PA 17108-1266

Walter E. Morrissey  
Supervising Engineer  
Nuclear Regulatory Affairs  
PPL Susquehanna, LLC  
769 Salem Blvd., NUCSA4  
Berwick, PA 18603-0467

Director - Bureau of Radiation Protection  
Pennsylvania Department of  
Environmental Protection  
P.O. Box 8469  
Harrisburg, PA 17105-8469

Michael H. Crowthers  
Supervising Engineer  
Nuclear Regulatory Affairs  
PPL Susquehanna, LLC  
Two North Ninth Street, GENPL4  
Allentown, PA 18101-1179

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 35, NUCSA4  
Berwick, PA 18603-0035

Regional Administrator, Region 1  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Susquehanna Steam Electric Station, Unit Nos. 1 and 2

cc:

Board of Supervisors  
Salem Township  
P.O. Box 405  
Berwick, PA 18603-0035

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
443 Orlando Avenue  
State College, PA 16803