

Office Memorandum • UNITED STATES GOVERNMENT

TO : Lyall E. Johnson, Chief, Licensing Branch, DATE: MAR 6 1958
Division of Licensing and Regulation

FROM : Marvin M. Mann, Assistant Director for Compliance, Division of Inspection *Mmm for m³*

SUBJECT: CURTISS-WRIGHT RESEARCH REACTOR

Symbol: INS:PAM

ME

A preoperational inspection of the Curtiss-Wright research reactor, at Quehanna, Pennsylvania, was made on March 5, 1958. The construction of this facility was observed to be complete, with the exception that no provision is now available for cooling by forced circulation.

This memorandum is to help expedite the issuance of a license to operate, with the condition that the maximum power level allowed be restricted to that which is acceptable with circulation by natural convection only, until such time as provision for forced circulation has been demonstrated.

A report of this investigation is now in preparation.

D-80

MAR 6 1958

Division of Licensing and Regulation

Marvin M. Mann, Assistant Director for
Compliance, Division of Inspection

CURTISS-WRIGHT RESEARCH REACTOR

Symbol: INS:PAM

A preoperational inspection of the Curtiss-Wright research reactor, at Quehanna, Pennsylvania, was made on March 5, 1958. The construction of this facility was observed to be complete, with the exception that no provision is now available for cooling by forced circulation.

This memorandum is to help expedite the issuance of a license to operate, with the condition that the maximum power level allowed be restricted to that which is acceptable with circulation by natural convection only, until such time as provision for forced circulation has been demonstrated.

A report of this investigation is now in preparation.