

Docket 50-39

APR 8 1958

Dr. John R. Torquato, Secretary  
Department of Labor and Industry  
South Office Building  
Harrisburg, Pennsylvania

Dear Dr. Torquato:

This is to inform you that the Atomic Energy Commission has submitted for publication in the Federal Register the attached notice of proposed issuance of a facility license to Curtiss-Wright Corporation authorizing operation of a 1000 kilowatt (thermal) light water moderated pool-type research reactor at the Corporation's Research and Development Center near Quakama, Pennsylvania.

Also attached is a copy of a memorandum setting forth the principal factors considered in reviewing the application.

You will note that the proposed license incorporates a condition that until equipment providing forced circulation has been installed the power level is limited to a maximum of 100 kilowatts.

Sincerely yours,

DISTRIBUTION

G. W. Morgan, L&R  
Helen Steele, L&R  
Formal  
Suppl.  
Doc. Rm.  
L<sub>h</sub> reading  
L&R reading

H. L. Price  
Director  
Division of Licensing and Regulation

Enclosures:

1. Notice of Proposed Issuance
2. Memorandum

OFFICE ▶	L&R	L&R	L&R				
SURNAME ▶	CTEdwards/mjm	LJohnson	HLPrice				
DATE ▶	4/8/58	4/8	4/8				

0-90

APR 8 1958

Docket 50-39

Dr. John R. Torquato, Secretary  
Department of Labor and Industry  
South Office Building  
Harrisburg, Pennsylvania

Dear Dr. Torquato:

This is to inform you that the Atomic Energy Commission has submitted for publication in the Federal Register the attached notice of proposed issuance of a facility license to Curtiss-Wright Corporation authorizing operation of a 1000 kilowatt (thermal) light water moderated pool-type research reactor at the Corporation's Research and Development Center near Quakana, Pennsylvania.

Also attached is a copy of a memorandum setting forth the principal factors considered in reviewing the application.

You will note that the proposed license incorporates a condition that until equipment providing forced circulation has been installed the power level is limited to a maximum of 100 kilowatts.

Sincerely yours,

H. L. Price  
Director  
Division of Licensing and Regulation

Enclosures:

1. Notice of Proposed Issuance
2. Memorandum