

Licensee/Facility:

FIRSTENERGY NUCLEAR OPERATING CO.
Davis-besse
Oak Harbor, Ohio
Dockets: 050-00346
[1] B&W-L-LP

Notification:

MR Number: 3-2004-0027
Date: 04/06/2004
RIII- Via Teleconf. with Site

Subject: Davis-Besse Synchronized to Grid

Discussion:

This information is current as of 10:00 a.m. (EDT) on April 6, 2004. The plant is currently in Mode 1 at 100% percent power. The plant performed a down-power evolution April 5 to establish plant conditions to support de-energizing the D2 non-essential 4.16 kV switchgear bus and replacement of a faulty feeder breaker to the D2 bus. The feeder breaker was identified as faulty when, during a routine breaker swap preventive maintenance evolution, the breaker failed to open using the remote control switch. Following the down-power evolution, the D2 bus was de-energized, and the breaker was removed from the enclosure. The D2 bus was re-energized via the normal alternate power source, and the plant returned to 100% power. The replacement breaker will be installed following completion of trouble-shooting efforts on the faulty breaker. Around-the-clock resident inspector coverage was utilized to monitor plant evolutions and maintenance activities.

□

The Davis-Besse Oversight Panel will continue to monitor plant activities utilizing enhanced inspection oversight coverage. For non-routine evolutions occurring after normal working hours, enhanced inspection oversight coverage will continue to be expanded to monitor these activities.

□□□□□□□□□□

Regional Action:□For Information Only

Contact:

THOMAS, C S

Org:

R3

Phone No:

(419) 244-4494

Email:

CST1@nrc.gov