



Pressure Boundary Materials

(Non-proprietary Version)

Marc Léger

Director, Materials Engineering

Presentation to US Nuclear Regulatory Commission

Washington DC

March 04, 2004



 **AECL**
TECHNOLOGIES INC.



Outline

- **Material Selection for Class 1 Boundary**
 - Feeders
 - Steam generators
 - Fuel channel materials
- **Compliance with regulatory guides where applicable**
- **Discussion of several issues of potential in-service degradation of components**



Material Selection

- **Feeder material will be austenitic stainless steel SA 312 TP 316N**
 - Additional specification to reduce carbon concentration
- **Piping and pressure vessels will be ferritic carbon steel meeting Appendix I of Section III of ASME**
- **Fuel channel materials not specified in ASME code**
 - Acceptance to be based on database of material property information and experience in existing CANDU



Feeder Compliance with RG 1.36

- **To prevent external stress corrosion cracking (ESCC) any insulation material that will be in contact with the component is tested in accordance with ASTM C 692 and the chemical analysis of the insulation material meets the requirements of ASTM C 795.**
- **All austenitic stainless steel pipe in contact with insulation is painted with silicone-based ThurmaloX 70 paint.**



Feeder Compliance with RG 1.44 and RG 1.37

- **Austenitic stainless steel components are protected against contaminants that can cause stress corrosion cracking**
- **Raw austenitic stainless steels material is supplied in solution heat treated condition**
- **The 'L' grade variant with C < 0.03 wt% of the un-stabilized austenitic stainless steels is specified**
- **All RCPB austenitic stainless steels are screened in accordance with ASTM A 262 to ensure non-susceptibility to stress corrosion cracking**



Feeder Compliance with RG 1.31, RG 1.34 and RG 1.71

- **All austenitic stainless steel filler metal used for welding of RCPB components meet the requirements of NB-2340 of the ASME BPVC, Section III, Division I**
- **All welding is performed according to the requirements of Articles NB-2400 and NB-4300 of ASME, Section III, Division I, using low hydrogen filler material only**
- **Austenitic stainless steel welds and repair welds exposed to system fluid are solution annealed; when impractical, a low heat input welding process with restricted low interpass temperature is used.**



Steam Generators

- **No exceptions to ASME requirements**
- **Steam generator construction practice and materials will be consistent with the best practices and information available**
 - **CANDU 6 reactors have ferritic stainless steel support structure and Incoloy 800 tubing**
 - **Very few problems experienced**
- **AECL has expertise in SG design, thermal hydraulic analysis, materials and chemistry requirements for long life**
- **Reference tubing material is Incoloy 800 with Inconel 690 judged acceptable also**




Fuel Channels

- **Pressure tube**
 - Pressure tubes are designed to ASME Section III NB3200
 - Tubes meet CAN/CSA Standard N285.6 and additional AECL Technical Specifications for material
 - Zr-2.5%Nb is an ASTM Standard B353 (UNS R60901) material
 - ASME – type criteria apply for allowable design stress levels
 - Tubes are a consistent, high quality product
 - Current production tubes have improved properties compared to earlier production achieved by improved material specifications and production methods – especially with respect to fracture toughness properties after irradiation – a result of R&D programs in fracture area



Double Melt vs. Quadruple Melted Material





Materials Degradation Issues

- **Rolled joint integrity and corrosion**
- **Garther spring material**
- **Annulus gas system performance**



Rolled Joint Integrity and Corrosion

- **Leakage experience – of the joint – not the pressure tube**
 - **Leakage rates usually exceptionally low and are not abnormal pressure boundary leaks**



Annulus Gas Performance



Annulus Gas Performance

- With added oxygen get hydrogen isotope reaction to produce additional water through this reaction:



- Additional reactions a result of radiation



Annulus Gas Performance



Annulus Gas Performance

- **Dewpoint rate of rise without any abnormal system leaks corresponds to water ingress from all joints combined at the rate of the order of 0.1 g/hr (grams per hour)**
 - **Much of the moisture may come from hydrogen isotope permeation through the end fitting material**



Rolled Joint Integrity and Corrosion

- **Leakage experience – of the joint – not the pressure tube**
 - **Extremely rare experience of abnormal leakage**
 - **In approximately 400 years of reactor experience there has been one joint removed due to excessive leakage**
 - **Leak rate increased over a period of months to 4 g/hr**
 - **Channel located within an annulus gas “string”**
 - **Channel inspection found individual leaking channel**
 - **Examination after removal showed that leak was caused by a scratch on the outside surface of the pressure tube that was likely formed during assembly but oxidized over time and finally led to leak**
- **Such small leakage cannot result in any component damage and none was observed**



Rolled Joint Integrity and Corrosion

- **ACR rolled joints must be shown by qualification testing to have similar very low, normal leakage**
 - **Virtually leak tight**
- **Developmental program is currently underway**




Rolled Joint Integrity and Corrosion

- **Galvanic corrosion effects in rolled joint lead to hydrogen ingress but total amount of corrosion is small**
- **Rolled joint corrosion not considered to be an integrity issue**



Rolled Joint Integrity and Corrosion



Note: Amount of corrosion-freed hydrogen entering metal is not to scale.



Rolled Joint Integrity and Corrosion

End Fitting

Pressure Tube

Inlet Rolled Joint After ~ 100,000 hrs of operation



Degradation of Components in Annulus System due to Moisture

- Annulus gas system is maintained dry during operation
- No opportunity for SCC under normal circumstances
 - No electrolyte can be present unless annulus becomes wet



Annulus Gas Pigtails

- **Plugging of pigtails occurred in only a few units**
- **Some units operating without oxygen addition do not observe any annulus flow blockages**
- **Plants that had blockages and added oxygen no longer experience blockages**
- **Blockages detected by checks of flow rotameters**
- **Consequence of blocked pigtail is longer detection time for leaks into the system. For a pressure tube leak, blockage would be cleared by increasing pressure as coolant enters the system.**




Annulus Gas Flowsheet

OUTLET TUBES
CIRCUIT 1: 36 STRINGS

CIRCUIT 1: 36 STRINGS x 4 CHANNELS
CIRCUIT 2: 35 STRINGS x 4 CHANNELS
TOTAL : (36x4) + (35x4) = 284 CHANNELS

INLET TUBES
CIRCUIT 1: 36 STRINGS





Predictions from Scattered Data

- In component design, for issues likely to affect the plant life, predictions of performance are based upon bounding (95%) rates – sometimes with additional margin
- Some coupled effects
 - E.g. wall thinning must account for irradiation deformation and corrosion
 - Upper bounds used for each separately
 - Strength used based on S_m in calculations



Data Outside Correlations

- **Data that falls outside correlations would generally only be removed if it could be demonstrated, with some confidence, to be not valid.**



Environmental Effects Testing

- **No evidence from pressure tube inspection or examination of surveillance pressure tubes that environmental effects are significant - except insofar as the environment causes hydrogen ingress**
- **Creep and growth tests have been carried out in water at high temperature in NRU - no effect of the environment on creep rates noted**
- **Very little pressure tube fatigue testing has been carried out in the coolant environment**
- **Tests of irradiated materials removed from surveillance tubes have been exposed to the environment but are not generally tested in the environment**



Differences between Light and Heavy Water

- Light and heavy water are chemically very similar
- Kinetics of reactions may be slightly different
- Corrosion behavior of pressure tube material and hydrogen isotope uptake during corrosion are very similar in two media
- Solubilities of hydrogen isotopes in pressure tube material are similar
- Diffusion kinetics and DHC velocities should differ by a factor of 1.4, but this small factor is difficult to determine in such tests



Pressure Tube Temperature at the Garter Spring Contact

- **Temperature will be calculated by conservative analysis – not yet done for ACR**
 - Factor in gamma heating of components
- **Temperature gradient at the garter spring should not be large enough to cause accumulation of hydride at the contact point at operating conditions even at the end-of-life**
- **Garter spring contact point changes continuously with time of operation due to pressure tube elongation**



 **AECL**
TECHNOLOGIES INC.