



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

June 4, 1998  
NOC-AE-000184  
File No.: G03.08  
10CFR50

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555-0001


South Texas Project  
Units 1 and 2  
Docket Nos. STN 50-498, STN 50-499  
Resolution of Thermo-Lag Concerns at the South Texas Project-  
Application of Regulatory Guide 1.75 Requirements

Reference: Correspondence from William T. Cottle, South Texas Project, to NRC Document Control Desk, dated April 15, 1998 (NOC-AE-000129)

The South Texas Project submits the following information to update the description of the current status of Thermo-Lag use previously provided in the referenced correspondence. In addition to the Thermo-Lag previously identified to be left in place, the South Texas Project intends to not remove Thermo-Lag found to be necessary for separation purposes under Regulatory Guide 1.75, "Physical Independence of Electric Systems."

Thermo-Lag satisfies the requirements of Regulatory Guide 1.75 for a separation barrier. Use of Thermo-Lag as a separation barrier in specified, selected areas is acceptable because there is no impact on cable ampacity in those applications and the remaining Thermo-Lag is bounded by the fire load analyses. It will not be counted as a fire barrier in these applications. Furthermore, Thermo-Lag will only be used as a separation barrier outside reactor containment.

Remaining South Texas Project efforts with regard to Thermo-Lag are planned to be completed by the end of 1998. Should that schedule change, the South Texas Project will notify the Nuclear Regulatory Commission. If there are any questions, please contact either Mr. P. L. Walker at (512) 972-8392 or me at (512) 972-8787.



T. H. Cloninger  
Vice President,  
Nuclear Engineering

1/0  
A029

PLW

9806100305 980604  
PDR ADDCK 05000498  
P PDR

Ellis W. Merschoff  
Regional Administrator, Region IV  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

Thomas W. Alexion  
Project Manager, Mail Code 13H3  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

David P. Loveless  
Sr. Resident Inspector  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, TX 77404-0910

J. R. Newman, Esquire  
Morgan, Lewis & Bockius  
1800 M. Street, N.W.  
Washington, DC 20036-5869

M. T. Hardt/W. C. Gunst  
City Public Service  
P. O. Box 1771  
San Antonio, TX 78296

A. Ramirez/C. M. Canady  
City of Austin  
Electric Utility Department  
721 Barton Springs Road  
Austin, TX 78704

Jon C. Wood  
Matthews & Branscomb  
One Alamo Center  
106 S. St. Mary's Street, Suite 700  
San Antonio, TX 78205-3692

Institute of Nuclear Power  
Operations - Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-5957

Richard A. Ratliff  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756-3189

D. G. Tees/R. L. Balcom  
Houston Lighting & Power Co.  
P. O. Box 1700  
Houston, TX 77251

Central Power and Light Company  
ATTN: G. E. Vaughn/C. A. Johnson  
P. O. Box 289, Mail Code: N5012  
Wadsworth, TX 77483