



R. A. JONES  
Vice President

Duke Power  
29672 / Oconee Nuclear Site  
7800 Rochester Highway  
Seneca, SC 29672

864 885 3158  
864 885 3564 fax

March 30, 2004

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

**SUBJECT:** Duke Energy Corporation  
Oconee Nuclear Station, Units 1, 2 and 3  
Docket Nos. 50-269, 50-270, 50-287  
Commitment Change Annual Report

Attached is a list of commitment change evaluations completed during the 2003 calendar year for Oconee Nuclear Station. These evaluations and subsequent commitment changes were made based on the guidance defined in NEI 99-04, *Guidelines for Managing NRC Commitments* and have no adverse effect on compliance with NRC rules and regulations.

If there are any questions, please contact Judy E Smith at 864-885-4309.

Sincerely,

R. A. Jones, Site Vice President

A001

U. S. Nuclear Regulatory Commission  
Commitment Change Evaluation Annual Report for 2003  
March 30, 2004  
Page 2

xc: L. A. Reyes  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, GA 30303

L. N. Olshan (addressee only)  
Project Manager  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

NRC Senior Resident Inspector  
Oconee Nuclear Station

NRC Notification Required	Number	Source Document	Original Commitment	Modified Commitment
Yes	2003-O-001	Response, July 14, 1999, to NRC Bulletin 88-08	Volumetric examinations will be performed on all HPI Safe Ends as a result of NRC Bulletin 88-08. These items are to be scheduled for every other outage for the remainder of the third inservice inspection interval. This schedule cannot be changed.	Postpone the ONS Unit 1 HPI RT examination from 1EOC21 to 1EOC22
No	2003-O-002	Response to URI 88-08-02, May 3 1988	A change will be made to reflect management decision on how or when to perform post-maintenance lubrication.	Delete Commitment concerning post-maintenance lubrication.