

**ATTACHMENT 2**

**Evaluation of Leaking McGuire 2 Containment  
Spray Piping**



**STRUCTURAL  
INTEGRITY  
Associates**

# CALCULATION PACKAGE

FILE No.: MNS-02Q-301

PROJECT No.: MNS-02Q

**PROJECT NAME:** Evaluation of Leaking McGuire 2 Containment Spray Piping

**CLIENT:** Duke Energy Corporation

**CALCULATION TITLE:** Determination of Allowable Flaw Size and Leakage

Document Revision	Affected Pages	Revision Description	Project Mgr. Approval Signature & Date	Preparer(s) & Checker(s) Signatures & Date
0	1 - 9 Computer Files	Original Issue	WF Weitze <i>WF Weitze</i> 3/18/04	WF Weitze <i>WF Weitze</i> 3/18/04 AF Deardorff <i>AF Deardorff</i> 3/18/04

## Table of Contents


1.0	OBJECTIVE .....	3
2.0	METHODOLOGY .....	3
3.0	INPUT AND ASSUMPTIONS .....	4
4.0	ANALYSIS.....	4
4.1	Allowable Flaw Size.....	4
4.2	Leakage.....	5
5.0	DISCUSSION.....	8
6.0	REFERENCES .....	9

## List of Tables

Table 1.	Allowable Flaw Size .....	5
Table 2.	Leakage Rate versus Crack Length (2c) and Sustained Bending Stress ( $P_b$ ).....	7

## List of Figures

Figure 1.	Leakage Rate versus Crack Length (2c) and Sustained Bending Stress ( $P_b$ ).....	8
-----------	---	---



Revision	0		
Preparer/Date	WFW 03/18/04		
Checker/Date	AFD 03/18/04		
File No. MNS-02Q-301		Page 2 of 9	

## 1.0 OBJECTIVE

Develop allowable flaw size (including appropriate safety factor) as a function of applied stress for the McGuire Nuclear Station (MNS) Containment Spray Piping System (NS). Calculate leakage rates based on the allowable flaw sizes.

## 2.0 METHODOLOGY

Using the limit load methodology described in Appendix C of ASME Section XI [1], C-3320, failure bending stress is calculated as follows:

$$P_b' = Z * SF (P_m + P_b + P_e / SF) - P_m \quad \text{(For flux welds)}$$

$$P_b' = SF (P_m + P_b) - P_m \quad \text{(For non-flux welds)}$$

Where Z = weld type factor  
 $P_b'$  = failure bending stress, psi  
 $P_m$  = primary membrane stress, psi  
 $P_b$  = primary bending stress, psi  
 $P_e$  = expansion bending stress, psi  
 SF = safety factor (2.77 for normal/upset; 1.39 for emergency/faulted [1])

Allowable flaw lengths at each weld location are determined using the methodology outlined in Appendix C of Section XI of the ASME Code [1]. For given values of  $P_m$  and half-flaw angle  $\theta$ , then the angle  $\beta$  to the neutral axis is calculated as:

$$\beta = \frac{1}{2} [\pi - (a/t)\theta - \pi P_m / (3S_m)], \text{ where}$$


a = flaw depth, inches  
 t = pipe wall thickness, inches  
 $S_m$  = Design stress intensity, psi

Based on  $\theta$  and  $\beta$ , a value of failure bending stress is calculated:

$$P_b' = (6S_m / \pi) [2 \sin \beta - (a/t) \sin \theta]$$

The value of  $\theta$  is varied until  $P_b'$  based on  $\theta$  and  $P_m$  equals  $P_b'$  based on the applied stresses. For longer flaws for which  $\theta + \beta > \pi$ , a somewhat different set of equations is used to calculate  $\beta$  and  $P_b'$  based on  $\theta$ , but this condition does not occur when the flaws are through-wall ( $a/t = 1$ ).

The leakage calculations are performed with the EPRI computer program PICEP [2].

	Revision	0			
	Preparer/Date	WFW 03/18/04			
	Checker/Date	AFD 03/18/04			
	File No.	MNS-02Q-301	Page 3 of 9		

### 3.0 INPUT AND ASSUMPTIONS

Duke has provided the following input [3]:

- McGuire Nuclear Station, Unit 2
- ASME Section XI, Code Edition 1998 with 2000 Addenda
- Containment Spray Piping System (NS)
- Pipe Specification MCS-1206.00-02-0002
- Design Pressure: 170 psig
- Design Temperature: 190°F
- Pipe Size: 8"
- Schedule: 10
- Pipe Material: SA-312 TP304
- Elbow Material: SA-403 WP304
- Type of Weld: GTAW
- Range of crack sizes to be evaluated: 0.2" - 4"

The following assumptions are made:

- Flaws assumed to be through-wall
- Smooth fatigue-type crack assumed to maximize leakage


For operability analysis, the factor of safety is chosen for Service Level C and D conditions as 1.39 from Section XI. To allow evaluation of a range of conditions, parametric evaluations are provided for the allowable flaw size and leakage.

### 4.0 ANALYSIS

#### 4.1 Allowable Flaw Size

Excel workbook MNS02301.XLS, included in the project computer files, calculates failure bending stress and allowable flaw length based on the stress and moment values. All welds use the gas tungsten arc weld (GTAW) method, which is non-flux [3]; therefore, the non-flux equation for  $P_b'$  based on stress is used, and  $P_c$  and  $Z$  are not used. For 8" schedule 10 piping, the outside diameter is  $D_o = 8.625"$  and the thickness is  $t = 0.148"$ . Axial stress is  $P_m = PD_o/4t = 170*8.625/(4*0.148) = 2,477$  psi. For both materials  $S_m$  is 20,000 psi at 190°F [4]. Since flaws are assumed through-wall,  $a/t = 1.0$ .

Table 1 shows allowable flaw size in radians and degrees for each value of bending stress chosen. Flaw half length  $c$  is calculated based on the flaw half angle and the pipe outside diameter. For

	Revision	0			
	Preparer/Date	WFW 03/18/04			
	Checker/Date	AFD 03/18/04			
	File No.	MNS-02Q-301			Page 4 of 9

evaluating a specific location using this table,  $P_b$  should include Service Level C and D primary bending stresses; that is, deadweight (DW) and safe shutdown earthquake (SSE), for example.

**Table 1. Allowable Flaw Size**

$P_m$ , psi	$P_b$ , psi	Z	SF	$P_b'$ , psi	$\theta$ , rad	$\theta$ , °	c, in
2477	1000	1.00	1.39	2356	1.996	114	8.6
2477	2000	1.00	1.39	3746	1.921	110	8.3
2477	3000	1.00	1.39	5136	1.853	106	8.0
2477	4000	1.00	1.39	6526	1.791	103	7.7
2477	5000	1.00	1.39	7916	1.732	99	7.5
2477	6000	1.00	1.39	9306	1.677	96	7.2
2477	7000	1.00	1.39	10696	1.625	93	7.0
2477	8000	1.00	1.39	12086	1.575	90	6.8
2477	9000	1.00	1.39	13476	1.527	87	6.6
2477	10000	1.00	1.39	14866	1.482	85	6.4
2477	11000	1.00	1.39	16256	1.438	82	6.2
2477	12000	1.00	1.39	17646	1.395	80	6.0
2477	13000	1.00	1.39	19036	1.353	78	5.8
2477	14000	1.00	1.39	20426	1.313	75	5.7
2477	15000	1.00	1.39	21816	1.274	73	5.5
2477	16000	1.00	1.39	23206	1.236	71	5.3
2477	17000	1.00	1.39	24596	1.198	69	5.2
2477	18000	1.00	1.39	25986	1.161	67	5.0
2477	19000	1.00	1.39	27376	1.125	64	4.9
2477	20000	1.00	1.39	28766	1.090	62	4.7


#### 4.2 Leakage

Although PICEP has not been qualified under SI's Quality Assurance (QA) program, it is widely accepted for use in LBB evaluations and has been evaluated by the US NRC [5]. As a check, the SI-developed program pc-LEAK, which has been qualified under SI's QA program, is used.

The previously-stated pipe section properties of  $D_o = 8.625"$  and  $t = 0.148"$  are input. Maximum crack size of 4" is used [3]. Material properties are taken as follows, at a temperature of 200°F [4]:

- Modulus of Elasticity = 27,600 ksi
- Ultimate tensile strength = 71.0 ksi
- Yield strength = 25.0 ksi
- Flow stress =  $(71.0 + 25.0)/2 = 48.0$  ksi
- $\alpha = 4.7$ ,  $n = 3.8$ , taken at 75°F [7]

Other leakage input is described as follows. The roughness is 0.000197 inch [6]. Several values of sustained bending stress are used ranging from 0 to 20 ksi. Pressure and temperature are 184.7 psia

	Revision	0			
	Preparer/Date	WFW 03/18/04			
	Checker/Date	AFD 03/18/04			
	File No.	MNS-02Q-301	Page <u>5</u> of <u>9</u>		


and 190°F [3]. The entrance loss coefficient is chosen as 0.61, which is also the default value. The following other parameters are also input to PICEP:

- MODE = 0 (compute critical crack length, crack opening displacement, and leakage)
- IPLAS = 2 (perform plastic zone correction)
- ISOL = 2 (combined tension and bending solution)
- IFDIR = 0 (circumferential crack)
- IFAREA = 1 (elliptical crack)
- NDIV = 8 (number of crack length increments)
- COD = 0 (ignored since MODE is not 1)
- TRACT = 0 (pipe axial nonpressure load)
- BMOM = 0 (pipe bending moment, stress is input instead)
- PMSTR = 0 (pipe membrane stress, pressure is input instead)
- IN = 3 (initially subcooled liquid water)
- PB = external pressure = 14.7 psia
- AR = ratio of the crack exit to inlet area = 1.0
- N45 = number of 45 deg turns = 0
- N90 = number of 90 deg turns = 0
- ZF = 1.0 (assume plastic collapse)
- SFV = 1.0 (safety factor for critical crack length)

The following input is specific to pc-LEAK. From equation 27 of the PICEP manual, the 0.61 entrance loss coefficient corresponds to a factor on pressure drop of  $1/0.61^2 =$  roughly 2.7, which is the input used for pc-LEAK. The pc-LEAK case for analysis is case 5: liquid water, circumferential crack, and axial plus bending stress. The following other input is used:

- YES for abbreviated output file
- 0 = Initial average crack opening, inches
- 2 = Beta for plastic zone corrections (plane stress)
- 1 = Iterations for plastic zone correction
- 0.2 = Increment for crack length (2c)


Table 2 shows the leakage rates calculated by PICEP, based on a range of flaw angles and bending moments, and Figure 1 plots these results. Results calculated by pc-LEAK are somewhat smaller, but similar in magnitude. For evaluating a specific location using this table,  $P_b$  should include only sustained loads, but should include secondary as well as primary loads; that is, DW, thermal expansion (TE), and thermal anchor movement (TAM), for example.



Revision	0			
Preparer/Date	WFW 03/18/04			
Checker/Date	AFD 03/18/04			
File No.	MNS-02Q-301	Page 6 of 9		

**Table 2. Leakage Rate versus Crack Length (2c) and Sustained Bending Stress (P<sub>b</sub>)**

2c, in	Leakage, gpm								
	P <sub>b</sub> = 0 ksi	P <sub>b</sub> = 2.5 ksi	P <sub>b</sub> = 5 ksi	P <sub>b</sub> = 7.5 ksi	P <sub>b</sub> = 10 ksi	P <sub>b</sub> = 12.5 ksi	P <sub>b</sub> = 15 ksi	P <sub>b</sub> = 17.5 ksi	P <sub>b</sub> = 20 ksi
0.2	0.0001	0.0002	0.0005	0.0010	0.0018	0.0041	0.0084	0.0163	0.0292
0.4	0.0004	0.0014	0.0029	0.0066	0.0146	0.0300	0.0573	0.1013	0.1668
0.6	0.0013	0.0041	0.0100	0.0228	0.0477	0.0927	0.1671	0.2800	0.4407
0.8	0.0028	0.0096	0.0247	0.0541	0.1087	0.2026	0.3504	0.5671	0.8696
1	0.0053	0.0201	0.0497	0.1052	0.2043	0.3679	0.6176	0.9773	1.4752
1.2	0.0090	0.0365	0.0878	0.1805	0.3404	0.5966	0.9801	1.5272	2.2570
1.4	0.0148	0.0605	0.1418	0.2842	0.5227	0.8967	1.4503	2.2305	3.2565
1.6	0.0238	0.0938	0.2147	0.4204	0.7573	1.2773	2.0426	3.0883	4.5089
1.8	0.0362	0.1382	0.3093	0.5931	1.0495	1.7482	2.7707	4.1434	6.0497
2	0.0528	0.1956	0.4284	0.8067	1.4073	2.3216	3.6248	5.4254	7.9232
2.2	0.0745	0.2678	0.5751	1.0658	1.8376	3.0093	4.6488	6.9644	10.1746
2.4	0.1021	0.3568	0.7523	1.3751	2.3491	3.8160	5.8657	8.7971	12.8618
2.6	0.1366	0.4647	0.9633	1.7399	2.9509	4.7416	7.3019	10.9646	16.0414
2.8	0.1791	0.5935	1.2114	2.1664	3.6538	5.8235	8.9870	13.5127	19.7817
3	0.2308	0.7454	1.5002	2.6607	4.4695	7.0833	10.9549	16.4953	24.1660
3.2	0.2928	0.9227	1.8338	3.2298	5.3804	8.5422	13.2418	19.9711	29.2858
3.4	0.3665	1.1277	2.2163	3.8834	6.4205	10.2266	15.8939	24.0128	35.2494
3.6	0.4534	1.3632	2.6524	4.6282	7.6115	12.1666	18.9584	28.6900	42.1508
3.8	0.5549	1.6316	3.1473	5.4750	8.9720	14.3925	22.4866	34.0933	50.1464
4	0.6726	1.9360	3.7066	6.4148	10.5221	16.9441	26.5473	40.3212	59.3774



Revision	0		
Preparer/Date	WFW 03/18/04		
Checker/Date	AFD 03/18/04		
File No.	MNS-02Q-301	Page 7 of 9	







Figure 1. Leakage Rate versus Crack Length (2c) and Sustained Bending Stress ( $P_b$ )

## 5.0 DISCUSSION

The allowable flaw sizes show that the piping is very flaw tolerant as the pressure stress is very low. Austenitic stainless steel welded by GTAW (TIG welding) fails in a very ductile manner, such that the Appendix C approach is applicable to evaluate the flaws in the piping. It is conservative to add the length of any actual flaw indications to compare against the calculated single flaws, in terms of assessing the margin.

The assumption of a smooth crack is conservative in that it minimizes the flow loss; therefore, the calculated leakage rates are conservatively high. PICEP generally calculates higher leakage than pc-LEAK because the inclusion of plasticity (which is handled only through a plastic zone correction factor in pc-LEAK) produces larger crack opening areas. For this calculation, that is conservative.


Note that the value of  $P_b$  for calculating allowable flaw size should include Service Level C and D primary bending stresses (typically DW + SSE), while  $P_b$  for calculating leakage should include primary plus secondary stresses due to sustained loads (typically DW + TE + TAM).



Revision	0		
Preparer/Date	WFW 03/18/04		
Checker/Date	AFD 03/18/04		
File No.	MNS-02Q-301	Page 8 of 9	

## 6.0 REFERENCES

1. ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition with 2000 Addenda.
2. Norris, D. M., and Chexal, B., *PICEP: Pipe Crack Evaluation Computer Program*, EPRI Report No. NP-3596-SR, Revision 1.
3. E-mail from Hoang Dinh (Duke) to Art Deardorff and Bill Weitze (SI) dated 3/16/2004 12:07 PM (PST), Subject: Re: Design Input for Crack and Leakage Calculations, SI File No. MNS-02Q-201.
4. ASME Boiler and Pressure Vessel Code, Section III Appendices, 1989 Edition.
5. NUREG/CR-5128, *Evaluation and Refinement of Leak-Rate Estimation Models*, Battelle for USNRC, April 1991.
6. *Calculation of Leak Rates Through Cracks in Pipes and Tubes*, EPRI Report No. NP-3395, December 1983.
7. Zahoor, Akram, *Ductile Fracture Handbook*, EPRI Report No. NP-6301-D, Volume 3, January 1991 (Research Project 1757-69, prepared for Novetech Corporation and the Electric Power Research Institute).
8. pc-LEAK, Version 2.0-8/20/98, Structural Integrity Associates.

	Revision	0			
	Preparer/Date	WFW 03/18/04			
	Checker/Date	AFD 03/18/04			
	File No.	MNS-02Q-301			Page 9 of 9