



**Constellation
Energy Group**

Nine Mile Point
Nuclear Station

April 7, 2004
NMP1L 1825

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Nine Mile Point Unit 1
 Docket No. 50-220
 License No. DPR-63

Special Report, Channel #11 of the Containment Hydrogen Monitoring
System Inoperable for Scheduled Corrective Maintenance

Gentlemen:

In accordance with Action 4.a of Nine Mile Point Unit 1 Technical Specification Table 3.6.11-2, "Accident Monitoring Instrumentation Action Statements," Nine Mile Point Nuclear Station, LLC, is submitting the following Special Report concerning inoperability of Channel #11 of the Containment Hydrogen Monitoring (CHM) System.

Description of Event

On March 29, 2004, at approximately 1237 hours, operators declared Channel #11 of the CHM System out of service to support corrective maintenance on the Containment Activity Monitoring (CAM) System.

The redundant Channel #12 was verified to be in service prior to removing Channel #11 from service.

Cause of Event

The CHM System was declared inoperable in order to perform scheduled corrective maintenance on the Drywell CAM air pump. Channel #11 CHM System shares a common return line with the CAM system and therefore, becomes inoperable during CAM maintenance. The CAM maintenance replaced the sample pump and motor.


JE22

Page 2
NMP1L 1825

Corrective Actions

The scheduled corrective maintenance was completed and Channel #11 of the CHM System was returned to an operable status on March 30, 2004, at approximately 0833 hours.

Very truly yours,



Lawrence A. Hopkins
Plant General Manager

LAH/RF/bjh

cc: Mr. H. J. Miller, NRC Regional Administrator, Region I
Mr. G. K. Hunegs, NRC Senior Resident Inspector