

CLINTON POWER STATION

Job Performance Measure

Perform Containment Hydrogen Purge per 4411.06

JPM Number: 4411.0607

Revision Number: 00

Date: 07/30/2003

Developed By:	<u>T. Pickley</u>	<u>7/30/03</u>
	Instructor	Date
Validated By:	<u>M. Griffin</u>	<u>10/17/03</u>
	SME or Instructor	Date
Review By:	<u>P. Ryan</u>	<u>8/18/03</u>
	Operations Representative	Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
Procedure Rev. _____ Date _____
- _____ 9. Pilot test the JPM:
 - a. verify cues both verbal and visual are free of conflict, and
 - b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor _____
Date

SME/Instructor _____
Date

SME/Instructor _____
Date

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

Revision Record (Summary)

1. **Revision 00** New JPM

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

Operator's Name: _____

Job Title: NLO RO SRO STA

JPM Title: Perform Containment Hydrogen Purge per 4411.06

JPM Number: 4411.0607

Revision Number: 00

Task Number and Title: 441106.07, Complete Control Room actions to perform CNMT
HYDROGEN PURGE

Suggested Testing Environment: Plant

Actual Testing Environment: Simulator Plant
Control Room

Testing Method: Simulate
 Perform

Faulted: No
Alternate Path: Yes

Time Critical: No

Estimated Time to Complete: 10 minutes **Actual Time Used:** _____ minutes

References: CPS No. 4411.06

EVALUATION SUMMARY:

Were all the Critical Elements performed satisfactorily? Yes No

The operator's performance was evaluated against the standards contained in this JPM,
and has been determined to be: Satisfactory Unsatisfactory

Comments: _____

Evaluator's Name: _____

Evaluator's Signature: _____ Date: _____

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

READ TO THE OPERATOR

I will explain the initial conditions, which step(s) to simulate or discuss, and provide the initiating cues. When you complete the task successfully, the objective of this Job Performance Measure will be satisfied.

SIMULATOR SET-UP CONDITIONS:

1. Initialize to any IC that will allow operation of the Standby Gas Treatment System.
2. Start both Hydrogen Mixing Compressors.
3. Verify that Containment pressure is less than 2.6 psig.
4. Remove tags from valves 1VR002A, 1VR002B, 1VQ006A, and 1VQ006B.
5. Override the control switch for 1VG01YA to prevent the damper from opening.
6. Shutdown CCP.
7. Start the Hydrogen Igniters.

TASK STANDARDS:

Containment Hydrogen Purge is initiated in accordance with CPS No. 4411.06, EMERGENCY CONTAINMENT VENTING, PURGING, AND VACUUM RELIEF.

TOOLS, EQUIPMENT, OTHER SPECIAL REQUIREMENTS:

None

PROCEDURAL REFERENCES:

CPS No. 4411.06, EMERGENCY CONTAINMENT VENTING, PURGING, AND VACUUM RELIEF

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

EVALUATOR INSTRUCTIONS:

Amplifying cues may be provided within the JPM steps.

INITIAL CONDITIONS AND INITIATING CUE:

An emergency condition exists. Primary Containment hydrogen concentration is 1%. You are directed to vent and purge the Primary Containment using CPS No. 4411.06, EMERGENCY CONTAINMENT VENTING, PURGING, AND VACUUM RELIEF, Section 2.8, Containment Hydrogen Purge. No other sections of CPS No. 4411.06 have been performed. The necessary clearance tags have been emergency released. Transient annunciators are in effect.

VG Train A is the preferred train

START TIME: _____

PERFORMANCE INFORMATION

Critical steps are denoted with an asterisk (*) to the left of the step number and appear in **BOLD** letters. Failure to meet the standards for a critical step constitutes failure of the Job Performance Measure. The sequence of steps is assumed unless denoted in the comments section of this JPM.

PERFORMANCE STEPS

2.8.1 **VERIFY CNMT PRESSURE < 2.6 PSIG BY HI CNMT PRESS WHITE INDICATING LIGHT (ABOVE 1VG01YA/B P801 SWITCH) BEING OFF.**

STANDARD: HI CNMT PRESS white light OFF

- COMMENTS: 1. Examinee should also verify that Containment and Drywell temperatures are less than 212°F per the CAUTION at beginning of section.
2. Hydrogen concentration is 1% as stated in Initiating Cue.

SAT _____ UNSAT _____ Comments Number

2.8.2 **IF Section 2.2, Vent Using Hydrogen Purge Supply Path was performed,**

THEN Reinstall relays.

STANDARD: Recall from initiating cue that section 2.2 was not performed.

COMMENTS:

SAT _____ UNSAT _____ Comments Number

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

***2.8.3 PLACE CONTROL SWITCHES FOR BOTH 1VG02YA & B, SGTS TRN A(B) FUEL BLDG ISOL DMPRS TO THE CLOSE POSITION.**

STANDARD: Key lock switches placed/verified in CLOSE position and Green Lights ON.

COMMENTS: 1VG02YA(B) will indicate shut with control switch in AUTO, switch must be taken to CLOSE to satisfy conditions for the Flowpath.

SAT _____ UNSAT _____ Comments Number

2.8.4 Verify following dampers shut:

- a) 1VG02YA & B, SGTS Trn A(B) Fuel Bldg Isol Dmprs.
- b) 1VG04YA & B, SGTS Trn A(B) Pmp Rms Suct Dmprs.
- c) 1VG05YA & B, SGTS Trn A(B) Fuel Bldg Suct Dmprs.
- d) 1VG06YA & B, SGTS Trn A(B) ECCS Rms Suct Dmprs.

STANDARD: Green lights ON for 1VG02YA & B, 1VG04YA & B, 1VG05YA & B, and 1VG06YA & B.

COMMENTS:

SAT _____ UNSAT _____ Comments Number

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

*2.8.5 **OPEN BOTH 1VQ006A AND B, CNMT BLDG EXH OUTBD (INBD)
ISOL BYP VLVS**

STANDARD: Red lights ON for 1VQ006A and 1VQ006B

COMMENTS:

SAT _____ UNSAT _____ Comments Number

2.8.6 START SGTS TRN A EXH FAN, 0VG02CA.

STANDARD: Red light ON for 0VG02CA.

COMMENTS: 0VG02CA will not have a flowpath until the next step is performed.

SAT _____ UNSAT _____ Comments Number

2.8.7 PLACE CONTROL SWITCH FOR 1VG01YA, SGTS TRN A DW PRG
ISOL DMPR TO PURGE.

STANDARD: Determines that 1VG01YA did not open

COMMENTS: If asked as CRS for directions, give direction to take the actions that would
be performed.

SAT _____ UNSAT _____ Comments Number

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

STOP SGTS TRN A EXH FAN, 0VG02CA.

STANDARD: Green light ON for 0VG02CA.

COMMENTS:

SAT _____ UNSAT _____ Comments Number

***2.8.6 START SGTS TRN B EXH FAN, 0VG02CB.**

STANDARD: Red light ON for 0VG02CB.

COMMENTS: 0VG02CB will not have a flowpath until the next step is performed.

SAT _____ UNSAT _____ Comments Number

***2.8.7 PLACE CONTROL SWITCH FOR 1VG01YB, SGTS TRN B DW PRG ISOL DMPR TO PURGE.**

STANDARD: Red light ON for 1VG01YB

COMMENTS:

SAT _____ UNSAT _____ Comments Number

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

2.8.8 Start both Hydrogen Mixing Units per CPS No. 3316.01, CONTAINMENT COMBUSTIBLE GAS CONTROL (HG).

STANDARD: Verifies that both Hydrogen Mixing Units are running.

COMMENTS: Mixing compressors were started as part of initial setup. CPS 3316.01 refers operation of mixing compressors to CPS No. 4411.11, EOP HYDROGEN CONTROL SUPPORT ACTIONS.

SAT _____ UNSAT _____ Comments Number _

*** 2.8.9 WHEN CNMT PRESSURE IS APPROXIMATELY 0 PSIG
THEN OPEN BOTH 1VR002A AND B, CNMT BLDG SPLY
OUTBD (INBD) ISOL BYP VLVS**

STANDARD: Red lights ON for 1VR002A and 1VR002B

COMMENTS: CUE: If containment pressure is > 0 psig then inform the examinee that pressure is approximately 0 psig.

STOP TIME: _____

SAT _____ UNSAT _____ Comments Number

CLINTON POWER STATION
SYSTEM JPM

JPM NUMBER: 4411.0607

REVISION: 00

TERMINATING CUES:

Containment Hydrogen Purge has been initiated.

K/A REFERENCE NUMBERS

K/A SYSTEM NUMBER	K/A NUMBER	IMPORTANCE RATING	
		RO	SRO
223001	A 2.04	3.7	3.8

INITIAL CONDITIONS AND INITIATING CUE:

An emergency condition exists. Primary Containment hydrogen concentration is 1%. You are directed to vent and purge the Primary Containment using CPS No. 4411.06, EMERGENCY CONTAINMENT VENTING, PURGING, AND VACUUM RELIEF, Section 2.8, Containment Hydrogen Purge. No other sections of CPS No. 4411.06 have been performed.

Use VG Train A