

From: Kenneth Riemer, *KTR*
To: Christine Lipa
Date: 2/20/04 6:41AM
Subject: Re: Fwd: Davis Besse EALs - Restart Discussions

Christine,

Not sure how detailed, or formal a discussion you're looking for. Take a look at the attached and let me know if it's what you need.

Ken

>>> Christine Lipa 02/19/04 11:04PM >>>
if you could writeup a short discussion of the EAL review at DB, that would help us answer Jim d's question

Thanks, CL

CC: Dave Passehl

B-21

On February 11, 2004, HQ EP staff and Region III inspectors completed a screening of the Davis/Besse emergency action levels (EALs) as part of agency actions in advance of the plant's re-start hearings. The EAL review provided an evaluation of potential areas where a decrease in effectiveness (DIE) could have occurred as a result of historical changes to the original NRC approved NUREG-0654 classification scheme used at Davis/Besse. DIE issues with other Region III plants using NUREG-0654 classification schemes prompted the review at Davis/Besse to ensure that similar problems were not evident. The initial result of this screening concluded that there are no DIE issues with the Davis/Besse EALs which would affect re-start. Potential minor discrepancies are being discussed with the licensee.