



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 15, 1988

MEMORANDUM FOR: Victor Stello, Jr.
Executive Director for Operations

FROM: Edward L. Jordan, Chairman
Committee to Review Generic Requirements

SUBJECT: MINUTES OF CRGR MEETING NUMBER 141

The Committee to Review Generic Requirements (CRGR) met on Tuesday, July 14, 1988 from 1-4 p.m. A list of attendees for this meeting is attached (Enclosure 1). The following items were addressed at the meeting:

1. A. Thadani (NRR) presented for CRGR review a proposed Generic Letter, "Instrument Air Supply Problems Affecting Safety-Related Equipment." The Committee recommended in favor of issuing the proposed Generic Letter, subject to several modifications and minor wording clarifications (to be coordinated with the CRGR staff). This matter is discussed in Enclosure 2.
2. B. Morris (RES) and J. Telford (RES) presented for CRGR review a proposed draft rule to require college degrees for senior reactor operators. The Committee recommended that the rule not go forward at this time, but that the staff should develop additional information to better demonstrate the need or justification for such a rule. This matter is discussed in Enclosure 3.
3. W. Minners (RES) and R. Woods (RES) presented for CRGR review the proposed resolution for USI A-45, "Shutdown Decay Heat Removal Requirements." The Committee recommended in favor of adopting the proposed resolution, which would involve addressing this issue in the context of the planned Individual Plant Examinations (IPEs), subject to minor revisions to be coordinated with the CRGR staff. This matter is discussed in Enclosure 4.
4. C. E. Rossi (NRR) presented for CRGR review a proposed NRC Bulletin, "Thimble Tube Thinning in Westinghouse Reactors." The Committee recommended in favor of issuing the proposed bulletin, subject to several minor modifications (to be coordinated with the CRGR staff). This matter is discussed in Enclosure 5.

In accordance with the EDO's July 18, 1983 directive concerning "Feedback and Closure on CRGR Reviews," a written response is required from the cognizant office to report agreement or disagreement with the CRGR recommendations in

8809010329 880815
PDR REVGP NRGCRGR
MEETING141 PNU

DF03
1/0

0-111-7
CRGR

these minutes. The response, which is required within five working days after receipt of these minutes, is to be forwarded to the CRGR Chairman and if there is disagreement with CRGR recommendations, to the EDO for decisionmaking.

Questions concerning these meeting minutes should be referred to Jim Conran (492-9855).

Original signed by
E. L. Jordan, Sr.

Edward L. Jordan, Chairman
Committee to Review Generic
Requirements

Enclosures:
As stated

cc w/enclosures:
Commission (5)
SECY
Office Directors
Regional Administrators
CRGR Members
W. Parler
B. Morris
W. Minners
A. Thadani
C. E. Rossi

Distribution: w/o enc.
Central File
PDR (NRC/CRGR)
S. Treby
W. Little
M. Lesar
B. Doolittle (w/enc.)
CRGR SF (w/enc.)
CRGR CF (w/enc.)
M. Taylor (w/enc.)
E. Jordan (w/enc.)
J. Heltemes (w/enc.)
J. Conran (w/enc.)
C. Sakenas (w/enc.)

| | | | | | | | |
|------|--------------|-------------|----------------|---|---|---|---|
| OFC | : AEOD: CRGR | : AEOD: DD | : C/CRGR: AEOD | : | : | : | : |
| NAME | : JConran:cg | : JHeltemes | : EJJordan | : | : | : | : |
| DATE | : 8/03/88 | : 8/15/88 | : 8/18/88 | : | : | : | : |