

April 13, 2004
2130-04-20087

GL 97-02

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555 - 0001


Oyster Creek Generating Station
Facility Operating License No. DPR-16
NRC Docket No. 50-219

Subject: Monthly Operating Report - March 2004

Enclosed is the March 2004 Monthly Operating Report for Oyster Creek Generating Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02

If any further information or assistance is needed, please contact David Fawcett at 609-971-4284.

Sincerely,



C. N. Swenson
Vice President, Oyster Creek Generating Station

CNS/DIF
Enclosure

cc: H. J. Miller, Administrator, USNRC Region I
P. S. Tam, USNRC Senior Project Manager, Oyster Creek
R. J. Summers, USNRC Senior Resident Inspector, Oyster Creek
File No. 04002

IE24

OPERATING DATA REPORT

DOCKET NO. 50-219
UNIT NAME Oyster Creek 1
DATE April 08, 2004
COMPLETED BY David I Fawcett
TELEPHONE (609) 971-4284

REPORTING PERIOD: March 2004

1. Design Electrical Rating	650.00		
2. Maximum Dependable Capacity (MWe-Net)	619.00		
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours the Reactor was Critical	744.00	2,184.00	220,621.02
4. Number of Hours Generator On-line	744.00	2,184.00	216,379.65
5. Reserve Shutdown Hours	0.00	0.00	918.20
6. Net Electrical Energy Generated (MWHrs)	470,564.00	1,380,768.00	123,775,521.0

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments

SUMMARY: During March, Oyster Creek generated 470,564 net MWh electric, which was 102.2% of its MDC rating.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)