



444 South 16th Street Mall
Omaha NE 68102-2247

April 13, 2004
LIC-04-0021

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: March 2004 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for March 2004. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

R. T. Ridenoure
Vice President

RTR/EPM/epm

Attachment

- c: B. S. Mallett, NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
J. G. Kramer, NRC Senior Resident Inspector
INPO Records Center

JE 04

LIC-04-0021
Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
 UNIT NAME Fort Calhoun Station
 DATE April 2, 2004
 COMPLETED BY E. P. Matzke
 TELEPHONE (402) 533-6855

REPORT PERIOD: March 2004

Design Electrical Rating (MWe-Net): 478
 Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO- DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	622	2062	216930
Number of Hours Generator was On-line:	621	2061	215586
Unit Reserve Shutdown Hours:	0	0	0
Net Electrical Energy Generated (MWh):	296764	1003817	93529920

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments
1	04/03/26	S	123.1	B	1	Maintenance outage to repair reactor coolant pump seals.

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

The Fort Calhoun Station (FCS) Nuclear Plant was operated at 100% power until 25 March when the plant commenced a scheduled down power sequence for a planned spring maintenance outage.