

April 28, 2004

Mr. Joseph M. Solymossy
Site Vice President
Prairie Island Nuclear Generating Plant
Nuclear Management Company, LLC
1717 Wakonade Drive East
Welch, MN 55089

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNIT 2 - FLAW
EVALUATION OF STEAM GENERATOR (#22) AND THE PRESSURIZER
DURING THE THIRD 10-YEAR INTERVAL INSERVICE INSPECTION
INTERVAL (TAC NO. MB8471)

Dear Mr. Solymossy:

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated April 4, 2003, the Nuclear Management Company, LLC (NMC) (the licensee), submitted their analytical flaw evaluation of 16 indications identified in the tubesheet to channel head weld region of the #22 steam generator, and one indication identified in the pressurizer bottom head to shell weld region. These indications were identified at Prairie Island Nuclear Generating Plant, Unit 2, in February-March 2002, during refueling outage 21 (RFO-21). The indications were found during follow-up examinations, required by the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code), Section XI, paragraph IWB-2420, due to flaws previously identified during the third 10-Year interval inservice inspections. NMC evaluated the indications per ASME Code, Section XI, paragraph IWB-3610, and used WCAP-14166, "Handbook on Flaw Evaluation for Prairie Island Units 1 and 2 Steam Generator and Pressurizer."

The NRC staff's review indicated that the flaw evaluation submitted by NMC on April 4, 2003, meets the acceptance criteria of the ASME Code, Section XI, paragraph IWB-3600, based on flaw size. NMC should comply with the successive inspection requirements in the ASME Code, Section XI, paragraph IWB-2420, for the new flaws that were analytically evaluated in their submittal.

This completes the NRC staff's efforts under TAC No. MB8471.

If you have questions or comments, you can contact me at 301-415-4106.

Sincerely,

/RA/

Anthony C. McMurtray , Sr. Project Manager, Section 1,
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-306

cc: See next page

April 28, 2004

Mr. Joseph M. Solymossy
Site Vice President
Prairie Island Nuclear Generating Plant
Nuclear Management Company, LLC
1717 Wakonade Drive East
Welch, MN 55089

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNIT 2 - FLAW
EVALUATION OF STEAM GENERATOR (#22) AND THE PRESSURIZER
DURING THE THIRD 10-YEAR INTERVAL INSERVICE INSPECTION
INTERVAL (TAC NO. MB8471)

Dear Mr. Solymossy:

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated April 4, 2003, the Nuclear Management Company, LLC (NMC) (the licensee), submitted their analytical flaw evaluation of 16 indications identified in the tubesheet to channel head weld region of the #22 steam generator, and one indication identified in the pressurizer bottom head to shell weld region. These indications were identified at Prairie Island Nuclear Generating Plant, Unit 2, in February-March 2002, during refueling outage 21 (RFO-21). The indications were found during follow-up examinations, required by the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code), Section XI, paragraph IWB-2420, due to flaws previously identified during the third 10-Year interval inservice inspections. NMC evaluated the indications per ASME Code, Section XI, paragraph IWB-3610, and used WCAP-14166, "Handbook on Flaw Evaluation for Prairie Island Units 1 and 2 Steam Generator and Pressurizer."

The NRC staff's review indicated that the flaw evaluation submitted by NMC on April 4, 2003, meets the acceptance criteria of the ASME Code, Section XI, paragraph IWB-3600, based on flaw size. NMC should comply with the successive inspection requirements in the ASME Code, Section XI, paragraph IWB-2420, for the new flaws that were analytically evaluated in their submittal.

This completes the NRC staff's efforts under TAC No. MB8471.

If you have questions or comments, you can contact me at 301-415-4106.

Sincerely,
/RA/
Anthony C. McMurtray , Sr. Project Manager, Section 1,
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-306

cc: See next page

DISTRIBUTION:

PUBLIC
PDIII-1 R/F
RidsNrrDlpmLpdiii-1 (LRaghavan)
TChan
RidsNrrPMAMcMurtray
RidsNrrPMMChawla
RidsNrrLATHarris
G. Hill (2)
RidsRgn3MailCenter (PLouden, DHills)
RidsAcrcAcnwMailCenter
RidsOgcRp

ADAMS Accession No.: ML041130647

NRR-106

OFFICE	PDIII-1/PM	PDIII-1/LA	EMCB/SC	PDIII-1/SC
NAME	AMcMurtray	THarris	TChan	LRaghavan
DATE	04/ 27 /04	04/ 26 /04	04/ 27 /04	04/ 28 /04

OFFICIAL RECORD COPY

Prairie Island Nuclear Generating Plant, Units 1 and 2

cc:

Jonathan Rogoff, Esquire
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Manager, Regulatory Affairs
Prairie Island Nuclear Generating Plant
Nuclear Management Company, LLC
1717 Wakonade Drive East
Welch, MN 55089

Manager - Environmental Protection Division
Minnesota Attorney General's Office
445 Minnesota St., Suite 900
St. Paul, MN 55101-2127

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
1719 Wakonade Drive East
Welch, MN 55089-9642

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Administrator
Goodhue County Courthouse
Box 408
Red Wing, MN 55066-0408

Commissioner
Minnesota Department of Commerce
121 Seventh Place East
Suite 200
St. Paul, MN 55101-2145

Tribal Council
Prairie Island Indian Community
ATTN: Environmental Department
5636 Sturgeon Lake Road
Welch, MN 55089

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall, R.S. 8
Minneapolis, MN 55401

John Paul Cowan
Executive Vice President & Chief Nuclear
Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Craig G. Anderson
Senior Vice President, Group Operations
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

November 2003