

**NUCLEAR REGULATORY COMMISSION**

**ORIGINAL**

Title: Advisory Committee on Reactor Safeguards  
511th Meeting

Docket Number: (not applicable)

PROCESS USING ADAMS  
TEMPLATE: ACRS/ACNW-005

Location: Rockville, Maryland

Date: Thursday, April 15, 2004

Work Order No.: NRC-1416

Pages 1-304

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

**ACRS OFFICE COPY**  
**RETAIN FOR THE LIFE OF THE COMMITTEE**

TROY

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
+ + + + +  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)  
511th FULL COMMITTEE MEETING  
+ + + + +  
THURSDAY,  
APRIL 15, 2004  
+ + + + +  
ROCKVILLE, MARYLAND  
+ + + + +

The full committee met at the Nuclear  
Regulatory Commission, Two White Flint North,  
Room T2B3, 11545 Rockville Pike, at 8:30 a.m.,  
Mario V. Bonaca, Chairman, presiding.

COMMITTEE MEMBERS PRESENT:

MARIO V. BONACA, Chairman  
GRAHAM B. WALLIS, Vice Chairman  
STEPHEN L. ROSEN, Member-at-Large  
GEORGE E. APOSTOLAKIS, Member  
F. PETER FORD, Member  
THOMAS S. KRESS, Member  
DANA A. POWERS, MEMBER

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

## 1 COMMITTEE MEMBERS PRESENT: (cont'd)

2 VICTOR H. RANSOM, Member

3 WILLIAM J. SHACK, Member

4 JOHN D. SIEBER, Member

5

## 6 NRC STAFF PRESENT:

7 LEE ABRAMSON

8 BENNETT BRODY

9 ARTHUR BUSLIK

10 DONALD E. CARLSON

11 STEPHEN DINSMORE

12 FAROUK ELTAWILA

13 HOSSEIN HAMZAHEE

14 DONNIE HARRISON

15 GLENN KELLY

16 MARK KOWAL

17 RALPH LANDRY

18 JAMES LAZEVNICK

19 DAVID LEW

20 STU MAGRUDER

21 EILEEN McKENNA

22 YURI ORECHWA

23 GARETH PARRY

24 MARK RUBIN

25 STUART RUBIN

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

NRC STAFF PRESENT: (cont'd)

ROB TREGONING

MIKE TSCHILTZ

I-N-D-E-X

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

AGENDA ITEM

PAGE

Opening Remarks by the ACRS Chairman	5
Action Plan for Implementing the Phased Approach for Improving PRA Quality	6
SECY-04-0037 -- Issues Related to Proposed Rulemaking to Risk-Inform Requirements Related to Large Break LOCA Break Size and Plans for Rulemaking on LOCA with Coincident Loss of Off-site Power	90
Options and Recommendations for Functional Performance Requirements and Criteria for the Containments of non-LWRs	202
Criteria for Evaluating the Effectiveness (Quality) of the NRC Research Program	241

## P-R-O-C-E-E-D-I-N-G-S

(8:30 a.m.)

CHAIRMAN BONACA: Good morning. The meeting will now come to order. This is the first day of the 511th meeting of the Advisory Committee on Reactor Safeguards.

During today's meeting the committee will consider the following: action plan for implementation of the phased approach to PRA quality; SECY-04-0037, issues related to proposed rulemaking to risk-inform requirements related to large break LOCA size and plans for rulemaking on LOCA with coincident loss of off-site power; options and recommendations for functional performance requirements and criteria for the containments of non-lightwater reactors; criteria for evaluating the effectiveness of quality of the NRC research programs; and preparation of ACRS reports.

Dr. El-Zeftaway is the Designated Federal Official for the initial portion of the meeting.

We have received no written comments from members of the public regarding today's session. We have received a request from NEI for time to make oral statements regarding SECY-04-0037.

A transcript of portions of the meeting is

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 being kept, and it is requested that the speakers use  
2 one of the microphones, identify themselves, and speak  
3 with sufficient clarity and volume so that they can be  
4 readily heard.

5 I will begin with some items of current  
6 interest. In front of you you have, in fact, a  
7 package of items of interest, and you see there there  
8 is -- it includes a Staff Requirements Memorandum,  
9 speeches by the Chairman and Commissioners, and  
10 congressional correspondence and testimony.

11 With that, if there are no comments or  
12 issues on the part of members, I will proceed with the  
13 meeting.

14 The first item on our agenda is action  
15 plan for implementing the phased approach for  
16 improving PRA quality. And Dr. Apostolakis will lead  
17 us with that.

18 MEMBER APOSTOLAKIS: Thank you, Mr.  
19 Chairman.

20 In a Staff Requirements Memorandum dated  
21 December 18, 2003, the Commission approved the  
22 implementation of a phased approach to achieving an  
23 appropriate quality for PRAs for NRC's risk-informed  
24 regulatory decisionmaking. The SRM requested an  
25 action plan that would define a practical strategy for

1 the implementation of the phased approach to PRA  
2 quality.

3 The Reliability and Probabilistic Risk  
4 Assessment Subcommittee met with the staff on  
5 March 25th to discuss this plan.

6 The SRM distinguishes between a baseline  
7 PRA and the risk-informed decisionmaking elements.  
8 The baseline PRA characterizes the actual risk of the  
9 facility, in terms of core damage frequency and large  
10 early release frequency. These are the words of the  
11 SRM.

12 The baseline PRA cannot assess plant  
13 changes. Therefore, it's not usually utilized by  
14 itself in regulatory decisionmaking. The risk-  
15 informed decisionmaking elements help in assessing  
16 changes and are more difficult to define.

17 Now, there is a sentence in the SRM that  
18 I find intriguing. The risk-informed decisionmaking  
19 elements "are by definition issue-dependent and they  
20 don't play a role in judging the quality of the  
21 baseline PRA."

22 So one of the things I'd like us to  
23 discuss today is how this distinction between baseline  
24 PRA and risk-informed elements, decisionmaking  
25 elements, is made in the plant, and to clarify what we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mean by PRA quality.

2 Are we referring to the baseline PRA? Are  
3 we referring to the risk-informed decisionmaking  
4 elements, but the Commission says they don't play a  
5 role in judging the quality of the baseline PRA? This  
6 is something that was not discussed last time.

7 MEMBER POWERS: Professor Apostolakis?

8 MEMBER APOSTOLAKIS: Yes.

9 MEMBER POWERS: I continue to get confused  
10 when people present PRA information, because it seems  
11 to me that what is missing, they present a -- only a  
12 subset of what has been asked. I mean, people ask  
13 what the -- what is the risk to this plant as a  
14 baseline? And they -- they give you a number. And  
15 you ask them, is this a mean? And they say yes, but  
16 it turns out to be only a point estimate.

17 And you ask them, well, does this include  
18 the risk of -- due to fire? And they say no. But  
19 we're told that fire is a big risk. I mean, it's very  
20 confusing to me.

21 MEMBER APOSTOLAKIS: It is. It is. And  
22 I think the idea of these phases is to maybe get out  
23 of it progressively. But, yes, I agree with you. I  
24 agree with you.

25 So we have this issue that at some point

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 today we should discuss -- the distinction between  
2 baseline and the extra work you have to do for making  
3 decisions.

4 Now, the phases -- there are four phases.  
5 Phase 1 is the application-specific phase, which is  
6 really what we are familiar with. It's based on  
7 Regulatory Guide 1.174.

8 Then, Phase 2 is called issue-specific --  
9 the issue-specific phase. And now all modes and  
10 initiating events that would change the decision  
11 substantially -- this is a word from the SRM --  
12 substantially -- should be included with uncertainty  
13 analysis.

14 Now, I'm also confused. It's not clear to  
15 me what the distinction is between Phase 1 and  
16 Phase 2. I'm sure there is one. This appears to be  
17 one of the distinctions -- that all modes and  
18 initiating events that could change the decision  
19 substantially should be included with uncertainty  
20 analysis.

21 MEMBER KRESS: How does one know which  
22 modes would influence the decision?

23 MEMBER APOSTOLAKIS: That -- yes, that's  
24 a good question. That's another question. How can  
25 you know a priori? Yes.

1 But the term "substantially" is something  
2 we have to focus on, and I'll come to it a little  
3 later.

4 So Regulatory Guide 1.174 in Phase 2 is to  
5 be supplemented by a PRA standard for the particular  
6 issue, plus a PRA review process.

7 And then there is an example of 50.69  
8 which says that full implementation would require a  
9 broad spectrum of systems and quantification, which in  
10 my mind means Phase 3.

11 But then it says for a system-by-system  
12 implementation a Phase 3 PRA is not required, in the  
13 sense that you don't need to have all of the  
14 initiating events and modes.

15 Now, this system-by-system implementation  
16 of 50.69 is something that I don't recall. Maybe I  
17 missed something, but that's another thing that I  
18 would like to have an answer to.

19 And another interesting statement in the  
20 SRM within Phase 2 is that the staff should give low  
21 priority, or even return non-conforming applications.  
22 Phase 3 is a no-applications phase, and the words "all  
23 currently envisioned issues" are in the SRM.

24 It is envisioned that a single baseline  
25 PRA -- now we are not talking about the distinction

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 between baseline and issue-specific decisionmaking  
2 elements, and I don't know whether that's intentional  
3 or not. But there is a clear statement that the  
4 single baseline PRA should be fully capable to support  
5 these uses.

6 So my question, again, to be discussed  
7 today is: what happened to the issue-specific  
8 decision-making elements? Are they part now of the  
9 baseline PRA in Phase 3? Are they separate? And if  
10 they are issue-specific, and we are talking about all  
11 currently-envisioned issues, surely we know what they  
12 are, because we know what the issues are. So they  
13 should be part of the baseline PRA perhaps.

14 Examples are given that are a little  
15 confusing, at least to me. 50.46 is mentioned all  
16 over the place, and I just don't see how you can do  
17 50.46 in Phase 2, or in Phase 1 is out of the  
18 question.

19 Okay. Now, the important thing is that  
20 Phase 3 -- Phase 2 should be implemented in the near  
21 term and Phase 3 by December 31, 2008. Phase 4 is a  
22 fully-quantified PRA, which is supposed to be state of  
23 the art. We will need consensus standards for low  
24 power and shutdown, for external events, and so on,  
25 which again raises the question, why wouldn't you need

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those in Phase 3?

2 The Commission says that we shouldn't  
3 really spend much time on Phase 4 right now. We  
4 should wait until Phase 3 is in place and is proven.

5 The SRM also wants the staff to discuss  
6 the resolution of technical issues, and they mention  
7 three -- model uncertainty, external events --  
8 earthquakes and others as relevant -- and human  
9 performance.

10 Now, the staff uses, the way I understand  
11 it from the subcommittee meeting, the availability of  
12 standards to determine the phases and the priorities.  
13 So this is a critical issue. It's the availability of  
14 standards that will guide the staff what kind of  
15 priority they should give to a particular application.

16 And an example that is given is that in  
17 50.69, where we put SSCs into various categories, if  
18 you have a PRA for the power -- at power mode, the  
19 standard exists, we have the Regulatory Guide 1.200,  
20 and we rely on real -- on peer review, and that will  
21 be given high priority.

22 And here comes now something that bothered  
23 the subcommittee. If the licensee at the same time  
24 submits a fire risk assessment for which there is no  
25 standard right now, that will have low priority, just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 because there is no standard, even though the licensee  
2 may have used state-of-the-art methods. And that  
3 bothered some members of the subcommittee.

4 Now, coming to the views of the  
5 subcommittee members, most did not feel that the  
6 technical issues had been addressed adequately --  
7 model uncertainty, earthquakes, and other external  
8 events -- and human performance. We felt that these  
9 are important to all phases, and they should be given  
10 high priority.

11 The reliance on the availability of  
12 standards to determine the phases and the staff's  
13 prioritization of reviews created several concerns.  
14 Some members felt that the schedule for completion of  
15 Phase 3, which is, I remind you, December 31st of  
16 2008, is hostage to the willingness of technical  
17 societies and the industry to cooperate in the  
18 development of these standards.

19 There was a letter sent to Dr. Travers by  
20 the ASME and the ANS where they state, "The schedule  
21 defined in the SRM seems rather ambitious." They  
22 point out that low power and shutdown standard will be  
23 released some time in 2005. The fire standard will  
24 not be balloted until at least in 2005. And there are  
25 no schedules right now for developing standards for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Level 2 and Level 3 PRAs.

2 The societies -- ANS and ASME -- propose  
3 to the staff that a committee be formed that will  
4 identify the need for additional standards and what  
5 these standards should be. And that, of course, will  
6 take time.

7 Another question that the subcommittee  
8 members raised was -- and it's related to my earlier  
9 comment regarding the willingness of societies and  
10 industry to cooperate in the development of the  
11 standards. What happens if you don't have such  
12 cooperation, and you don't have the standards produced  
13 as expected? What would the NRC staff do?

14 And then again, the issue of giving low  
15 priority to reviewing and analysis, because there is  
16 no standard. That is something that the subcommittee  
17 members did not like. And NEI sent a letter to the  
18 NRC on the 8th of April, and they expressed the same  
19 concern.

20 Now, some personal comments. What is  
21 missing from all of this discussion -- and I'm not  
22 trying to be negative here -- I'm going to stimulate  
23 discussion. What is missing is an assessment of what  
24 the impact of the various phases would be on the  
25 glorified integrated decisionmaking process, which is,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of course, in Regulatory Guide 1.174 and everybody  
2 likes, including us.

3 On page 7 of the action plan, at least the  
4 version that I had, the plan says that all modes and  
5 initiating events that could change the regulatory  
6 decision substantially should be included. And it  
7 sends us to Section 3.1.4, where the word  
8 "substantially" presumably is explained. But,  
9 unfortunately, it's not explained clearly enough for  
10 me to understand it.

11 What benefits, besides prompt NRC reviews,  
12 would the licensee have if the licensee -- if we all  
13 moved to Phase 3? Would the decisionmaking process be  
14 more risk-based? To what extent would it be risk-  
15 based?

16 NEI says, of course -- and we agree --  
17 that it will never be purely risk-based. And, again,  
18 the distinction between the baseline PRA and risk-  
19 informed decisionmaking elements is not clear to me,  
20 and I didn't see that distinction made in the action  
21 plan.

22 So what are we dealing with? Are we  
23 dealing with a baseline PRA, all of the PRA, or what?

24 Now, in Section 3.1.2, the draft action  
25 plan states that an objective is "for each application

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 type to identify the role that PRA results make in the  
2 decision." And I was wondering whether it was a good  
3 idea to bury this objective in this section or give it  
4 much more prominence, because that's really a major  
5 issue that we are really dealing with here.

6 Okay. So the action plan is due to the  
7 Commission this coming July, and at the subcommittee  
8 -- and we are expected to discuss our views regarding  
9 the action plan when we meet with the Commission next  
10 month.

11 At the end of the subcommittee meeting, we  
12 discussed whether we should write a letter or not, and  
13 at that time the members felt -- present felt that  
14 maybe we didn't have enough to write a letter, and  
15 that we would create at this meeting three or four  
16 bullets that would be used when we met with the  
17 Commission.

18 I at least have changed my mind. I think  
19 we should write a letter at this meeting, after, of  
20 course, we hear what the staff has to say and we  
21 discuss among ourselves what the letter should say.  
22 That's a cleaner solution in my mind; we have enough  
23 to say. And then the presentation to the Commission  
24 will come naturally from the letter.

25 So with that, I will turn it over to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 staff to tell us what they've done and where we're  
2 going.

3 Gareth?

4 MR. PARRY: Good morning. I'm Gareth  
5 Parry from NRR. With me at the table is Donnie  
6 Harrison from NRR, Mary Drouin from Research, and Stu  
7 Magruder from NRR. And at the side table we have Mike  
8 Tschiltz from NRR and Dave Lew from Research.

9 Okay. So what I will do is I will try and  
10 answer some of the questions that George has posed  
11 while going through this presentation. We have a lot  
12 of viewgraphs. I think we'll probably need to move  
13 through some of them fairly quickly. But, clearly, we  
14 need to go through what our description of the phases  
15 is, which I think is -- perhaps needs a little bit of  
16 clarification, and then we'll talk about the  
17 implementation issues.

18 I should also say that the draft plan that  
19 you have, which was issued a few weeks ago, is in a  
20 state of flux. We are changing it. We have -- in  
21 particular, we have changed the flow diagram that  
22 talks about our process for review when these phases  
23 are implemented. And I'll go through that when we get  
24 to that point.

25 There's no need for me to introduce the

1 idea of why we're here. As George said, we're here to  
2 give you a draft of the response to the SECY.

3 I will, though, go through our definition  
4 of PRA quality, because I think it may be worth  
5 keeping that in mind. The way we've defined PRA  
6 quality in the context of this draft plan is the same  
7 as it is in Reg. Guide 1.200, and also in Reg.  
8 Guide 1.174.

9 So we defined quality in the context of  
10 using a PRA, and it's defined by the appropriateness  
11 of -- there are different elements to it. One is the  
12 scope. What does the PRA cover? Does it cover  
13 internal and external initiating events? Does it  
14 cover the full power and low power and shutdown  
15 operating modes, for example?

16 There's another element that relates to  
17 level of detail, and the third element is technical  
18 acceptability, which is really what the standards are  
19 addressing.

20 VICE CHAIRMAN WALLIS: Doesn't it really  
21 mean that it's sufficient? If you added something, it  
22 wouldn't change your decision. You've got enough of  
23 a PRA that adding something -- there's nothing left  
24 out which would change your decision if you put it in.  
25 Isn't that your real definition of "quality"?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARRY: Well, I think you could change  
2 your decision in some ways, particularly if you think  
3 about applications like 50.69, which is associated  
4 with categorizing equipment according to safety  
5 significance. I think the more detailed and the more  
6 complete PRA the more you can recategorize components.

7 So, in that sense, that's a change of a  
8 decision. But I think in terms of whether you're  
9 allowing an extension to an AOT or not, you're right,  
10 because you want to take the PRA down to the level  
11 that you wouldn't want to change that application.

12 MEMBER APOSTOLAKIS: So, Gareth, the first  
13 question was, what do we do about this distinction  
14 between baseline and risk-informed elements? When you  
15 said in the previous slide --

16 MR. PARRY: Right.

17 MEMBER APOSTOLAKIS: -- PRA quality is  
18 this, are you referring to the totality of PRA  
19 analysis and arguments that will be used in making the  
20 decision, including the issue-specific elements?

21 MR. PARRY: I think what that refers to is  
22 -- I think we are dealing with the base PRA, the PRA,  
23 the decision of the risk from the plant. I think what  
24 the SRM is trying to say there is that -- they're  
25 trying to avoid the issue of, how do you change the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 model to address specific applications? Which may not  
2 be in the baseline PRA.

3 For example, how do you change the basic  
4 event probabilities to reflect the fact that you've  
5 changed your graded QA or your QA process? I think  
6 all it's doing is making the distinction between  
7 understanding the base risk picture of the plant  
8 versus changing that picture for a specific  
9 application, which is dealt with in other regulatory  
10 guides.

11 MEMBER APOSTOLAKIS: It is?

12 MR. PARRY: Yes.

13 MEMBER APOSTOLAKIS: There is a guide that  
14 tells us how to change the probabilities of --

15 MR. PARRY: Well, actually, no, it  
16 doesn't. It doesn't do that. But it tells you you  
17 have to -- you have to have a reason for -- I mean,  
18 you have to have a rationale for why you're doing it.  
19 And, you know, there are some things which clearly we  
20 don't have a standard approach to yet.

21 MEMBER APOSTOLAKIS: Yes.

22 MR. PARRY: And those I think become part  
23 of the argument as to how you are changing the model,  
24 and why you are -- you think that change is adequate.  
25 And I think that's what the SRM is trying to do. It

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is trying to --

2 MEMBER APOSTOLAKIS: But you are not sure.  
3 I mean, that's reasonable -- what you're saying. I  
4 mean --

5 MR. PARRY: Well, that's certainly the  
6 premise that we've adopted in developing this plan is  
7 that the -- the guidance on how to change the PRA  
8 model to reflect the change that an application is  
9 requesting is -- is to be included in the regulatory  
10 guide that's associated with that application. And  
11 that's the way we've written the plan.

12 MEMBER APOSTOLAKIS: Well, the plan -- the  
13 version that I have is silent on it.

14 MR. PARRY: Well --

15 MEMBER APOSTOLAKIS: You should mention  
16 that.

17 MR. PARRY: I think it is in that.

18 MEMBER APOSTOLAKIS: It is?

19 MR. PARRY: Yes, I believe it is. We --

20 MEMBER APOSTOLAKIS: I didn't see it.

21 MR. PARRY: -- don't highlight it. I  
22 mean, we just say that -- specifically, we say that we  
23 have different elements of guidance, which is the  
24 guidance related to the quality of the base PRA and  
25 the guidance related to the applications. We'll make

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that clearer -- that that's where --

2 MEMBER APOSTOLAKIS: Yes, because --

3 MR. PARRY: -- the distinction is  
4 addressed.

5 MEMBER APOSTOLAKIS: So you are addressing  
6 the baseline.

7 MR. PARRY: Using the baseline in this,  
8 yes.

9 MS. DROUIN: Now, I've just made a note,  
10 George, that I think we need to go back at the  
11 beginning of the plan under the scope and make that  
12 clear.

13 MEMBER APOSTOLAKIS: Yes. I think that  
14 would be an excellent idea, because, you know, the  
15 other question that came to my mind is, when we -- the  
16 way -- maybe the SRM should have given an example,  
17 because the example you gave was very good -- how do  
18 you change the probabilities, you know, when --

19 MR. PARRY: Okay.

20 MEMBER APOSTOLAKIS: -- time available is  
21 from 42 to 39 minutes. I mean, it -- because what  
22 confused me is that later we say that in Phase 2 or 3  
23 -- you know, 3, all -- we use the words "all currently  
24 envisioned applications."

25 MR. PARRY: Right.

1 MEMBER APOSTOLAKIS: I said, "Well, if you  
2 envision them, why don't you know what you need to  
3 do," and include that in the PRA.

4 MR. PARRY: Yes.

5 MEMBER APOSTOLAKIS: I mean, in the  
6 quality discussion.

7 MR. PARRY: I think in a sense what that  
8 means is that any element of the PRA that you need to  
9 use to support the modification of the PRA that you  
10 will make for an application is included in the  
11 guidance. That's what really it means, which in fact  
12 probably means pretty much everything, once we've  
13 covered all our applications.

14 MEMBER APOSTOLAKIS: Right. Right.  
15 Because when you --

16 MR. PARRY: That's what the intention was.

17 MEMBER APOSTOLAKIS: For example --

18 MR. PARRY: That's not clear enough, okay.

19 MEMBER APOSTOLAKIS: -- in the technical  
20 issue that refers to human performance --

21 MR. PARRY: Yes.

22 MEMBER APOSTOLAKIS: -- and you combine  
23 that with the model uncertainty issue, and so on,  
24 there should be sufficient quality there to allow you  
25 to make the changes that you mentioned earlier.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARRY: Right.

2 MEMBER APOSTOLAKIS: Although there are no  
3 standard rules how to do that.

4 MR. PARRY: Right, I agree. Yes. That I  
5 think is our vision of the case.

6 MEMBER APOSTOLAKIS: Okay. No, that makes  
7 sense to me.

8 MR. PARRY: Okay. And as George  
9 mentioned, the approach in the SRM is that we -- we  
10 should adopt a phased approach to achieving the  
11 appropriate quality for licensee PRAs.

12 And the nice thing about this SRM I think  
13 is it allows us -- in contrast to perhaps the message  
14 that was being given in the March SRM of last year,  
15 which called for an all modes, all -- all initiating  
16 events PRA that had been reviewed and approved by the  
17 staff, before we did any applications, we suggested  
18 that -- I think this allows us to move forward with  
19 the tools we have currently while progressing towards  
20 that aim.

21 Okay. I'll skip over that one.

22 Let me tell you the status of our plan so  
23 far. We have a small working group, all of which is  
24 actually here at the table and the side table. And we  
25 made this draft plan available on 3/15, specifically

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 so that we could talk to you about it and we could  
2 talk also to our public stakeholders.

3 So we've had two public meetings, and  
4 we've had one meeting with the subcommittee. We're  
5 planning a third meeting. It's probably going to be  
6 on the 13th of May, not the 12th. And we have had, as  
7 George mentioned, a letter from the NEI and also a  
8 letter from joint ASME and ANS regarding future  
9 standards activities.

10 As George mentioned, the phases in the SRM  
11 we believe are differentiated by the availability of  
12 the guidance documents. And then, as I just  
13 explained, both for using the PRA in regulatory  
14 applications and for establishing that the PRAs are of  
15 sufficient quality.

16 So that the total suite of guidance  
17 documents includes industry consensus standards,  
18 industry guidance documents, and regulatory guides  
19 which may specific -- such like Reg. Guide 1.177, for  
20 example, which specifies a particular approach for  
21 doing one of the applications.

22 Our regulatory guides may, in fact, just  
23 endorse industry guidance documents, which is -- seems  
24 to be the way we are going with 50.69, for example.  
25 We will also need guidance documents that are internal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to the staff on how to perform our reviews and how to  
2 allocate priorities to the various reviews, which is  
3 a subject we'll come back to shortly.

4 Okay. I'll go through the definition of  
5 the phases, because I think from what George said --  
6 I don't think it's quite the way he said it. At least  
7 that's not our interpretation.

8 Phase 1 really in a sense represents the  
9 status quo, at least it's starting out as the status  
10 quo. And I think you'll see when I talk a little bit  
11 later that actually Phase 1 is in itself a transition  
12 phase to reach Phase 2.

13 And currently the way PRA quality is  
14 judged, it's really judged only in the context of --  
15 I'm just talking about the base PRA now. It's really  
16 only judged in the context of what's needed for the  
17 application. So there's no requirement to review the  
18 whole thing.

19 But in accordance with the guidance and  
20 documents like Reg. Guide 1.174, when you make a risk-  
21 informed decision you have to look at all contributors  
22 to risk. However, what Reg. Guide 1.174 -- and those  
23 that developed from it -- allows is that contributors  
24 to risk that are not in the scope of the base PRA can  
25 be addressed in a number of other ways.

1 VICE CHAIRMAN WALLIS: Isn't this a bit  
2 awkward, this number 2? I mean, you have a core  
3 damage frequency of something which you quote for some  
4 application. You get another application, you have a  
5 different value, because you've included something  
6 else in the PRA. So what is the core damage  
7 frequency?

8 MR. PARRY: Well, the nice thing about --  
9 if you like, the nice thing about Reg. Guide 1.174 is  
10 that it allowed you to make some decisions without  
11 knowing precisely what that was. Okay? As long as  
12 you could demonstrate that the change --

13 VICE CHAIRMAN WALLIS: It's all very  
14 logical to you, but how about the public and the  
15 public's --

16 MR. PARRY: Well --

17 VICE CHAIRMAN WALLIS: Different core  
18 damage frequencies quoted for different purposes.  
19 What is it?

20 MR. PARRY: I think that's the purpose,  
21 though, of this phased approach is to get us to that  
22 state where the PRAs are predictable, and, therefore  
23 -- and conform to standards, which would then give, I  
24 think, an increased public confidence and also an  
25 increased regulatory confidence in the use of the

1 PRAs.

2 MR. HARRISON: Can I add something?

3 MR. PARRY: Sure.

4 MR. HARRISON: On the base PRA, though,  
5 just to make it clear -- even when, say, two different  
6 applications come from a licensee on two different  
7 topics, it's not like they report a baseline CDF given  
8 one topic and a different baseline CDF for another  
9 topic. They should have the same baseline CDF value  
10 for both applications at the same time -- as long as  
11 they're at the same time.

12 What we do see is you have a baseline CDF  
13 on one application, and then a year or two goes by,  
14 the plant makes changes, updates their PRA, and then  
15 reports a new CDF in a new application a couple years  
16 later.

17 And that usually triggers us to go ask  
18 them what changed. So --

19 VICE CHAIRMAN WALLIS: So you have to make  
20 a distinction between this baseline and all of these  
21 other things, which affected a particular decision.  
22 That's part of George's issue, isn't it?

23 MR. HARRISON: Right. This gets at the  
24 point of when we judge -- in the context of the  
25 application, if I'm doing a diesel generator AOT, my

1 review will focus on the electric power system. It  
2 won't necessarily go track down LOCA frequencies and  
3 look into those types of questions in the baseline  
4 PRA.

5 It will focus on the aspects of the PRA --  
6 the review focus is focused on the application topic.  
7 But, again, the baseline PRA for two applications at  
8 the same time should be reporting the same CDF.

9 VICE CHAIRMAN WALLIS: Right.

10 MR. HARRISON: It's just the delta  
11 calculation they do will be for the application and  
12 will focus in on those areas.

13 MEMBER KRESS: Let me tell you what  
14 problem I have with this slide. If I'm going to use  
15 Reg. Guide 1.174 for my decision process, I need some  
16 sort of estimate of the full absolute value of CDF and  
17 LERF. Now, I can get that estimate by bounding  
18 analysis and other ways. But every time we get an  
19 application the question is: what do you do about  
20 fire contribution to the CDF? What do you do about  
21 shutdown low power risk? What do you do about the  
22 other missing elements? For example, if the seismic  
23 is treated in a qualitative way?

24 And in order to get some measure of what  
25 the real CDF and LERF are, I have to have some sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 bounding estimates for those things, and add them in.  
2 But it's never done. And you'll -- so you say Phase 1  
3 represents the status quo, but the status quo does not  
4 really deal properly with the fourth bullet. And  
5 that's what bothers me about this slide.

6 MR. PARRY: Well, I think that's why the  
7 phased approach is being proposed. I mean, this is  
8 the way things are done currently. And I think a lot  
9 of them are done by restricting the scope of  
10 application, for example, so that you restrict it so  
11 that those elements of risk that you haven't modeled  
12 are not, in fact, changed.

13 But regardless, this is where we're at  
14 right now, and this is where we're trying to move  
15 forward from.

16 MEMBER KRESS: Well, I don't think it's  
17 where we're at, because I don't think we properly add  
18 in those risks to the absolute values.

19 MR. HARRISON: Right. And if you look at  
20 Reg. Guide 1.174, in there it has a discussion on  
21 seismic margin types or vulnerability type analyses  
22 that are used. If you get to a high enough -- it  
23 talks about if there's an indication that you might  
24 have a higher risk, then you would have to go back and  
25 look at more detail.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And there are some examples where we  
2 actually have, if you will, done an approximation of  
3 what the seismic risk might be using some seismic  
4 margin and some techniques to try to get at that, or  
5 in the fire area what we may do is we'll establish  
6 licensee commitments for fire watches and stuff like  
7 that to try to control the risk that we know from the  
8 fire analysis that may have been done.

9           So we try to either bound or control the  
10 base case risk in those situations.

11           MR. PARRY: Actually, I think what you try  
12 and do is bound and control the change, the delta.

13           MR. HARRISON: Yes, the delta that would  
14 occur.

15           MR. PARRY: And if the base case risk is  
16 -- if the delta is small enough, then Reg. Guide 1.174  
17 does allow you -- or it does allow the fact that you  
18 do not have to assess the complete CDF, and I know  
19 that that's --

20           MEMBER KRESS: If you're down in that  
21 lower --

22           MR. PARRY: That's in the lower region,  
23 right.

24           MEMBER KRESS: -- lower regime you can  
25 forget about that.

1 MR. PARRY: Right. And I know that people  
2 have -- are uncomfortable with that. But -- but in  
3 any case, that is more or less what we do these days.

4 MEMBER POWERS: Let me ask you a question.

5 MEMBER KRESS: Yes, but that presupposes  
6 every one of these things will be in that lower  
7 regime, and they're not all --

8 MR. PARRY: Well, if they're not -- if  
9 they're not, though, as Donnie said, they will get --  
10 they will get further scrutiny, and they become more  
11 complicated to process.

12 MEMBER POWERS: Let me ask you a question,  
13 Dr. Kress. You indicated as the slide indicates that  
14 we can use bounding arguments to assess those things  
15 that are missing from the scope of the PRA.

16 MEMBER KRESS: Well, that's the way I  
17 interpreted the bullet.

18 MR. PARRY: That's one approach.

19 MEMBER POWERS: And I'd like to understand  
20 that just a little better, because it seems to me that  
21 they're not bounding arguments, they are in fact  
22 plausibility arguments.

23 MEMBER KRESS: I would agree with that  
24 assessment, yes.

25 MEMBER POWERS: Because --

1 MEMBER KRESS: You know, we say that there  
2 have been some estimates of plausibility on fire. It  
3 says equal to the -- or greater than the parametric  
4 CDF or CDF without it. There have been guesses that  
5 the same thing applies to shutdown and low that's of  
6 that order. And those are plausibility arguments, and  
7 -- but they come out of some sort of assessments,  
8 but --

9 MEMBER POWERS: Well, I mean, at least a  
10 couple of these things I'm reasonably familiar with.  
11 For instance, if you frequently appeal to a scoping  
12 estimate that was done for the shutdown risk at  
13 Surry --

14 MEMBER KRESS: That's right.

15 MEMBER POWERS: -- I happen to know that  
16 that was done quite conservatively and that the  
17 operating procedures at Surry have changed since it  
18 was done.

19 MEMBER KRESS: Yes.

20 MEMBER POWERS: To where they do shut down  
21 and --

22 MEMBER KRESS: And unless they reevaluate  
23 that, I would have to be stuck with the original one  
24 as my bounding analysis, unless it's reevaluated to  
25 see what the effect of the changes are. If I'm going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to be conservative about it, which I think bounding --

2 MEMBER POWERS: Well, I guess I'm not  
3 asking you to be conservative. I'm asking you to just  
4 be realistic and --

5 MEMBER KRESS: Well, if I'm going to be  
6 realistic, I have to have a good shutdown PRA to -- it  
7 will require a PRA that's realistic and has some  
8 certainties that --

9 VICE CHAIRMAN WALLIS: We've got  
10 qualitative arguments and plausibility guesses. This  
11 doesn't make me feel very confident.

12 MEMBER APOSTOLAKIS: Yes. I think there  
13 are two issues here. The first issue has to do with  
14 the fact that we -- the staff's presentation has to  
15 end by 9:45 or so, because NEI -- NEI will take the  
16 floor.

17 The second -- the purpose of today's  
18 meeting is to discuss the phases and how we move away  
19 from where we are now, not how good Phase 1 is, which  
20 I think some of the issues that you are raising --

21 VICE CHAIRMAN WALLIS: Hence the need for  
22 the other phases.

23 MR. PARRY: We've established --

24 MEMBER APOSTOLAKIS: Yes, and that's what  
25 Gareth keeps saying, that that's why we have the other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 phases.

2 MR. PARRY: Okay.

3 MEMBER APOSTOLAKIS: So let's see -- but  
4 the last bullet there -- keep going. Keep going.

5 MR. PARRY: Okay. All right. That sounds  
6 like the right approach.

7 Phase 2 is -- as George mentioned, in the  
8 SRM it's called an issue-specific approach. We've  
9 rechristened it, if you'd like, an application-type  
10 approach, which I think is more really appropriate.  
11 In which -- in this phase the base PRA quality is  
12 demonstrated by a comparison with an applicable  
13 consensus standard for those elements of the PRA that  
14 are required for the application.

15 And the -- again, as in Phase 1, we have  
16 to address all contributors to risk. But the  
17 distinction, as George pointed out, is that now all  
18 significant risk contributors should be included in  
19 the PRA scope. And significance is defined in the SRM  
20 as being determined whether -- by taking it into  
21 consideration you could change the decision  
22 substantially. That's a nice statement, but it's a  
23 little vague. We've recognized that, and one of the  
24 tasks in this plan is to define that more clearly.

25 MEMBER APOSTOLAKIS: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARRY: And we haven't done it yet.  
2 We will define it in the process of implementing the  
3 plan.

4 MEMBER APOSTOLAKIS: Gareth, would you say  
5 what is happening now with respect to risk-informed  
6 in-service inspection is a Phase 2 application? Even  
7 now?

8 MR. PARRY: Not yet, because --

9 MEMBER APOSTOLAKIS: Why not? Why not?  
10 What's missing?

11 MR. PARRY: Well, because the PRAs that  
12 are being used as the base have not yet been tested  
13 for quality against Reg. Guide 1.200, which, you  
14 remember, has only just been released for trial use.

15 MEMBER APOSTOLAKIS: But it's going  
16 through a peer review, right? I mean -- okay, 1.200  
17 basically endorses --

18 MR. PARRY: Right.

19 MEMBER APOSTOLAKIS: -- the standard, so,  
20 I mean, it's not Phase 1, though. It may not be fully  
21 Phase 2, but it's not Phase 1 either.

22 MR. PARRY: Well --

23 MEMBER APOSTOLAKIS: And then --

24 MR. PARRY: But what you're saying is --

25 MEMBER APOSTOLAKIS: -- it's an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 application type, isn't it?

2 MR. PARRY: It's an application type. I  
3 think what you're saying is that -- that the only PRA  
4 that you need to do ISI is an internal events PRA at  
5 full power. If you can make that statement --

6 MEMBER APOSTOLAKIS: Well, we are  
7 approving them, aren't we?

8 MR. PARRY: We are, but there are -- but,  
9 remember, there are other considerations. It's not  
10 just based on that. That's part of the input. We  
11 still have to consider the other applications. But if  
12 you can convince yourself that the low power and  
13 shutdown mode is not relevant, or that fires are not  
14 relevant for ISI, which is probably true --

15 MEMBER APOSTOLAKIS: Well, yes, we must  
16 have convinced ourselves, because we're approving  
17 them.

18 MR. PARRY: Yes. But, again, you're going  
19 back to what we're doing now. Okay.

20 MEMBER APOSTOLAKIS: But my question is --  
21 or statement -- not everything we are doing now is  
22 necessarily Phase 1.

23 MR. PARRY: I think currently it really  
24 is.

25 MEMBER APOSTOLAKIS: Well --

1 MR. HARRISON: If I can --

2 MEMBER APOSTOLAKIS: -- let's suppose  
3 1.200 was not used. I mean --

4 MR. HARRISON: If I can address the risk-  
5 informed ISI piece of that, though. One of the things  
6 that's missing is the reg. guide that goes along with  
7 risk-informed ISI at some point needs to be updated or  
8 revised to reflect what the requirements are for that  
9 scope.

10 In other words, if -- right now in all of  
11 the SEs there will be a paragraph that's written  
12 dealing with external events, saying why those aren't  
13 required. That logic needs to be put into the reg.  
14 guide. It's a technicality, if you will. Once that  
15 gets done and gets approved and gets, you know, cast  
16 in stone, then I think you're right. Then we do move  
17 into a phase 2 application immediately on that.

18 MR. PARRY: But we're not ready to say it  
19 as yet. So I think that --

20 MEMBER APOSTOLAKIS: But it's almost  
21 there.

22 MR. PARRY: Yes.

23 MEMBER APOSTOLAKIS: Because basically the  
24 standard, which is the Westinghouse and the EPRI  
25 approaches, were reviewed and approved by you. And

1 that's what people are implementing.

2 MR. PARRY: Okay. Right.

3 MEMBER APOSTOLAKIS: Okay.

4 MR. PARRY: Okay. So, and this actually  
5 gets to your point, really. To achieve Phase 2, then  
6 the guidance has to exist for, how do you use the PRA  
7 in making the decision? And this includes the  
8 definition of the scope of the PRA that you need to  
9 make that decision, and then the assessment of the  
10 quality of the base PRA for each item that you need.

11 Phase 3 is not so very different from  
12 Phase 2 in the sense -- in one sense. It's still  
13 based on having the guidance documents and standards  
14 to judge the quality of the PRAs. But what Phase 3  
15 does -- it rolls everything up for all of the Phase 2  
16 applications that you've -- to date, and it rolls them  
17 up into one framework.

18 So it would pull together all of the  
19 requirements, for example, on PRA quality for all the  
20 applications that -- I think what the -- the term that  
21 the SRM uses -- currently-envisioned applications --  
22 but I think it's really what we currently do and what  
23 we anticipate to be doing in the near term rather than  
24 -- I currently envision it to be, as somebody pointed  
25 out last time, could be ---

1 MEMBER APOSTOLAKIS: Well, if you do --

2 MR. PARRY: -- it's infinite.

3 MEMBER APOSTOLAKIS: If you do 50.46, I

4 mean --

5 MR. PARRY: Yes.

6 MEMBER APOSTOLAKIS: -- you've done the

7 big one.

8 MR. PARRY: Yes.

9 MEMBER APOSTOLAKIS: Everything else will  
10 be nothing.

11 MR. PARRY: So, actually, tech spec 4B  
12 might be the big one that --

13 MEMBER APOSTOLAKIS: Good.

14 MR. PARRY: And the idea with Phase 3,  
15 it's scheduled to be completed by the end of 2008.  
16 Now, so I think the goal for the end of 2008 that we  
17 would have the regulatory framework in place -- the  
18 licensee to say that he's got a Phase 3 PRA, then he  
19 has to develop the PRA to meet that regulatory  
20 framework and -- which includes meeting the standards,  
21 getting it peer reviewed, etcetera.

22 VICE CHAIRMAN WALLIS: When you say  
23 Phase 3 is completed, do you mean that will then be  
24 the way in which you will do business?

25 MR. PARRY: We'll come to that in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 description of the flowchart.

2 MR. MAGRUDER: The policy issues.

3 MR. PARRY: There are some policy issues  
4 in there, right. Yes. At least the framework will be  
5 in place.

6 Phase 4 -- I don't think we should spend  
7 too much time on this, but it really is that stage --  
8 that phase when the PRA has been developed to the  
9 state of the art. And I think we would define state  
10 of the art as being something like capability  
11 Category 3 of the ASME standard. It's beyond current  
12 good, accepted practice.

13 MEMBER ROSEN: Isn't that a moving target?

14 MR. PARRY: Well, yes. I think that's why  
15 it would be very difficult to -- to write guidance for  
16 Phase 4. Whereas, Phase 3 it might be -- I mean,  
17 Phase 3 guidance could -- it will also be a moving --

18 MEMBER ROSEN: By definition, if all  
19 plants are at Phase 4 and I am one plant and find my  
20 -- find a new use and improve my PRA in some way,  
21 everybody else falls back to Phase 3.

22 MEMBER APOSTOLAKIS: That's a good point.

23 MR. PARRY: Yes. For that application you  
24 fall back to Phase 1.

25 MEMBER APOSTOLAKIS: Because you move the

1 state of the art.

2 (Laughter.)

3 MEMBER ROSEN: Phase 4 is an honorary  
4 degree.

5 MR. MAGRUDER: But there are other  
6 distinctions which we will get to about the staff  
7 review --

8 MR. PARRY: Yes.

9 MR. MAGRUDER: -- of the Phase 4 peer  
10 review.

11 MR. PARRY: So let me -- okay. Let me  
12 talk about the review of the base PRA. Now, this is  
13 a little different from what you saw last time. In  
14 Phase 1, currently what we do is the review of the  
15 base PRA is at the discretion of the reviewer. But  
16 what we're expecting is that while we're waiting for  
17 Phase 2 to be completed, which means getting all of  
18 the standards in place for a specific application, we  
19 will still have Reg. Guide 1.200 in place, which  
20 endorses currently the standards for internal events.

21 So we would expect that once the trial use  
22 is completed and we've modified Reg. Guide 1.200 that  
23 that would indeed be used to assess the quality of the  
24 phase -- of the base PRA even in Phase 1. So that  
25 explains my remark -- what I said earlier that Phase 1

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is like a transitional phase, really.

2 So rather than -- as far as the staff  
3 review goes, the transition from having sort of ad hoc  
4 reviews like we do currently to a more systematic  
5 review based on Reg. Guide 1.200.

6 MEMBER APOSTOLAKIS: Is it only Regulatory  
7 Guide 1.200 that matters?

8 MR. PARRY: Well, that's where -- that's  
9 the document where we will endorse the standards. So  
10 in that sense --

11 MEMBER APOSTOLAKIS: Oh, so you will keep  
12 that in appendices.

13 MR. PARRY: Yes.

14 MEMBER APOSTOLAKIS: Okay, okay. Okay,  
15 okay. So it's not in Phase 3 -- they want to handle  
16 it in Phase 3 is not the same as they want to handle  
17 it in Phase --

18 MR. PARRY: As it is now, right.

19 MEMBER APOSTOLAKIS: Ah. Maybe clarify  
20 that a little bit.

21 MR. PARRY: Yes. Yes. So in Phase 2,  
22 again, the review of the base PRA will be based  
23 primarily on 1.200 for all of the significant  
24 contributors to the application. And Phase 3, as I  
25 say, is similar to Phase 2.

1 Phase 4 is really different, because the  
2 way the SRM is written this requires staff review and  
3 approval of the base PRA, which really means getting  
4 into debt.

5 Okay. Now, this is the famous diagram,  
6 which usually takes a lot of explanation. This has  
7 changed a little bit since you saw it last,  
8 particularly on the left-hand side. I'll try and walk  
9 through it fairly quickly.

10 Okay. This -- we start off with box 1.  
11 It says the licensee has identified a specific  
12 application. Box 2 says, "Are we in Phase 3 yet?"  
13 We're going to assume for the moment that we're not.  
14 Well, we're not. So this is a futuristic box.

15 Box 3 asks, "What PRA scope is needed to  
16 support the identified application?" And that would  
17 be covered in the regulatory guides that address that  
18 application. Box 4 is the screening box that says,  
19 "Are we in Phase 2 or Phase 1 for that application?"

20 Okay. If we have the guidance in place to  
21 assess the quality of all the significant contributors  
22 that we think will be needed for that application,  
23 then we're in Phase 2, and we come out on the right-  
24 hand side of that diagram.

25 Box 2-1 asks, "Do the applicable portions

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of the base PRA conform to the existing standards for  
2 the risk-significant PRA scope?" In other words, are  
3 we consistent with the PRA requirements for that  
4 application type? If it's yes, we get kicked out to  
5 Box -- not kicked out, we go out to Box 2-2, which  
6 says you get a high priority review. We're going to  
7 have to work on these words. Really, it's a normal  
8 review.

9 If, on the other hand, not all the PRA --  
10 if the PRA is not of sufficient scope for that  
11 application -- okay, so in other words, if the  
12 application required a fire PRA, then they don't have  
13 -- they have not satisfied the fire PRA standards.  
14 Then you come out of that box with a no.

15 No, if the risk-significant contributors,  
16 however, are still addressed, they get what we've  
17 called a low priority review, because it's going to be  
18 more resource-intensive. Okay. A lot of the  
19 decisions that we've got on this graph are based on  
20 review resources.

21 If, on the other hand, the licensee hasn't  
22 even addressed these risk-significant contributors,  
23 that gets rejected.

24 MEMBER APOSTOLAKIS: But it's not up to  
25 you. I mean, the SRM tells you to do this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARRY: Well, yes, but when you  
2 actually go to the SRM -- well, this is a policy issue  
3 we've identified, and I'll --

4 MEMBER APOSTOLAKIS: Yes.

5 MR. PARRY: -- tell you why. I'll tell  
6 you why we've identified it. You could just reject  
7 it. Okay? The SRM actually says either --

8 MEMBER APOSTOLAKIS: Low priority.

9 MR. PARRY: -- they give it low priority  
10 or --

11 MEMBER APOSTOLAKIS: Which is what you  
12 have there, yes.

13 MR. PARRY: -- or reject.

14 MEMBER APOSTOLAKIS: Yes.

15 MR. PARRY: The reason we want to keep the  
16 low priority in here is really -- it's an optical one,  
17 because if we were to reject it outright it would sort  
18 of imply that what we've been doing up to date is not  
19 appropriate. And I don't think -- we don't believe  
20 that what we're doing now is inappropriate.

21 MEMBER APOSTOLAKIS: But you cannot  
22 disagree with the Commission's direction that you  
23 should give low priority or reject.

24 MR. PARRY: Or reject. And that's -- and  
25 we have that --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Yes.

2 MR. PARRY: -- that logic in here. Okay.

3 So that's --

4 MEMBER APOSTOLAKIS: So you guys agree  
5 with this?

6 MR. PARRY: Yes. But -- yes.

7 MEMBER APOSTOLAKIS: Or you are doing it  
8 because you were directed to do it?

9 MR. PARRY: No, we agree with it also.  
10 Both, actually. We think it's a good idea. Okay.

11 MEMBER APOSTOLAKIS: Yesterday I had a guy  
12 from MIT presenting something about decision analysis.  
13 Okay? And he said -- or it had to do with  
14 maintenance. He said we screened the -- we have a  
15 priority. The top priority is if the president of the  
16 institute wants it, it's done.

17 (Laughter.)

18 For the rest, we use decision analysis.  
19 So this is a practical application. Okay.

20 MR. PARRY: Okay. Now, suppose we -- in  
21 the situation which we are in with a lot of  
22 applications, where we think we would need a fire PRA  
23 or a seismic PRA, but as yet we do not have the  
24 standards in place to judge them.

25 MEMBER APOSTOLAKIS: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARRY: Okay. So that's Phase 1. So  
2 we come out to the left of this box.

3 Box 1-1 asks, "Do the applicable portions  
4 of the PRA conform to existing standards?" Does it  
5 mean those PRA -- the PRA that we've done, does it  
6 conform to Reg. Guide 1.200 guidance? If you say yes,  
7 okay, we come down to Box 1-2. This is the one that  
8 caused you a lot of -- well, you and industry a lot of  
9 heartache.

10 But what it asks is, does the application  
11 use a PRA scope that's beyond the current guidance to  
12 expand the scope of the application? Let's assume for  
13 now the answer is no. Okay. Then, this is a normal  
14 Phase 1 review, and it gets the normal priority  
15 review.

16 Now, let's go back to that box. What we  
17 really were looking for in that box was to say is --  
18 if the expansion of the PRA is to purely -- is purely  
19 to get more from regulatory requirements, then we  
20 would say that that -- we're going to say that that  
21 should get a low priority review, based on the  
22 additional resources that we would have to spend to  
23 review that application, because we currently do not  
24 have the standards to judge that. So we would have to  
25 do a lot more ad hoc review.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           An example of this, and the one we used  
2           last time, was 50.69. 50.69 -- the guidance for how  
3           to do the categorization -- is in NEI 0004. What  
4           NEI 0004 allows you to do is if you don't have a fire  
5           PRA, you don't have a seismic PRA, then what it tells  
6           you to do is then don't recategorize those components  
7           that you are relying on to deal with fire and seismic,  
8           that contribute to fire and seismic risk. You can  
9           only recategorize those things that are associated  
10          with internal events risk.

11           Okay. Now, that somewhat restricts the  
12          categorization. So if the licensee were to come in  
13          with a fire PRA to broaden the scope of 50.69 to  
14          increase the chances of recategorizing things as risk-  
15          free, that is the type of thing we're talking about  
16          here, because it's expanding the scope of the  
17          application of 50.69 by bringing in a PRA for which we  
18          do not yet have a standard. And that's the reason --  
19          that's an example of why we put that box in there.

20           MEMBER APOSTOLAKIS: But you are looking  
21          at it from the point of view that the only benefit  
22          from this is to the licensee. The licensee wants to  
23          expand the scope.

24           MR. PARRY: Right.

25           MEMBER APOSTOLAKIS: But it seems to me if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the licensee was willing to spend the resources  
2 necessary to do this extra work, that licensee is  
3 contributing to the advancement of the state of the  
4 art, which creates the foundation for developing the  
5 standards you want.

6 MR. PARRY: Yes.

7 MEMBER APOSTOLAKIS: So by having the  
8 staff review it and, you know, making comments, and so  
9 on, you are contributing to this advancement. And  
10 that is a benefit that is not here.

11 MR. PARRY: Well, I think it will be in  
12 the sense that pilot applications -- for example, tech  
13 spec initiative 4B -- I think we would not apply that  
14 rule here, because clearly it's, if you like, a proof  
15 of principle of an approach, and that is certainly  
16 developing the state of the art for that application.

17 That would not be -- I don't think we'd  
18 give that -- well, clearly, we're not going to give  
19 that a low priority review for the application that we  
20 have, because it's part of the Reg. Guide 1.200  
21 pilots. We understand that this appears to be a  
22 disincentive for some.

23 MEMBER APOSTOLAKIS: It is.

24 MR. PARRY: Well, not a disincentive.

25 MEMBER APOSTOLAKIS: To what degree, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 don't know. But there is a disincentive.

2 MR. PARRY: And that's why we have this as  
3 a policy issue.

4 MR. TSCHILTZ: We're trying -- this is  
5 Mike Tschiltz. We're trying to address that I think  
6 by saying that we would allow pilots before the  
7 standards are in place for certain applications.

8 But the problem we have is that if people  
9 proceed with using PRAs where there's no standards in  
10 existence, we're promoting ad hoc reviews, we're  
11 promoting resource-intensive reviews, and we're  
12 promoting non-standardization within the industry,  
13 whereas we're trying to harmonize things, so we're  
14 more consistent, and licensees are more consistent in  
15 their approaches to the development of standards.

16 MEMBER APOSTOLAKIS: And I agree with  
17 that. But, for example, one solution might be to  
18 break up this Box 1-5 into two boxes or three, and say  
19 that there may be other reasons that the staff may  
20 decide to give it a normal review.

21 MR. TSCHILTZ: Yes. And I think --

22 MEMBER APOSTOLAKIS: If it's of something  
23 very innovative -- I mean, the thing about the  
24 standards is you don't just declare, "I want a  
25 standard on XYZ by next December," without having the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 technical foundation to develop it, right? So this is  
2 where the technical foundation is developed, and you  
3 may choose certain things to say, "Boy, this is really  
4 new. Who is going to review it?"

5 MR. PARRY: I don't think that's what Mike  
6 was saying, that that's what we will --

7 MR. TSCHILTZ: We've discussed that, and  
8 we thought rather than putting it in the flowchart,  
9 which would maybe tend to get too complicated, you  
10 were going to address that in the text of the plan  
11 itself.

12 MEMBER APOSTOLAKIS: Well, it's attracting  
13 so much discussion, maybe it belongs --

14 MR. PARRY: Well, I think that -- well, if  
15 we make the viewgraph any more busy, though, I think  
16 we'll -- we'll make things even more complicated. I  
17 think this is really just a -- ultimately, we'll have  
18 to read the --

19 MEMBER APOSTOLAKIS: Put one or two words  
20 there to direct people somewhere else to --

21 MR. PARRY: Okay. All right.

22 MEMBER APOSTOLAKIS: Because right now it  
23 doesn't say that.

24 MR. PARRY: That's fine. We'll do that.  
25 And what box -- let me go back up to Box

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 1.1, then. If the applicable portions of the PRA do  
2 not conform to existing standards, which means, for  
3 example, if a licensee comes in with an application  
4 that he has not done a -- he has not used Reg.  
5 Guide 1.200 to demonstrate quality of his PRA, then he  
6 would basically get a low priority review ultimately.

7 And this is a picture of when -- you had  
8 asked, George, I think through Mike, that we talk a  
9 little bit about the schedule. This is not going to  
10 take place immediately the guidance documents are  
11 established. Okay? There's a phase-in period for  
12 this.

13 For example, we've built in currently into  
14 the schedule a year after the guidance has been  
15 developed to allow licensees to meet that guidance.  
16 Now, the year is perhaps negotiable. I don't know.  
17 We haven't decided that that's definitely the date,  
18 but there has to be like a grace period to allow  
19 everybody to catch up to the guidance.

20 So moving on from this one, we have the  
21 second --

22 VICE CHAIRMAN WALLIS: How do you deal  
23 with these statements about risk-significant  
24 contributors are meeting current guidance? If you  
25 haven't put them in, how do you know if they are risk-

1 significant or not?

2 MR. PARRY: I think it's a -- well, I  
3 think you can make a -- you can make a judgment as to  
4 whether the change you are trying to make with the  
5 application is going to affect the risk from fires or  
6 seismic.

7 MEMBER ROSEN: You say -- "could" is the  
8 word you used.

9 MR. PARRY: I said "could," yes.

10 MEMBER ROSEN: You say "could affect."

11 MR. PARRY: But I think --

12 MEMBER ROSEN: And I think that's flexible  
13 enough.

14 MR. PARRY: Yes. And I think we have to  
15 -- I think the general guidance will have to come out  
16 and make those statements. It will say, "To do this  
17 application, you need a fire PRA, you need a seismic  
18 PRA." That doesn't prevent a licensee from -- for his  
19 plant to come in and say, "Well, because I'm in this  
20 seismic region, I don't have to do a seismic PRA  
21 because my plant is not vulnerable at all."

22 VICE CHAIRMAN WALLIS: So these are  
23 plausible qualitative arguments that we got into  
24 before.

25 MR. PARRY: Well, they may be -- yes.

1 Well, they may be more than plausible and qualitative,  
2 but --

3 MEMBER POWERS: What I'm struggling with  
4 a little bit here is I sit here and say I'm interested  
5 in some component, and I have done a prior PRA. And  
6 so I come along and I make a plausibility argument  
7 that says, "Gee, the thing I worry about most in the  
8 case of fire is spurious operation of this --  
9 operation badly."

10 If I can come up with some scenario with  
11 this component I'm interested in spuriously operating  
12 in some -- in an unusual fashion causes a problem, do  
13 I always end up in low priority review, then?

14 MR. PARRY: No. Well, it depends where we  
15 are with the standards. I mean, the low priority is  
16 -- first of all, the guidance for the application has  
17 to specify which -- what the scope of the PRA is you  
18 need.

19 Okay. If you -- currently, if it's a fire  
20 PRA you need, we don't have fire standards. That  
21 doesn't relegate you to low priority review. If after  
22 the fire PRA standards are in place you still come in  
23 without a fire PRA, that would.

24 MEMBER POWERS: I guess what I'm worried  
25 about is your significant contributors not being

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 included.

2 MR. PARRY: Right.

3 MEMBER POWERS: And --

4 MR. PARRY: Well, let me, before you  
5 complete your question -- in this context, significant  
6 contributor, what I'm really talking about is the big  
7 contributor, like the type of initiating event and the  
8 type of operating mode.

9 The level of the -- the contributor at the  
10 level of the specific basic event is a function of the  
11 PRA, and that gets addressed when you do an  
12 application. You have to go through and find out  
13 which elements of the PRA are relevant to the answer.  
14 So I think you are talking at a somewhat deeper level  
15 than I was talking about here.

16 MEMBER POWERS: Okay.

17 MR. PARRY: And that won't be forgotten,  
18 but it will be addressed in the application-specific  
19 guidance.

20 MEMBER APOSTOLAKIS: You have five  
21 minutes.

22 MR. PARRY: Okay. Well --

23 MEMBER APOSTOLAKIS: Tony, how much time  
24 do you need?

25 MR. PIETRANGELO: I want my time allotted

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on the schedule.

2 MEMBER APOSTOLAKIS: You will have it.

3 MR. PARRY: I'm going to skip over this,  
4 because this is when the Phase 3 --

5 MEMBER APOSTOLAKIS: Yes.

6 MR. PARRY: -- this is sort of futuristic.  
7 The only -- okay. The policy issues that we've  
8 identified -- and I will focus I think primarily on  
9 the statement of the issue. We're still -- we had a  
10 meeting with our risk-informed licensing panel the  
11 other day, and they gave us some advice on how to  
12 perhaps restate some of the pros and cons in here.  
13 But I'll at least give you our rationale for why we're  
14 making the decision.

15 So the first issue was the one we  
16 discussed about in relation to that box. It's the use  
17 of the PRA scope greater than that for which standards  
18 exist, simply to increase the scope of relaxation  
19 requirements.

20 And we asked: should this submittal be  
21 given low priority? And our recommendation is yes,  
22 primarily on the basis that this is a very resource-  
23 intensive thing, and we really would -- and the reason  
24 it's resource-intensive is that we wouldn't have the  
25 standards to judge it.

1           The second policy issue is once a -- and  
2           this is related to the words that were in the SRM. If  
3           the licensee submits an application for which all of  
4           the applicable guidance documents are in place, which  
5           is Phase 2, but they don't conform to that guidance,  
6           should we give that application low priority? Or  
7           should it be rejected outright?

8           Our argument is that we should err towards  
9           the low priority, primarily because rejection would  
10          send a message that we haven't been doing the job  
11          properly up to date.

12          The issue 3 is when all of the guidance  
13          for all current and anticipated applications is in  
14          place -- Phase 3 -- should every licensee be required  
15          to conform to that guidance before submitting any  
16          risk-informed submittals?

17          Okay. Our recommendation here is no,  
18          because if the licensee is really only interested in  
19          one application, to develop a PRA that would cover all  
20          of them would be really, in a sense, an unnecessary  
21          burden.

22          The arguments against our proposed  
23          recommendation, really, is that without this there  
24          really is no forcing function to go to Phase 3.

25          MEMBER APOSTOLAKIS: You are going back to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Phase 1.

2 MR. PARRY: Well, no, there's another one.  
3 When all the guidance for Phase 3 is in place, if you  
4 followed our recommendation, then they would still be  
5 able to come in with Phase 2 applications. Okay? For  
6 specific application types.

7 And this policy issue says, okay, if they  
8 don't follow all the guidance for Phase 2 at this  
9 point, which means they're really coming in with a  
10 Phase 1, should we reject it outright? And our  
11 recommendation here is yes, because this would  
12 reinforce the Commission's view that we need to  
13 develop more complete PRAs.

14 There is maybe a -- this is also perhaps  
15 a little contradictory to what we said in policy  
16 issue 2. But we feel that when -- and this is why I  
17 think it has to be a policy decision, because the  
18 Commission has to weigh in on this -- because reg.  
19 guides typically tell you one way of doing things and  
20 not -- and we were allowing these applications in the  
21 past.

22 So the next policy issue, and the last one  
23 we've identified, is effective -- and that was brought  
24 up by Mr. Rosen last time. Actually, I think that he  
25 suggested this. If the SDOs decline to produce a

1 standard considered necessary for an application,  
2 should the NRC develop its own guidance? And our  
3 recommendation here is yes.

4 And don't worry about the pros and cons.  
5 As I say, we're still working on those.

6 Okay. The activities that we need to do  
7 to implement this phased approach, we need to -- I  
8 haven't described the tasks here. And, in fact,  
9 they've changed a little bit from the version of the  
10 plan you have.

11 We need to continue supporting the  
12 development and the endorsement of PRA standards. We  
13 need to update regulatory guides, and that includes  
14 Regulatory Guide 1.200. We probably need to develop  
15 regulatory guides for new applications. These are  
16 anyway -- in any case being done.

17 We need to develop methods and supporting  
18 documents for the technical issues. As you mentioned  
19 earlier, George, there are three of the technical  
20 issues that were identified in the SRM that we need to  
21 address. And we also need to develop staff  
22 implementation guidelines, which include things like  
23 the standard review plan and office instructions.  
24 That's -- the office instructions is where we'll find  
25 the discussion of the priorities of review.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And the industry also has to do some  
2 things. Okay?

3                   MEMBER APOSTOLAKIS: Let's look at the  
4 schedule itself.

5                   MR. PARRY: Okay. We have I think a  
6 viewgraph that talks about the schedule. Again, this  
7 is not final. The reason I bring it up here is to  
8 show you that if you look at, for example -- look at  
9 the second group of two -- PRA quality, Reg. Guide  
10 1.200 pilots. We are planning to finish those by  
11 December 30th, and then modify the reg. guide.

12                   The implementation, which is when we would  
13 expect this guide to be used for all applications in  
14 the future that use internal events PRA, would be --  
15 currently it's September 30, 2005. And these are  
16 tentative dates, but you will see that -- all  
17 throughout here that the implementation follows a year  
18 after the completion of the documents. And this is to  
19 build in that grace period.

20                   MEMBER APOSTOLAKIS: Now, there is nothing  
21 on Level 2 on --

22                   MR. PARRY: No. Because currently none of  
23 our applications really requires a Level 2 and a  
24 Level 3 PRA.

25                   MEMBER APOSTOLAKIS: Doesn't the guide

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 talk about LERF -- I mean, 1.174?

2 MR. PARRY: It only talks about LERF. And  
3 the --

4 MEMBER APOSTOLAKIS: And we have guidance  
5 with LERF?

6 MR. PARRY: Yes. The ASME standard  
7 addresses LERF.

8 MEMBER APOSTOLAKIS: Which one?

9 MR. PARRY: The current one.

10 MEMBER APOSTOLAKIS: The existing one.

11 MR. PARRY: The existing one covers LERF,  
12 yes.

13 MEMBER APOSTOLAKIS: No, you're right.

14 CHAIRMAN BONACA: I had a question on the  
15 decisionmaking process that we discussed before -- at  
16 the beginning. You know, the presumption is that the  
17 delta CDF is independent of the baseline model. I  
18 mean, if you do have -- and I agree with that for the  
19 foreseeable changes.

20 I'm concerned about a major change like  
21 50.46 with tentacles all over the place where you have  
22 -- you may have missed certain pieces -- power  
23 shutdown, other pieces there which are still affected  
24 by that. And, therefore, you're assuming some  
25 bounding examples based on similar plants, and so on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and so forth.

2 My concern is that plant specificity is so  
3 critical in some of these evaluations -- I mean, in  
4 the model -- that, you know, the assumption of delta  
5 CDF independence may not be true. How do you get  
6 comfortable about reviewing it?

7 MR. PARRY: I don't think we can answer  
8 that question in this -- in this --

9 CHAIRMAN BONACA: I understand that. But  
10 we were discussing before the issue of, you know, Reg.  
11 Guide 1.174, and I understand that -- but that's an  
12 assumption that is always being made, and even is made  
13 in the SRM.

14 MR. PARRY: I think that sort of decision,  
15 though, will have to be made in any regulatory guide  
16 that's associated with 50.46 and the implementation of  
17 it. That will have to address what those issues are,  
18 and it will define --

19 CHAIRMAN BONACA: Okay.

20 MR. PARRY: -- what's needed for the  
21 application. And that will decide whether it's  
22 Phase 1, 2, or 3. Well, it won't be 3, that's for  
23 sure, and it may not be 2 --

24 CHAIRMAN BONACA: Yes.

25 MR. PARRY: -- for a while.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BONACA: Because, I mean, there  
2 is a widespread belief that that's always true. But  
3 in practical terms, when you do the modeling, and then  
4 you do certain assumptions, and then you call, you  
5 know, a comparable plant and you say, well, you know,  
6 this is -- well, you know, you discover you have a lot  
7 of differences in fact that you don't understand until  
8 you do the PRA.

9 MR. PARRY: Yes, I think you're right.  
10 But in a way this -- this draft plan is irrelevant if  
11 we don't have applications that are moving forward  
12 that require these different scopes I think.

13 MEMBER APOSTOLAKIS: The item there called  
14 alternate methods and treatment of uncertainties,  
15 that's the model uncertainty issue?

16 MR. PARRY: Yes.

17 MEMBER APOSTOLAKIS: And the human  
18 performance is somewhere else?

19 MR. PARRY: Yes. It's -- well, it's  
20 probably not on this. It's not on here, I don't  
21 believe.

22 MEMBER APOSTOLAKIS: But in the -- I don't  
23 know to what extent you have changed the plan itself.  
24 But the discussion of human performance there was not  
25 very convincing, and it was --

1 MR. PARRY: We have --

2 MEMBER APOSTOLAKIS: -- completely  
3 separated from the issue of model uncertainty. I  
4 mean, that issue in human performance is model  
5 uncertainty.

6 MR. PARRY: Right.

7 MEMBER APOSTOLAKIS: So it should be  
8 handled in some way. Developing guidance regarding  
9 accepted practices, or whatever way they put it,  
10 doesn't help.

11 MR. PARRY: Well, it helps I think that  
12 our review is to understand what's needed to meet the  
13 standard. But I agree with you. Those --

14 MEMBER APOSTOLAKIS: It doesn't appear --  
15 you have it somewhere else, but not here.

16 MR. PARRY: Right. No.

17 MEMBER APOSTOLAKIS: Here the issue is if  
18 there are different views out there, different models,  
19 what should I do?

20 MR. PARRY: What should you do, yes. Yes.  
21 And, actually, to some extent that's already covered  
22 in some of the current reg. guides. To some extent.

23 Okay. But, yes, we need to -- we haven't  
24 really focused on that. We've been focusing more on  
25 the implementation, but we will revise that. We know

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that we have to do that.

2 MEMBER APOSTOLAKIS: Well, do you agree  
3 that the technical issues are important to all phases?

4 MR. PARRY: They're all important, yes.  
5 And I think what you -- but what it -- but, again, I  
6 think what that comes down to is that -- is that when  
7 you define your decisionmaking process, it has to be  
8 robust enough to recognize that these issues have not  
9 yet been resolved.

10 And, therefore, I think it has to be done  
11 in tandem with the decisionmaking process. It's not  
12 really -- this plan really is only to help develop the  
13 base PRAs. The model uncertainties will still be  
14 there.

15 MEMBER APOSTOLAKIS: Yes.

16 MR. PARRY: But they have to be addressed  
17 I think through the vehicle of the decisionmaking  
18 process, not through this guide, or through this plan  
19 I should say. And so --

20 MEMBER APOSTOLAKIS: So the only  
21 benefit -- the only benefit, then, that a licensee  
22 would have from the -- this whole process is the level  
23 of priority that they would get when they submit an  
24 application, in reviewing it.

25 MR. PARRY: But there may be other --

1 MEMBER APOSTOLAKIS: What else?

2 MR. PARRY: There may be other benefits,  
3 though.

4 MEMBER APOSTOLAKIS: Like?

5 MR. PARRY: Well, like, for example, if  
6 you have a Phase 3 PRA, then its use in resolving  
7 another phase -- Phase 3 SDP issues would be -- I  
8 think it would be of great benefit.

9 I also think that the development of the  
10 PRAs does allow the scope of things like 50.69 to be  
11 expanded.

12 MEMBER APOSTOLAKIS: But we could bring it  
13 up -- maybe it's most the obvious example, but --

14 MR. PARRY: It is an obvious example.

15 MEMBER APOSTOLAKIS: Anyway, you've  
16 handled your time very well.

17 MR. PARRY: Thank you.

18 MEMBER APOSTOLAKIS: Are there any  
19 comments or questions from the committee?

20 Well, thank you very much.

21 MR. PARRY: Thank you.

22 MEMBER APOSTOLAKIS: It was very  
23 enlightening.

24 So one last question. The plan that I  
25 have is not the plan that you have? Mine is dated?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PARRY: Yes. I mean, it's in the  
2 process of flux.

3 MEMBER APOSTOLAKIS: So your view about  
4 the committee writing a letter is what?

5 MR. PARRY: Well, I think the --

6 MEMBER APOSTOLAKIS: Not what the letter  
7 should say.

8 MR. PARRY: No.

9 MEMBER APOSTOLAKIS: Should the committee  
10 write a letter now or wait until June or something,  
11 you know, when we review the final thing?

12 MR. PARRY: I think --

13 MEMBER APOSTOLAKIS: If we review it.

14 MR. PARRY: Yes. I think that probably my  
15 guess is that what you're more interested in is the  
16 overall philosophy rather than the detailed tasks --  
17 task descriptions. And the -- I would suspect also  
18 the policy issues, doing a weigh-in on those.

19 I don't think those are going to change  
20 dramatically. I don't anticipate they will change  
21 dramatically. So if you feel you have enough to go on  
22 on those issues, then I think you could write the  
23 letter now.

24 MEMBER APOSTOLAKIS: Okay.

25 MR. PARRY: But if you wanted to see the

1 detailed task plans, which I'm not sure you -- I mean,  
2 well, I think we've identified the issues that we're  
3 going to address.

4 MEMBER APOSTOLAKIS: Very good. Thank  
5 you. That was very --

6 MR. PARRY: Thank you.

7 MEMBER APOSTOLAKIS: -- useful.

8 Okay. Mr. Pietrangelo.

9 MR. PIETRANGELO: Good morning. What I  
10 want to start with is where we were with the SRM  
11 March 31st of last year versus where we are now after  
12 the December 18th SRM.

13 From our perspective, what the Commission  
14 paid for and SRM put out in December was a vast  
15 improvement over the guidance and direction that was  
16 provided last March. And I think Gareth touched on  
17 this a little bit, but I wanted to underscore it.

18 The position put forward in that SRM --  
19 the previous SRM was what we referred to as the all  
20 singing and dancing PRA to do any further  
21 applications, which was really a significant change  
22 from the way we were proceeding and the direction we  
23 were heading. It was a -- not only a step change, I  
24 call it a cliff change in approach. Okay?

25 Therefore, we view what the Commission put

1 out in December, and the associated paper, as a  
2 significant improvement for the following reasons.  
3 The direction is to continue to evolve PRA technology,  
4 both the scope and technical adequacy and level of  
5 detail, while at the same time allowing practical uses  
6 of that technology in the regulatory process and to  
7 get more efficient as we go. I think we shouldn't  
8 forget that.

9 That's a key part of that SRM, and I think  
10 that's a lot of what's behind the staff's paper is to  
11 try to gain efficiency as we go forward. We want  
12 those efficiencies, too. A licensee pays the NRC for  
13 the review. If the review takes longer, you're  
14 already penalizing the NRC -- or the licensee, because  
15 he's paying for it. So we want efficiency in the  
16 regulatory process, both for the staff and for the  
17 licensee. So I think that there's a good balance  
18 there.

19 So we wholeheartedly agree with the  
20 overall thrust of the Commission's direction to allow  
21 progress as we move forward with evolving the scope  
22 and technical adequacy of PRAs.

23 You know, put all the rest of the  
24 mechanistic waste and the phases and how to proceed,  
25 that's the key part of this decision. And I think

1 it's the right one from our perspective.

2 The other part I wanted to mention also is  
3 that we believe applications drive the evolution of  
4 PRA. If there's no good use for it, or cost benefit  
5 for it, it's going to be highly unlikely that a  
6 licensee is going to invest resources in it.

7 A lot of what's in the paper we sent to  
8 the staff last week talks about our current efforts,  
9 what we're doing this year, and it wasn't mentioned  
10 very much in the previous talk about the pilot plan we  
11 have on Reg. Guide 1.200 to use the ASME standard.  
12 That's a significant effort.

13 That standard alone took over four years  
14 to develop. The peer reviews for the Level 1 PRAs  
15 that are now a requirement in the standard, the  
16 industry started that before the standard was even  
17 developed. That took five years, and that's on the  
18 areas of PRA we know them most about.

19 The standard came out last year. It took  
20 another year to get a reg. guide that endorses it for  
21 trial use. It'll take another year at least for us to  
22 pilot that and specific applications. And I think per  
23 the staff's schedule, it will take about nine months  
24 to put out the revision of the reg. guide. So, and  
25 that's the thing we know the most about and have the

1 most experience with.

2 When you get into these other areas with  
3 you know, fire and seismic and shutdown, there haven't  
4 -- there hasn't been one peer review, I don't think,  
5 in any of those areas yet. It took the industry five  
6 years to do the Level 1 peer reviews. So I think the  
7 paper -- this isn't the last time I think the  
8 Commission is going to weigh in on the direction for  
9 the evolution of PRA and scope of technology.

10 This is going to take a long time. I  
11 think what you heard in the ASME/ANS letter was that  
12 the schedule might be ambitious. We didn't even talk  
13 about schedule in our letter. Okay? We just want to  
14 make sure the arrow is pointing in the right  
15 direction. However long it takes it takes, and things  
16 always take longer than we think they're going to take  
17 up front.

18 VICE CHAIRMAN WALLIS: Now, this  
19 reluctance to proceed, is it due solely to economic  
20 forces? Or is it because you don't know how to do  
21 better? It seems to me you do know how to make better  
22 PRAs, but you just don't think it's worth it.

23 MR. PIETRANGELO: No, that's not it at  
24 all. In fact, you know, I'm going to disagree with  
25 the staff on the first policy issue. There are people

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that are making investments in scope enhancements to  
2 their PRA. Fire I think is the best example.

3 And also, I'm going to penalize somebody  
4 because there isn't a standard there? We disagree  
5 with the staff on that, as did the subcommittee. We  
6 think that sends the wrong message.

7 So it's not a reluctance. It's a tool.

8 VICE CHAIRMAN WALLIS: But it is an  
9 economic thing. You're reluctant to invest when you  
10 don't see a payoff.

11 MR. PIETRANGELO: Well, anyone would have  
12 that --

13 VICE CHAIRMAN WALLIS: Right. That is the  
14 reason -- that is what motivates your --

15 MEMBER APOSTOLAKIS: I believe, though,  
16 Graham, that comes back to a point I tried to make in  
17 my introduction.

18 Maybe you missed it, Tony. You'll have  
19 your time, Tony. Don't worry about that.

20 MR. PIETRANGELO: Okay.

21 MEMBER APOSTOLAKIS: Namely, the  
22 integrated decisionmaking process. The way it's done  
23 now, I'm not sure it encourages better PRAs, because  
24 you can get by with, you know, a PRA that's not as  
25 good as somebody else's. And that is not addressed in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 all of this, which is part of the philosophical  
2 approach that Gareth I think mentioned that a  
3 committee might want to look at.

4 That was a timeout. We'll start again  
5 with you.

6 MR. PIETRANGELO: Okay.

7 MEMBER APOSTOLAKIS: I don't want you to  
8 be anxious, Tony.

9 MR. PIETRANGELO: Okay. But I'll disagree  
10 to some extent with the point you just made.

11 MEMBER APOSTOLAKIS: Okay.

12 MR. PIETRANGELO: It's not the  
13 decisionmaking process that's not sending the right  
14 message to licensees. It's the applications. 50.69  
15 is the best example. We mentioned that a lot in our  
16 paper.

17 MEMBER APOSTOLAKIS: I agree.

18 MR. PIETRANGELO: Okay. I can't -- as a  
19 licensee, I can't opt to do 50.69, unless I have a PRA  
20 that meets that ASME Level 1 standard. That's the  
21 incentive to get them to go further, and I can't  
22 expand the scope of that application to include more  
23 SSCs without expanding the scope of my PRA.

24 MEMBER APOSTOLAKIS: That's a very  
25 clear --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. PIETRANGELO: I'd be penalized for  
2 using that now. I think that's, again, the wrong  
3 message.

4 MEMBER APOSTOLAKIS: You're right. For  
5 50.69, you are right.

6 MR. PIETRANGELO: Later on, the staff in  
7 the -- I think the Phase 3 part penalizes you for --  
8 if you don't meet the standard and don't have a PRA.

9 MEMBER APOSTOLAKIS: Right.

10 MR. PIETRANGELO: Okay? So you're  
11 penalized if you have it in Phase 1, and then you're  
12 penalized again in Phase 3 if you don't have it.  
13 Okay? I just think that's wrong.

14 Phase 1 is Phase 1. It is where we are  
15 today. If they have the resources, they review it.  
16 I mean, we have a -- and I'm going to ping Mike  
17 Tschiltz a little bit on this. We've had an  
18 application in on containment ILRT on an industry  
19 perspective to go from 10 to 20 years that isn't being  
20 reviewed right now. It's been in there since  
21 December. It's a big industry activity.

22 The staff asked us to do it, but they  
23 don't have enough resources to do it right now.  
24 That's just a practical reality. I'd like to get them  
25 to get some resources on that, but I would assume

1 that's got a low priority because nobody is reviewing  
2 it, and it's an industry initiative.

3 MEMBER POWERS: Tony, I guess I'm just a  
4 little puzzled. If a licensee comes in and he has  
5 been aggressive in developing PRA, and he has things  
6 for which -- in his PRA for which he -- there are no  
7 standards to review against, doesn't that ipso facto  
8 mean that it's going to take more review on the part  
9 of the NRC and, consequently, he is going to be  
10 penalized in dollar cost if nothing else?

11 MR. PIETRANGELO: Yes. But evidently,  
12 though, he wouldn't submit that application unless he  
13 thought that the benefit on the other end of that  
14 process was worth it.

15 All right. So it's already tough to do  
16 it, and I'm not disagreeing with the staff that that  
17 would be a more resource-intensive review. It would.  
18 But if somebody is willing to pay for it, it shouldn't  
19 automatically get a low priority. It's just going to  
20 be the reality that it takes more staff review, and  
21 that's the boat we're in now. And I think assigning  
22 priorities high and low based on that now --

23 MEMBER POWERS: So it's only --

24 MR. PIETRANGELO: -- inadvertently sends  
25 the wrong message I think.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: So it's really the  
2 labeling that you're objecting to --

3 MR. PIETRANGELO: Yes.

4 MEMBER POWERS: -- not the conscientious  
5 attempt to reflect reality.

6 MR. PIETRANGELO: Yes, and inadvertently  
7 conveying the wrong message.

8 MEMBER POWERS: I agree with you that the  
9 -- it's an unfortunate choice of words. And I think  
10 the staff does, too. I mean, they kind of apologized  
11 when they presented it.

12 MR. PIETRANGELO: Let me move on here.  
13 Overall, we think the staff implementation plan is a  
14 reasonable response to what the Commission direction  
15 was. I mean, we agree with probably 98 percent of  
16 what's in there.

17 I've just shared with you the one where we  
18 do disagree on this kind of what we call penalizing  
19 the licensee for using a broader scope PRA than the  
20 standards available.

21 The other thing we mention in there is the  
22 terminology. If you're following this on a day-to-day  
23 basis like we do, you know, we understand the nuances  
24 in it. But it's not immediately apparent to people  
25 outside the process. We thought we were on a path

1 where we weren't talking so much about PRA quality as  
2 much as -- more about PRA technical adequacy. I mean,  
3 that's the title of Reg. Guide 1.200 is the technical  
4 adequacy of PRAs to support applications.

5 Scope means, you know, Level 1, fire,  
6 shutdown, other external events, Level 2, Level 3.  
7 That's what we mean by scope. We reserve the term  
8 quality for a higher level, and that is the ultimate  
9 decision out of that risk-informed decisionmaking  
10 process. That, to me, is where we really want quality  
11 to be achieved.

12 All right. We want good, robust  
13 decisions. And you need technically adequate PRAs and  
14 -- with an appropriate scope to support that decision.  
15 So that's kind of our triangle -- quality, technical  
16 adequacy, and scope.

17 When you say PRA quality, and you use,  
18 let's say, a bounding method -- all right, it would --  
19 things start getting mixed up while you're not using  
20 a quality PRA, and it just gets more confusing to  
21 communicate to people. So we think we ought to stick  
22 with a set and be consistent, and we've already got  
23 reg. guides out there that say that, so --

24 MEMBER APOSTOLAKIS: So what you're saying  
25 is that the PRA itself may not be of the highest

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 quality, but the decision, though --

2 MR. PIETRANGELO: The decision has to be  
3 quality.

4 MEMBER APOSTOLAKIS: -- was -- yes.

5 MR. PIETRANGELO: The PRA has to be  
6 technically adequate.

7 MEMBER APOSTOLAKIS: That's an interesting  
8 distinction. Interesting distinction.

9 MR. PIETRANGELO: Okay. You were talking  
10 about the different phases. I think we're in a lot of  
11 -- in some respects, we're in Phase 1.5. Okay? We  
12 have been using the peer review results. It's  
13 somewhat analogous to -- you'll use the results of  
14 your assessment against the ASME standard. So it's  
15 not totally Phase 1, and it's not totally Phase 2.  
16 But we're about Phase 1-1/2. That's okay.

17 The other thing -- you know, standards are  
18 supposed to capture good practices. And this goes  
19 back to this other issue about penalizing somebody for  
20 having -- you know, how do you get the good practices  
21 if you're not incentivizing people to use the methods  
22 and improve them? Okay. Again, I think it's  
23 unfortunate.

24 The technical issue on uncertainty -- as  
25 an industry, we're trying to gather our forces into a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 single entity to develop some guidance on treatment of  
2 uncertainty. We've had some initial discussions with  
3 Mary and the staff on this, and I hope we'll get to a  
4 point later this year where we can share what that  
5 work is about, both with the staff and with the ACRS,  
6 because I know it's an important --

7 MEMBER APOSTOLAKIS: I understand EPRI is  
8 doing something for the industry, too.

9 MR. PIETRANGELO: Yes. But we're trying  
10 to make sure what we do -- EPRI and the owners groups  
11 -- that we --

12 MEMBER APOSTOLAKIS: Okay.

13 MR. PIETRANGELO: There's probably about  
14 four different efforts. We want one --

15 MEMBER APOSTOLAKIS: Okay.

16 MR. PIETRANGELO: -- that's supported by  
17 everybody.

18 Okay. I wanted to quickly go through the  
19 policy issues. I think we talked about one. The  
20 staff's recommendation is, yes, we don't agree. Okay.

21 On the second one --

22 MEMBER APOSTOLAKIS: You don't agree.  
23 Okay.

24 MR. PIETRANGELO: Yes, that's the  
25 penalizing thing we've talked about.

1 MEMBER APOSTOLAKIS: Yes.

2 MR. PIETRANGELO: And the second one -- if  
3 a licensee submits an application for which all of the  
4 applicable documents are in place, but does not  
5 conform to the guidance, should the application be  
6 given low priority?

7 We agree with the staff's recommendation,  
8 and it says it in our paper. If there is a standard  
9 out there, and you're using a PRA for that element,  
10 and you don't conform to it, then you ought to get a  
11 low priority. We don't disagree with that at all.

12 Okay. Policy issue 3 -- when all guidance  
13 for all current and anticipated applications is in  
14 place, should every licensee be required to conform to  
15 that guidance before submitting any risk-informed  
16 submittals?

17 The recommendation is no. This is -- I  
18 think it was explained before, for the licensee who  
19 doesn't want to do that whole suite of things, we  
20 shouldn't penalize that. So we agree with the staff's  
21 recommendation there.

22 Number 4 -- we disagree. This is on the  
23 -- if an application does not conform to the Phase 2  
24 guidance, you reject it outright. And the staff I  
25 think appropriately captured our concern in the con

1 here, and that there will still be -- and the  
2 Commission paper acknowledges this -- if you have a  
3 bounding analysis that was good enough before, all  
4 right, whether it restricts the scope of the decision  
5 or the application, appropriately restricts the  
6 application, it's not a resource issue anymore,  
7 because it's a bounding analysis. So that's not it.

8 This is just the -- we want you to have a  
9 greater scope PRA, and if you don't have it, you know,  
10 you can't come in. I think that's the wrong message  
11 to send. Not every -- it's going to be a cost-benefit  
12 decision. If you want to have everybody have the full  
13 suite, require it. Okay? If you can't -- I don't  
14 think the agency can even just reject things if  
15 there's an appropriate bounding analysis in there  
16 that's appropriate for the decision.

17 On number 5, I think this issue is moot.  
18 The NRC is paying the standards development  
19 organizations to develop standards. Okay? I mean,  
20 they're falling all over themselves trying to -- to  
21 hurry up and get these things done. So I don't even  
22 think this is an issue, and -- but I agree with the  
23 recommendation. If the staff thinks a standard is  
24 necessary and the SDOs don't want to do it, then go  
25 ahead, develop your own guidance.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ROSEN: Isn't that a little bit  
2 simple, Tony? I mean, sure the NRC is paying the  
3 standards organization, and the standards  
4 organizations use participation across the whole  
5 industry.

6 MR. PIETRANGELO: That's true.

7 MEMBER ROSEN: And it is sometimes  
8 difficult to get the right people involved --

9 MR. PIETRANGELO: It is.

10 MEMBER ROSEN: -- and that -- and that  
11 takes a long time and may -- may or may not be  
12 available. So I think it's not entirely moot. I  
13 think there is a situation where we have -- I think  
14 we've used the word "hostage." I'm not sure that's  
15 exactly the right word, but I -- but it -- you know,  
16 we are going to have cases where we're not going to  
17 have the availability of consensus standards for one  
18 or more reasons.

19 And the question, really, then comes if we  
20 need a standard, well, yes, the NRC should develop its  
21 own guidance, and the industry and the standards  
22 organizations should just read it and weep, because  
23 they had their chance. The preference is for the  
24 standards organizations to do the job. If it's not --  
25 isn't done and the agency feels it needs it and goes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ahead, fine, that's the way it is, and that fully  
2 comports to the OMB Circular.

3 The OMB Circular just says use it if it's  
4 available. It doesn't say, you know, hold up with any  
5 regulatory action if -- until it's available.

6 MR. PIETRANGELO: Right. And the other  
7 point -- you mentioned about they're not -- there's  
8 nothing on the schedule for Level 2, Level 3, and so  
9 forth. And the proper -- I think the right response  
10 was given, "Well, there's no applications that use  
11 those elements now."

12 Well, the same can be said for shutdown.  
13 There's not one application, I don't think, that  
14 requires a shutdown PRA.

15 We think the order of the development of  
16 these standards is wrong. We think the fire one  
17 should be moved up. That's the one I think that has  
18 more -- we need to risk-inform the priorities of the  
19 standards development.

20 MEMBER ROSEN: That is a good point.

21 MR. PIETRANGELO: Fire is the one we think  
22 we're going to need sooner than the other ones.

23 MEMBER ROSEN: Yes. I agree with you on  
24 that, but I think that to -- the need for the low  
25 power and shutdown standard is incorrect, because it

1 is important -- and it comes up frequently in the IDPs  
2 and elsewhere -- to do cycle risk optimization, where  
3 you're making a decision about when you should do  
4 online maintenance.

5 The question is often, well, it's going to  
6 -- we're going to take some risk, even in shutdown, by  
7 having this system out. Will we take more or less if  
8 we do it online? Well, you really don't know. I  
9 mean, you have some bounding analysis, and you have  
10 some qualitative arguments. But you really don't know  
11 unless you have a shutdown PRA.

12 MEMBER APOSTOLAKIS: Donnie?

13 MR. HARRISON: Tony is going to have to  
14 hold on to that thought, right? This is Donnie  
15 Harrison from the staff. I just wanted to back up to  
16 issue 4 real quick.

17 I think we probably need to clarify what  
18 our position is on issue 4. It wasn't to penalize a  
19 licensee that's using a bounding analysis. It's  
20 really to get out of the -- where we get qualitative  
21 arguments, or you don't do any analysis but you put on  
22 compensatory measures to try to control -- do fire  
23 watches.

24 And that's really the intent of stopping  
25 you from doing that. If you can do a bounding

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 analysis to screen out a hazard, that would be  
2 acceptable and --

3 MEMBER APOSTOLAKIS: Yes. Because that  
4 can be as rigorous as anything.

5 MR. HARRISON: Right. So I think we need  
6 to clarify issue 4.

7 MR. PIETRANGELO: And then we agree.

8 MR. HARRISON: Yes. So I think that's --

9 MEMBER APOSTOLAKIS: But if it's a  
10 statement that -- to make it clear.

11 MR. SNODDERLY: Chairman Bonaca, I also  
12 wanted to make the committee and Tony aware of one  
13 other thing. Tony mentioned the importance of the  
14 Reg. Guide 1.200 pilot reviews. Next month in May at  
15 the full committee meeting Donnie Harrison is going to  
16 do an information briefing to the committee on the  
17 status of the pilot application, so we invite NEI to  
18 be aware of that.

19 MR. PIETRANGELO: Good. Okay. That's a  
20 very important effort. I want to leave you with one  
21 last thing.

22 MEMBER APOSTOLAKIS: Sure.

23 MR. PIETRANGELO: We are currently  
24 considering an effort to develop guidance on an  
25 enhanced decisionmaking process. Recall ancient

1 history -- there was the EPRI PSA applications guide,  
2 and then the development of Reg. Guide 1.174 that this  
3 committee had a lot to do with. Okay?

4 It's been out there for several years. It  
5 has served us well. We're kind of entering this next  
6 phase now where we're going to have, you know,  
7 quantitative results, some qualitative things, some  
8 bounding analysis, some uncertainties, this and that.

9 And there's a thought on our side to  
10 saying maybe we need to have an enhanced  
11 decisionmaking framework to consider these different  
12 things. I think Dr. Kress raised the point about  
13 adding in, you know, the contributions from the other  
14 elements of scope. And, you know, obviously there's  
15 different levels of uncertainties with some of those  
16 other things, but is it appropriate to add it in? Or  
17 if it is appropriate, how do you do it? That kind of  
18 thing.

19 So we're seriously considering an effort  
20 on kind of an enhanced decisionmaking framework,  
21 probably akin to what we did on the applications  
22 guide, but more perhaps for the staff to endorse in a  
23 subsequent review relative to 1.174, or just as input  
24 to a revision to 1.174. That's still the motherhood  
25 document in Reg. Guide 1.200.

1 MEMBER ROSEN: Who has used that?

2 MR. PIETRANGELO: We developed it for  
3 ourselves I think first of all. I mean, the  
4 applications guide was for ourselves. I mean, there's  
5 a lot of risk-informed decisionmaking that doesn't --  
6 is not submitted to the NRC. Okay?

7 So I think we have to be certain about how  
8 we're doing that and doing it appropriately. And if  
9 it works in the regulatory process, then that's even  
10 better.

11 MEMBER KRESS: Would that include a more  
12 substantive quantifiable definition of defense-in-  
13 depth, do you think?

14 MR. PIETRANGELO: Perhaps.

15 (Laughter.)

16 MEMBER KRESS: And safety margins.

17 MR. PIETRANGELO: I think we're kind of in  
18 the embryonic stage, but I think given that that's one  
19 of the elements in the decisionmaking framework and  
20 1.174, I think yes.

21 MEMBER KRESS: Yes. Well, it would be  
22 quite interesting to see --

23 MEMBER APOSTOLAKIS: Well, the  
24 quantitative measure of defense-in-depth in fact is  
25 known as PRA I think.

1 MEMBER KRESS: Yes, but it's -- you can  
2 mess around with --

3 MEMBER POWERS: Only to a misguided  
4 rationalist.

5 (Laughter.)

6 MEMBER APOSTOLAKIS: Mr. Pietrangelo, do  
7 you have anything else that is much more --

8 MR. PIETRANGELO: No. Thank you for the  
9 time.

10 MEMBER APOSTOLAKIS: Okay. Thank you very  
11 much.

12 I hear no other comments. Back to you,  
13 Mr. Chairman.

14 CHAIRMAN BONACA: Okay.

15 MEMBER APOSTOLAKIS: Because I didn't ask  
16 for any, right?

17 CHAIRMAN BONACA: Let's take a break and  
18 get back at 10:30.

19 (Whereupon, the proceedings in the  
20 foregoing matter went off the record at  
21 10:11 a.m. and went back on the record at  
22 10:27 a.m.)

23 CHAIRMAN BONACA: Okay. Let's get back  
24 into session.

25 The next item on the agenda is SECY-04-

1 0037, issues related to proposed rulemaking to risk-  
2 inform requirements related to large break LOCA break  
3 size and plans for rulemaking on LOCA with coincident  
4 loss of off-site power.

5 And Dr. Shack is going to lead us through.

6 MEMBER SHACK: Okay. We had a  
7 subcommittee meeting on this in which we discussed  
8 essentially the status of the rulemaking in terms of  
9 some policy and technical issues that the staff had  
10 identified, and the status of the expert elicitation  
11 to define the frequency of large break LOCAs.

12 And we'll be reviewing those two items  
13 here today, and Eileen and Glenn are going to start  
14 off by going over the policy and technical issues that  
15 the staff has identified. And then we'll follow with  
16 a discussion of the frequency of the large break LOCA.

17 MS. McKENNA: Good morning. My name is  
18 Eileen McKenna. I'm currently a Section Chief in the  
19 Policy and Rulemaking Program in NRR, but I had been  
20 the Lead Project Manager on this effort during the  
21 development of the paper that we had sent up to the  
22 Commission.

23 With me is Glenn Kelly, Senior Reliability  
24 Risk Analyst in the Probabilistic Safety Assessment  
25 Branch in NRR. In the room we have other members of

1 our working group who, you know, may be called upon if  
2 necessary for various topics.

3 We want to try to get to the technical  
4 issues for discussion as quickly as possible, so I'm  
5 going to kind of cover this one part fairly quickly --  
6 typical agenda, the purpose, background, into the  
7 discussion of the issues, and then a wrap-up.

8 Our purpose at this point is -- was to  
9 inform the committee about what we've been doing since  
10 we got the SRM and to certainly obtain any feedback  
11 from the committee that they would like us to consider  
12 as we move forward in resolution of the technical  
13 issues and development of the rulemaking.

14 Briefly, in background, option 3, there  
15 had been previous discussions with the committee about  
16 risk-informing technical requirements in Part 50, and  
17 50.46 was one of the candidate rules that was  
18 suggested as opportunity to consider the risk  
19 importance of various break sizes and how that relates  
20 to the requirements and make appropriate changes.

21 There was papers that went up to the  
22 Commission in '01 and '02, and that resulted in an  
23 SRM on March 31, 2003, that, among other things,  
24 tasked the staff to conduct two rulemakings -- one to  
25 prepare a proposed rule that allows for a risk-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 informed alternative to the present maximum LOCA break  
2 size, and, second, to prepare a proposed rule that  
3 would risk-inform the functional reliability  
4 requirements and thus relax the current requirement  
5 that for -- assuming large break LOCA with a  
6 coincident loss of off-site power.

7 The SRM had a number of specific  
8 statements about what they wanted the rulemaking to  
9 consider, and I just want to cover a few of those  
10 because they led to, in some respects, some of the  
11 issues that we're dealing with.

12 As I mentioned, the first one was to  
13 develop the risk-informed alternative maximum LOCA  
14 break size. The Commission suggested a change to the  
15 definition of LOCA to exclude some low-risk  
16 contribution. But, you know, they kind of left it  
17 open as to exactly how that might be accomplished.

18 It did state that the staff must establish  
19 the risk cutoff for defining the new maximum LOCA  
20 break size. And, again, they gave some examples of  
21 how that might be undertaken.

22 There was a statement in there that the  
23 Commission would not support changes to functional  
24 requirements unless they were fully risk-informed, and  
25 the Commission gave as an example that they did --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that they did not support changes to ECCS coolant flow  
2 rates or containment capabilities.

3 VICE CHAIRMAN WALLIS: Unless they are  
4 fully risk-informed.

5 MS. MCKENNA: Well, the first sentence was  
6 -- the functional requirements, unless fully risk-  
7 informed. This was a separate sentence.

8 VICE CHAIRMAN WALLIS: Yes. So it wasn't  
9 clear to me whether it was dependent on the -- this  
10 being risk-informed or not. This is part of our  
11 discussion in the subcommittee.

12 MS. MCKENNA: Well, yes. Exactly, right.

13 VICE CHAIRMAN WALLIS: It seems to be a  
14 bit up in the air.

15 MEMBER APOSTOLAKIS: And fully risk-  
16 informed means what?

17 MS. MCKENNA: Well, this is one of the  
18 things that we spent a lot of time discussing in our  
19 working group as to -- we'll get into that in I think  
20 some of the issues that we are presenting.

21 MEMBER APOSTOLAKIS: Phase 3 or 4.

22 MS. MCKENNA: There were three other  
23 statements I'll just touch on from the SRM. One about  
24 -- it's kind of using best estimate ECCS evaluation  
25 models. I won't spend a lot of time dwelling on it,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 just that that was part of it.

2 The next one I think leads directly to the  
3 point that was just made. The SRM had a statement  
4 that once the standards are in place, the PRA should  
5 be Level 2 internal and external initiating all modes.  
6 PRA subjected to peer review and submitted to and  
7 endorsed by the NRC.

8 Now, obviously, this SRM predated the  
9 December SRM on the action plan, but this was, you  
10 know, a statement in the SRM that we were responding  
11 to. And, finally, there was a statement that  
12 operational changes should be reversible if local  
13 frequency estimates, which are -- you know, as Rob  
14 will probably tell you, you know, there is a tasking  
15 to revisit the estimates every 10 years. And if we  
16 find that the frequency change is unacceptable in some  
17 sense that we might need to reverse what was  
18 implemented under this undertaking.

19 MEMBER FORD: Could you say something  
20 about the origin of the 10 years, and whether that's  
21 immutable? Given the fact that many of the  
22 degradation modes that become unfortunately  
23 unexpected.

24 MS. MCKENNA: I think it came out of the  
25 Commission vote sheets in the SRM. There was a

1 separate provision for a five-year look for new  
2 failure mechanisms. And I think, as Rob had mentioned  
3 at the subcommittee, this doesn't mean that we're  
4 going to be ignoring operating experience and  
5 information as time goes on. But it was more that the  
6 Commission wanted this periodic, you know, more in-  
7 depth perhaps consideration of the information and  
8 reassessment.

9 So that's how it kind of -- I don't know  
10 if there's any more magic to the 10, beyond just --

11 MEMBER FORD: So it's not immutable.

12 MS. MCKENNA: I don't think -- I mean,  
13 just other than, you know, as I said, the Commission  
14 proposed it. But, you know, if there was some basis  
15 for us to say, you know, we really think we need to do  
16 it more often, or whatever, I'm sure, you know, the  
17 Commission would not, you know, say no on that -- in  
18 that sense if we had, you know, reason for that.

19 MEMBER KRESS: And PRA referred to in your  
20 second bullet --

21 MS. MCKENNA: Yes.

22 MEMBER KRESS: -- that's -- if you change  
23 the rule, then the licensee comes in and wants to make  
24 changes to his plat based on risk information, that's  
25 the PRA you're talking about.

1 MS. MCKENNA: That's correct. Because  
2 this is meant to be a voluntary alternative that a  
3 licensee could take and use, not that they'd be  
4 required to do that. And this would be, again, part  
5 of -- if you were making these changes, then we need  
6 to consider the impact on risk. And the Commission  
7 was looking for this level of PRA.

8 MEMBER KRESS: That looks like a Phase 3  
9 PRA. What would you call it?

10 MS. MCKENNA: I'm not an expert, but I  
11 think -- Glenn, maybe -- would you call it a Phase 3?  
12 Or Mark?

13 MR. KELLY: No. It's actually a Phase 4,  
14 because it has been reviewed by the NRC, and that  
15 doesn't happen until Phase 4.

16 MEMBER APOSTOLAKIS: But weren't we told  
17 earlier that there has been no application of Level 2  
18 PRA to this day? And the letter from the -- from ANS  
19 and ASME says that there are no plans to issue a  
20 Level 2 standard. So when you say once standards are  
21 in place, that means now you are talking about several  
22 years in the future.

23 MS. MCKENNA: Well, that was one of our  
24 considerations as we were working on this effort. And  
25 as I mentioned, I think the December SRM kind of gave

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 another opportunity to revisit this point as to  
2 whether this level of PRA is necessary for the  
3 applications that might come out of this redefinition,  
4 which kind of leads into the paper and what the scope  
5 of the rulemaking might be.

6 MR. MARK RUBIN: Yes. This is Mark Rubin  
7 from the staff. The original SRM said reviewed and  
8 endorsed by the staff, and this is something, as  
9 Eileen said, that's being sort of revisited by the  
10 further work being done by the rulemaking. It will  
11 probably be subsumed by the phase quality initiative  
12 and be developed in more detail by the rulemaking and  
13 fleshed out by the detailed rulemaking.

14 MS. MCKENNA: So, as I said, that was kind  
15 of the backdrop of where we were in the basically  
16 March/April timeframe last year, and just -- I'm going  
17 to go through a couple of bullets on what we -- you  
18 know, we did. As I mentioned, we had a working group  
19 that we brought together people from various groups  
20 that would be impacted and would need to contribute to  
21 this effort.

22 And we went through the SRM and some of  
23 the things like, what does fully risk-informed mean to  
24 us, and how would we carry that out, and we tried to  
25 understand, you know, that if we really did this in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 particular ways what would it mean and how would we do  
2 it.

3 We got some initial stakeholder input  
4 about, you know, what kind of applicants -- this was  
5 supposed to be voluntary alternative -- you know,  
6 candidate offered as a -- for potential burden  
7 reduction as -- that's suitably risk-informed. And  
8 so, you know, we get some -- so I had some discussion  
9 about what could be the scope and what should be  
10 required for implementation, and some idea of possible  
11 applications that industry might be interested in as  
12 a result of the redefinition.

13 We started looking at, okay, how might we  
14 write a rule? How would we do this? You know, should  
15 we redefine LOCA, and what's the implication if we did  
16 that? Or should we write it in a different way that  
17 was more focused on, you know, an application that  
18 you'd -- you know, you'd list particular applications  
19 or, you know, as a process like, you know, instead of  
20 saying here's the requirements that no longer apply,  
21 and here's the new requirements.

22 And we tried to look at various ways you  
23 might go about that, so that we did do it in a risk-  
24 informed way and made sure that we had the right  
25 requirements, that the changes that might occur to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 plant would be appropriately looked at, that PRA scope  
2 would be suitable to what we're doing. And as we said  
3 in the last bullet, the lifetime aspects, you know,  
4 which gets you to the reversibility things of, you  
5 know, over time are we -- you know, are the changes  
6 going to continue to be acceptable?

7 As a result of those deliberations and  
8 discussions, we identified a number of issues that we  
9 thought needed development and resolution in order to  
10 move forward with the rulemaking. And we'll talk  
11 about these a little bit more shortly.

12 And we also did some -- initiated some  
13 research activities to look at some implications of  
14 some of these things -- that if you were to do, for  
15 example, uprates, what might be the kind of change in  
16 the thermal hydraulic response. You know, how might  
17 that affect risk on some candidate sample basis to,  
18 you know, give us an idea of what ballpark we might be  
19 in on some of these things?

20 We had a briefing for the Commission  
21 assistants in January, and kind of as a result of some  
22 of that discussion and our efforts to try to present  
23 these issues and how they were challenging us to  
24 complete the rulemaking, we ended up sending up the  
25 SECY-04-0037 paper. And what we tried to do is frame

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the issue.

2 The major issue we saw is that we needed  
3 to have a better understanding from the Commission of,  
4 really, how far they meant us to go. Were they really  
5 looking for a very specific set of a few small things  
6 that could be done that are support arising from the  
7 large break LOCA redefinition?

8 Or were they really looking for a broader,  
9 it's redefined, and take it where it leads you with  
10 some suitable set of acceptance criteria that, you  
11 know, are risk-informed, but these were very different  
12 kinds of rulemakings and approaches. And the  
13 complexity of solving the issues and the success of  
14 those would certainly vary.

15 So that's the major issue we framed to the  
16 Commission as policy of how -- do we go in a specific,  
17 narrow, or do we go more broad, comprehensive? And we  
18 also had some others in there, but this was the major  
19 topic.

20 And then, as I'll turn it over to Glenn in  
21 a moment, there were also a number of technical --  
22 technical/regulatory we called them -- issues that we  
23 felt needed to be considered.

24 Let me turn to Glenn.

25 MR. KELLY: Hi. I'm Glenn Kelly with PRA

1 Branch in NRR. This morning I'd like to talk to you  
2 about some of the technical and regulatory issues that  
3 arose as we attempted to meet the guidance that was  
4 laid out in the SRM that the Commission gave us in  
5 March of 2003.

6 We found that there were -- some of these  
7 technical issues were potentially very challenging.  
8 The first one that I'd like to talk about is  
9 determining -- one of the things we felt we had to do  
10 was to determine what are the appropriate criteria  
11 that we needed to use to decide what would be the new  
12 maximum design basis LOCA.

13 And then, once we decided what that  
14 criteria was, how much confidence would we need to  
15 have in that particular criteria, or in the  
16 information that was going to be used to determine  
17 whether or not that criteria was met. And Rob  
18 Tregoning is going to be talking later to you about  
19 the elicitation -- expert elicitation that developed  
20 frequencies for these small and large break sizes.

21 VICE CHAIRMAN WALLIS: I don't know how  
22 you assess confidence when you ask experts.

23 MR. KELLY: Well, I think that that's one  
24 of the things that Rob is going to be talking about,  
25 and about the process that they use. And they have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 attempted to include the uncertainty among the  
2 experts, as well as just the inherent uncertainty in  
3 the results themselves. But they'll talk in more  
4 detail about that.

5 MEMBER KRESS: Will you talk about the --  
6 what is the -- what you think is the appropriate  
7 criteria?

8 MR. KELLY: I'm sorry?

9 MEMBER KRESS: Well, you know, you talked  
10 about the issue is what is the appropriate criteria to  
11 use, redefining the LOCA. Are you going to talk about  
12 what you've decided at --

13 MR. KELLY: In our paper that we sent to  
14 the Commission on March 3rd, we identified a number of  
15 technical issues. And one of the ones that we said  
16 that we wanted to --

17 MEMBER KRESS: Well, you want feedback  
18 from the Commission on that. That's what you --

19 MR. KELLY: We were not seeking Commission  
20 feedback on that. We were indicating to the  
21 Commission that this was a technical issue that we  
22 were going to be working on.

23 MEMBER KRESS: I see.

24 MS. MCKENNA: The paper we did kind of  
25 talk -- suggest that we thought a frequency of break

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 size was part of this criteria for selection, rather  
2 than a risk number, for example. I think that -- but  
3 it's not something that we've picked a number and  
4 we're going with it, but it's kind of an approach that  
5 we had suggested in the paper.

6 MR. MARK RUBIN: This is Mark Rubin again  
7 from the staff. A frequency-based approach and an  
8 appropriate confidence about that are two I think of  
9 the challenges that, you know, we are faced with, that  
10 we have to develop. We are early in the process. We  
11 are certainly seeking guidance and consult in doing  
12 that, and I think Rob may have some --

13 MR. TREGONING: Yes, just a clarification.  
14 This is Rob Tregoning from the staff. We looked at  
15 uncertainties due to two -- two areas. One, we looked  
16 at the uncertainty within the responses for each panel  
17 member in the elicitation, but then -- so we captured  
18 that. We also captured the variability among the  
19 panel members, so we had two different measures that  
20 we used to capture each of those areas of uncertainty.

21 And we would propose that -- and one of  
22 the things we've talked about and we're still kicking  
23 around on the staff level -- and it goes to the heart  
24 of this issue -- how do you use both of these measures  
25 of uncertainty in a rigorous way when you go set the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 regulatory -- when you revise the regulatory  
2 framework.

3 So that's -- that's certainly a  
4 substantial technical issue that we're, as Mark said,  
5 still struggling with.

6 MR. KELLY: And one of the aspects that I  
7 think you'll find as I think we go through these  
8 technical issues is that potential resolution of one  
9 issue many times depends on how you're resolving  
10 something else, because, for example, one of the  
11 things that we'll talk about later here is about the  
12 retention and mitigation capability.

13 Having -- if you had no retention and  
14 mitigation capability, you might choose a different  
15 criteria than if you had very high confidence in  
16 having retained mitigation capability. So these are  
17 all things that have to be considered when we come up  
18 with our final recommendations.

19 MEMBER SHACK: Now, the elicitation scope,  
20 too, is only the degradation of piping systems, which  
21 is certainly not the only way that you can get LOCAs.  
22 And it wasn't clear how you were going to address  
23 essentially the other LOCA frequencies.

24 MR. KELLY: There are -- the elicitation  
25 has attempted to address other non-piping breaks, such

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 as manway covers, things like that. It -- they have  
2 not, at this point, completed work on things such as  
3 the effect of seismic events on the piping, or water  
4 hammer, what -- and I don't believe that they're going  
5 to be dealing with heavy load drops. But they have  
6 covered things up through vessel rupture.

7 MR. TREGONING: Yes. Glenn, let me try to  
8 be clear. What we did in the elicitation -- and we're  
9 having a lot of the discussion that may best be  
10 postponed for when I'm up there. I don't want to take  
11 too much of your time here this morning. But the SRM  
12 was very clear in the direction that was really  
13 specifically to look at that -- those portions of  
14 LOCAs that were due to primarily normal operating  
15 loading due to passive system degradation.

16 As you've mentioned, you certainly get  
17 LOCAs from a variety of additional sources. One of  
18 the things that we've mentioned is an issue is when we  
19 do this rule revision we have to consider all of the  
20 sources of LOCA to make sure that we're fully risk-  
21 informed.

22 So in areas -- and, you know, so areas of  
23 crane drops, areas of seismic, areas of -- we  
24 considered water hammer, just not the rare water  
25 hammer -- the water hammer that would only occur -- we

1 defined "normal loads" as loads that you'd expect over  
2 a 60-year plant life. So if it's the rare -- you  
3 know, the one in a 100-year water hammer, we didn't  
4 explicitly consider that.

5 So all of these things need to be also  
6 rolled in and considered as well. And we've looked at  
7 one piece. We obviously still need to go back -- and  
8 there's been a lot of work done over the years in  
9 these other pieces, and our plan is to go back and  
10 look at this work, dust it off, and see which of this  
11 -- which of this -- given what we want to do with the  
12 information, does this work still hold? You know, is  
13 it still valid, or do we need to update it in some  
14 sense?

15 There's been a lot of work done on seismic  
16 piping failure frequencies, and we don't want to  
17 reinvent the wheel so to speak. We just want to take  
18 what we've done, update it as we need to to try to  
19 make sure it's consistent with the intent of, again --

20 MEMBER SHACK: Well, I was more interested  
21 in Glenn's example for -- of the manway failures. Is  
22 that included, or isn't it included --

23 MR. TREGONING: Yes.

24 MEMBER SHACK: -- in your scope?

25 MR. TREGONING: Yes, that's included in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the scope.

2 MEMBER ROSEN: How about reactor coolant  
3 pump seal?

4 MR. TREGONING: Not pump seals. We  
5 defined -- we were very clear dealing with passive  
6 system metallic components. And we didn't deal with  
7 things like stuck open valves, pump seals. We defined  
8 those as active system LOCAs.

9 Now, we are -- we do have a corollary  
10 effort that's looking at updating those frequencies.  
11 Those frequencies have been studied pretty extensively  
12 throughout the years, and we've got a pretty good  
13 operating experience for those types of frequencies.  
14 So we are updating those numbers just to ensure that  
15 they are consistent with the latest numbers that we  
16 have for the passive system failures.

17 MEMBER KRESS: Do you envision this rule  
18 when it's written to be -- have a different form for  
19 application to new plants as opposed to an operating  
20 plant?

21 MR. KELLY: As we had talked about for the  
22 subcommittee, we've proposed that for future plants  
23 that the -- that we postpone the effort to define how  
24 LOCAs would work for them. And one of the reasons was  
25 that it's not clear what would constitute a design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 basis event for future plants.

2 And because what we're talking about here  
3 is modifying the design basis to exclude certain  
4 breaks above a certain size. It's just not -- I'm not  
5 sure how that would fit in with -- because it may be  
6 that a future application might be entirely risk-  
7 informed.

8 I'd like to move on to technical issue  
9 number 2, and that issue had to do with a better  
10 understanding of what is the practical effect if I  
11 actually take an event, such as breaks above a certain  
12 size, out of the design basis? What does that mean  
13 technically? What does that mean legally, for QA  
14 maintenance, reliability, all of these other things?  
15 How far do the tendrils of this go throughout the  
16 design? That's a very challenging question.

17 What can be changed under the rule if you  
18 change the design basis, if you take these events out  
19 of the design basis? Will I be able to have much  
20 larger power uprates than I was able to do before? I  
21 think that would be an expected consequence.

22 Would I be able to change my ECCS  
23 capabilities? Will I be optimizing my flow rates to  
24 handle small break LOCAs rather than large break  
25 LOCAs? Ultimate heat sink capacity might change. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 could change boron concentration in the refueling  
2 water storage tank or in other places. EQ profile is  
3 going to change in containment, things like that.

4 So where if we go to a broader rule, where  
5 it's a process-oriented rule rather than a very  
6 defined list of changes to equipment, under a broad  
7 rule, where, if anywhere, do we want to say, okay,  
8 here is where you stop.

9 VICE CHAIRMAN WALLIS: But if the large  
10 break LOCA had never been there, all of these things  
11 would have been different.

12 MR. KELLY: That's correct.

13 MEMBER ROSEN: We have the great fortune  
14 in this industry of having a bunch of innovative and  
15 intelligent people running these plants. And you can  
16 be sure that if this rule goes into place they will  
17 scurry around and find all of the opportunities, even  
18 the ones you missed.

19 MR. KELLY: Right.

20 MEMBER ROSEN: Now, that leads me to my  
21 question, which is, are you using the industry's  
22 resources or asking the industry to help participate  
23 in these discussions? Because they will likely have  
24 ideas about ways this could be used that will go  
25 beyond what you might expect.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KELLY: I'm sure that they have  
2 already been thinking about many ways that they can  
3 make use of this potential rule change. We have asked  
4 a number of times. We've gotten some responses back  
5 from the industry. I think one of the most complete  
6 responses was a white paper that they put together,  
7 gave us a draft in July of 2003 that describes some of  
8 what they wanted to do.

9 There was also some discussions that were  
10 held at an overseas conference where they talked in  
11 more detail about some of the potential changes that  
12 they might like to make. So we've had some  
13 discussions.

14 For various reasons, we've not had --  
15 since -- when was the last time we had a public  
16 meeting?

17 MS. MCKENNA: July, I think.

18 MR. KELLY: July of last year -- we've not  
19 had a public meeting, and it's in part because we were  
20 preparing to go forward to the Commission and explain  
21 where we were.

22 MS. MCKENNA: We weren't sure of the  
23 Commission's receptiveness to some of the areas one  
24 way or the other. So, you know, it's kind of -- we  
25 could have discussion with the stakeholders externally

1 and say, "Okay. Yes, it sounds like these are good  
2 candidates," and then but -- but, you know, the  
3 Commission said, "But we didn't want you to change  
4 ECCS flow rates." So, you know, is that one off the  
5 table?

6 So that was part of our difficulty with  
7 having too much discussion on possible -- I think we  
8 have an idea from the things that Glenn mentioned of  
9 some of the things that are in people's minds, and I  
10 -- you know, I think they are looking for, okay, well,  
11 what would be involved?

12 You know, what's the -- again, some of  
13 those -- am I going to have to do a full scope PRA in  
14 order to get these? You know, what else -- you know,  
15 are there some other tradeoffs? Things like that.  
16 And, you know, should we continue on these, or are  
17 they just going to be rejected?

18 MR. MARK RUBIN: But in direct answer, we  
19 will be actively soliciting industry participation.  
20 As part of the rulemaking we will be having numerous  
21 public meetings asking just those questions and  
22 incorporating in our rulemaking activities all  
23 stakeholder participation.

24 MEMBER ROSEN: Very good. Because as this  
25 comes into focus more and more in the industry, they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 will get -- more and more ideas will come forward that  
2 -- some of which will be challenging, and some of  
3 which will be no-brainers. But whatever, it takes --  
4 what I want to do is encourage you to continue to do  
5 that, to continue to pulse it as you go forward,  
6 because it's not a one-shot kind of thing. People  
7 will think of new things as the process moves forward.

8 CHAIRMAN BONACA: The question I have  
9 regarding some of the examples here -- I mean, some of  
10 them would prevent the reversibility that the SRM is  
11 specific on. And why would you use them as examples?  
12 For example, I see using the excess capability of ECCS  
13 for doing many things. A reduction in ECCS capability  
14 -- are you speaking of qualification?

15 MS. MCKENNA: Well, certainly some are  
16 more difficult to reverse than others. Absolutely.

17 CHAIRMAN BONACA: Or flow rates?

18 MS. MCKENNA: Yes.

19 MR. KELLY: Part of the -- one of the  
20 things that we've talked about in reversibility is  
21 that there are two ways to do reversibility. One way  
22 would be to actually physically reverse the  
23 modification, whatever was made, in a sense of if I  
24 took out a pump, put the pump back in.

25 Another way of reversing it might be to --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 changing how I operate the plant in some way to give  
2 me the same effect, in the sense of I might be saying  
3 what I'm really reversing is the increase in core  
4 damage frequency. And, therefore, if I can do other  
5 things that are going to change that increase in core  
6 damage frequency, that would be equivalent to making  
7 -- reversing that change. And that would be, you  
8 know, the way we're postulating it, where we would say  
9 that that's acceptable.

10 CHAIRMAN BONACA: Because, I mean, maybe  
11 I misunderstood it, but I read the SRM always as, in  
12 fact, not proposing to reduce the functional  
13 capability of the system, but to use it for other  
14 purposes. I mean, that to me is -- defines  
15 reversibility.

16 You know, if you talk about beginning to  
17 remove pumps and pipes, yes, I mean, to reverse it  
18 means pretty massive changes to the plant. I mean --

19 MS. MCKENNA: Well, this was one of the  
20 issues we did pose back to the Commission to say, you  
21 know, could they give us any more insight of what they  
22 had in mind by reversibility, and were they open to  
23 the kind of reversibility that we were talking about  
24 of, you know, kind of an overall risk thing rather  
25 than saying, you know, this -- on a change-by-change

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 basis, you have to undo it versus what Glenn was  
2 talking about of considering that it's a risk  
3 contribution, is there something else that offsets it.

4 MR. KELLY: In looking at the SRM, their  
5 SRM was put together from a number of vote sheets.  
6 And there are some places where we had some difficulty  
7 in interpreting exactly what was meant, and there are  
8 some places we felt it was requiring a very narrow  
9 rule. In other cases, it appeared to be applying in  
10 a much broader sense.

11 And so, again, that's one of the things  
12 that we've gone back to the Commission and said if you  
13 want a very specific, potentially a rule where we  
14 basically list, you know, the only changes that you  
15 can make, are you going to do it on a basis of broad  
16 changes?

17 CHAIRMAN BONACA: Yes, okay. That's  
18 great. Appreciate your bringing it up, because, I  
19 mean, I always presumed in my mind that reversibility  
20 meant something. And that combined with the  
21 reevaluation of the frequency of breaks every 10  
22 years, so it seems to me that if you have that process  
23 -- but you are right, I mean, you could interpret it  
24 differently. And so --

25 MS. MCKENNA: And it is a bit of a new

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 concept in regulation to say that, you know, you do  
2 something and then you reverse it later, you know, if  
3 particular -- on a case by case -- you know, there is  
4 always kind of the you revisit it if you get new  
5 information. But to specifically build into your  
6 process reversibility I think is a little unusual.

7 MEMBER ROSEN: Well, it's not entirely  
8 new, Eileen. I think in the exemption request, the  
9 graded QA thing for South Texas, there was a  
10 requirement to relook -- to look at whether the  
11 changes that had been made were, in fact, affecting  
12 the failure rates, and, if so, to consider whether the  
13 new failure rates that were being observed were large  
14 enough that you'd want to reverse the changes. So I  
15 would say there is some precedent.

16 MS. MCKENNA: Okay. That's fair. I mean,  
17 again, we're getting more into the risk-informed  
18 applications, where I think it becomes more of a  
19 consideration.

20 CHAIRMAN BONACA: But to me, the SRM  
21 really meant controlling the interface between within  
22 design basis and beyond design basis, and be flexible  
23 about that -- flexible based on the information you do  
24 have regarding frequency of breaks. And so that, to  
25 me -- well, that's the way I interpret it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: I think you have the other  
2 issue, too, of if you change the plant's design basis,  
3 and then you modify the plant -- for example, the sump  
4 screens -- if you say risk-informing that issue means  
5 leak before break or limiting the break size, that  
6 limits the debris accumulation which is what really  
7 sets the size of that screen. So that's not a  
8 reversible process. That's a tear out and replace  
9 process.

10 CHAIRMAN BONACA: See, that's what I mean.  
11 I think that, you know, I see a more narrow definition  
12 of reversibility -- I mean, something you can effect.

13 MEMBER SIEBER: Well, that goes a step  
14 further, too. You know, you really don't need to  
15 change 50.46 in order to apply that principle to that  
16 particular question. And I think that application,  
17 though, would have to be consistent with whatever it  
18 is you do in 50.46, you know, because you're relying  
19 on the same philosophical and theoretical --

20 MS. MCKENNA: Absolutely.

21 MEMBER SIEBER: -- basis to make that  
22 change to the plant.

23 MS. MCKENNA: I mean, this goes back to  
24 the comment I think that -- about what areas there is  
25 interest in the industry, and this one has come up as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a potential candidate of, you know, is there room  
2 here?

3 I mean, I think there's recognition that  
4 some of these other issues that we talked about, like  
5 mitigation capability, would have to be dealt with in  
6 a manner consistent with what we're talking about  
7 here.

8 But this is one where there is, you know,  
9 a real application potentially, and people seeing --  
10 you know, they're going to have to make a decision  
11 about what kind of upgrades to make on their screen  
12 potentially, and, you know, could that be done in the  
13 -- something other than consider the double-ended and  
14 treat it like, you know, we would normally do and, you  
15 know, take -- see where that takes you.

16 MEMBER SIEBER: Well, I think that without  
17 some kind of guidance, when licensees propose a  
18 modification to the plant to deal with that, you are  
19 going to get all -- a wide variety of approaches and  
20 a wide variety of assumptions. And it would be good  
21 if you are prepared for that when the time comes.

22 MS. MCKENNA: Well, I think that's why,  
23 you know, we want to try to work through these issues,  
24 and those activities, you'll see in a later slide, you  
25 know, to try to get us to that point of having some

1 consistent basis to make those kind of decisions from.

2 MEMBER SIEBER: Well, that will be your  
3 first challenge -- to come --

4 MS. McKENNA: No question.

5 MEMBER SIEBER: -- to come in the door  
6 before you even get to 50.46.

7 VICE CHAIRMAN WALLIS: It is very  
8 thoughtful on that, but it seems to me that you really  
9 ought to consider a broad -- what would you do if  
10 there were a broad interpretation of this? And then  
11 back off from that.

12 So, I mean, that's the biggest thing you'd  
13 have to face when you have very broad interpretation,  
14 and then you'd face all of these issues in spades. If  
15 you faced that and thought about that, then you might  
16 be able to argue about how you should back off from  
17 some of the implications of that.

18 MR. KELLY: Well, I think that's one of  
19 the things --

20 VICE CHAIRMAN WALLIS: You can't just  
21 whittle away at a problem by asking all of these  
22 questions. You may well have to interpret a broad  
23 change in the rule.

24 MR. KELLY: Well, I think most of these  
25 questions -- these issues came up with the thought

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that a broad rule might be the approach the Commission  
2 chose.

3 MS. MCKENNA: Again, there were  
4 indications about, okay, if you really define the  
5 definitions -- the LOCA in the regulations and said --  
6 you know, and carry it forward, you would do that  
7 broad thing.

8 And so then we started asking ourselves,  
9 well, you know, did the Commission really mean, would  
10 the -- did we think it would be appropriate to really  
11 use it in this way? Or, you know, does that mean that  
12 you can change this part of containment? Does that  
13 mean you can do this? Can you do that? And on what  
14 basis would you decide that?

15 You know, as Glenn said, are there things  
16 where we're saying, "No, we don't want to entertain  
17 changes in that area, because we think it would not be  
18 risk-informed"? And do you do that by writing  
19 criteria? Do you do it by fencing things off?

20 There's different ways you could approach  
21 it, but those are some of the considerations, because  
22 we were looking from the -- you know, if it really was  
23 broad, you know, just doing broad by itself, you know,  
24 we think is not sufficient. You would have to figure  
25 out, what is the box you build around it, so that when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 -- the changes that actually get implemented are the  
2 right ones.

3 MR. KELLY: I think issue number 3 we've  
4 already talked about. So I'd like to jump on to issue  
5 number 4, and that has to do with mitigation  
6 capability. Technically, if one were to merely say,  
7 okay, I've taken break sizes, say, above six inches  
8 out of the design basis, that if one did that, then  
9 there would be no requirement that the design mitigate  
10 breaks above six inches.

11 And, therefore, there would be no  
12 requirement that a LOCA of six and a half inches would  
13 not go to core melt, would not go to early containment  
14 failure. There would be no requirement at all for  
15 that.

16 CHAIRMAN BONACA: Right.

17 MR. KELLY: Now, we -- and the industry  
18 has indicated their agreement, too, in meetings that  
19 they think that this -- some mitigation capability  
20 should be retained for these break sizes that are  
21 greater than up to the double-ended guillotine break.

22 But the question comes: what would this  
23 mitigation capability be? We've talked about that we  
24 wouldn't need as much assurance. For example, now we  
25 basically require for a design basis accident you can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 handle, you know, loss of off-site power or loss of  
2 one of the, you know, greatest single failure, and all  
3 of these other things that go along with it.

4 Maybe we would say, you know, you need  
5 only one train. We require -- we don't think that --  
6 maybe we're going to let you go beyond 2,200 degrees F  
7 peak clad temperature. It's still -- we have some  
8 research work going looking into that, about what are  
9 the potentials for --

10 CHAIRMAN BONACA: Well, most likely they  
11 use best estimate.

12 MR. KELLY: That's correct. We would be  
13 using codes, especially once you're going beyond, you  
14 know, what -- your design basis would be looking for  
15 best estimate type -- those are realistic codes in  
16 this case.

17 MEMBER POWERS: Professor Bonaca, you  
18 raised this interesting issue of best estimate in  
19 connection with peak clad temperature. It seems to me  
20 that when we go look at what the intentions of peak  
21 clad temperatures were when they formulated the  
22 original versions of 50.46, you have to be careful we  
23 do not forget what the realities are today.

24 The realities today are that we're taking  
25 fuel to much higher levels of burnup than were ever

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 envisaged at the time the original regulation was  
2 written. Yet we do these peak clad temperatures now  
3 both in -- in the DB analysis codes and even in the  
4 best estimate codes in this rather peculiar fashion  
5 where we're not looking at the peak temperature at any  
6 time of a particular location.

7           What you see in these plots is the  
8 temperature that's highest wherever it is in the core.  
9 And so we're looking at things that temperatures  
10 affect to see if that clad will rupture and release  
11 its fission product inventory.

12           But, in reality, if you take clads to high  
13 levels of burnup, you oxidize them more, you create an  
14 oxide layer, and they are susceptible to other things  
15 now than were ever envisaged at the time. For  
16 instance, thermal shock -- now it's not just the peak  
17 temperature, it's what the delta T that the clad  
18 experiences and it suddenly cools down, and what not,  
19 that becomes important.

20           So when we say we go to best estimates, I  
21 think we have to think about not best estimates in a  
22 stylized design, but best estimates of what's  
23 physically going on in the fuel.

24           CHAIRMAN BONACA: That's right. Because  
25 probably in this case, I mean, the concern would be,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you know, coolability more, and so you relax the  
2 criteria which you are using. But you are still  
3 expecting some level of coolability of the fuel, and  
4 that would go -- that kind of evaluation.

5 MR. MARK RUBIN: Yes. Mark Rubin again.  
6 We certainly agree. We'll be working with our  
7 colleagues in the Office of Research to try to develop  
8 the appropriate approaches and methods to develop the  
9 criteria to arrive at the appropriate criteria as part  
10 of the rulemaking development.

11 MEMBER POWERS: I think your colleagues in  
12 the Office of Research are going to be very heavily  
13 stressed when you come and ask them this question --

14 (Laughter.)

15 -- because you're going to ask them, gee,  
16 what really happens in a core when I have a break, and  
17 they're going to have to admit that they don't have a  
18 whole lot of experimental data for these kinds of  
19 scenarios that you're looking at.

20 And they're going to give you plausibility  
21 arguments, and I hope you're skeptical enough that you  
22 will be able to see through plausibility arguments and  
23 say, "Where is your data?"

24 MR. KELLY: One or the other areas about  
25 the mitigation is once we decide -- once we decide

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 whatever level of mitigation it is that we want, then  
2 we have to decide, is that something that we expect a  
3 licensee to justify that they've met that? Is that  
4 something that we're going to look at generically and  
5 try to do it? How is that actually going to happen?  
6 And, again, it will depend on whatever the mitigation  
7 was.

8 If it -- certainly, the further we go  
9 beyond 2,200 peak clad temperature design basis, and  
10 the further out we go, the more uncertainty we have,  
11 the more we're stressing the codes themselves, and  
12 whatever analytical tests or physical tests will be  
13 performed.

14 The fifth issue --

15 MEMBER APOSTOLAKIS: In the fourth, as I  
16 remember, in NUREG-1150 the conditional containment  
17 failure probability was essentially between zero and  
18 one. The uncertainty was huge.

19 (Laughter.)

20 MEMBER POWERS: Well, I don't think  
21 Professor Apostolakis is being facetious there. I  
22 believe that's what the result was.

23 MEMBER APOSTOLAKIS: Yes. So when you  
24 say, how will this be shown, uncertainty in core  
25 damage and severe accident would need to be addressed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 -- are you going to do more than what 1150 did, or --  
2 I mean --

3 MR. KELLY: I think -- when I say that, I  
4 think one of the things that we have to do is we have  
5 to take a very hard look at exactly what Dr. Powers  
6 has talked about, is what is the data that we have?  
7 You know, if we say that we're going to go beyond  
8 2,200 degrees F, we're going out in these other areas,  
9 how are we going to -- I think it's important that we  
10 very carefully characterize our state of knowledge  
11 about how good these new numbers are, and then take  
12 that into account in our decisionmaking process.

13 MEMBER APOSTOLAKIS: But my point is, with  
14 the current state of the art, this uncertainty is  
15 huge.

16 MR. KELLY: Yes.

17 MEMBER APOSTOLAKIS: So now you are moving  
18 beyond the current state. The uncertainty is not  
19 going to go down, is it?

20 MR. KELLY: No, it's more huge.

21 (Laughter.)

22 MEMBER APOSTOLAKIS: Huger.

23 (Laughter.)

24 MR. MARK RUBIN: This is Mark Rubin again.  
25 We may move beyond. We may not. What we need to have

1 is confidence in mitigative capability. And it really  
2 will be up to the utilities who want to voluntarily  
3 implement this approach what approaches and what  
4 criteria they want to use.

5 They may -- we've seen an initiative from  
6 the BWR Owners Group on an initiative for a LOCA/LOOP.  
7 They're going to use the current peak clad temperature  
8 in 50.46, and they have enough margin to do that using  
9 some best estimate and hydraulic codes. And they're  
10 going to stay with 2,200 degrees peak clad  
11 temperature.

12 They don't have to push beyond the current  
13 criteria. The PWRs may or may not have the ability to  
14 do that.

15 Whether people have to go into areas  
16 pushing the technology and having to look into some of  
17 the areas of greater uncertainty will be something we  
18 may have to look at or we may not have to look at. We  
19 don't know yet.

20 MEMBER ROSEN: The only thing I would  
21 quarrel with what you said, Mark, is you said you were  
22 going to have to have confidence, and I would say you  
23 need to have appropriate levels of confidence, given  
24 the circumstances beyond the new design basis --

25 MR. MARK RUBIN: Yes.

1 MEMBER ROSEN: -- break. And it would be  
2 -- it ought to be variable. Maybe you'll have less  
3 confidence if you are thinking about the full 36-inch  
4 break, the biggest break, let's say.

5 MS. MCKENNA: I think that goes back to  
6 something Glenn said earlier about the  
7 interrelationship among things. Depending on where  
8 you select your break size, what you do, what kind of  
9 changes you make, the degree of mitigation and/or the  
10 confidence you have in it, they all have to be  
11 commensurate with each other, so that, you know, you  
12 support whatever you're doing.

13 CHAIRMAN BONACA: And the definition you  
14 put in about what happens beyond design basis will  
15 affect, for example, how many megawatts I can increase  
16 my power level by.

17 MS. MCKENNA: Absolutely.

18 CHAIRMAN BONACA: I mean, you are, you  
19 know, potentially here considering the large span of  
20 breaks beyond six inches or eight inches, or whatever  
21 it might be. You know, you could conceivably raise  
22 your power level very much.

23 MEMBER POWERS: You were looking  
24 apparently at just changing break sizes. Have you  
25 looked at all at what the Germans have been doing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about the double-ended guillotineness of the break?

2 MS. McKENNA: Do you mean in terms of the  
3 rate at which it --

4 MEMBER POWERS: No, just take it -- no,  
5 no.

6 MS. McKENNA: I'm not sure I understand  
7 what you --

8 MEMBER POWERS: They got rid of the  
9 double-ended guillotine, and they said, "Well, the  
10 thing will break, and it's an offset, and I have this  
11 much" -- and they changed the flow area.

12 MS. McKENNA: Okay.

13 MEMBER POWERS: On the -- for the flow  
14 based on a variety of arguments that I never really  
15 quite understand, but they have blacksmiths, too, and  
16 they make arguments that this is how pipes -- large  
17 pipes really break. And I believe their blacksmiths  
18 as much as I believe our American versions of that  
19 profession, which is totally without question.

20 (Laughter.)

21 MR. KELLY: Well, you'll have an  
22 opportunity to ask the blacksmiths a little later as  
23 they explain their numbers that they have for the  
24 break size frequencies. From our standpoint, we are  
25 -- you know, we will work with that information that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we get.

2 And I would only assume based on the level  
3 of expertise that was amongst the 12 experts that were  
4 there that they are aware of -- or at least a number  
5 of them were certainly aware of that data, and Rob can  
6 talk to you more about some of the input that they  
7 gave to the experts to make sure they were all kind of  
8 on the same page.

9 MEMBER POWERS: You're asking blacksmiths  
10 to all speak from the same page. That's an impossible  
11 task.

12 MR. KELLY: To the extent possible.

13 (Laughter.)

14 VICE CHAIRMAN WALLIS: And as I said at  
15 the subcommittee, number 4 is very interesting to me,  
16 because it looks to me the beginning of a discussion  
17 of what one might do about a reactor where you didn't  
18 have a design basis accident spectrum, but you had to  
19 put far more preventative, mitigative, and all these  
20 other features in there as part of the design. But  
21 you didn't have the current design basis structure.  
22 So this looks like we are beginning to look at a  
23 regulation of that sort.

24 MR. KELLY: Right.

25 MEMBER RANSOM: It seems to me in making

1 some of these decisions you also have to decide what  
2 risks are acceptable. In other words, are there  
3 incredible accidents which provide a risk that you  
4 can't do anything about? And while pipe breaks are  
5 more probable than some of these more incredible  
6 events like vessel failure, vessel rupture, they don't  
7 provide -- because of the mitigating systems -- as  
8 much risk as those.

9 And so, really, it seems like the tradeoff  
10 here is in risk based between what risk -- do these  
11 contribute significant risk? And a lot of times the  
12 large breaks don't contribute significant risk because  
13 of the mitigating systems that you have. And if you  
14 take them out, they now become more significant from  
15 a consequence point of view.

16 And so that tradeoff, it seems to me, is  
17 there. And I wonder in a way if this isn't driven  
18 more by the intuitive idea that large breaks are less  
19 probable than small breaks, even though the -- and the  
20 consequences often times are less, too, because of the  
21 mitigating systems, you know, that you have  
22 accumulators and you can take care of them.

23 And, in fact, I think that's borne out by  
24 the advanced reactors in which they turn small breaks  
25 into large breaks, because they are easier to manage.

1 MR. KELLY: Well, I think, as we've talked  
2 about before, is that all of the risk assessments that  
3 I'm aware of have shown that the design basis  
4 accidents are "no, never minds" in risk space. They  
5 don't constitute a risk challenge to the plant. It's  
6 when you get additional failures that you run into  
7 problems. So --

8 MEMBER POWERS: Well, the design basis  
9 accidents, by definition, should contribute nothing at  
10 all to the risk.

11 MR. KELLY: Well, one would hope that, and  
12 it works out that the way that the plants are designed  
13 and operated that that is the reality as far as --

14 MEMBER POWERS: Kudos to the designers,  
15 because they did their job.

16 MS. MCKENNA: But it's also why, you know,  
17 we were saying that once you get into consideration of  
18 particular changes that there would need to be some  
19 kind of risk assessment, because if you -- as a result  
20 of redefining your break you decide to change your  
21 mitigation, you need to see how that influences  
22 whatever events you have.

23 If you change something in your low  
24 pressure injection, that may deal with your large  
25 break LOCAs, but it may deal with other events where

1 you ultimately have that as part of your success path  
2 as well. You need to think -- you know, consider that  
3 impact, too.

4 MEMBER ROSEN: You know, I'm troubled by  
5 a little bit of this discussion in the area of this  
6 constant refrain of when you take out the design --  
7 the mitigating systems, when you remove the high  
8 pressure safety injection system.

9 Well, the reality of it is that I don't  
10 think anybody is going to do that. Now, of course,  
11 I'm guessing, too, about the future. But I don't  
12 think anybody is going to do that. I think it would  
13 be costly to do that and difficult, and would  
14 introduce all kinds of problems.

15 But what more likely will happen is  
16 someone might say, "Well, there are these requirements  
17 for the high pressure injection system -- for testing  
18 and maintenance and all of that -- and if one -- and  
19 I'll keep on doing those. But if one day I run into  
20 trouble and I can't quite do it exactly right, I might  
21 once in a while not do that."

22 And it's that kind of thing that's more  
23 likely, and I think we ought to be careful about  
24 leaving the impression that if this is ever passed  
25 that there's going to be a wholesale on 100 plants

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 tearing out of the mitigating systems. I just don't  
2 think that's --

3 MR. MARK RUBIN: No, we're not -- of  
4 course not, and we're not suggesting that. My  
5 microphone just fell apart.

6 (Laughter.)

7 We're not suggesting that, of course, at  
8 all. But what we just wanted to point out is the  
9 current Part 50 regulatory structure, the way the  
10 design basis accidents are formulated, that's not  
11 precluded. The way the regulations are formed you do  
12 the design basis accidents. Those constrain what  
13 systems you need to respond to them.

14 And if you were designing a plant today,  
15 if you don't need it for a design basis accident, it  
16 doesn't have to be there. But the real issue is if  
17 you do change the limiting accident -- and for a  
18 number of the plants the large break LOCA is limiting  
19 -- you could -- if you had the thermal capability and  
20 the generator, and the steam generators in the case of  
21 the PWRs -- you could do a substantial power uprate to  
22 the degree that you maybe couldn't hack a double-ended  
23 guillotine break any more without significant core  
24 damage.

25 And so you could, in a sense, back into a

1 scenario where you couldn't survive a large break LOCA  
2 anymore without a large amount of core damage. And  
3 we're just pointing that out.

4 MEMBER ROSEN: Okay. Well, that's -- I  
5 accept that. I agree with that. But let's be careful  
6 about the -- even referring to the idea that we're  
7 going to be taking out -- these systems out.

8 MR. MARK RUBIN: We didn't mean to suggest  
9 that.

10 MEMBER ROSEN: I think that's not likely.

11 MS. MCKENNA: No.

12 MR. KELLY: The reality more is -- as  
13 you're saying is maybe that somebody is going to say,  
14 you know, I don't need these accumulators any longer.  
15 I can vote them out. Or I can have -- I have a train  
16 that -- where I needed it before, and I -- maybe I can  
17 have a six-month outage in this train now, because I  
18 really just don't seem to need it that much.

19 So that's the type of thing that would be  
20 the potential that's there.

21 The fifth issue is: how should adequate  
22 defense-in-depth be assured under this rule? And to  
23 what extent do the guidelines laid out in Reg. Guide  
24 1.174 need expansion? I think there's two aspects to  
25 this.

1           Number one, Reg. Guide 1.174 provides an  
2 excellent -- in answers to George's comment, since  
3 he's not here -- the -- in risk-informing what we  
4 really -- when we talk about doing that and being  
5 fully risk-informed, we're really talking about  
6 following the process laid out in Reg. Guide 1.174.

7           And in Reg. Guide 1.174 there are a number  
8 of areas where it talks about defense-in-depth. And  
9 one of them is it gives a listing of seven different  
10 aspects that it feels if you meet -- if you follow  
11 these things, it's going to help give you adequate  
12 defense-in-depth.

13           And we've heard back from industry that  
14 even though these define that that maybe that they're  
15 not sufficiently well defined that it was too much of,  
16 you know, I'll know it when I see it, in a sense of  
17 the way the NRC has treated it. And they'd like maybe  
18 a little bit better definition.

19           We've said that -- told the Commission we  
20 will look at that and we will see whether we can do a  
21 better job of defining what -- you know, what those  
22 mean, if that's necessary. And the other area is that  
23 in Reg. Guide 1.174 it was designed as a way of  
24 changing the licensing basis. But it was not meant as  
25 a way of changing regulations.

1           One of the inherent assumptions in Reg.  
2 Guide 1.174 is that you would continue to meet all of  
3 the regulations. Now we're talking about having a  
4 process whereby we're going to be modifying the  
5 regulations based on a Reg. Guide 1.174 type process.

6           So we're also going to be looking at  
7 seeing whether there is any additional aspects to  
8 defense-in-depth that need to be added, not -- I'm not  
9 saying that we've identified anything at all, but we  
10 just want to look and see, is there anything else,  
11 since we're going to be changing, you know, the  
12 underlying pinnings of -- of how we've basically --  
13 what we've used to design our plants, is there  
14 anything else that we need to think about to add to  
15 Reg. Guide 1.174 as an enhancement?

16           VICE CHAIRMAN WALLIS: Well, as we said at  
17 the subcommittee meeting, the large break LOCA is in  
18 the rules now because of defense-in-depth. If you're  
19 going to take it out, you have to give a proper  
20 argument in terms of defense-in-depth for taking it  
21 out and somehow negate the arguments which were then  
22 used to put it in the regulation.

23           It looks as if risk is going to be used to  
24 nibble away at defense-in-depth rather than defense-  
25 in-depth being used to trump risk arguments. I'm not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 quite sure which wins here.

2 MR. KELLY: Well, my understanding -- and  
3 I was not around when they originally did this. But  
4 my understanding is that the -- part of the concept of  
5 defense-in-depth was that it was designed to help  
6 protect against the unknown, the uncertainties that we  
7 have, the significant uncertainties.

8 And some of the things that would --  
9 reasons that have been expressed about why we're even  
10 looking at changing these -- considering removing some  
11 of these larger breaks from the design basis is that  
12 we have more knowledge now about pipe break phenomena,  
13 about materials, and that we've had much more  
14 experience amongst the nuclear reactors.

15 And it is believed that there may be good  
16 reasons, therefore, to, based on that now increased  
17 knowledge, and, therefore, lesser uncertainty, that  
18 maybe now we can get rid of some of those things from  
19 the design basis.

20 VICE CHAIRMAN WALLIS: Okay.

21 MR. KELLY: Issue number 6 deals with a  
22 concern that -- and there's two parts to 6, so I just  
23 want to make sure I come back to two different parts.  
24 But 6 talks about cumulative increases in risk and  
25 about the need to limit that. And I think there's two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 areas to that.

2 One of them is as -- what we don't want to  
3 have is a plant coming in, let's say -- let's say that  
4 we said that, okay, the increase in risk that you  
5 could have under -- under the rule, say, was  $10^{-5}$  core  
6 damage frequency per year, if we decided that that was  
7 the appropriate value.

8 And so this month I'd come in and I'd get  
9 that, and three months from now I come in and I'd say,  
10 "Ah, I have this other fix, and I want to increase  
11 that  $10^{-5}$ ." And six months later I have another  $10^{-5}$ .

12 There's nothing in Reg. Guide 1.174 to  
13 preclude you from doing that. It does ask you to --  
14 but we do say under Reg. Guide 1.174 that somebody is  
15 supposed to be tracking cumulative risk, and that  
16 cumulative risk is total cumulative risk, total risk  
17 on the plant. And they're also supposed to be  
18 tracking the total increases.

19 And I think what we're looking here is  
20 that some way we're deciding -- we want to decide how  
21 -- what's a good way to actually track the change in  
22 risk associated with whatever plant modifications are  
23 made under the rule.

24 CHAIRMAN BONACA: And limit.

25 MR. KELLY: Excuse me?

1 CHAIRMAN BONACA: And limit at some point.

2 MR. KELLY: Right. And have a limit. And  
3 then the question is: if we have a limit, is that  
4 limit only for changes made under the rule? Or what  
5 if I'm making other changes outside of the rule and  
6 they're affecting this, how does that count?

7 If my total core damage frequency is two  
8 times  $10^{-5}$  per year, is it okay for me to continue to  
9 make changes that are going to be increasing my risk?  
10 Or do we decide that maybe we don't want to do that?  
11 That's one of the things that we believe needs to be  
12 discussed and addressed in the --

13 MEMBER APOSTOLAKIS: So what if I have a  
14 record of a bad safety culture, would you do the same?

15 MR. KELLY: If you can tell me how to  
16 quantify it, I would --

17 MEMBER APOSTOLAKIS: It's common knowledge  
18 that my safety culture has not been good the last 15  
19 years. Would that play a role in anything?

20 MR. KELLY: We normally handle changes --  
21 problems with safety -- we used to handle it in the --  
22 in how we put plants on the watch list.

23 MEMBER APOSTOLAKIS: Yes. But you don't  
24 do that anymore.

25 MR. KELLY: We don't do that any longer.

1 I wouldn't know how to do that. Certainly, it's a  
2 consideration, but how you would address that in a  
3 rule I'm not sure.

4 MEMBER KRESS: It seems to me like Reg.  
5 Guide 1.174 already has built into it limits by way of  
6 the requirements on the various regions due to the  
7 absolute values of CDF and LERF. It seems to me like  
8 what you need to do is specify or -- or require some  
9 frequency of update of the PRA, so that it  
10 incorporates all of the changes that have been made as  
11 they are made, and also have some specification on the  
12 scope and quality of the PRA itself.

13 So, then, the Reg. Guide 1.174 processes  
14 automatically have limits in them and keep track of  
15 the cumulative changes in risk, it seems to me.

16 MR. KELLY: Dr. Kress, I -- it looks very  
17 simple on the surface, but it's not. And one of the  
18 reasons why it's not is historically what happens is  
19 when a utility makes an update to its PRA, it will not  
20 only update its PRA associated with whatever plant  
21 changes have been made in the period since the last  
22 time they had an update, but they'll also make  
23 modifications to the PRA itself to improve the PRA in  
24 some area. And those modifications --

25 MEMBER KRESS: Well, it seems to me that's

1 all right, though.

2 MR. KELLY: Oh, it is. It's wonderful  
3 that the PRA is updated. But the -- as I modify my  
4 PRA, if I were to go back and look at modifications  
5 that I made under my PRA -- under my plant before, the  
6 changes to my PRA may, in turn, because I've improved  
7 my PRA, may change how much those changes to the plant  
8 increased or decreased the plant risk.

9 So over time as -- each time I change my  
10 PRA, potentially I have to go back and look at all of  
11 the plant changes, and it becomes very messy. We --

12 MEMBER KRESS: Yes. Well, that's what I  
13 mean by an update to the PRA. Just make sure it's  
14 always current.

15 MR. KELLY: That's fine. But what --

16 MEMBER APOSTOLAKIS: Phase 4.

17 (Laughter.)

18 MR. KELLY: But the problem comes with,  
19 then, just saying, "Okay. I'm just going to sum up  
20 all of my old changes and say that constitutes or  
21 equals the actual change that's been made."

22 CHAIRMAN BONACA: By the way, another  
23 point is, I mean, Reg. Guide 1.174 -- it gives you a  
24 limit, but that is not an end point.

25 MEMBER KRESS: Yes. I don't want you to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sum up all of the old changes. I think you just keep  
2 track of the status and condition of your plant, and  
3 calculate the new CDF and LERF. And it automatically  
4 incorporates all of the changes.

5 CHAIRMAN BONACA: Yes. No, but I'm saying  
6 that the -- you know, I mean, by saying that there is  
7 a limit there, I could creep to that limit, change --  
8 through changes, and to me that is not right.

9 MEMBER KRESS: Well, I don't know why not.

10 CHAIRMAN BONACA: Well, perhaps we should  
11 discuss that.

12 MEMBER KRESS: I mean, you -- you creep up  
13 to the limit with more --

14 CHAIRMAN BONACA: Well, the fundamental  
15 principle in the regulation has always been that  
16 whenever the plant is, you stay there. I mean, so far  
17 as your licensing basis. And even if you have some  
18 margin, even though you can apply for it now that it's  
19 under 50.59, but it doesn't mean necessarily that you  
20 can push everything to your -- you know what I'm  
21 trying to say? Now, this is -- would be a different  
22 concept.

23 MEMBER KRESS: Well, as long as you are  
24 risk-informed and keeping your defense-in-depth, you  
25 should be able to do that.

1 CHAIRMAN BONACA: If you can creep to that  
2 limit, why can't you make a big change all the way to  
3 that limit?

4 MEMBER KRESS: I don't see why not, as  
5 long as you maintain defense-in-depth and keep within  
6 the limits.

7 MEMBER APOSTOLAKIS: No. The regulatory  
8 guide doesn't allow that.

9 MEMBER KRESS: The guide wouldn't allow  
10 you to do that, because it limits -- it limits the  
11 delta you can get within a region. But, you know, the  
12 cumulative -- it would allow you to creep up to it,  
13 and that should be all right.

14 CHAIRMAN BONACA: I mean, that's an issue  
15 that -- right now I agree with it.

16 MEMBER APOSTOLAKIS: Are you familiar with  
17 the phased approach that the Commission has proposed  
18 to reach --

19 MR. KELLY: I'm somewhat familiar, yes.

20 MEMBER APOSTOLAKIS: Could 50.46 be risk-  
21 informed with anything that is less than a Phase 4  
22 PRA? I'm serious.

23 MR. KELLY: Could it be risk-informed?

24 MEMBER APOSTOLAKIS: Yes. I mean, could  
25 any of these issues that you are raising --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KELLY: I think clearly it could be  
2 risk-informed at a Phase 3.

3 MEMBER APOSTOLAKIS: Why?

4 MR. KELLY: Because you would have  
5 addressed all of the -- you would have provided  
6 guidance for all of the major risk contributors, and  
7 that they would have addressed those, and that they  
8 would have followed that guidance.

9 Now, the question comes, would we, you  
10 know -- would their peer review be adequate for us?

11 MEMBER APOSTOLAKIS: Sure.

12 MR. KELLY: And if we felt that a peer  
13 review was adequate, I think we'd -- then we'd be  
14 okay.

15 MR. TSCHILTZ: This is Mike Tschiltz. I'd  
16 just like to say that I think we're not there yet. I  
17 think we need to define what 50.46 is going to allow  
18 before we define what the quality is going to be.  
19 So --

20 MEMBER APOSTOLAKIS: I mean, you have  
21 issues here like uncertainty, and core damage and  
22 severe accident analyses would need to be addressed.  
23 Okay? How should adequate defense-in-depth be assured  
24 under this rule? And there were all sorts of other  
25 statements regarding PRA and quality, and so on.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And it seems to me that if you don't have  
2 a Phase 4 PRA, you're not going to be able to answer  
3 it.

4                   MEMBER ROSEN:    The Phase 4 PRA is the  
5 state of the art.

6                   MEMBER APOSTOLAKIS:  State of the --

7                   MEMBER ROSEN:    And so it --

8                   MEMBER APOSTOLAKIS:  No, no, no.  It's  
9 also NRC reviewed, right?  Phase 3 is not --

10                  MEMBER ROSEN:    And approved and endorsed.

11                  MEMBER APOSTOLAKIS:  Endorsed, yes.  Yes,  
12 this is endorsed.  There is much more to it than just  
13 state of the art.

14                  MS. MCKENNA:    I think Donnie wanted to --

15                  MR. DINSMORE:   Yes.  Well, just a second.  
16 This is Steve Dinsmore from the staff.  I think --  
17 see, what we've been working with is that when you  
18 change the design basis LOCA sites, when you just do  
19 that without changing the plant, you're not really  
20 changing the risk.  It's only when you start changing  
21 the plant that you're affecting the risk.

22                                And so what we postulated is possible was  
23 -- yes, well, that's assuming that the --

24                  MEMBER APOSTOLAKIS:  How about the way I  
25 operate the plant?

1 MEMBER SHACK: It's still a change.

2 MEMBER APOSTOLAKIS: Oh. You consider  
3 that --

4 MS. MCKENNA: Yes.

5 MR. DINSMORE: Yes. Well, if it's in your  
6 design basis, it's embedded in the design basis, so  
7 you'd have to change the design basis to credit -- to  
8 take credit for the change in the size. And the way  
9 we work now is if -- every time somebody comes in with  
10 a change we would evaluate the part of the PRA they  
11 need for that change.

12 So we could envision that -- if we set the  
13 limit on the delta CDF and the delta LERF like we do  
14 now, we can do that evaluation. And we can evaluate  
15 the part of the PRA which is needed to support that,  
16 using the current methodology as being approved by the  
17 phased approach.

18 So, in other words, if they -- they want  
19 to change something that's not in the PRA, which is a  
20 significant contributor, we'd say, "We can't do that."  
21 But it is possible to make some changes --

22 MEMBER APOSTOLAKIS: Are you referring to  
23 50.46 now?

24 MR. DINSMORE: Yes.

25 MEMBER SHACK: It depends on what change

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you want to make.

2 MS. MCKENNA: Right. It's more narrow or  
3 broad, if you have specific changes that --

4 MR. TSCHILTZ: I think what he's saying,  
5 in effect, is you could be in Phase 1 for certain  
6 changes envisioned under 50.46.

7 MR. DINSMORE: Or at least that's the way  
8 we're kind of talking about it right now. It might  
9 get modified, but --

10 MR. HARRISON: This is Donnie Harrison.  
11 If I can jump in for a second, if I can just talk  
12 about the phases just briefly.

13 If you remember Phase 2, if we write the  
14 guidance for the application, and in that guidance it  
15 tells you what PRA quality you need or what scope of  
16 issues need to be addressed within that, so as part of  
17 the rulemaking there will be some type of guidance  
18 also developed that will need to address that area.

19 So you can enter Phase 2 and the PRA phase  
20 of -- quality phases for a 50.46 application when it's  
21 done -- once that guidance gets written and it tells  
22 you what you need from a PRA quality perspective, and  
23 then those standards are in place.

24 MEMBER APOSTOLAKIS: Are these statements  
25 consistent with what I keep hearing from our Chairman

1 about the tentacles of 50.46 all over the place? Now  
2 you are telling me, oh, they can pick a little thing  
3 and do it, and no big deal. I thought 50.46 was  
4 everywhere.

5 MR. HARRISON: Well, again, I'm just  
6 talking about the phased approach, so that we don't --

7 MEMBER APOSTOLAKIS: But you can do this  
8 with Phase 1.

9 MS. MCKENNA: I think this goes back to  
10 what you're actually -- what's the application, what  
11 are you really changing as a result -- you say, "I've  
12 redefined my break size," or "I've taken something out  
13 of the design basis," and then what do I really do?  
14 Am I changing my diesel start time? Am I, you know,  
15 doing some -- you know, how I operate one of my --

16 MEMBER APOSTOLAKIS: Well, the two major  
17 issues --

18 MEMBER SHACK: A major power uprate is  
19 very different from changing the diesel start time.

20 MS. MCKENNA: Right. Right. True.

21 MEMBER SHACK: And the PRA level I need to  
22 support those two changes may, you know, be  
23 substantially different.

24 MR. MARK RUBIN: We'll be developing --

25 MEMBER APOSTOLAKIS: As a general

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 statement, that's correct.

2 (Laughter.)

3 MR. MARK RUBIN: We'll certainly be  
4 focusing on the PRA quality attributes explicitly as  
5 part of the rulemaking development. But we're going  
6 to be leveraging the phased quality initiative as part  
7 of it and trying to fit as much as we can directly  
8 into that.

9 VICE CHAIRMAN WALLIS: Well, we've had 20  
10 percent power uprates without any magical, huge  
11 advance in PRA already. And we have had some  
12 questions about the PRA quality, but they haven't  
13 really led to any holdups in approving those power  
14 uprates.

15 MEMBER APOSTOLAKIS: Which comes back to  
16 my comment this morning. I mean, the heart of the  
17 matter is the decisionmaking process. As long as you  
18 can get all this stuff, with the present situation  
19 where presumably we are in 1.5 -- Phase 1.5, there is  
20 absolutely no incentive to move it. Anyway, okay.

21 MR. DINSMORE: Well, I guess this comes  
22 back a little bit to whether it's a broad or a narrow  
23 scope. If it's a broad scope, we'd have to be  
24 prepared for pretty much any changes, whereas Dr.  
25 Rosen said that they will be out there looking to see

1 what they can change.

2 So we'd have to really deal with this  
3 directly, and we haven't quite figured out how to do  
4 it, which is why it's up there. Whereas, if it's a  
5 narrow scope, where it's defined beforehand, we can  
6 take a look at that, and then we could actually figure  
7 out what exactly the PRA quality requirements would be  
8 to support those allowable changes.

9 MR. KELLY: Issue number 7 is, what's the  
10 appropriate scope and quality of PRA, which we've  
11 already talked about here. And 8 is also the question  
12 about future reactors, which we've talked about. So  
13 let's move on to the next page.

14 The staff has seven activities outlined in  
15 the paper that we're going to -- we're going to talk  
16 -- we're going to determine the -- how we're going to  
17 choose the maximum break size, identify the level of  
18 mitigation required for the LOCAs beyond the new  
19 maximum break size.

20 We're going to develop criteria, including  
21 the metrics, for determining what would constitute an  
22 acceptable plant change. We're going to develop  
23 criteria for determining total CDF, maximum CDF, that  
24 would be -- we might use as saying, okay, if you're  
25 above this, we want to handle you differently than if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you're below this.

2 We're going to look at the need for  
3 additional defense-in-depth criteria, if any. We're  
4 going to, as we mentioned, see if we need to improve  
5 on the guidance in Reg. Guide 1.174 on how you attain  
6 defense-in-depth.

7 We're going to develop criteria to  
8 demonstrate what it means to have adequate mitigation.  
9 And we're going to look at over time what kind of  
10 information the utility is going to have to retain or  
11 develop in order to assure that things are going okay.

12 And, of course, we're going to do this  
13 very quickly.

14 (Laughter.)

15 Research has ongoing work in thermal  
16 hydraulics and risk assessment, and we may be faced as  
17 we go along asking for additional work.

18 MEMBER APOSTOLAKIS: What does it mean?

19 MR. KELLY: Is Hossein here? There he is.  
20 Would you like to speak about what --

21 MEMBER APOSTOLAKIS: What does the first  
22 bullet mean, Hossein? You have to go to a microphone  
23 and speak with sufficient clarity and volume.

24 MR. HAMZAHEE: Yes. This is Hossein  
25 Hamzahee, Section Chief, PRA Branch in Research. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 think what Glenn is saying under bullet one is that  
2 Research has already undertaken a number of activities  
3 to support this rulemaking, one of which is the  
4 thermal hydraulic calculations.

5 Mainly, we are trying to look at some of  
6 the postulated changes and then look at some of the  
7 potential changes in -- like peak cladding temperature  
8 or oxidation limits, and this is ongoing. And the  
9 other thing we are doing is we are trying to look at  
10 those and then do some risk assessment, trying to  
11 figure out what are the potential changes to some of  
12 the assumptions in the PRA models, and then making  
13 some of those changes, try to look at some selected  
14 plants and see how the risk profile would look like.

15 So these are the ongoing activities that  
16 Research has been working on.

17 MEMBER APOSTOLAKIS: So this doesn't mean  
18 that thermal hydraulics and risk assessment are trying  
19 to put together --

20 MS. MCKENNA: No.

21 MEMBER APOSTOLAKIS: It's activities in  
22 risk assessment that --

23 MR. HAMZAHEE: That's correct. However,  
24 sometimes as -- what we get from the thermal  
25 hydraulics may help us in understanding what would be

1 the potential impact on some of the PRA assumptions.

2 MEMBER APOSTOLAKIS: Well, it should.

3 MR. HAMZAHEE: It should.

4 MEMBER APOSTOLAKIS: It should.

5 MR. KELLY: Okay. And the last bullet  
6 involves LOCA/LOOP - the March 31<sup>st</sup>, 2003 SRM asked us  
7 to address looking at relaxing the requirements for  
8 LOCA/LOOP. We have BWR Owner's Group topical which we  
9 believe is going to be coming in shortly, which will  
10 be addressing that issue. We've asked the Commission  
11 if it's okay if we go ahead and review the topical,  
12 deal with that issue, and then go forward once we've  
13 gotten some experience and real-life exemption  
14 requests in this area.

15 MEMBER ROSEN: Do you think that the BWR's  
16 approach will be instructive for the pressurized water  
17 reactors, as well, or are they two separate issues on  
18 LOCA/LOOP?

19 MR. KELLY: My personal opinion is that  
20 it's going to be a little bit different for the  
21 boilers because they have significant thermal margin  
22 that may not be available for all PWRs. And the  
23 boilers are able to make modifications to the plant  
24 and still using realistic code runs show peak clad  
25 temperature below 2200 degrees F.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER ROSEN: Well, isn't your strategy  
2 a little unfair to most of the plants, that two-thirds  
3 of the plants are PWRs. And so if you're saying  
4 you're going to wait to work on the PWRs until later  
5 while you work on the BWRs, and not have any  
6 likelihood that what you'll learn from the BWR  
7 approach will be helpful to the PWRs, it seems a  
8 little unfair. Have you thought about that?

9                   MR. KELLY: The boilers have done -- the  
10 BWR Owner's Group has done some work on developing  
11 rationale why the seven changes can be made, or  
12 combinations of these seven changes can be made and it  
13 be acceptable to the plant.

14                   As far as we know, the pressurized water  
15 reactor plants have not gone ahead and done this work.  
16 We have already investigated looking at the issues  
17 such as developing a methodology to determine plant-  
18 specific conditional probability of loss of off-site  
19 power given a LOCA, which is very important because  
20 it's a very site-specific issue, where a plant even  
21 within -- if you have multiple plants on a site, can  
22 depend on different plants at the site.

23                   This issue can be handled on a plant-  
24 specific basis. And what we're trying to do, and that  
25 would be available for reactors if they chose to come

1 in that way. We prefer to be able to do it for a  
2 number of reasons, including resources to do it via  
3 topical report. I'm not sure if I'm really answering  
4 your question in part, but in essence the BWR Owner's  
5 Group has done a significant amount of work here. I  
6 mean we recognize that.

7 MEMBER ROSEN: You don't need to be  
8 specific to my point. Just be aware, I hope we've  
9 exchanged -- my feeling about that is that I'm not  
10 sure that's exactly fair to PWR to delay work on the  
11 PWR world while you consider the BWR LOOP/LOCA.

12 MR. RUBIN: This is Mark Rubin again from  
13 the staff. I don't think we're actually delaying the  
14 work. Any design would have to show thermal hydraulic  
15 success for delayed diesel start. And the BWRs happen  
16 to be showing that success through a TRACG  
17 calculation, still using 2200 peak clad temperature.  
18 A PWR may come in using RELAP or some other code. The  
19 general approach should be as applicable to a PWR.  
20 They don't have the same thermal margin. They may  
21 have a little tougher job in the T/H calculation, but  
22 the general analytical approach should be applicable,  
23 but they much not have as much pad in the delay of the  
24 diesel start. Instead of going to 80 seconds, they  
25 may only be able to delay to 22, 23, 32 seconds. But

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I think we're going to learn a lot from the BWR  
2 Owner's Group approach, and I think it's going to be  
3 very efficient from a staff researcher's perspective,  
4 and I think the real expert is now standing at the  
5 microphone, and will be able to share his perspective.  
6 That's Mr. Lazevnick.

7 MR. LAZEVNICK: Yes. I'm Jim Lazevnick  
8 from the Electrical Branch in NRR, and Glen and Mark  
9 addressed the thermal hydraulic aspects which are, of  
10 course, different between the BWR and PWR. But the  
11 electrical aspects between a BWR and PWR are not based  
12 on thermal hydraulic issues. They're based on  
13 electrical design features, grid features and other  
14 things that are not necessarily specific to BWR and  
15 PWR. So we do expect to learn a good deal from the  
16 BWR approach in terms of the electrical areas that  
17 will carry-over directly to the PWR designs, as well.

18 MEMBER ROSEN: Well, I don't want to make  
19 too much of this.

20 MS. MCKENNA: Well, we want to wrap up  
21 because we don't want to take all of Rob's time, so I  
22 think just quickly in summary that, as we've said, we  
23 want to be careful in doing a redefinition of the  
24 large break LOCA so that we don't lose the margins  
25 that exist as a result of the current designs as we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 move forward. I think this question about should it  
2 be narrow or broad, and what kind of changes could be  
3 forthcoming from the rule, we have to get to some  
4 meeting of the minds on that.

5 We sent the paper to the Commission. We  
6 asked for policy direction in certain areas. We are  
7 continuing to work on some of these technical issues,  
8 as was mentioned, while we're awaiting that kind of  
9 feedback. And as indicated, certainly any feedback  
10 from the Committee that you would like us to consider  
11 as we move forward, we get direction from the  
12 Commission as we try to shape the rule making. We'd  
13 certainly be very interested in that. Thank you.

14 MEMBER SHACK: I think we better move on  
15 because I think Rob will have a fair amount of  
16 material to cover in his time that he has available.

17 MEMBE POWERS: Well, despite his limited  
18 time, I have to say that I continue to be troubled  
19 primarily about some identified sites, and the  
20 paradoxes that you can get from there. I continue to  
21 worry whether PRA is the right technique to both  
22 design and assess these design-basis accidents. And  
23 I keep coming back to my structuralist biases, George,  
24 and say shouldn't -- if we're looking at 50.46, should  
25 we really be looking at what it was intended to do;

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and that was to preserve barriers, that what would be  
2 intolerable in any design is a failure of the reactor  
3 coolant system that led to a concomitant failure of  
4 containment, and to assess that they took the biggest  
5 load that they could think of to put on containment.  
6 We now know that containments are much stronger than  
7 just their design levels, and so one can think about  
8 backing off. At the same time, we were worried about  
9 preserving the ability to cool the core, and they  
10 asked what's the fastest we get the water out of the  
11 system, and make it difficult to get the water back  
12 in, and so they came up with this doubled-ended  
13 guillotine pipe break. And they designed a system  
14 that can put water back in very quickly. We now know  
15 that that's not the only way to get to an incurable  
16 situation.

17 MEMBER ROSEN: It may not be the worst way  
18 either.

19 MEMBE POWERS: That's right, it may not be  
20 the worst way. And I keep wondering if we shouldn't  
21 -- if we are so enamored with this PRA that we're not  
22 looking at these barrier-type arguments as a way to  
23 approach redesigning 50.46. And that if the  
24 preservation of barriers isn't a better objective for  
25 50.46, than risk. I mean, this comes inherently

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 because of a disbelief in the omniscience of the PRA  
2 analysts. I simply don't believe they can think of  
3 everything that a plant can be asked to do.

4 MEMBER KRESS: I think I tend to agree  
5 with you, Dana, that we have to think of barrier  
6 presentation, so I think in this rule change you have  
7 to do something about preserving that type of defense-  
8 in-depth. But the fact is that this rule results in  
9 other things that have very little to do with  
10 barriers. And I think we can deal with these other  
11 things in risk-based, but I think -- I'm with you. I  
12 think I'm a structuralist defense-in-depth in this  
13 thing, and you have to maintain that part of it  
14 somehow.

15 MEMBER SIEBER: I'm a rationalist with  
16 structuralist tendencies, which I admit to. And so I  
17 think Dr. Powers has offered an important caution,  
18 that when we go forward we ought to be thinking about  
19 defense-in-depth. But I don't think these two  
20 approaches are exclusive, mutually exclusive. I think  
21 we're thinking about finding a balance.

22 CHAIRMAN BONACA:: Sure. And I think what  
23 we're saying is that these plants were built with  
24 margin we didn't realize we had when we built them.  
25 And now through PRA we measure the margin, it doesn't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mean that you have to cash it all in. I mean, you  
2 can't.

3 MEMBE POWERS: Where I worry about self-  
4 identified sets is identify that margin, and then I  
5 use the PRA to take advantage of that margin. I will  
6 get into paradoxes. I worry about that a lot. And I  
7 think the consequences that Dr. Kress speaks of,  
8 people lose quickly, very quickly lost sight of what  
9 they were trying to accomplish in 50.46, and said this  
10 is the end in itself, and I think that was not the  
11 case. And I think the PRA is an excellent vehicle for  
12 showing you where those things resulted in unnecessary  
13 margin having been created. I mean, PRA clearly is  
14 the technique to show you where you have margin. I'm  
15 not sure that it's the technique they subsequently use  
16 to design something that's better, and I'm not sure  
17 it's the right technique to use to design something  
18 that's taken knowledge in neutral. I just offer that  
19 for my concerns.

20 MR. TREGONING: Okay. We want to follow-  
21 up the discussion we had on some of the regulatory  
22 concerns and issues that we're struggling with as an  
23 agency, and again we had a lot of good discussion and  
24 insight on today to talk about one piece of this. But  
25 it's sort of the first piece we've tackled of this

1 revision exercise, so I'm going to be giving what  
2 hopefully will be very a condensed version of the  
3 presentation.

4 MEMBER SHACK: It will be a condensed  
5 version.

6 MR. TREGONING: I qualify it. I'm at the  
7 discretion of the ACRS here, so I trust in your  
8 judgment. I'm Art Tregoning, and Lee Abramson and I  
9 will be presenting the development of the passive  
10 system LOCA frequency that will be used as part of the  
11 technical basis to provide information to do a risk-  
12 informed revision of 10 CFR 50.46.

13 The objectives and scope of the  
14 elicitation, we touched on this a little bit earlier  
15 in regard to the questions that we had during the  
16 earlier presentations. I'm just doing these again to  
17 make sure that they're clear. I've gone over these a  
18 number of times at various ACRS meetings, but really  
19 the primary objective that we set out to do with this  
20 elicitation was to develop generic BWR and PWR piping  
21 and non-piping passive system LOCA frequency  
22 distributions as a function of both the break size -  
23 so obviously how big the break is, if it's a small,  
24 medium and large - and also, the operating time.

25 MEMBER ROSEN: Why do you say non-piping?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I thought we heard earlier that you only considered  
2 piping.

3 MR. TREGONING: No, only passive system,  
4 not active system. We looked at non-piping pressure  
5 system components, as well.

6 MEMBER ROSEN: For example?

7 MR. TREGONING: For example, pump bodies,  
8 valve bodies, the vessel itself.

9 MEMBER ROSEN: Okay.

10 MR. TREGONING: Manways, all of those -  
11 steam generator tubes which aren't historically  
12 considered as piping, even though they have many  
13 similarities. CRDM nozzles and tubes, things like  
14 that. Anything which could break due to degradation  
15 that could -- the break itself could lead to a LOCA,  
16 so not a consequential LOCA, but a primary LOCA in the  
17 primary system. And that's the first point, so we're  
18 looking at LOCAs which initiate in an isoluable  
19 portion of the RCS. These are primarily LOCAs that  
20 are related to passive component aging, but we just  
21 don't look at aging without considering mitigation,  
22 because we're just not letting the plant sit there,  
23 and we're doing something in many cases to try to  
24 combat aging, so for specific aging mechanisms, we  
25 tried to temper the effects by whatever mitigation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 measures are currently in place now.

2 I said that we did this as a function of  
3 break size. We looked at small, medium, and large  
4 break LOCAs. Even though the rule we've talked about  
5 -- we've talked about potentially redefining a break  
6 size which has more impact on --

7 VICE CHAIRMAN WALLIS: Well, you didn't  
8 look at this number 2 about the risk of someone over-  
9 tightening the bolts on a manway or something like  
10 that.

11 MR. TREGONING: We did consider --

12 VICE CHAIRMAN WALLIS: Is that passive  
13 component aging?

14 MR. TREGONING: Even though passive  
15 component aging was the primary thing, we did look at  
16 common cause failures for things like bolting.

17 VICE CHAIRMAN WALLIS: I thought you did.

18 MR. TREGONING: Yes, so that's true. So  
19 again, we looked at small, medium and large breaks,  
20 and we also looked at -- we further subdivided the  
21 large break category. Historically we looked at three  
22 LOCA sizes. We looked at six, so we broke the large  
23 break LOCAs into four separate regions. And the idea  
24 behind that is we wanted to try to get a more  
25 comprehensive look at the frequency spectrum -- at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 frequencies over a spectrum of break sizes, and we  
2 wanted to go into bigger break sizes that may be of  
3 the level that we're looking at doing this  
4 redefinition. So we looked at large breaks and we  
5 categorized them to a much finer extent than we've  
6 ever done previously.

7 We looked at three different time frames.  
8 We provided fixed estimates at these different times.  
9 We provided estimates for the current day which we  
10 defined roughly as 25 years of average fleet  
11 operation. We looked at 40 years and 60 years. Why  
12 those two times? Well, 40 years and 60 years  
13 correspond roughly to the end of the original license  
14 period, and then the end of the license extension.

15 The 25 and 40 year estimates also  
16 coincided with direction that we got from the SRM that  
17 we need to consider LOCA frequencies which look  
18 forward 10 years, with the expectation that at a  
19 minimum in another 10 years we're going to have to go  
20 back and revisit those if -- again, assuming that  
21 something doesn't come up in the interim which calls  
22 into question the basis of the frequencies that we've  
23 developed to date. So that's why we picked these  
24 three different time periods, so we can give forward-  
25 looking estimates, and again also provide information

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that we could use to assess when we get to the point  
2 of redefinition in 10 years time how much change would  
3 be expected over this original set of estimates.

4 Primary focus as I mentioned were  
5 frequencies associated with normal operating loads and  
6 expected transients, and a major assumption here that  
7 I'd like to list to make sure people are clear about -  
8 we assume that there were no significant changes  
9 would occur in the future in the plant operating  
10 profiles, so that essentially -- why do we make that  
11 assumption? Well, we have a certain amount of service  
12 experience. We're essentially saying that we're not  
13 going to have such radical changes that the service  
14 experience is going to become moot at that point, so  
15 we're not going to do something which dramatically  
16 undermines the historical database that we've  
17 developed.

18 Of course, the database for big LOCAs are  
19 essentially zero LOCAs over thousands of years of  
20 reactor operating experience. But we do have an  
21 extensive database of precursor LOCA events, which  
22 would be things like cracks, leaks, things like that.  
23 And that's something that we've developed over the  
24 years fairly extensively, especially for piping. And  
25 that was really the primary basis that the various

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 experts used to extend that to go from the precursor  
2 information to LOCA frequency. So we want to make  
3 sure, which is that final bullet or that final caveat,  
4 that we don't do anything that undermines that basis.

5 CHAIRMAN BONACA:: But if you use this  
6 margin to increase power level, there will be a  
7 significant change in the plant operating profiles.

8 MR. TREGONING: If the plant operating  
9 profiles would result in additional, I'll say  
10 additional precursors occurring, then that's obviously  
11 -- that would undermine the basis of the LOCA  
12 frequency, yes. It's very simple.

13 MEMBER FORD: But you're making the  
14 assumption there that the mitigation actions are going  
15 to counter the degradation due to, for instance, power  
16 uprates. It relates to Mario's question, that your  
17 presumption there is that mitigation actions will  
18 offset any increased degradation rate due to power  
19 uprates.

20 MR. TREGONING: With any of the aging  
21 mechanisms we looked at the effectiveness of  
22 mitigation, and tried to assess that. But just -- and  
23 this is why that 10 year window is so important. As  
24 we do changes, if we find things that change in -- the  
25 operating profiles have changed, that's changed the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 basis for these estimates, we have to very carefully  
2 evaluate them, and make sure that we are clear in  
3 saying hey, these no longer hold for this reason.

4 MR. RUBIN: This is Mark Rubin from NRR.  
5 The preliminary transmittal we got raised questions on  
6 whether significant power uprates would be covered by  
7 the evaluation that was done by the expert elicitation  
8 panel, so if we're going to be allowing significant  
9 power uprates based on the preliminary curves we got,  
10 it raises some questions on the validity of the  
11 application. So that's something that would need to  
12 be looked at before that was allowed.

13 MR. TREGONING: That's exactly correct.  
14 And that's why specifically I wanted to raise that  
15 caveat because that's a very obvious application that  
16 we need to be careful as we go forward with.

17 I just have a couple of summary slides  
18 here, and I've tried to boil down what I've presented  
19 a couple of weeks ago. And I've two slides which show  
20 qualitative insights that we got from the experts.  
21 This isn't comprehensive by any sense, and it's not  
22 even necessarily a consensus among the panel, but it  
23 is sort of many of the common themes that came out of  
24 this exercise, so I just wanted to summarize these  
25 quickly. We've gone over these much more in-depth at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the Subcommittee meeting.

2 With BWR and PWR plants, we -- a number of  
3 different aging mechanisms were identified, and I've  
4 listed here some of the ones that the experts thought  
5 were most important. For BWRs, they thought thermal  
6 fatigue, ICSCC, mechanical fatigue, FAC were some of  
7 the major drivers. With BWRs a lot of the experts  
8 indicated that they do see increased operating  
9 transients compared to the Ps, i.e., greater  
10 likelihood of water hammer, and that's going to effect  
11 the frequencies that you would develop for Bs versus  
12 Ps.

13 Some interesting comments from the  
14 experts. A number of people had this, which I didn't  
15 expect going in, but they really look at the BWR  
16 community as being further up on the learning curve  
17 with dealing with aging mechanisms, and developing  
18 mitigative measures to effectively combat them based  
19 on the IGSCC experience that the BWRs lived through in  
20 the 70s and early 80s.

21 MEMBER SIEBER: That's a nice way to state  
22 that.

23 MR. TREGONING: Well, you know, you always  
24 evaluate your experiences and try to grow from them,  
25 both personally and professionally, so I think you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 have to look --

2 MEMBER SIEBER: I'm sure they have the  
3 greatest amount of growth.

4 MR. TREGONING: They've had growth  
5 certainly, because of that. The cautionary note is  
6 that when you look at service experience for BWRs, you  
7 have to be very careful because it's colored by a  
8 large extent to some of this pre-mitigative experience  
9 in IGSCC, so that was a challenge with the experts.  
10 We provided them operating experience data back to  
11 essentially the beginning of reactor time, you know,  
12 in the early 70s and 80s. I'll say the beginning of  
13 large scale commercial reactor time. So that was one  
14 of the things that they really had to do to make sure  
15 that they -- as they evaluated that data they  
16 accounted for the mitigative measures that have been  
17 put in place.

18 For PWR plants they really identified a  
19 lot of the same mechanisms, although certainly one was  
20 predominant, which is one that we started seeing  
21 greater frequency within the operating experience  
22 database recently, and that's primary water stress  
23 corrosion cracking. So this was one that probably  
24 dominated for most experts the answers that they gave  
25 us for PWR plants. But thermal fatigue and mechanical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fatigue are important, as well.

2 We looked at both piping and non-piping  
3 passive system failures, so I just wanted to put a  
4 couple of insights that we got for each of those  
5 categories. And I don't know that there's -- there's  
6 no great revelations here, but I think they're worth  
7 stating, nonetheless.

8 With piping, with a bigger LOCA you can  
9 get -- or I'll say an intermediate LOCA, so something  
10 let's say an effective six inch break. You can get an  
11 effective six inch break by a complete break of a six  
12 inch pipe, or you can get it due to a partial failure  
13 of a much bigger, say a 30 inch pipe. So when you  
14 looked at these different LOCA categories, each expert  
15 had to make an assumption - well do I think the  
16 complete failure of the smaller pipe is more likely,  
17 or the partial failure of the bigger pipe?

18 Typically without fail, the experts tended  
19 to consider that the complete failures of the smaller  
20 piping was generally more likely than the partial  
21 failures of the larger piping, so this is a general  
22 truism that many of the experts expressed.

23 Interestingly, a lot of the experts felt  
24 both qualitatively and quantitatively that aging may  
25 have the greatest effect on intermediate size piping,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and by intermediate size, I'm talking about breaks in  
2 6 to 14 inch pipes, and 14 inch up to maybe the surge  
3 line for PWRs.

4 Why is that? That seems kind of odd at  
5 first. Well, the rationale is that the smallest  
6 piping we have a lot of experience with, not all of it  
7 good, but we've had failures in small piping. And we  
8 sort of have a good understanding of what the small  
9 pipe failure rate. And many experts expected that  
10 that would be relatively constant as we move forward  
11 into the future.

12 Consequently, larger piping up to the  
13 reactor coolant, the primary lube piping, that we have  
14 the biggest margin on for two reasons. One, we tend  
15 to have higher quality inspections of that piping.  
16 And secondly, the bigger the piping is, and the  
17 thicker it is, the more leak before break margin we  
18 have in that piping. So when you looked at the  
19 results, what you saw was if aging had an effect with  
20 given experts, it tended to occur in these 6 to 14  
21 inch pipe break ranges.

22 MEMBER ROSEN: Before you go on, would you  
23 say that there's an operating experience database to  
24 support that first bullet, that complete failures of  
25 small piping are more likely than partial failures of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 large piping?

2 MR. TREGONING: If you take it to the  
3 extreme, yes. I mean, we have seen complete failures  
4 of like one inch, maybe even up to two inch pipes.  
5 Certainly if you include steam generators, we've seen  
6 a lot of complete failures of steam generator tubes.

7 MEMBER ROSEN: Well, if you left the steam  
8 generator tubes out --

9 MR. TREGONING: Even leaving them out of  
10 it, we have a lot of small pipes that are socket  
11 welded that we've seen complete failures of.

12 MEMBER ROSEN: The ones I think about all  
13 the time are things like, well, like the Surry  
14 failure, you know, big fish mouth and partial failure  
15 of a large pipe. Not a double-ended guillotine, a  
16 very astounding failure, but it wasn't --

17 MR. TREGONING: Pretty close, yes.

18 MEMBER ROSEN: It wasn't double-ended but,  
19 you know, I'm talking about the Summer case which was  
20 more of a leak.

21 MR. TREGONING: Right. And again, with  
22 small pipes you tend to have, especially the socket  
23 weld pipes you get into issues with small pipe where  
24 they mainly have one or two weld passes. And again  
25 you have increased -- you have a problem with one of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the weld passes, and then all of a sudden you've got  
2 a crack in that pipe that may go completely around an  
3 essentially 50 percent through-wall, so I think  
4 there's a lot of operating experience, when you go to  
5 the very small pipe, the one and two inch pipe that  
6 does tend to support that assertion.

7 MEMBER FORD: Well, I'm having as I had  
8 the other day, great problems with these qualitative  
9 statements. They're undoubtedly true, but they are  
10 based on a very, very scattered database. There's a  
11 great deal of uncertainty, quantitative uncertainty,  
12 so how do you come up with quantitative conclusions  
13 from these observations? Are they supplemented by  
14 some sort of modeling or what? Real modeling, not  
15 field modeling.

16 MEMBER ROSEN: Not opinions.

17 MR. TREGONING: Again, as we developed  
18 this basis, as we developed what we call the base  
19 cases, those were actually physical models.

20 MEMBER FORD: Well, could you give me an  
21 example of a physical model?

22 MR. TREGONING: Yes. Probabalistic  
23 fracture-base models trying to model the evolution of  
24 let's say IGSCC within --

25 MEMBER FORD: Is this the PRAISE code?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. TREGONING: We used PRAISE, and we  
2 also use the PRODIGAL code, yes. So you have --  
3 certainly, you have limitations that are inherent in  
4 whatever code you're using, and that was certainly  
5 something that each expert had to consider. But we  
6 didn't model every piping system, but we picked four  
7 different piping systems that we tried to model, and  
8 four or five different degradation mechanisms that we  
9 tried to model, and that we also tried to model in  
10 other ways using service history data as the basis.

11 Service history data was the basis for all  
12 of these but we tried to predict LOCA size based on  
13 essentially statistical methods, as well. Markovian  
14 methods and sort of dosimetry analysis, so we had four  
15 different experts that looked at that precursor data  
16 and tried to, for those specific systems, make  
17 assessments as to the LOCA frequency. And as I've  
18 shown earlier, we got a quite wide variety of  
19 responses.

20 MEMBER FORD: You pointed out the BWRs I  
21 think correctly are more experienced at resolving some  
22 of these problems, understanding them for various  
23 reasons. And yet if you based your modeling solely on  
24 historical behavior for BWR pipes for instance, as you  
25 mentioned here, I fail to see how you could come to

1 any conclusion based on historical piping failures.

2 MR. TREGONING: It depends on how you  
3 define historical. And again, that was the challenge  
4 with Bs, because we had to look at both pre and post  
5 mitigative service experience. And we really based it  
6 on -- redeveloped our idealized model of the IGSCC  
7 type of failure. We had -- even though we considered  
8 normal water chemistry, we applied a weld overlay. We  
9 applied one mitigative measure. We asked the experts,  
10 and we said okay, many plants have more than one  
11 mitigative measure, so how would that affect the  
12 failure rates in those particular plants.

13 MEMBER FORD: And there's a database so  
14 that they could say there's a factor of improvement of  
15 Yay.

16 MR. TREGONING: Yeah, we gave them data  
17 that looked at it. And we parsed it in many ways. We  
18 just did it on a calendar year, so that's sort of pre-  
19 19 versus post 1983. These were the failure  
20 frequencies - I don't want to say failure frequencies,  
21 but this was the rate of precursors versus --

22 MEMBER FORD: A group of experts had the  
23 same database and they made a conclusion based on that  
24 database.

25 MR. TREGONING: Yes. And we actually had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 several databases. We had two primary databases that  
2 we used, and why is that? Well, every database is  
3 slightly different. And we wanted to give the experts  
4 a sampling of some of the databases that were out  
5 there. I will say though that even though we gave  
6 them two primary databases, the general conclusions of  
7 the databases were similar, even though one was much  
8 more comprehensive than the other one.

9 With non-piping, as I'm trying to move  
10 along here, the - so I said allegedly it's going to be  
11 compressed. Non-piping, again estimation of non-  
12 piping failures is more challenging than piping. Why  
13 is that? Well, there's a number of very good reasons.  
14 One, we had widely varying operating requirements,  
15 design margins, materials and inspectability, i.e.,  
16 you're looking at component failure and then also bolt  
17 failure, as we talked about with Dr. Wallis. So you  
18 have widely varying failure modes and scales. And  
19 with non-piping, you don't tend to have the same  
20 wealth of precursor information that you do with  
21 piping, just because it hasn't received historically  
22 as much study as the piping arena has.

23 However, the large non-piping components,  
24 and for the Ps we're talking the pressurizer valve  
25 bodies, pump bodies, they tend to have a bigger design

1 margin compared to piping, but they tend to have  
2 decreased inspection quality and quantity. They tend  
3 to be large all static cast stainless steel components  
4 which as most people know are just generally a bear to  
5 inspect, and sometimes they're not even inspected at  
6 all, or very infrequently. So you have these sort of  
7 competing things. You have a bigger design margin,  
8 but then you also have reduced inspection quality.

9 And then with the smaller non-piping  
10 components, the steam generator tubes, the CRDM  
11 nozzles, things like that, I think in general the  
12 experts expected these components to benefit most from  
13 improved inspection methods and mitigation programs.

14 So these are the frequencies that we got,  
15 and this is sort of a simplified plot of the  
16 frequency. It doesn't show any of the panel  
17 variability. These only show -- these are essentially  
18 a consolidation of the mean predictions from the  
19 experts, and what this shows are the mean, and then  
20 the 95<sup>th</sup> percentile.

21 We asked each expert essentially what they  
22 thought their best guess was for these LOCA  
23 frequencies, and then we asked them to bound it above  
24 and below. We essentially said give us a guess that  
25 you think there's a 5 percent likelihood that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 frequencies will be above the value that you give us,  
2 and then a 5 percent likelihood that the frequencies  
3 would be below that, so we tried to capture their  
4 uncertainty in that way.

5 MEMBER APOSTOLAKIS: Let me understand  
6 this. If I take say one of these dots, the first one  
7 on the left, the blue one. Okay. The top one says  
8 BWR 95<sup>th</sup>. Right?

9 MR. TREGONING: Yes. That's the 95<sup>th</sup>  
10 percentile.

11 MEMBER APOSTOLAKIS: And the other one is  
12 --

13 MR. TREGONING: Is the mean.

14 MEMBER APOSTOLAKIS: Whose percentile?  
15 You say the communities of experts that you elicited  
16 opinions from, or --

17 MR. TREGONING: This is the community.  
18 These are boiled down to community -- we asked each  
19 individual expert --

20 MEMBER APOSTOLAKIS: I understand that.

21 MR. TREGONING: -- for their individual  
22 estimates, but these are boiled down estimates. These  
23 are the mean and the --

24 MEMBER APOSTOLAKIS: And they processed  
25 somehow the individual --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. TREGONING: Yes. Yes.

2 MEMBER APOSTOLAKIS: This is very  
3 interesting.

4 MR. TREGONING: This particular -- we did  
5 this a number of different ways so I want to be  
6 careful. I believe this particular result is the  
7 median of all the community means that we got. I  
8 believe that to be the case. It may have been we  
9 looked at the median, we looked at taking the  
10 geometric mean and the trend geometric mean. There's  
11 essentially no difference, so I believe this one is  
12 the median, but --

13 MEMBER APOSTOLAKIS: But you didn't try to  
14 get the experts to reach consensus?

15 MR. TREGONING: No, we did not.

16 MEMBER APOSTOLAKIS: So if I look at the  
17 95<sup>th</sup> now, there were some experts that actually gave  
18 you a higher estimate.

19 MR. TREGONING: Of course. What I'm not  
20 showing --

21 MEMBER APOSTOLAKIS: And all experts are  
22 treated as having equal credibility.

23 MR. TREGONING: All experts are treated as  
24 equal credibility, except what we're recommending is  
25 that we use -- when we estimate these community

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 distributions that we use the term geometric mean,  
2 which would essentially mean we'd be throwing out the  
3 highest and the lowest. That would be, I think, Lee's  
4 and my recommendation, so that would down weight --

5 MEMBER APOSTOLAKIS: If you use a  
6 geometric mean you are throwing away?

7 MR. TREGONING: A trend mean.

8 MR. ABRAMSON: It's Olympic-type scoring  
9 where you throw away the high and the low scores.  
10 That's the analogy.

11 MR. SNODDERLY: George, here's a plot that  
12 we can show you from the Subcommittee meeting that I  
13 think really showed the results for each individual  
14 expert, and then how they were combined to make this  
15 plot.

16 MEMBER APOSTOLAKIS: I'm going to need  
17 much more than that, Mike, given what plans Dr. Powers  
18 has for me. I'm going to need to understand this much  
19 better. Right?

20 MR. TREGONING: Right. But you're  
21 correct, there certainly is variability associated  
22 with each of these dots. And I haven't shown the  
23 confidence bounds associated with these dots. Just  
24 really only in the interest of time, and no other --

25 MEMBER APOSTOLAKIS: Isn't it remarkable

1       though that you have experts -- I mean, is this plot  
2       sending the message that for this particular break  
3       diameter on the left which is, I guess, one-eighth of  
4       an inch or something - the community of experts - oh,  
5       but this is -- you have lots of data for this problem.  
6       Right?

7                   MR. TREGONING:   Yes.

8                   MEMBER APOSTOLAKIS:   So as you move to the  
9       right, you would expect to see --

10                  MEMBER SHACK:   Steam generator tubes you  
11       have a database.

12                  MR. TREGONING:   Right.

13                  MEMBER APOSTOLAKIS:   I mean, look --

14                  MR. TREGONING:   And with PWRs, that's what  
15       dominates there at the smallest break sizes.

16                  MEMBER APOSTOLAKIS:   Yeah, but even if I  
17       go to what, more than 10 inches, the uncertainty is  
18       not that great.

19                  MR. TREGONING:   But again, what this  
20       doesn't capture is the panel variability.   That's  
21       what's not captured here through -- and that's  
22       captured through confidence bounds about either of  
23       these plots.   What you see is the confidence bounds  
24       increased associated with any of these one data --

25                  MEMBER APOSTOLAKIS:   You have a confidence

1 bound on the 95<sup>th</sup> percentile?

2 MR. TREGONING: Yes, and also the mean.

3 MEMBER APOSTOLAKIS: Okay.

4 MR. ABRAMSON: What we got, as Rob said,  
5 is from -- the basic analysis was we took the results  
6 from every expert and we just propagated it through  
7 and got an answer, actually a median 95<sup>th</sup> percentile  
8 for each expert. And for BWRs, we had eight experts  
9 that we had enough information to get a total  
10 frequency, for PWRs we had nine. And then we took  
11 each of those data sets, and this is supposed data  
12 sets.

13 MEMBER APOSTOLAKIS: Right. But these  
14 results like this presumably would be used as input to  
15 what we heard earlier about PRA, you know, the Phase  
16 VI PRA. If you have 5<sup>th</sup> and 95<sup>th</sup>, and then a  
17 confidence interval of 5<sup>th</sup>, a mean and 95<sup>th</sup>, that is  
18 not consistent with the inputs of a standard PRA. A  
19 standard PRA would require a distribution of the  
20 frequency that you have there. So now you are giving  
21 me additional stuff which is confidence interval on  
22 the 95<sup>th</sup> percentile, and the PRA analysts will not  
23 know what to do with it.

24 MR. ABRAMSON: Well, the reason that this  
25 differs from a usual PRA is because we had a panel of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 experts here. Presumably one panel -- the usual PRA  
2 is based on one expert or one expert group. It's one  
3 answer that you get, including uncertainty. The point  
4 of departure here, of course, is that we use this  
5 expert elicitation based on a panel of experts. We  
6 did not try to get a consensus. We thought it was  
7 very important to let our analysis reflect the  
8 diversity of opinion, the variability among the panel  
9 members, and that's what we show.

10 How this is going to be used for  
11 regulatory purposes is something that we're working  
12 on, how you would use this diversity and variability  
13 among the panel members.

14 MEMBER KRESS: Would it be appropriate to  
15 assume that distribution is normal, and therefore you  
16 have all the information you need right there?

17 MR. ABRAMSON: Yes.

18 MEMBER APOSTOLAKIS: No. You see, that's

19 --

20 MEMBER KRESS: If it's all normal, you  
21 have it all right there.

22 MEMBER APOSTOLAKIS: No, but that's what  
23 he's saying, that take any dot, there is a confidence  
24 interval.

25 MR. ABRAMSON: That's right.

1 MEMBER APOSTOLAKIS: That's what I'm  
2 saying, that the PRA analysts will not know what to do  
3 with it.

4 MEMBER ROSEN: We don't give it to them.

5 MEMBER KRESS: We don't have that level.

6 MEMBER APOSTOLAKIS: What will you give?

7 MR. ABRAMSON: It's not the PRA analyst.  
8 It's the decision maker ultimately that's going to  
9 have to use this. The Commission, obviously, the  
10 Committee is going to have to use this in making the  
11 decisions.

12 MEMBER SHACK: We're going to have to wrap  
13 up in about five minutes.

14 MEMBER APOSTOLAKIS: Four. All this is  
15 documented some place, isn't it?

16 MR. ABRAMSON: Oh, yes.

17 MEMBER APOSTOLAKIS: Good.

18 MR. TREGONING: I'm going to skip the next  
19 slide, and just move onto the summary. Again, just to  
20 quickly summarize, we used a formal elicitation  
21 process to estimate generic P and BWR frequencies,  
22 function of flow rate and operating time, considering  
23 both piping and non-piping contributions. We  
24 developed quantitative estimates for these base cases  
25 that Dr. Ford and I discussed a little --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Oh. I'm sorry. I  
2 got excited by the summary. That's very nice.

3 MR. TREGONING: Developed quantitative  
4 estimates for piping and non-piping, these base cases,  
5 which were these idealized set of conditions where we  
6 tried to analyze certain systems and certain  
7 degradation mechanisms using a variety of approaches.  
8 Panelists gave us quantitative estimates supported by  
9 qualitative rationale. They first had to determine  
10 important contributing factors, i.e., what important  
11 piping and non-piping systems were important for  
12 failure, what degradation mechanisms were important in  
13 terms of governing specific LOCA frequencies for each  
14 given break size. And then they provided  
15 relationships between these important contributing  
16 factors and the base cases.

17 The base cases were the only set of  
18 quantitative frequency numbers that we initially  
19 derived as part of this exercise, so each expert gave  
20 us qualitative or I'll say ratios between those  
21 factors and the base case frequencies.

22 On the results we had relatively good  
23 agreement among the experts about what factors are  
24 important, and which ones contribute to LOCAs in  
25 piping and non-piping system. We did have large

1 uncertainty and variability in actually quantifying  
2 those frequencies associated with the contributing  
3 factors, but we certainly expected this going on.

4           There's a wide variety of approaches and  
5 opinions on how you take precursor data and assess the  
6 likelihood of LOCAs given that precursor data. So  
7 this was not unexpected, and this was one reason why  
8 we didn't want to get consensus, because we didn't  
9 want to suppress this uncertainty and variability in  
10 any way.

11           And the slide I didn't show is that the  
12 smaller break sizes were generally within the range of  
13 the NUREG/CR-57.50 estimates, and those were the last  
14 estimates that we did with LOCA frequencies. This is  
15 serendipitous because --

16           MEMBER APOSTOLAKIS: Tell me again what  
17 57.50 was.

18           MR. TREGONING: That was a large study  
19 that was done in INEL which --

20           MEMBER APOSTOLAKIS: Oh.

21           MR. TREGONING: The initiative event  
22 frequency study.

23           MEMBER ROSEN: What year was that?

24           MR. TREGONING: '97 was when they did the  
25 pipe aspect of it. That was data up through '97.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ROSEN: So they're looking at data  
2 up to '97.

3 MR. TREGONING: Right. But we used --

4 MEMBER APOSTOLAKIS: That's when we made  
5 the news that some of the initiating event frequencies  
6 were four times -- because they were using the PRAs,  
7 were four times greater than what the data would  
8 support. This is an important NUREG.

9 MR. TREGONING: And we used a totally  
10 different approach than what they used, the 57.50. So  
11 the fact that many of these estimates were somewhat  
12 comparable was a bit of a surprise. Again, when we  
13 tended to see -- we did see some elevation in the  
14 57.50 estimates around the medium break LOCA regime,  
15 and that's consistent with the qualitative rationale  
16 that the experts felt that aging would affect. Again,  
17 the 6 to 14 inch pipes.

18 MEMBER APOSTOLAKIS: The surprise was  
19 what, that your estimates were close to 57.50.

20 MR. TREGONING: That was a surprise, yes.

21 MEMBER APOSTOLAKIS: Because you expected  
22 your estimates not to be close. 57.50 is databased,  
23 isn't it?

24 MR. TREGONING: Well, again, there's no --  
25 they had to extrapolate precursor data, as well.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I'm sure.

2 MR. TREGONING: So they used a totally  
3 different methodology that was essentially one expert  
4 instead of a team of experts.

5 MEMBER APOSTOLAKIS: Did you make sure  
6 that your experts were not influenced by 57.50?

7 MR. TREGONING: I don't want to say not  
8 influenced. We told them what was done in 57.50  
9 because we wanted them to have an understanding of  
10 that.

11 MEMBER APOSTOLAKIS: Somebody gave them a  
12 copy in the middle of the night.

13 MR. TREGONING: They all had copies of --

14 MEMBER APOSTOLAKIS: But then why are we  
15 surprised that the results are not that different?

16 MR. TREGONING: That wasn't the basis --  
17 the 57.50 numbers was not the basis of this exercise.  
18 It was the data -- and we had a much -- the 57.50  
19 looked at a database of leak events, which is  
20 incredibly small. We looked at this database of  
21 entire precursor events, part through-wall cracks,  
22 full leaks, and even pinhole leak sort of things, so  
23 57.50 was really looking at data that just looked at  
24 bigger leaks, essentially. We did have one of the  
25 57.50 authors on the expert panel, so he was likely

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       biased by --

2                   MEMBER ROSEN: By his prior work.

3                   MR. TREGONING: Right. But that was one

4       --

5                   MEMBER APOSTOLAKIS: We have to be very  
6 careful with our words here.

7                   MR. TREGONING: Right. So that was one of  
8 the team of 12 was 57.50 people, but we thought it was  
9 important to provide perspective as what was done in  
10 the past, because we're just revisiting and trying to  
11 update that study.

12                   MEMBER APOSTOLAKIS: The reason why I'm  
13 saying is because in the early days of PRAs, this  
14 doesn't count against the five minutes, in the early  
15 days of PRAs, all sorts of people, consultants were  
16 coming from different directions. We have our own  
17 database. Everybody was copying Wash 1400. You know,  
18 instead of 5, 10 to the minus 3, they would make it  
19 5 and a half. I have my own --

20                   VICE CHAIRMAN WALLIS: George, are we out  
21 of the early days of PRA yet?

22                   MEMBER SHACK: I think we're going to hear  
23 from NEI.

24                   MEMBER APOSTOLAKIS: Okay. Great.

25                   MEMBER ROSEN: In other words, this is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 entry.

2 MR. SNODDERLY: While NEI is coming up to  
3 the table, right now I think we need to consider how  
4 we want to review the final wrapping up of Rob's work,  
5 which is going to be in the form of a NUREG. What  
6 we've tentatively done is we scheduled a Subcommittee  
7 meeting for June 24<sup>th</sup>. Rob would have a draft of the  
8 NUREg ready by the end of May. That would give the  
9 Committee about three weeks to look at that, and then  
10 we could write a letter on the final NUREG at the July  
11 meeting.

12 MEMBER ROSEN: Which subcommittee?

13 MR. SNODDERLY: It's been under Dr.  
14 Shack's Regulatory Policies and Practices, and  
15 everyone is invited.

16 MEMBER ROSEN: Everybody is invited to  
17 submit themselves to Dr. Shack's tender ministrations.

18 MR. SNODDERLY: June 24<sup>th</sup>. We'll discuss  
19 it at the PM -- I just wanted you to consider that's  
20 the approach that -- so we've got to think about how  
21 we're going to wrap this up.

22 MEMBER APOSTOLAKIS: Are you going to  
23 change it?

24 MEMBER SHACK: We may.

25 MEMBER APOSTOLAKIS: In May, or you may?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: We may change it.

2 MEMBER APOSTOLAKIS: Okay.

3 MEMBER SHACK: The problem is the Thermal  
4 Hydraulics Committee would value the whole week.

5 MEMBER APOSTOLAKIS: Only that week? Is  
6 it 15 minutes time, this time?

7 MR. PIETRANGELO: I know I'm between  
8 lunch, and I know I'm hungry, so I'm going to make  
9 this as brief as possible.

10 Okay. First of all, before I start this  
11 I want to say I have tremendous respect for the staff  
12 that worked on the SECY, the working group that's been  
13 working on this. I even like some of them personally  
14 as human beings. Okay? But the staff requirements  
15 memorandum from the Commission that they've been  
16 working to had a lot in it, and was subject to some  
17 interpretation.

18 Nevertheless, I would be less than candid  
19 if I said anything that we were extremely disappointed  
20 by what was in this SECY, and what went up to the  
21 Commission on this. I think it was noted earlier, we  
22 had two meetings, one last June, one last July. We  
23 sent the staff a white paper in September. There has  
24 been no dialogue since that time. I didn't hear  
25 anything this morning, and the issues that were teed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 up that were different from what we heard seven months  
2 ago. Okay? And that isn't even in a way just  
3 reopening some of the stuff that went into the 1174  
4 decision making process.

5 It took them seven months to get another  
6 SECY up to the Commission to ask for direction less  
7 than one month from when the proposed rule was due, so  
8 when you have a lack of engagement like this, and you  
9 circle the wagons, and I don't know what the reasons  
10 for it internally at the NRC. When you stop dialogue,  
11 I think it's very destructive. We have people in the  
12 industry who are interested doing things on this, that  
13 are funding activities, and for the staff to just  
14 close -- you know, we call it the cone of silence in  
15 the industry. We never like when it's raised. And in  
16 this case, I thought we had productive dialogue early  
17 on but it's been stymied.

18 When we read the SECY, I'll be very honest  
19 with you. It was, to us, a lot of hand wringing about  
20 what licensees might do if we actually had an  
21 alternative break size in the regulation, and how do  
22 we know what the effects are going to be, and what if  
23 they do this, and what if they do that? Like we heard  
24 this morning, we're already doing research on what a  
25 power uprate might mean if we had an alternative break

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 size.

2 I mean, we know there's going to be a lot  
3 -- there's no delusions about the technical work  
4 that's going to be necessary to do this. I think  
5 research has done an excellent job thus far. It's  
6 taken a long time. Okay? But we've got a good  
7 foundation to start with, and their efforts should be  
8 focused on getting a firm technical basis for an  
9 alternate break size for both a B and a P. Doing  
10 anything beyond that at this point I think is wasting  
11 their resources. Okay.

12 There's been no successful regulatory or  
13 form initiative that hasn't been preceded by some form  
14 of industry pilot or exemption-type request. And this  
15 effort is sorely in need of one. To be honest, I have  
16 no interest whatsoever in discussing some of those  
17 issues that were raised by the staff this morning in  
18 this abstract context.

19 This Committee has been discussing  
20 defense-in-depth since it has been formed. Okay. I  
21 mean, to what end is that going to take us? So we  
22 need specifics, we need a pilot here.

23 We're in total agreement with the staff  
24 recommendation on the LOOP/LOCA BWR pilot. You're  
25 going to get a submittal on that soon. It will have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 some good things for Ps in it too that are relevant.  
2 But on the P side, what I think we're pushing at this  
3 point is to bring a risk-informed approach to GSI 191,  
4 the PWR sump issue. That's an issue of the day.

5 We think there's a net safety benefit in  
6 using a risk-informed approach on GSI 191. That was  
7 the other thing that bothered us about this SECY.  
8 There was no mention of any safety benefits or  
9 potential safety benefits in that entire SECY. It was  
10 all about inadvertent consequences, and all of this  
11 other stuff. And that's not what the intent of this  
12 effort is. And I think they just made it a lot more  
13 complicated than it has to be in terms of what we're  
14 trying to do.

15 Most of it's margin. It's operating  
16 margin for licensees. The double-ended guillotine  
17 break is used for things like valve opening times, and  
18 flows, and things like that. That's where most of the  
19 changes are going to come in. Do I have to overhaul  
20 a pump that's 5 gpm under its flow that was sized for  
21 the double-ended guillotine break? I mean, that's  
22 what we do now for tech specs. That's the kind of  
23 thing we're trying to get rid of.

24 There was a laundry list of --

25 VICE CHAIRMAN WALLIS: All things like that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it's not large power uprates?

2 MR. PIETRANGELO: They were given a  
3 laundry list of things that might occur, and they took  
4 the most extreme ones in this thing. And they're even  
5 doing research on those now. I mean, there may be  
6 very legitimate reasons to not go forward with a power  
7 uprate. I think you already touched on them this  
8 morning. We didn't get to the application phase on  
9 this. It's too early. Okay.

10 We would have been better off with a very  
11 focused pilot, so that's what we're going to propose  
12 now. We have proposed it in GSI-191 space. I hope  
13 that all the staff that was working on this will help  
14 us in that effort, because we're going to need help in  
15 that effort, because we're under a very time  
16 constrained effort on this.

17 We will not be reducing ECCS capability  
18 when we risk-inform G-191. We will be changing it to  
19 be more risk-informed and response. It's not reducing  
20 ECCS capability. If we can make some changes that  
21 stem from an alternative break size, you can have a  
22 net safety benefit. You could even get small breaks  
23 which are the higher frequency ones that drive the  
24 risk of the sump issue out of scope for this issue  
25 because you'd never get to recirculation using the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sump, so I think there's tremendous potential there.  
2 And unless we get something accomplished that shows  
3 that there's a net safety benefit, then I don't see  
4 any future for this effort.

5 I mean, the Chairman has been pretty clear  
6 about that's why he's pushing this effort in all his  
7 talks on this, and I think that's what the  
8 Commission's expectation is. And to get a SECY back  
9 like that that had no mention of it, and that only  
10 spoke to the abstract discussion and all these -- how  
11 we have to do mitigation capability for beyond design  
12 basis events. We raised that issue eight months ago.  
13 We know we have to do that.

14 I mean, that's one of the things research  
15 could work on now, is what's appropriate acceptance  
16 criteria for those beyond design basis things. That  
17 would be at least a tangible thing we could use in  
18 this. But as was mentioned, for the BWRs they're  
19 probably going to use the existing acceptance criteria  
20 that's in 50.46.

21 For the GSI-191 we'll probably use net  
22 positive suction out at the stream. It's a lot more  
23 work to go develop these alternative acceptance  
24 criteria, and we understand that. And it probably  
25 does warrant a research effort, so it depends on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 application and what you want to get out of it at the  
2 end as to what acceptance criteria you can settle for.  
3 If you need something that's less conservative, then  
4 you have to do more work to go get it.

5           Again, using more realistic methodology,  
6 we all knew we were going to do that for beyond design  
7 basis things. And GSI-191, maybe it's credit for  
8 containment back pressure, credit for non-safety  
9 related equipment, and less conservative assumptions  
10 that are used in our baseline methodology under  
11 regeneration and transport, and all that other stuff.  
12 So, I mean, this is not brain surgery to figure out  
13 more realistic methodology. But just to throw all  
14 those issues up, and they go back to the Commission  
15 and say - and there's three of them up there, and they  
16 have limited staff, all these technical and policy  
17 issues. I think the Commission has not been well-  
18 served on this issue.

19           I have no idea what they're going to do  
20 with that SECY, but again, we're just disappointed  
21 that it got to this point, and that the dialogue was  
22 stopped on this. So we're going to focus on pilots  
23 that can help demonstrate how these things would be  
24 done, because to try to discuss these in the abstract,  
25 at least from our perspective, leads nowhere.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN WALLIS: Now, Tony, I'm  
2 puzzled because I thought when we had a discussion  
3 with you folks some time ago that you guys were going  
4 to make the case for changes in 50.46 rule. And now  
5 it seems to be that you're annoyed because the staff  
6 hasn't done it for you.

7 MR. PIETRANGELO: No, that's not it at  
8 all. Okay. We knew the research work was ongoing.  
9 That is going to be the basis for the alternative  
10 breaks. Ultimately, we're going to have to  
11 demonstrate the applicability to our plants of that,  
12 whatever number is come up with, and how you would  
13 control change using that. Okay.

14 Again, as I think was said before, just  
15 the placement of an alternative break size in the  
16 regulation or in the licensing basis of a plant  
17 changes nothing. It's what goes forward from that.  
18 You know, trying to discern in advance all the  
19 potential effects of all the changes that could stem  
20 from an alternative break size is a useless exercise.  
21 We don't have enough resources, time or money to do  
22 that.

23 MEMBER ROSEN: I think I understand your  
24 point, and I think I feel some of your pain. Now tell  
25 me what it is you're going to do on this pilot that

1 will help. What is the pilot going to be?

2 MR. PIETRANGELO: I think at least on the  
3 BWR pilot, there are some defined changes in that  
4 topical report that stem from decoupling LOCA from  
5 LOOP. Okay. So that's very well defined. You can  
6 draw a nice box around it.

7 The same thing can be said for GSI-191.  
8 I'm not going to try to change the universe with an  
9 alternative break size. I'm going to use it for  
10 debris generation purposes, and I also may use it on  
11 containment spray operation set points.

12 MEMBER ROSEN: So you're going to get a  
13 plant, a PWR, obviously, for the sump issue.

14 MR. PIETRANGELO: Right.

15 MEMBER ROSEN: To actually do some  
16 calculations and vary the break size --

17 CHAIRMAN BONACA:: To show how it would be  
18 done.

19 MEMBER ROSEN: To show how it's going to  
20 be done, rather than rely on the NEI document?

21 MR. PIETRANGELO: We have to go forward.  
22 We had an effort ongoing on GSI-191 for quite some  
23 time, a baseline evaluation methodology. What we have  
24 right now is a deterministic approach and a risk-  
25 informed approach. The deterministic approach is what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you think it is. Okay.

2 The risk-informed approach would be an  
3 alternative break size along with a beyond design  
4 basis, how do you mitigate the double-ended guillotine  
5 break, as we've been talking about, and for any kind  
6 of Option 3 activities.

7 MEMBER KRESS: Tony, there are a lot of  
8 possible changes that could be --

9 MR. PIETRANGELO: There are.

10 MEMBER KRESS: And I agree with you, it's  
11 not very progressive to try to figure out what all of  
12 those are, and to try to figure out their implications  
13 with respect to risk. It seems to me like the way to  
14 handle those is change them one at a time on a plant-  
15 specific basis, and using something like Reg. Guide  
16 1.174, and some defense-in-depth considerations. And  
17 that would automatically allow the thing to be  
18 controlled and looked at.

19 MR. PIETRANGELO: That's precisely what we  
20 proposed last September, was an approach based on Reg.  
21 Guide 1.174.

22 MEMBER KRESS: Do you think the existing  
23 plant-specific PRAs are doing that for that type of --

24 MR. PIETRANGELO: It depends on the  
25 application.

1                   MEMBER KRESS: But it seems to me like to  
2 handle those changes, plant by plant, each plant basis  
3 is the way to handle this.

4                   MR. PIETRANGELO: The way we envisioned it  
5 going forward was that these specific applications  
6 would be identified to use the alternative break size.  
7 And then we would develop guidance on each of those  
8 applications, just like we have the last 10 years.  
9 And we get a lot of interaction with the staff, we get  
10 a lot of input from the industry that says here's the  
11 way to do that application. All right. And then  
12 plants would go in -- there's always been the  
13 understanding that even with a revised break size, it  
14 was an amendment request that was going to be needed  
15 to change it, so by getting the alternative break size  
16 -- this was kind of the enabling rule we petitioned on  
17 before.

18                   By getting an alternative break size in  
19 the regulation, you enabled people to go out and do  
20 some things and then come in with amendment requests.  
21 You can't do that unless you're doing exemption  
22 requests if you don't have a change to the  
23 regulations.

24                   I know I vented a little bit here and took  
25 more time than I wanted to, but --

1 CHAIRMAN BONACA:: No, that's valuable,  
2 first of all, input to us. And second, examples would  
3 limit this genuine concern about all that could happen  
4 out there in the universe because of this. Okay. And  
5 it will make it more tangible and more specific.

6 MEMBER SHACK: Back to you, Mr. Chairman.

7 CHAIRMAN BONACA:: Thank you very much,  
8 appreciate it. And we want to get back in, let's see  
9 now, at 1:30 or do you want the full hour? Full hour,  
10 so quarter of 2.

11 (Whereupon, the proceedings in the above-  
12 entitled matter went off the record at 12:44:32 p.m.  
13 and went back on the record at 1:43:54 p.m.)

14 CHAIRMAN BONACA:: We're back in session.

15 MEMBER KRESS: You guys recall that with  
16 respect to licensing advance reactors or with respect  
17 to the technology neutral framework thing, the staff  
18 came up with a number of what we thought were  
19 excellent issues to the guidance, and they had options  
20 for the Commission to consider with preferred options,  
21 and we liked their issues, we liked their options, and  
22 they set the thing up. As usual, the Commission  
23 didn't agree with all of us, so they sent them back an  
24 SRM basically asking them to look at two things.

25 One of them was what the heck do we do

1 about multi-module plants on a site with respect to  
2 integrating the overall risk.

3 MEMBE POWERS: You told us several times  
4 what to do on that. Did they listen to you?

5 MEMBER KRESS: They didn't listen, no.  
6 But we've got another chance here. The other thing  
7 has to do with non-light water reactor, where you have  
8 to deal with the question of maybe you don't want --  
9 maybe you don't have to have a real containment like  
10 with leak-tight barium. Maybe you can have other  
11 types of arrangements, so the question is containment  
12 versus confinement is the way it's been capsulized,  
13 but it's more detailed.

14 MEMBE POWERS: If you're in that spectrum  
15 of containment to confinement, does the European  
16 vented filtered containment?

17 MEMBER KRESS: That's a good interesting  
18 question. That probably would be called real  
19 containment.

20 MEMBE POWERS: That's a containment.

21 MEMBER KRESS: Yes, I would call it that.  
22 But anyway, those are two issues that the staff was  
23 asked to reconsider or think about, and they've done  
24 that now. And they're going to tell us what their  
25 early thinking is on these issues, and get our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 feedback, I suppose. So with that, I'll turn it over  
2 to you, John.

3 MR. FLACK: All right. Thank you, Tom.  
4 My name is John Flack. I am the Branch Chief of the  
5 Advanced Reactors at Regulatory Effectiveness Branch  
6 in the Office of Research. To my left is Stu Rubin,  
7 who is a senior level advisor in the branch. To my  
8 right is Mary Drouin who is, I guess everybody knows,  
9 from the probabalistic risk assessment branch.

10 MEMBE POWERS: Is she qualified to --

11 MEMBER ROSEN: Is that Mary Drouin that  
12 was here this morning, or you have two of them?

13 MR. FLACK: No, same one.

14 MEMBER ROSEN: Or evil twin.

15 MEMBE POWERS: Hey, evil is not a word we  
16 associate with Mary.

17 MR. FLACK: And to her right is Tom King,  
18 a former director in Office of Research, who everyone  
19 knows.

20 What I'll do is I'll briefly go over  
21 what's in the SECY, some of the background that led up  
22 to that and the issues, and the messages we're  
23 sending.

24 Basically, first viewgraph, the objectives  
25 of our meeting here with the ACRS is to discuss the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 proposed response to the SRM we received from the  
2 Commission last year. That SRM was in response to  
3 seven policy issues that stemmed from our review of  
4 Advanced Reactors, so we're here to discuss them, and  
5 then obtain a letter that would approve where we're  
6 headed. And in this context, integrate whatever  
7 comments you have with respect to the SECY.

8 The next viewgraph briefly goes over  
9 background.

10 MEMBER APOSTOLAKIS: When is your response  
11 due?

12 MR. FLACK: It is due April 23<sup>rd</sup>, so we  
13 have very little time on that.

14 Briefly going through the seven policy  
15 issues that were raised previously that are listed  
16 here on this viewgraph, the first two are basically  
17 over-arching policy issues, the first being  
18 expectations for safety, and generally the Commission  
19 agreed with the staff's position on that; with the  
20 exception of accounting for integrated risk and you'll  
21 hear more about that today.

22 The second was defense-in-depth, and again  
23 the Commission approved the Staff's approach.  
24 However, they provided additional guidance, and  
25 instead of basically coming up with a new policy, was

1 to revisit some of the policies that we already had,  
2 specifically PRA policy statement and others, to see  
3 if they can be revised to reflect what we mean by  
4 defense-in-depth.

5 The third policy issue, use of  
6 International Consensus Codes and Standards, was not  
7 approved by the Commission. The staff was seeking to  
8 be proactive in that area, to get out in front, to  
9 seek to look at the international community for their  
10 codes and standards and their application to plans  
11 under review. However, the Commission guided the  
12 staff in its guidance, guided the staff to review only  
13 those there were applicable to a design under review,  
14 and that we should enhance our own codes, and not seek  
15 out International Codes to do that job.

16 On the fourth one, probabalistic licensing  
17 basis, this was generally to revisit the Commission on  
18 the fact that we're using PRA more today than when we  
19 first proposed this as a policy issue back in the  
20 early 90s, and they agree with the staff's position on  
21 that on the greater use of PRA, and picking events and  
22 identifying system structures and components that are  
23 important to safety.

24 On the fifth one, scenario specific  
25 licensing source term, that basically is consistent to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 where we were headed from earlier Commission's  
2 decisions on that, so we're consistent with using  
3 mechanistic source terms in our licensing decisions.

4 Containment versus confinement, number 6,  
5 is what you'll hear again today. The Commission did  
6 not approve of the staff's position in SECY and wanted  
7 to know a little bit more about it, wanted the staff  
8 to go off and look at potential options for  
9 containment performance requirements and so on, so  
10 you'll hear about that today from Stu.

11 And finally the last one was the emergency  
12 preparedness policy issue. And at the time, the staff  
13 recommended we do not change anything there, and the  
14 Commission agreed to that, no changes regarding  
15 emergency preparedness, or no reductions in EPZ.

16 Okay. And then the bottom there, I just  
17 summarize what has been approved and disapproved. And  
18 it's issues 1 and 6, which you'll be hearing about  
19 today.

20 On the next viewgraph we're just briefly  
21 looking at how the SECY was structured. It's  
22 structured around those issues, 1 and 6. And then  
23 there are four attachments to the SECY. The first  
24 attachment gives a summary and a basic status of the  
25 framework. Mary is prepared to address some questions

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on that, but basically, you'll be hearing a lot more  
2 about that throughout the year. It's not to provide  
3 anything new at this point, but only to say this is  
4 where we are.

5 Attachment 2 discusses and summarizes the  
6 basis for the recommendation that you'll hear on the  
7 integrated risk issue. Attachment 3 is the  
8 containment functional performance requirements and  
9 discussions, a discussion of that issue. And  
10 Attachment 4 summarizes the workshop we had, where we  
11 entertained the public and other stakeholders on that  
12 containment versus confinement issue. Again, the SECY  
13 is scheduled to be sent up to the EDO next Friday,  
14 which is April 23<sup>rd</sup>.

15 Okay. Specifically, with respect to the  
16 two issues, and I'm not going to get too far into this  
17 at this point because you'll hear a lot more about it,  
18 but basically, on Issue 1, we were to provide options  
19 for and impacts of requiring modular reactor designs  
20 to consider integrated risk from the use of multiple  
21 reactor modules, and that goes to the issue of putting  
22 on many smaller reactors that were equivalent to one  
23 larger one, and how to treat that probabalistically  
24 from a --

25 MEMBER KRESS: Now when they say risk,

1 they mean both CDF and LERF.

2 MR. FLACK: That's right, front-end and  
3 back-end, both pieces.

4 MEMBE POWERS: John, two years ago the  
5 modular concepts were all the wild rage. I've heard  
6 less people being -- not so much enthusiasm about  
7 those in the last year and a half or so. Are they  
8 still considered a viable concept?

9 MR. FLACK: Well, there are advantages and  
10 disadvantages. I guess the plants seem to be getting  
11 bigger for some reason that they're building. And the  
12 advantage of building --

13 MEMBE POWERS: Yes. I know that the Finns  
14 just purchased a new reactor, and it's 1600 megawatt  
15 electrical. It doesn't look like it's moving -- it's  
16 definitely a module. It's a heck of a module. I  
17 believe it is. I think that's one of four they think  
18 they're going to buy. I'm just asking you with your  
19 pulse to the floor, do you see people pushing these  
20 modules the way they were, say two years ago, or have  
21 they just kind of fallen aside?

22 MR. KING: I think maybe Jerry Wilson  
23 ought to talk about what the early site permit folks  
24 are asking for.

25 MEMBE POWERS: Well, I know that the early

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 site permits have these -- I mean up to 21 modules in  
2 one case. But there was two written like two years  
3 ago and conceived of two years ago. I'm asking what's  
4 the current - say the last six months. I just haven't  
5 seen people pushing modules so hard.

6 MR. FLACK: Yes. No, I think you're  
7 right. I think the only place we're seeing any action  
8 at this point is over in South Africa with the pebble-  
9 bed that they're proposing, but at this point in time  
10 there's uncertainty there as to when, and what, and  
11 how long, so I think at this point, you're correct in  
12 your observation. We do not have a module in, or  
13 someone that's interested in building a plant for that  
14 matter in this country that size.

15 MEMBE POWERS: I mean, even in the Gen-  
16 Four Program it seems to me that they have put any  
17 modular concepts on the back burner in favor of the  
18 more --

19 MEMBER KRESS: In any event, I think these  
20 conceptual issues apply to just multi-plant size.

21 MEMBE POWERS: Yes, multi-unit sites.  
22 It's a position that you've taken for as long as I've  
23 been doing this as a matter of fact, which we won't go  
24 into.

25 MR. FLACK: Well, the advantage there is,

1 of course, you could build a number of them as you  
2 need them, and not just build one, and hold up all  
3 your resources in building one plant all at once, so  
4 I think that was the advantage that they promoted when  
5 the concept came out, that you can add to the site as  
6 needed.

7 MR. WILSON: This is Jerry Wilson of NRR,  
8 if I could amplify a little bit on that. WE're  
9 expecting two design certification applications next  
10 year, advanced CANDU reactor and ESBWR. And at the  
11 moment, both of them are optimizing their design to  
12 come up a little higher power, so you could see that  
13 as some indications that they're looking at higher  
14 power. But at the same time, we've recently received  
15 a letter from the pebble bed folks saying that they'd  
16 like to initiate a pre-application review on the  
17 pebble bed reactor next year with possible design  
18 certification down the road. And as you also  
19 observed, all three of the early site permit  
20 applications included the option of possibly building  
21 pebble bed reactors, so there's kind of votes on both  
22 sides of that issue.

23 MEMBE POWERS: Yeah, the siting permits -  
24 I mean, that's just prudence to include that in the  
25 range of possibilities. I mean, they also leave open

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the possibility of buying an EPR at 1600 megawatts a  
2 pop.

3 MR. FLACK: Okay. So those are the --  
4 well, that was the first issue, was again modular  
5 issue. The second issue is the containment functional  
6 performance requirements and criteria, and the options  
7 and recommendations. So at this point, the SECY is  
8 basically intended to summarize the efforts developed  
9 for the risk-informed framework and defense-in-depth  
10 description. And Mary can talk about that, and inform  
11 the Commission of the relevance of the integrated risk  
12 issue to the early site permits reviews, are also part  
13 of the intent of the SECY.

14 Okay. Basically, the SECY recommends to  
15 the Commission two things. It seeks approval of the  
16 Staff's recommendation on the treatment of the  
17 integrated risk for the modular reactors. And  
18 secondly, it's seeking approval of the integration of  
19 the options on the containment functional performance  
20 requirements with policy recommendations on the frame  
21 work. So those are the two basically messages that  
22 the SECY is sending us at this particular time. Those  
23 are sort of the bottom lines on that, and that's where  
24 we're headed. So I'll turn it over now, if there's no  
25 further questions, first to Mary, and then that will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 be followed by Stu to address these two issues.

2 MS. DROUIN: I'm going to speak on the  
3 first technical issue of integrated risk, which is  
4 Attachment 2 of your SECY. And what we were asked to  
5 look at is should the risk, and we looked at it from  
6 a modular perspective, that when you look at the risk  
7 concerning modules, should they be considered on a  
8 unit, a per module basis, or should the risk be looked  
9 across all the modules? And we're only at this point  
10 with this issue is looking at it from the modular.  
11 We're not looking at it from the site. It does have  
12 implications for that, but the policy issue is very  
13 specific to address the modules.

14 In coming up with the options that we have  
15 --

16 MEMBER KRESS: When you're talking about  
17 risk here now, are you talking about both CDF and  
18 LERF?

19 MS. DROUIN: Yes. When we talk about the  
20 risk, we're going to be talking -- I would say right  
21 now we're going to use CDF and LERF as the examples.

22 MEMBER KRESS: As the examples.

23 MS. DROUIN: Because without knowing the  
24 exact design we have, CDF and LERF might not be the  
25 correct figures. But for illustrative purposes in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 options that we've looked at, we're going to use CDF  
2 and LERF as our examples.

3 MEMBER KRESS: The proper definition for  
4 those for gas cooled reactors.

5 MS. DROUIN: Correct.

6 MEMBE POWERS: Why is this an issue? If  
7 I look at the safety goals, doesn't it answer that  
8 question?

9 MS. DROUIN: If you keep the question up  
10 at the safety goal level, but if you try to do it at  
11 a surrogate level, CDF and LERF are not always the  
12 correct surrogates.

13 MEMBE POWERS: I guess I'm puzzled. I  
14 mean, don't the safety goals say that the risk in the  
15 individual to nuclear activities will be no more, and  
16 it specifies the limits? It doesn't say anything  
17 about -- it's very clear, anything within the site  
18 boundary counts in that risk.

19 MS. DROUIN: At one time, we've got to go  
20 back a little bit historically. The safety goals were  
21 applied across the industry as an average. When we  
22 went into Reg. Guide 1.74, there was a  
23 reinterpretation of the safety goal, and then it was  
24 applied on a plant-specific basis.

25 MEMBE POWERS: I see now. It's because of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that -- George let you get away with things in 1.174.

2 MS. DROUIN: But you are correct. I mean,  
3 if you go back 15 years ago --

4 MEMBER APOSTOLAKIS: I'm trying to be  
5 quiet here.

6 MEMBER KRESS: And I've complained about  
7 that interpretation in 1.74.

8 MEMBE POWERS: I know you did.

9 MEMBER KRESS: Umpteen dozen times.

10 MEMBE POWERS: And you got just as far as  
11 George did on his defense-in-depth philosophy  
12 statement. They didn't pay any more attention to you  
13 than they did to him.

14 MS. DROUIN: Anyway, the options that we  
15 have examined or evaluated and the one we finally  
16 ultimately recommended are based on three factors;  
17 based on risk guidelines looking at accident  
18 prevention mitigation, using CDF and LERF as our  
19 examples.

20 It's also looking at the number of  
21 potential modules you have at the site, and then the  
22 megawatt thermal size of each reactor. And we have  
23 identified three specific options.

24 Okay. The first option, where there's  
25 really not very much consideration of the integrated

1 or the cumulative risk. And what we're saying on this  
2 one is that when you look at each module, we're  
3 evaluating each module separately and independently  
4 from each other. So, therefore, if you're using CDF  
5 and LERF, for example, as your risk matrix -- you're  
6 using CDF and LERF and you're using the 1E-4, and the  
7 1E-5 respectively, then what we're saying is that each  
8 one of these modules has to meet each of those  
9 guidelines. So we're not looking at, for example, it  
10 doesn't matter whether you have one module or ten  
11 modules. It's not looking at the size of the reactor,  
12 so whether you have one module that's 100 megawatts  
13 thermal, and they're all 100 megawatts thermal, or you  
14 have five that's 100 megawatts thermal and another 20  
15 that's 600 megawatts thermal, it's not making any  
16 difference.

17 MEMBER APOSTOLAKIS: Why would the power  
18 level matter? I can see the issue of modules --

19 MEMBER KRESS: It's because the LERF is  
20 defined in terms of the fixed fission product  
21 inventory.

22 MEMBE POWERS: Source term.

23 MEMBER APOSTOLAKIS: Because what?

24 MEMBER KRESS: LERF is defined and back-  
25 calculated based on a fixed fission product release

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 inventory.

2 MEMBER APOSTOLAKIS: And the frequency we  
3 have as a goal for LERF is based on that.

4 MEMBER KRESS: Based on that, yeah.

5 MEMBER APOSTOLAKIS: So it's the  
6 definition that changes.

7 MEMBER KRESS: It's the actual LERF  
8 surrogate for a safety goal that changes.

9 MEMBE POWERS: But it could be  
10 recalculated because LERF is consistent with the  
11 safety goals.

12 MEMBER KRESS: Yes, it's consistent with  
13 it. It can be considerably higher for a smaller power  
14 reactor.

15 MEMBE POWERS: But you could back-  
16 calculate it and get the appropriate number for the  
17 surrogate straightforwardly. Whereas, the CDF would  
18 be not necessarily consistent.

19 MEMBER ROSEN: Now, George, you said  
20 something that a little puzzled me. You said for  
21 light water reactors, but I thought the QHOs were  
22 broader on that.

23 MEMBE POWERS: The light water reactors  
24 have different weight function than those from  
25 advanced --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: No, the frequency  
2 that we use now as a goal is for the current  
3 generation, because they're working backwards, they're  
4 evaluating backwards.

5 MEMBER KRESS: LERF is very specific for  
6 the current change in light water reactors.

7 MEMBER APOSTOLAKIS: But the change -- if  
8 you have a smaller reactor, what we call now a large  
9 early release may not be appropriate.

10 MEMBER ROSEN: But the quantitative health  
11 objective --

12 MEMBER APOSTOLAKIS: Same for everybody.

13 MEMBER KRESS: Yeah, they're technology  
14 neutral.

15 MEMBER APOSTOLAKIS: It's the surrogate  
16 that you have to be careful about.

17 MS. DROUIN: Even if your surrogate have  
18 changed, I mean, the size reactor could potentially  
19 make a difference.

20 MEMBER KRESS: But you still have a  
21 question there, even if the surrogate changes.

22 MS. DROUIN: Correct. And we're just  
23 saying at this option, all we're doing is staying with  
24 the current practice.

25 MEMBER KRESS: The operative words I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on this slide is that bottom bullet.

2 MS. DROUIN: Oh, yes. Sorry.

3 MEMBE POWERS: What, pre-decisional?

4 MEMBER KRESS: Yeah, that's the --

5 MS. DROUIN: No, is that we could be  
6 under-estimating the risk to the public, very much so.

7 MEMBER APOSTOLAKIS: By the way, is this  
8 by design to look that way, or it just xeroxed on the  
9 notebook on the left there.

10 MS. DROUIN: It's supposed to look like a  
11 notebook.

12 MEMBER APOSTOLAKIS: The spiral is what?

13 MEMBER KRESS: It's a notebook.

14 MS. DROUIN: It's pre-decisional so you're  
15 still in your notebook phase.

16 MEMBER KRESS: She just tore these out of  
17 her notebook and xeroxed them.

18 MS. DROUIN: Okay. On the second option,  
19 we are started to be a little bit integrated here, but  
20 we're only considering the frequency. And what we  
21 mean by that is that the risk from all the modules  
22 combined has to meet the guidelines. In addition,  
23 each module has to meet the guidelines equally.

24 MEMBER KRESS: Now let me ask you about  
25 this. Does that mean that you have 10 modules and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 your CDF goal were 1 times 2 to the minus 4, each  
2 module has to be one-tenth times 2 to the minus 4?

3 MS. DROUIN: That's correct. It's  
4 whatever your guideline is over N.

5 MEMBE POWERS: But why is that the case?  
6 I mean, does that mean that there is no common mode  
7 failure here?

8 MS. DROUIN: No, you could have common  
9 mode failures. It's just the option we've come up  
10 with that we're just going to split it equally. We're  
11 just going to look at the number, and not consider  
12 still at this time power, the megawatt thermal size of  
13 the reactor. We're just going to say you have to meet  
14 these guidelines, and the more you have, it's going to  
15 be tougher to meet them because we're going to split  
16 them up equally.

17 MEMBER KRESS: Does it also say each  
18 module must meet the LERF goal?

19 MS. DROUIN: Yes.

20 MEMBER KRESS: So one-tenth of the LERF  
21 goal for each module. Now that presupposes each  
22 module has some sort of separate containment.

23 MS. DROUIN: No.

24 MEMBER KRESS: Confinement, or that the  
25 LERF could all be taken out by the CDF.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. DROUIN: We're still treating these  
2 each independently. You're looking at each module as  
3 its own little unit.

4 MEMBER KRESS: Just like it's a reactor  
5 sitting over by itself.

6 MS. DROUIN: Right.

7 MEMBER KRESS: And another reactor here,  
8 another reactor here.

9 MEMBER ROSEN: This would say that if the  
10 licensee thought he might build ten of these  
11 ultimately, but it was only going to build one to  
12 begin with, you need to be careful and make sure that  
13 first one was one-tenth of the LERF and the CDF if he  
14 wanted to preserve the option.

15 MS. DROUIN: That's right.

16 MEMBER ROSEN: To design one that ate up  
17 too much of the --

18 MEMBER KRESS: They're not going to  
19 recommend this option.

20 MEMBER ROSEN: Well, I don't know what  
21 they're going to recommend because I haven't heard  
22 anything.

23 MEMBER KRESS: Oh, okay.

24 MEMBER ROSEN: But I'm just saying, he'd  
25 have to be thinking ahead. He couldn't just plunge

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 right on it and put anything he wants on the site  
2 first. He might chew up all his CDF and LERF.

3 MS. DROUIN: That's correct.

4 MEMBE POWERS: That would be good, Steve,  
5 because then when he built the next one it's going to  
6 be really incredibly safe, and we could shut down the  
7 first one, and --

8 MEMBER ROSEN: You might have to build the  
9 next one out of impervium, which is any way to build  
10 it.

11 MEMBE POWERS: Well, technological  
12 advances there.

13 MEMBER APOSTOLAKIS: The penultimate  
14 bullet confuses me a little bit. Recognize this  
15 accident provision is important regardless of megawatt  
16 power. You mean, so if I have 10 modules for CDF, I  
17 will have 10 to the minus 5, because --

18 MS. DROUIN: That's right, for each one.

19 MR. KING: The logic, George, is that  
20 preventing a core melt accident is important,  
21 regardless whether it's a small reactor or a big  
22 reactor.

23 MEMBER APOSTOLAKIS: But I would say that  
24 this would be true if you kept the 10 to the minus 4  
25 forever. But to divide by 10, then that means that if

1 you have a single unit which is 1000 plus megawatt,  
2 you're willing to tolerate a higher core damage  
3 frequency because it's only one unit. In which case,  
4 I don't know that you recognize that accident  
5 prevention is important.

6 MEMBER KRESS: Well, I think, George, you  
7 are exactly right. I think that 10 to the minus 4 is  
8 predicated on the fact that there's something like 100  
9 reactors out there of a given size, and that that's an  
10 acceptable preventative role with the reactors. If  
11 you had 1000 reactors the same size, you might want to  
12 think about making that goal something smaller.

13 I think we've already said that for  
14 advance reactors, we would probably want to have a 10  
15 to the minus 5 anyway.

16 MEMBER SHACK: Yes, but this would just  
17 make it 10 to the minus 6.

18 MEMBER KRESS: Yeah, but I can't see the  
19 logic to that. I think you want 10 to the minus 5 for  
20 each reactor, because that still gives you the same  
21 concept that you're using now for the 10 to the minus  
22 4.

23 MEMBER APOSTOLAKIS: If you build tomorrow  
24 900 reactors, and you have a total of 1,000 - you  
25 can't really apply these only to the 900. You have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 go back and apply it to all 1,000.

2 MEMBER KRESS: That's right. That's  
3 exactly right.

4 MEMBE POWERS: I have never understood  
5 this argument. And if I am in Connecticut, I am not  
6 threatened at all by the San Onofre reactor.

7 MEMBER APOSTOLAKIS: The Commission was  
8 thinking, at least in my interpretation, in terms of  
9 the risks nuclear power imposing on the nation.

10 MEMBE POWERS: They may well have thought  
11 about that, but they didn't write that.

12 MEMBER KRESS: They never used a CDF,  
13 actually used it in the safety goals.

14 MEMBER SHACK: And expectations.

15 MEMBE POWERS: I remain confused by this  
16 sentiment, because I read the explicit words, and they  
17 talk about an individual. And an individual in  
18 Connecticut is never going to be affected by the San  
19 Onofre reactors.

20 MEMBER KRESS: I think they will be, and  
21 I'll tell you why. You have one more reactor  
22 accident, you're going to shut down all --

23 MEMBE POWERS: He may have a code, but  
24 he's not going to be affected by the radioactivity --

25 MEMBER KRESS: But I think the idea is you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 just don't want to have a core melt. And the  
2 probability of having one has to do with the frequency  
3 times the time, times the number of --

4 MEMBE POWERS: This may be a belief on  
5 your part, because there is nothing in policy that  
6 says that we don't want to have a core melt.

7 MEMBER APOSTOLAKIS: The policy says  
8 nuclear power should not contribute more than one-  
9 tenth of one percent to the accident rate. It didn't  
10 say in Connecticut or in Oklahoma.

11 MEMBE POWERS: Yes, in individual.

12 MEMBER APOSTOLAKIS: How do you interpret  
13 that?

14 MEMBER KRESS: I don't think you would  
15 interpret that part of the safety goal in terms of  
16 this.

17 MEMBER APOSTOLAKIS: Living in the  
18 country. It didn't consider spatial distribution of  
19 individuals.

20 MR. KING: It talks about individuals  
21 around a reactor site.

22 MEMBE POWERS: Yes, it talks about  
23 individuals around the reactor. I don't think any --

24 MEMBER KRESS: I don't think you can use  
25 the QHOs to arrive at this 10 to the minus 4, or 10 to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the minus 5 at all. I think it's a good issue. It  
2 has to do with we don't want to have a reactor  
3 accident.

4 MEMBER APOSTOLAKIS: Yeah, I think that's  
5 --

6 MEMBE POWERS: I know they don't want to  
7 have a reactor accident, but that's not what their  
8 explicit QHO says.

9 MEMBER KRESS: I don't think this has  
10 anything to do with the QHOs. It's an input into the  
11 final thing. I think the reason for having 10 to the  
12 minus 4 is another reason in the QHOs. You could have  
13 the QHOs with lots of CDFs.

14 MEMBE POWERS: I think the answer to that  
15 in debating this issue is to quite referencing  
16 yourself to this surrogate, go back to explicitly what  
17 you're trying to achieve.

18 MEMBER KRESS: Oh, I wouldn't be against  
19 that, but LERFs have been very useful things, I think.

20 MEMBE POWERS: Well, LERF I will agree  
21 with you is a useful thing, because it's indifferent  
22 to the QHOs. It is CDF that causes the problem, and  
23 that's because we don't know exactly how they got CDF.

24 MEMBER KRESS: But I still say the QHOs  
25 cannot be used to back derive this CDF, unless you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 somehow think you can use the CDF as a surrogate --

2 MEMBE POWERS: What I'm telling you is  
3 quit using CDF to adjudicate this decision, and go to  
4 the QHOs.

5 MEMBER KRESS: Yeah, but what I'm saying  
6 there is the QHOs are incomplete in terms of the  
7 expectations. The expectations are also that you  
8 won't have a core melt accident. You don't get that  
9 out of the QHOs.

10 MEMBE POWERS: That may well be your  
11 belief.

12 MEMBER KRESS: Oh, okay.

13 MEMBE POWERS: And we all know that the  
14 beliefs in Tennessee are unusual. The explicit words  
15 don't say that.

16 MEMBER APOSTOLAKIS: Wasn't there a  
17 commissioner who --

18 MEMBE POWERS: Yes, Balinski did all the  
19 back calculations --

20 MEMBER APOSTOLAKIS: And he considered 100  
21 reactor --

22 MEMBE POWERS: He came up with a different  
23 number, yes. But that's not what got written down.  
24 The fact that somebody did an analysis at one time  
25 doesn't carry any weight. What counts is what's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 written down.

2 MEMBER APOSTOLAKIS: The fundamental  
3 problem is, and you touched upon it, is that we have  
4 goals that are in terms of per unit something, per  
5 reactor here, per reactor here basically; whereas, it  
6 should have been the total risk. Then you are  
7 covered. If you have total risk, then everything  
8 flows naturally. The moment you say the individual  
9 around the reactor, the reactor here should be the  
10 thing, then you run into problems like this. You  
11 can't do it on a per unit basis theoretically. In  
12 practice, it works if you have a stable fleet of 100  
13 and some reactors more or less of the same power level  
14 and so on.

15 MEMBER KRESS: Very much what we've got.

16 MEMBER APOSTOLAKIS: That's why it's  
17 important. I'm not saying this to you, but it's  
18 important to understand why certain mathematical  
19 theories are formulated the way they are. If you go  
20 to decision analysis you'll never see anything on a  
21 per unit thing, unless there is convincing evidence of  
22 doing it on a per unit time, or per unit something  
23 doesn't affect anything, that it's constant no matter  
24 what you do. It should be the total impact. And I  
25 think the total impact is on the nation, not the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 maybe the goals are not stated well. You're right,  
2 stated for individual basis, but I think what they had  
3 in mind was the nation.

4 MEMBER KRESS: But still, with respect to  
5 CDF --

6 MEMBER APOSTOLAKIS: That's why --

7 MEMBE POWERS: George, your outrageous  
8 beliefs are on better in Boston than they are in  
9 Tennessee. It's what is explicitly written down that  
10 --

11 MEMBER APOSTOLAKIS: No, but the staff  
12 though -- if you work backwards like you did with LERF  
13 for CDF, you remember you come up with something like  
14 10 to the minus 3. The staff says no, we don't want  
15 any accidents, 10 to the minus 4. Okay. And  
16 everybody said fine.

17 Now when they said we don't want any  
18 accidents, it seems to me they meant anywhere in the  
19 country.

20 MEMBER KRESS: That's what I --

21 MEMBER APOSTOLAKIS: They didn't mean no  
22 accidents in San Onofre, but it's okay to have in  
23 northern --

24 MEMBE POWERS: George, again your beliefs  
25 are fine.

1 MEMBER APOSTOLAKIS: It's not a matter of  
2 belief.

3 MEMBE POWERS: It's the explicit words  
4 that count here.

5 MEMBER APOSTOLAKIS: And, Dana, you cannot  
6 be as literal as you usually are when --

7 MEMBE POWERS: I am perfectly capable of  
8 being as literal as --

9 MEMBER APOSTOLAKIS: Your level of comment  
10 is the same level as your earlier comment, the last  
11 word, predecision. You're going literally.

12 MR. KING: But remember, the Commission  
13 did write down the 10 to the minus 4 CDF. They wrote  
14 it down in a June 15th, 1990 SRM that told us how to  
15 implement the safety goal policy, so they sort of  
16 supplemented the safety goal policy with that SRM. It  
17 was like a six or eight page SRM. It didn't get into  
18 the modular plant issue, it did say core damage  
19 prevention is important, and use a 10 to the minus 4  
20 CDF as a guideline for assessing --

21 MEMBER KRESS: I remember that, and in  
22 their expectations for an increased level of safety  
23 for advanced reactors they said drop that down to 10  
24 minus 5.

25 MR. KING: Well, they said don't do that.

1 The staff recommended drop it down to 10 minus 5, but  
2 the Commission said no, keep it the same, today's  
3 plants, future plants the same.

4 MEMBER APOSTOLAKIS: Yes, that was a  
5 different issue.

6 MEMBER KRESS: Right. That's right.

7 MEMBER APOSTOLAKIS: And with the  
8 expectation --

9 MR. KING: That's an issue we're wrestling  
10 with on the framework --

11 MEMBE POWERS: Well, then you say with the  
12 expectation. How does that figure? That the future  
13 plants will be safer, right?

14 MR. KING: They've come out qualitatively  
15 and said in a policy statement we expect future plants  
16 to be safer, but they never put a number on that.

17 MEMBER KRESS: That true, but they said  
18 use the same procedure and thinking you did with the  
19 evolutionary plants, and those were 10 to the minus 5.  
20 Now I guess that's where I assume that 10 to the minus  
21 5 was the operative number. I could be wrong.

22 MEMBER APOSTOLAKIS: It's the intent that  
23 matters.

24 MEMBER KRESS: Yes.

25 MEMBER APOSTOLAKIS: Right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KING: Expectation.

2 MEMBER KRESS: But still, if you have  
3 three units on a multi-unit site, you wouldn't ask  
4 each one of them to have -- going forward of the CDF  
5 goal, and in the modular place just the same thing.  
6 You ask each reactor to meet the goal on CDF, not a  
7 one --

8 MS. DROUIN: That was option one.

9 MR. KING: I mean, that's the fundamental  
10 question of how to interpret the safety goal policy,  
11 on a per reactor or per site basis. If it's a per  
12 reactor basis, you're exactly right.

13 MEMBER KRESS: Well, I'm ambidextrous on  
14 that. If it's CDF, it's per reactor. If it's LERF,  
15 it's per site.

16 MEMBER APOSTOLAKIS: Yeah. I thought that  
17 was what you were proposing.

18 MEMBER KRESS: That's not what you're  
19 proposing.

20 MEMBER APOSTOLAKIS: Oh.

21 MR. KING: Well we'll go through, and  
22 we'll come back --

23 MS. DROUIN: Why don't we get to Option 3.

24 MEMBER APOSTOLAKIS: Yes, just get to  
25 Option 3.

1 MS. DROUIN: In Option 3, what we're  
2 saying is that when you look at the risk guidelines,  
3 when you look at CDF, that all the modules have to  
4 individually meet the CDF.

5 MEMBER APOSTOLAKIS: And what will that be  
6 now? Can you give me the numbers because I don't want  
7 to have to divide.

8 MS. DROUIN: 1E minus 4.

9 MEMBER APOSTOLAKIS: Each module meets the  
10 10 to the minus 4.

11 MS. DROUIN: If it turns out that the risk  
12 guidelines for the advanced reactors is a CDF of 1E  
13 minus 4, that's what we're saying. And each module  
14 would have to meet the 1E minus 4.

15 MEMBER APOSTOLAKIS: Okay. All right.  
16 Good. Next.

17 MS. DROUIN: Now for LERF, if it turns out  
18 the risk guideline is the 1E minus 5, what we're  
19 saying is that each module has to meet it, and the  
20 combined has to meet it.

21 MEMBER APOSTOLAKIS: But isn't that what  
22 Tom and I just said, and you guys said no?

23 MS. DROUIN: No.

24 MEMBER APOSTOLAKIS: That's what we just  
25 said.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: No, no. I'm saying --

2 MR. KING: If Option 3 is -- if the  
3 overall goal is 10 to the minus 4 for CDF for a plant,  
4 for a modular plant, if it's 10 modules it would be  
5 one-tenth of that, because when you add up --

6 MEMBER APOSTOLAKIS: That's not what Mary  
7 said.

8 MR. KING: I know that's not what Mary  
9 said.

10 MEMBER SHACK: That's what the paper says  
11 though.

12 MR. KING: That's what the paper says.

13 MS. DROUIN: I don't think they said on  
14 the accident prevention they had to each meet it  
15 equally.

16 MEMBE POWERS: No, not equally.

17 MR. KING: The paper says --

18 MEMBER ROSEN: Do you guys want to have a  
19 caucus?

20 MR. KING: Yes, we may want a caucus here.  
21 But the intent of the paper is that each one has to  
22 meet one-tenth of the CDF goal, the overall CDF goal.

23 MEMBER ROSEN: We can always take a break.

24 MR. FLACK: I think that's right. The  
25 idea is not to allow modules to float up to what a CDF

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 would be for a large plant, recognizing that you have  
2 10 modules equivalent to one plant. So you would want  
3 any one of those modules to have a lower frequency of  
4 core damage, so that when the 10 of them are running,  
5 the integrative risk of all 10 running would be no  
6 more or less than one large unit running. I mean, I  
7 think that's the intent of it at the front-end.

8 MEMBER APOSTOLAKIS: Yes, but again, John,  
9 if I think in terms of accident prevention period, the  
10 accident prevention is important, I just don't want  
11 any accident.

12 MR. FLACK: Right. That's the intent.  
13 It's front-end loaded.

14 MEMBER APOSTOLAKIS: Because you have a  
15 larger number now.

16 MR. FLACK: That's right. It's front-end  
17 loaded. It's leaning towards the preventive side.  
18 Now in the mitigation side --

19 MEMBER APOSTOLAKIS: But it's not power.  
20 It's because -- it's the number. I don't care. No,  
21 it's important. Because you have many more now, you  
22 want a lower CDF.

23 MR. FLACK: Right. A lower likelihood of  
24 getting --

25 MEMBER APOSTOLAKIS: Whether it's 100

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 megawatt or 1,000, you really don't care, because what  
2 matters is not to have an accident.

3 MS. DROUIN: Right.

4 MR. FLACK: Right.

5 MEMBER SHACK: WE're in perfect agreement,  
6 George.

7 MEMBER KRESS: No, we're not.

8 MEMBER SHACK: Well, you and I are.  
9 You're not.

10 MEMBER APOSTOLAKIS: You and I what?

11 MEMBER SHACK: We're in agreement.

12 MEMBER KRESS: I'm saying each one of  
13 them, each reactor ought to be treated the same.

14 MR. FLACK: Reactor or module? The module

15 --

16 MEMBER KRESS: Module is a reactor in my

17 --

18 MR. FLACK: Okay.

19 MEMBER KRESS: So when you impose the CDF,  
20 you don't take the 10 to the minus 4 and divide it by  
21 the number of modules.

22 MR. FLACK: Why not?

23 MEMBER KRESS: Because I'm interested in  
24 not having an accident happen nationwide, and that's  
25 equal to the frequency, the CDF times the number of

1 plants, times the time they're operating. That's the  
2 probability of having one, and that's what I'm trying  
3 to prevent. But now when I go to protect the people  
4 around the site from having a -- I use the QHOs. So  
5 then I say well, I've got to add up all of the LERFs  
6 on this site, and the summation has to meet the QFOs,  
7 so I take care of protecting the site people by my  
8 LERF. My CDF is a different animal.

9 MEMBE POWERS: Yes. But, Tom, in this  
10 case, it seems to me when you go to add up those  
11 LERFs, you're really adding up a tenth of the  
12 inventories. In other words, you're going to add them  
13 all up, but you're going to have divided the numbers  
14 by 10 automatically, because --

15 MEMBER KRESS: I eventually am, yes.

16 MEMBE POWERS: So the number is going to  
17 come out the same. It's still going to be 10 to the  
18 minus 5<sup>th</sup> for the site as a whole, because the  
19 inventories are divided.

20 MEMBER KRESS: But now that imposes CDF on  
21 each one of them though, that I should not have  
22 imposed.

23 MEMBE POWERS: I mean, that's George's  
24 hangup, George and Shack are the ones that are going  
25 to be shaft them on the CDF.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: No, but I don't want to do  
2 that. I don't want to shaft them on the CDF, but I  
3 want to make sure they meet the LERF.

4 MEMBE POWERS: The LERF is okay because  
5 the inventory is --

6 MEMBER SHACK: This is what you're trying  
7 to do. You're trying to prevent a reactor accident.  
8 If you've got ten of them, you divide by ten to avoid  
9 the accident. Your goal of avoiding a small core  
10 melt, you know, you have a strong desire to avoid  
11 that. And it's --

12 MEMBER ROSEN: We can argue, and we will,  
13 each of the members' opinion, but I'd like to know  
14 what the staff thinks. And so, John, will you --

15 MS. DROUIN: I don't have a problem with  
16 that.

17 MR. FLACK: All right. She has the option  
18 on the next slide. The recommendation for --

19 MS. DROUIN: Our recommendation is Option  
20 3.

21 VICE CHAIRMAN WALLIS: And is it your  
22 version or Tom King's version?

23 MS. DROUIN: No, it's both our versions.

24 VICE CHAIRMAN WALLIS: Which is?

25 MEMBER ROSEN: CDF divided by ten because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you have ten modules.

2 MS. DROUIN: Right.

3 MEMBER ROSEN: And LERF --

4 MS. DROUIN: And LERF, they each have to  
5 meet it, and the combined has to meet it.

6 MEMBER KRESS: Doesn't the combined  
7 suppose that each would meet it? I mean, they have to  
8 be lower. I mean, you don't have to have both  
9 statements, just the combined --

10 MS. DROUIN: But it is more, but if you  
11 have a combination of modules - and what I mean by  
12 that, say you have a mixture where they're not all the  
13 same size.

14 MR. KING: Or they're not all the same  
15 condition. One can be in refueling, and one can be  
16 operating.

17 MEMBER KRESS: Yes, but --

18 MR. KING: The idea was to allow some  
19 variation among the modules.

20 MEMBER KRESS: Yes, but that's all taken  
21 care of by saying the combined LERF has to meet it.  
22 LERF should have taken into consideration that --

23 VICE CHAIRMAN WALLIS: But doesn't this  
24 depend on the megawatts per module?

25 MEMBER KRESS: It should.

1 MS. DROUIN: Yes.

2 MEMBER KRESS: It should, and instead of  
3 saying LERF, maybe we ought to say QHOS.

4 MR. KING: Yes. Perhaps we could just  
5 talk about the combined effect, and that would take  
6 care of everything. But the idea is --

7 MEMBER KRESS: I think you don't have to  
8 say each one of them.

9 MR. KING: Yes. The real key point is  
10 that it is the combined effect that we're interested  
11 in. But our view is it's the same thing for CDF.

12 MEMBER KRESS: Yes, but I think we're  
13 wrong on that.

14 MEMBER APOSTOLAKIS: I think there is a  
15 problem with it, because again, you have to have a  
16 point of view. Okay. The point of view you have now  
17 is that a 10 to the minus 4 CDF refers to a site. So  
18 if I have 10 modules there, I have to divide by 10.  
19 That's a point of view. It's not in the goals.

20 My point of view, and I think that's what  
21 Tom was arguing also here, is that I don't care how  
22 many you have on the site. It's the total in the  
23 nation. So if I have -- if you take each site and put  
24 10 reactors there, then I go on the order of 1,000  
25 reactors, then I should divide --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: But shouldn't the --

2 MEMBER APOSTOLAKIS: But just because I  
3 did the grand site, it's a perturbation.

4 VICE CHAIRMAN WALLIS: George, I disagree.  
5 It's all risk benefit. If you get more megawatts,  
6 then you can tolerate more risk. It must be. It's  
7 balancing risk versus --

8 MEMBER APOSTOLAKIS: Not when it comes to  
9 prevention. Preventing nuclear accidents is a  
10 fundamental objective by itself, regardless of the  
11 power you get out of it.

12 VICE CHAIRMAN WALLIS: If you have a  
13 reactor that produces no power --

14 MEMBER APOSTOLAKIS: It's the LERF that  
15 depends on that.

16 MEMBER KRESS: Yes.

17 MEMBE POWERS: Well, let's just pursue  
18 something a little further. Suppose I have ten  
19 reactors on this site, each reactor is so small that  
20 it can never violate the 10 CFR Part 100 siting  
21 criteria. Okay. Then I should be willing to tolerate  
22 all kinds of accidents there.

23 MEMBER APOSTOLAKIS: And I'm saying no,  
24 because even a small accident, people don't care.  
25 It's the same thing with security, for heaven sake.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 If you hit the fence, all you're going to see on CCN  
2 is nuclear plant was attacked.

3 VICE CHAIRMAN WALLIS: How do you know?

4 MEMBER APOSTOLAKIS: The fact that --  
5 well, how do I know, because I live here. Don't you  
6 know that anything that starts with N has a problem,  
7 so I think the prevention policy is not to find  
8 yourself in that situation. It has nothing to do with  
9 whether you produce 1,000 megawatt or 100. You just  
10 don't want anything that is called nuclear accident,  
11 and that's why we even tolerate the 10 to the minus 4  
12 instead of 10 to the minus 3, which would be  
13 consistent with the goal.

14 MEMBER KRESS: That's exactly right.

15 MEMBER APOSTOLAKIS: Yes. It's a  
16 different objective, it's a fundamental objective  
17 independently of the risk.

18 MEMBER KRESS: Absolutely. That's why you  
19 can't get it out of the QHOs.

20 VICE CHAIRMAN WALLIS: George, you're  
21 going against all the principles of PRA, were you look  
22 at consequences, say no accident whatsoever. If the  
23 accident has more consequences, you're more careful  
24 about preventing it. Right?

25 MR. KING: Having an accident to begin

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 with is a consequence, forget the amount of radiation.

2 MEMBER KRESS: That's part of defense-in-  
3 depth and --

4 MEMBE POWERS: Psychological, financial.

5 MEMBER APOSTOLAKIS: The goals of Mary's  
6 -- the project that Mary is -- K minus 1 project, on  
7 the goals it says -- defense-in-depth says that for  
8 core damage frequency you have 10 to the minus 4, and  
9 therefore, use 10 to the minus 5. And there is a not  
10 so subtle assumption there that prevention is a  
11 thousand times more important than mitigation, 10 to  
12 the minus 4, 10 to the minus 5, something like that.  
13 So I think it's a fundamental objective not to have an  
14 accident, period. I don't care how much power you've  
15 got --

16 VICE CHAIRMAN WALLIS: Then you should  
17 make it 10 to the minus 10 or something.

18 MEMBER APOSTOLAKIS: You could, if you  
19 could.

20 MEMBER KRESS: It's a policy statement,  
21 and there's no technical reason for it. It's what  
22 people think is realistically achievable, and  
23 acceptable to the general public.

24 VICE CHAIRMAN WALLIS: Then you better ask  
25 the public and not this group of people here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: The public is the  
2 five commissioners. That's what the public is.

3 MR. KING: It's clearly a policy decision,  
4 and that's why it's gone to the Commission.

5 MEMBER APOSTOLAKIS: Good.

6 MEMBER KRESS: It's policy.

7 MEMBER APOSTOLAKIS: So do I understand  
8 where you stand, and the gentleman stands.

9 VICE CHAIRMAN WALLIS: Yes. I'd like the  
10 rationale from the staff. I haven't heard much  
11 rationale yet that I believe, so is there some  
12 believable rationale that you have that you can  
13 persuade us with?

14 CHAIRMAN BONACA: Yes, we heard the other  
15 rationales.

16 VICE CHAIRMAN WALLIS: The staff's thought  
17 about it much more than we have perhaps, so maybe you  
18 could give us a convincing argument.

19 MR. KING: Well, the rationale is that  
20 prevention of an accident is important regardless of  
21 the reactor size. And when you're adding a group of  
22 modules all at one time to a site or over some period  
23 of time to a site, you don't want the likelihood of a  
24 core melt accident on that site to all of a sudden  
25 jump up.

1 VICE CHAIRMAN WALLIS: It says megawatt  
2 thermal of modules considered in one line. In the  
3 next line it says it's regardless of power, so I don't  
4 understand this slide.

5 MEMBER APOSTOLAKIS: Eleven?

6 VICE CHAIRMAN WALLIS: You weren't  
7 considering megawatts at all.

8 MEMBER APOSTOLAKIS: Eleven.

9 VICE CHAIRMAN WALLIS: If you're not  
10 considering megawatts, that's a false statement.

11 MEMBER APOSTOLAKIS: That's exactly what  
12 it said.

13 MR. KING: One is talking about accident  
14 prevention.

15 VICE CHAIRMAN WALLIS: It says megawatts  
16 considered, and then two lines down it says regardless  
17 of megawatts.

18 MEMBER APOSTOLAKIS: This is mitigation,  
19 the other is LERF.

20 MS. DROUIN: Action is important.

21 MR. KING: Yes, regardless of plant size.

22 MEMBER KRESS: Megawatts will be  
23 considered because when you calculate CDF, it enters  
24 into the calculation. But you're not explicitly  
25 putting it in the acceptance criteria.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KING: Right. But accident mitigation  
2 does have dependence upon source term, which is  
3 dependent upon plant size, so we're allowing the  
4 analysis to give credit for that.

5 CHAIRMAN BONACA:: Yes, and this slide is  
6 confusing because it doesn't specify that the  
7 statements relate to LERF.

8 MR. KING: Yes, that last one doesn't.  
9 You're right. Well, it says accident mitigation the  
10 last two words.

11 MEMBER APOSTOLAKIS: Yes, you have to know  
12 that.

13 VICE CHAIRMAN WALLIS: I don't understand  
14 this at all. You've got three conflicting statements  
15 about megawatt thermal. Are you considering megawatt  
16 thermal or not? Are you giving credit for --

17 MR. KING: For accident prevention, no.  
18 For accident mitigation, yes.

19 VICE CHAIRMAN WALLIS: Well, that's not  
20 stated. I mean, it's just three -- it's not spelled  
21 out in this slide anyway.

22 MEMBER KRESS: That's what they mean.

23 MEMBER APOSTOLAKIS: I guess the only  
24 minor disagreement in I think Tom's and my point of  
25 view and your's, is that you take the number of

1 reactors or modules at the site, and you divide the  
2 goal by that. I would take a broader view and say the  
3 total number in the country should be the number you  
4 divide the 10 to the minus 4 by. Now you might say  
5 well, I don't know what it is, and so on. But if you  
6 -- yes. Yes, the total number in the country, not on  
7 that site.

8 MEMBER KRESS: Absolutely, George. You're  
9 absolutely right.

10 MEMBER APOSTOLAKIS: You could disagree,  
11 maybe, but don't --

12 MEMBER KRESS: Well, from what I hear, I  
13 may be adding comments to --

14 MEMBER APOSTOLAKIS: I'm not sure that's  
15 a critical point though. Do you think it's a critical  
16 point? Well, it is --

17 MEMBER KRESS: I think it is because --

18 MEMBER APOSTOLAKIS: Because they assumed  
19 there would be 1,000 reactors.

20 MEMBER KRESS: But I think the industry  
21 would be up in arms over that.

22 MEMBER APOSTOLAKIS: I think everybody  
23 meets that, 10 to the minus 5. Now one of them, who  
24 was it, IG or First Energy -- these guys are going to  
25 have a problem.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BONACA:: I understand where  
2 you're coming from, but you can go to the limit,  
3 assuming you have your module on that site. Okay.  
4 And then you say each one of them is 10 to the minus  
5 4 because -- well, you know, we're making the  
6 likelihood of core damage on that site very high.

7 MEMBER APOSTOLAKIS: No, no, no. That's  
8 not what we're saying. We're not saying you keep the  
9 10 to the minus 4. We're saying you take the 10 to  
10 the minus 4 and divide by the total number of modules  
11 in the country.

12 MEMBER KRESS: That's exactly what I --

13 MEMBER APOSTOLAKIS: Not on one site.

14 MEMBER KRESS: If 10 to the minus 4 is  
15 acceptable for 100 reactors, you've got the right  
16 show, what you need right there.

17 MEMBER SHACK: Back to the reactors, every  
18 time you add a new --

19 MEMBER APOSTOLAKIS: It's a problem.

20 MEMBER KRESS: Well, no, that's a problem.  
21 So what you do is you make for advance reactors, you  
22 make it 10 to the minus 5 and say now when you step up  
23 to 1,000 reactors, which we're never going to get, so  
24 we're taking care of the problem. That's the way you  
25 deal with the fact that you change it every time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 MEMBER APOSTOLAKIS: And then you can say  
2 the existing reactors are grandfathered.

3 MEMBER KRESS: Yes. Exactly right. You  
4 don't have to backfit.

5 MEMBER APOSTOLAKIS: Look, I don't think  
6 this is more stranger than what they're proposing.

7 VICE CHAIRMAN WALLIS: Well, could you  
8 explain to me --

9 MEMBER KRESS: I think it's the right  
10 thing. It makes a lot of logic and technical sense,  
11 and properly I think interprets the --

12 MEMBER APOSTOLAKIS: It could be an Option  
13 4.

14 VICE CHAIRMAN WALLIS: So if I put 100  
15 modules on a site --

16 MEMBER KRESS: Each one of them has a 10  
17 to the minus 5.

18 VICE CHAIRMAN WALLIS: Each one produces  
19 --

20 MEMBER APOSTOLAKIS: Ten to the minus 6  
21 now.

22 VICE CHAIRMAN WALLIS: -- ten megawatts.  
23 Each of them has to have a 10 to the minus 6 CDF?

24 MEMBER KRESS: Sure.

25 VICE CHAIRMAN WALLIS: So the group of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           them is equivalent to one.

2                   MEMBER KRESS:   Yeah.

3                   MEMBER ROSEN:   Right.

4                   VICE CHAIRMAN WALLIS:   And then how about  
5 LERF, same thing?

6                   MEMBER KRESS:   No, no, no.   That's what  
7 they're saying, not George and I.  I said each one of  
8 them has to have 10 to the minus 5.  That's what  
9 George and I are saying.

10                   MEMBER APOSTOLAKIS:   They're saying that  
11 rather than dividing by the group, you divide by the  
12 number in the country.

13                   MS. DROUIN:   We're looking at in a site,  
14 not across the country.

15                   MEMBER APOSTOLAKIS:   They're looking at it  
16 on a site basis, we're looking at it on a nation  
17 basis.

18                   VICE CHAIRMAN WALLIS:   But if you put 100  
19 modules on a site, does the public believe you are now  
20 doubling the risk of reactor accidents?

21                   MEMBER KRESS:   You take care of that with  
22 your LERF.  You protect them with your LERF.  You have  
23 to add up all of the LERFs.

24                   MEMBER APOSTOLAKIS:   Yeah, the LERFs will

25           --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: That takes care of  
2 protecting the people around the site. The CDF --

3 VICE CHAIRMAN WALLIS: So safety has to do  
4 with LERF, and sometimes psychological --

5 MEMBER KRESS: Except there is this  
6 question with balance in your LERF calculation. You  
7 still have to balance CDF properly, but we've already  
8 decided what that's going to be.

9 MEMBER APOSTOLAKIS: I mean, they're not  
10 independent. It could be another interpretation.

11 MEMBER KRESS: I mean, when we calculate  
12 this --

13 CHAIRMAN BONACA:: That's more a practical  
14 approach, however.

15 MEMBER KRESS: When you take 10 modules,  
16 each one of them with the same CDF and calculate the  
17 LERF, you don't just take that one CDF. You use the  
18 10 times that CDF, times some sort of way you can fail  
19 their containments, whatever it says, so you do add up  
20 the CDFs when you calculate the LERF.

21 MEMBER SHACK: But you're going to have a  
22 hard time explaining to the guy that he's 10 times  
23 more likely to have a nuclear accident in his  
24 neighborhood than the guy over there is, even though  
25 you tell him the LERF is going to be the same.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: Well, we do what's right,  
2 not what has appearances of --

3 MEMBER SHACK: The people have certain  
4 expectations.

5 MR. KING: Accident prevention is right.  
6 I don't see how you can say that's not right.

7 MEMBER KRESS: Well, we're preventing it  
8 by --

9 VICE CHAIRMAN WALLIS: What's right is  
10 what he thinks is right, not what you think is right  
11 for him.

12 MEMBER ROSEN: And that's democracy.

13 MEMBER APOSTOLAKIS: How do you know what  
14 he thinks?

15 CHAIRMAN BONACA:: Well, I think  
16 instinctively he believes more in prevention than --

17 MEMBER APOSTOLAKIS: I don't think you  
18 guys should -- I mean, I don't understand this  
19 argument he thinks this individual. These people are  
20 represented by the five commissioners, period. All  
21 you have to do is convince the commissioners.

22 MEMBER KRESS: That's right.

23 MEMBER APOSTOLAKIS: We don't have to go  
24 out on the street and start asking people what do you  
25 think. That's the way the system works. The people

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are the commissioners, so if the commissioners approve  
2 this, then it's fine. I mean, let's not talk about --  
3 there is no end to this.

4 VICE CHAIRMAN WALLIS: And you've got to  
5 give them a good rationale.

6 MEMBER APOSTOLAKIS: And that's what this  
7 meeting is all about.

8 CHAIRMAN BONACA:: All right. I think --

9 MEMBER SHACK: This inspires confidence,  
10 I'll tell you.

11 MEMBER APOSTOLAKIS: What the staff is  
12 proposing is similar to what Tom and I think is right,  
13 if you assume that you will have 1,000 of those.  
14 Right? Because they divide by 10. And in that sense,  
15 they are saying the 100 --

16 MEMBER SHACK: You're sharing the risk out  
17 over all the reactors.

18 MEMBER APOSTOLAKIS: Yes.

19 MEMBER SHACK: These guys are really  
20 keeping the site --

21 MEMBER APOSTOLAKIS: It's the same thing.  
22 It's exactly the same thing.

23 MEMBER SHACK: No, it's not the same  
24 thing.

25 MEMBER APOSTOLAKIS: Because then the next

1 step would be okay, I have 100 units and now they're  
2 a little higher, I can give an argument that I don't  
3 have to worry about them. I don't want to backfit.  
4 Okay. Of course, some of them are above 10 to the  
5 minus 4, but we don't --

6 CHAIRMAN BONACA:: But the other plants  
7 all exist already, but this guy here wants to put 20  
8 modules on his location. I can do something about it.  
9 Okay.

10 MEMBER APOSTOLAKIS: Yeah, but that  
11 something has to have some basis.

12 MS. DROUIN: George, I mean if you've got  
13 two different sites and each site has 10 modules, we  
14 are saying that they have to meet it -- each module at  
15 each site has to meet it at 1E minus 5.

16 MEMBER APOSTOLAKIS: Yes.

17 MS. DROUIN: Because we're looking at it  
18 on a site basis. If I understand what you're saying,  
19 then they'd have to meet at 5E minus 6, because you're  
20 saying you want to take it across everything, which  
21 would be a total of 20 --

22 MEMBER APOSTOLAKIS: No.

23 MS. DROUIN: Well, that's what it sounded  
24 like you were saying.

25 MEMBER APOSTOLAKIS: Now you will be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 higher than the minus 5, because in my case I'll  
2 divide by the total.

3 MEMBER RANSOM: All sites.

4 MEMBER APOSTOLAKIS: All sites, 140. You  
5 divide by 10, but I would divide by 100 and whatever.

6 MS. DROUIN: Okay. But we are not looking  
7 at the current set. We are just answering -- the  
8 question posed to us by the Commission was what do we  
9 do with the modules. It does have implications.  
10 That's a separate policy issue if you want to now  
11 bring in the current set of plants. But we were just  
12 asked to look at the integrated risk across the set of  
13 modules, and we answered it in that very narrow  
14 context.

15 Now if you want to extend that to the site  
16 where you have current plants, that's a separate  
17 issue, and we don't have a recommendation for that.

18 MEMBER APOSTOLAKIS: Let me give you my  
19 thinking on --

20 MEMBER KRESS: When you do this, and you  
21 have say 10 modules on one site, and you take one-  
22 tenth CDF for each one of them, and somebody at  
23 another site builds three identical sets of these  
24 modules, now you're going to have one-third of the CDF  
25 for each.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. DROUIN: Correct.

2 MEMBER KRESS: It doesn't make sense.

3 VICE CHAIRMAN WALLIS: It does to the guy  
4 who's living there.

5 MEMBER KRESS: No, it doesn't. He's  
6 smarter than that.

7 VICE CHAIRMAN WALLIS: No. If you're  
8 going to put 100 modules, he's going to see 100  
9 reactors in my backyard, and --

10 MEMBER KRESS: Well, he's going to ask  
11 what risk am I being put to, and you're going to tell  
12 him the LERF value.

13 MEMBER APOSTOLAKIS: He's never heard of  
14 LERF.

15 MEMBER KRESS: LERF in terms of .1 percent  
16 of his chances of dying some other way.

17 MEMBE POWERS: Tom, you're absolutely  
18 correct. It's not going to take long for that guy to  
19 realize that he's getting three times the core banding  
20 frequency that his neighbor down the road is being  
21 subjected to per module.

22 MEMBER KRESS: That's right. He's the guy  
23 that's going to complain.

24 MEMBE POWERS: He's going to complain like  
25 crazy.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: Yes.

2 MEMBE POWERS: And if George --

3 MEMBER KRESS: It works both ways.

4 MEMBE POWERS: And since George is worried  
5 about the headlines in the "Boston Globe", this guy is  
6 going to get headlines in the "Boston Globe" as big as  
7 the --

8 MEMBER KRESS: Absolutely. And so you  
9 pick out a number and you apply it to all of it, and  
10 it would be justified on the basis of total number and  
11 expectations for increased safety. My guess would be  
12 that would be 10 to the minus 5 for every CDF for  
13 every module, because I've not used 10 to the minus 4  
14 because there is an expectation of increased safety  
15 for new plants. And you're planning on increasing  
16 these, so I would choose 10 to the minus 5, and say  
17 that's what our recommendation is.

18 MEMBER APOSTOLAKIS: Or even higher. It  
19 could be higher because --

20 MEMBER KRESS: It could be higher, you  
21 know. It could still be 10 to the minus 4.

22 MEMBER APOSTOLAKIS: Let me give you this  
23 line of thinking. We want to prevent accident  
24 anywhere. Right now it's 10 to the minus 4 per  
25 reactor. We have 100 units. That implies that per

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 year we want the probability of 1 percent or less of  
2 an accident anywhere.

3 MEMBER KRESS: That's right.

4 MEMBER APOSTOLAKIS: And that's  
5 independent of the number of units. So if now my  
6 number of units become 1,000, then on a per unit  
7 basis, it should be 10 to the minus 5, to preserve the  
8 1 percent. If I have 500, it would be whatever it is,  
9 to 10 to the minus 5.

10 MEMBER KRESS: Yes. And my point was that  
11 the 1 percent, I think rethinking that and having  
12 second thoughts about it, it ought to be better than  
13 that for new reactors, so let's make it 10 to the  
14 minus 5.

15 MEMBER APOSTOLAKIS: No, I preserve the 1  
16 percent.

17 MEMBER KRESS: No, what I'm saying is you  
18 really shouldn't because the Commission is having  
19 second thoughts about that being appropriate.

20 MEMBER APOSTOLAKIS: The 1 percent is  
21 anywhere, from any reactor.

22 MEMBER KRESS: I know, but they're having  
23 second thoughts about that, so let's make the new  
24 reactors 10 to the minus 5.

25 MEMBER APOSTOLAKIS: Oh. And that's a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 factor of 2.

2 MEMBER KRESS: Yes.

3 MEMBE POWERS: Let just inject a comment  
4 that Mr. Wallis would likely make. You guys can't  
5 pull these numbers out of the air. They have economic  
6 consequences. I mean, you can't just grab at some  
7 number and say let's make it this.

8 MEMBER APOSTOLAKIS: No, I'm just  
9 inferring from what the policy of the agency is right  
10 now. I'm not grabbing anything. I'm saying you have  
11 a 10 to the minus 4 goal, 100 reactors. That tells me  
12 that on a per year basis, it's 1 in 100. You are  
13 working with that. That has been the policy for 40  
14 years. Now if you want to go to 500 reactors, or  
15 1,000 reactors, I want to preserve it 10 to the minus  
16 2 per year, so I have divide by --

17 MEMBE POWERS: Who said that you wanted to  
18 preserve the 1 percent? I mean, where is that  
19 written?

20 MEMBER APOSTOLAKIS: Make some assumption,  
21 okay. I don't want to increase it.

22 VICE CHAIRMAN WALLIS: But, George, here's  
23 one of the most important decisions you can make for  
24 people living near a plant. You're making it just by  
25 pulling 1 percent, or a factor of 10 here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I'm amazed that you  
2 say that, because I'm not making any decision. I'm  
3 just trying to analyze the implications of the  
4 recommendations, and the five Americans who represent  
5 the public will make the decision.

6 MR. FLACK: But getting back to the  
7 option, there's a global issue and there's a local  
8 issue, you might say. We're looking at the local  
9 issue in this paper; the integrated risk when you  
10 build a number of modules at a site. And how do you  
11 address that risk as coming forward with a licensing  
12 application for that site, for that plant that now  
13 consists of X number of modules? How do you integrate  
14 that risk to come up with criteria, and that's the  
15 option that's being chosen.

16 MEMBER APOSTOLAKIS: I think there is a  
17 misunderstanding around the table, at least on my  
18 part. I know Tom has his own views. I'm not saying  
19 this is wrong. All I'm saying is there is an equally  
20 plausible, or perhaps a little more plausible  
21 interpretation of the goals and the policies, the  
22 existing policies, that could lead to an Option 4  
23 according to what we've been arguing. I'm not  
24 criticizing this. There is a big difference.

25 MR. FLACK: I understand, but --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I mean, you gave  
2 Option 1. Now come on, what was Option 1? Option 1,  
3 as I recall is --

4 MR. FLACK: Let's treat them all like we  
5 do today with regular plants, and --

6 MEMBER RANSOM: Well, what do you today if  
7 you have like four plants on --

8 MEMBER APOSTOLAKIS: Nothing.

9 MR. FLACK: Well, we have three plants at  
10 a site, Paolo Verde -- and I think it was an option to  
11 build two more, correct me if I'm wrong, so we would  
12 just look at each plant.

13 MEMBER RANSOM: It's per plant, not per  
14 site.

15 MR. FLACK: And we'd consider that in the  
16 context of the safety goals, and recognizing that if  
17 the plant is meeting the safety goals in every one of  
18 those plants, it's safe enough, basically is the way  
19 we do business. That's in the context of a policy.  
20 It's not a requirement now, it's a policy. We look  
21 for the --

22 MEMBER RANSOM: Well, it's a little hard  
23 to see the difference between that and say multiple  
24 modules.

25 MR. FLACK: Well, the only thing with

1 multiple modules is that you could have many more of  
2 those that generate the same quantity of electricity.  
3 So the question is okay, now instead of coming forward  
4 with one large plant, you come forward with 10 smaller  
5 ones. What is the integration of that risk of 10  
6 smaller ones, and how should we perceive that risk if  
7 we're going to take that and break it down to each  
8 module? And I think that was the question at hand,  
9 how are we going to deal with that issue.

10 MEMBER RANSOM: I understand that, but --

11 MR. FLACK: And that's what this is about.  
12 Now if we talk about other plants across the nation,  
13 that's a bigger issue.

14 MEMBER APOSTOLAKIS: Okay. Let me ask  
15 another question. I said that this is not wrong,  
16 nothing is wrong in this case. This is a different  
17 kind of argument. Are you saying that what Tom and I  
18 are proposing is wrong?

19 MR. FLACK: Oh, no. I'm just trying to say  
20 there's a difference between what we're moving forward  
21 with here.

22 MEMBER APOSTOLAKIS: Right, there is a  
23 difference.

24 MR. FLACK: And this option that you  
25 propose.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: So what would be the  
2 impediment to putting it as an Option 4, the fact that  
3 we don't have time.

4 MR. FLACK: Well, it expands the scope to  
5 something more than just modules.

6 MEMBER APOSTOLAKIS: It's that you don't  
7 have time, John.

8 MR. FLACK: Well, that's what I mean,  
9 expanding the scope --

10 MEMBER APOSTOLAKIS: Because you don't  
11 just sit down and write an extra section. I mean, it  
12 has to be reviewed by N plus 1 people.

13 MR. FLACK: Yes. Of course.

14 MEMBE POWERS: John, let me ask you this  
15 question. You're dealing with a local question. Why  
16 are you dealing with it in terms of CDF? Why don't  
17 you just go to BRISK?

18 MR. FLACK: I would say in the -- although  
19 it's a sort of -- I mean, you might call it a cop-out.  
20 It's a lot easier to deal with it as an engineering,  
21 the engineering aspect is easy to deal with at that  
22 type of consideration, and provided it's consistent  
23 with that goal. I'm not trying to say that we're  
24 moving away from that goal. We understand that goal  
25 is there, but it's a much more difficult goal to work

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 with when you're doing a review of a plant.

2 MEMBE POWERS: But what I'm thinking is --  
3 my thinking would go this way. With the risk, looking  
4 at the QHO and trying to deal with that, I can get a  
5 consistent answer. And then from that, I can figure  
6 out a way to calculate the CDF that I want to use. I  
7 think CDF is getting you in trouble because this  
8 doesn't have any logical connection -- any  
9 quantitative, easy to understand connection with QHO.  
10 It has a connection with things that George has been  
11 talking about, the time, the reactors in the nation  
12 times the number of years they operate. And that's  
13 fine if you were working on the global issue. But  
14 since you're working on the local issue, I think you  
15 have to come back to the QHO. Once you get that  
16 answer from the QHO, then calculate what the  
17 appropriate CDF is.

18 MEMBER APOSTOLAKIS: But I would not --  
19 risk is not the only fundamental objection.

20 MEMBE POWERS: I don't argue with that,  
21 but his ground rule is he wants to work the local  
22 issue.

23 MEMBER APOSTOLAKIS: I understand that.

24 MEMBE POWERS: Okay. And I think where  
25 you run into logical traps is working a parameter

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that's based on the global issue and trying to apply  
2 it in the local issue. It gets around that if you  
3 would just go and work the QHO approach, and then once  
4 he gets that answer, say what does that imply about  
5 the CDF, because I know kind of how they got to it.  
6 And you could do preservations of some point --

7 MEMBER APOSTOLAKIS: We do this for LWRs,  
8 as you remember, Sherrie did that for us, because he  
9 went back to 11.50 and other standards, and found that  
10 the contribution of the containment, for example, was  
11 a certain number. Okay. So you can work backwards  
12 now from the QHOs to the large release, and then he  
13 looked again and said well, you know, from core damage  
14 to release there is a factor of X, and work backwards.  
15 With the new designs you don't have --

16 MEMBER KRESS: You don't have that  
17 containment.

18 MEMBER APOSTOLAKIS: You haven't done the  
19 PRAs, you don't know what the factor will be. It will  
20 be difficult to work backwards as we did --

21 MEMBE POWERS: But the QHO, you can come  
22 back and you get a LERF. Okay?

23 MEMBER APOSTOLAKIS: If you know how much  
24 you buy from the containment.

25 MEMBE POWERS: No, no. I can get a LERF.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Okay. So then I can say okay, well the LERF is  
2 typically a tenth of the CDF --

3 MEMBER KRESS: That's an assumption.

4 MEMBER APOSTOLAKIS: See, that's an  
5 assumption for LWRs.

6 MEMBE POWERS: That is a way of doing it.  
7 Okay. And you can make your judgment on what CDF is,  
8 but you come up with a LERF. It's quantitatively  
9 related to the QHO.

10 MEMBER APOSTOLAKIS: You're right.

11 MS. DROUIN: Okay. If you remember on our  
12 slides --

13 MEMBER APOSTOLAKIS: We did that for LWRs.  
14 It was 10 to the minus 3, and then they reduced it by  
15 10. Sherrie did it for us.

16 VICE CHAIRMAN WALLIS: The LERF is a local  
17 thing. It's the guy who's actually living near the  
18 plant. And what you're doing here is you're balancing  
19 the whole nuclear game, is this is risk/benefit -  
20 whose risk, whose benefit? Are you going to look at  
21 it as a nationwide thing, or are you going to look at  
22 it --

23 MEMBER APOSTOLAKIS: You must because the  
24 person, the guy --

25 VICE CHAIRMAN WALLIS: Well, I don't know.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 You have to enunciate some principles. I'm telling  
2 you, the safety of the person living next to the plant  
3 is paramount. Therefore, we will decide on LERF. Or  
4 it's a risk benefit spread over the whole nation.  
5 Therefore, we going to have some other principle --

6 MEMBER KRESS: The risk benefit has  
7 already been done.

8 MEMBER APOSTOLAKIS: I'm not introducing  
9 any new principles.

10 CHAIRMAN BONACA:: Well, it seems to me  
11 that we understand the differences of a plant, and  
12 there is another -- I mean, we have little more than  
13 half an hour left. I think we should move on, because  
14 I see that --

15 MS. DROUIN: The thing I'd like to make  
16 clear is that we were using CDF and LERF as examples  
17 of our accident prevention in mitigation.

18 MEMBER KRESS: Yes, we understand that.

19 MS. DROUIN: And if you go through the  
20 paper, you don't see the words CDF and LERF there, and  
21 they weren't on our slides.

22 MEMBER KRESS: That's right.

23 MS. DROUIN: And as we point out on this  
24 last slide here, there's guidance that's going to have  
25 to be developed. What we're trying to say with Option

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 3 is that in Option 3, that we want to focus in on  
2 accident prevention, because we think it's important.  
3 We want to prevent accidents. I think that's a goal  
4 you can't go away from. And when we look at accident  
5 mitigation, we want to take into account on the  
6 accident mitigation the size of the reactor. And  
7 that's the recommendation we're making conceptually.  
8 And there's going to have to be details worked out.

9 MEMBER KRESS: When somebody comes in and  
10 says I want to build a modular reactor system on this  
11 site, are you going to require him to tell you what  
12 the maximum number of modules he's going to have on  
13 there?

14 MS. DROUIN: This is a detail that would  
15 have to be worked out.

16 MEMBER KRESS: That's one detail because  
17 that fixes the number of the CDF and the LERF --

18 MR. KING: I think the way the ESPs are  
19 now, they put down the maximum number of megawatts  
20 thermal, and then you can divide into that however big  
21 your module is. That'll tell you how many modules you  
22 can have. I think that's the way they're coming in.  
23 Jerry is shaking his head yes over there. So they  
24 don't say number of modules, they say total number of  
25 megawatts thermal.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: Say they're going to build  
2 two modules this year, add two more at the end of five  
3 years, and add two more five years from now, and we've  
4 accounted for the risk of all of those starting today,  
5 which doesn't seem like it's developed consistent to  
6 me.

7 MEMBER APOSTOLAKIS: So the pebble bed  
8 reactor will have a particular design, which may turn  
9 out to be okay to be licensed at Site X, but not Site  
10 Y. That's what you're saying, because at Site Y they  
11 may want to put more. That doesn't make sense to me.

12 MEMBER KRESS: That doesn't make sense.

13 MEMBER APOSTOLAKIS: It doesn't make  
14 sense. It has to be nationwide.

15 MEMBER KRESS: Absolutely.

16 MEMBER APOSTOLAKIS: Anyway, I think I've  
17 said my peace.

18 MEMBER KRESS: I think it's maybe two  
19 against I don't know how many.

20 MEMBER APOSTOLAKIS: Galileo was right.

21 MEMBER SHACK: Burning is fun.

22 MR. KING: Okay. Are we ready to move on  
23 to the next one? Okay.

24 MEMBER APOSTOLAKIS: I still want to  
25 emphasize that these are matters for interpretation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I'm not saying that what you're doing is wrong. It's  
2 just another way of interpreting.

3 MR. FLACK: Okay. We recognize that.

4 MEMBER APOSTOLAKIS: You think what I'm  
5 saying is wrong?

6 MR. FLACK: Okay. Are ready to move on?

7 MR. RUBIN: Okay. Fortunately this next  
8 topic is a lot less controversial than the one we're  
9 leaving. I'm Stuart Rubin. I'm with the Office of  
10 Research Advanced Reactors. This next topic is  
11 essentially a status report on the work of the staff  
12 to develop options, as was mentioned, in the area of  
13 non-light water reactor containment and functional  
14 performance requirements and criteria. It's been  
15 referred to as confinement versus containment but the  
16 Commission has kind of broadened that to be a more  
17 functional look at containment requirements. This is  
18 the third meeting, I believe, with the ACRS on this  
19 subject. Next slide.

20 MEMBER APOSTOLAKIS: What am I missing  
21 here? The feedback is verbal.

22 MR. RUBIN: Well, because we are --

23 MEMBE POWERS: George, how do you get  
24 feedback other than verbally?

25 MR. RUBIN: Well, I mean as opposed to in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 writing in your letter.

2 MEMBER APOSTOLAKIS: No, no, no. He's  
3 right.

4 MEMBE POWERS: You meant oral.

5 MEMBER APOSTOLAKIS: Don't you know you  
6 have a Mr. Literal over there.

7 MR. RUBIN: And I thought this would be no  
8 controversial. I was wrong.

9 MEMBER ROSEN: Maybe you could get here on  
10 Saturday morning when things go smoother.

11 MEMBER APOSTOLAKIS: No, no. John was  
12 about to say --

13 MR. RUBIN: The letter is really -- what  
14 it's requesting is on the integrated risk part. Okay.  
15 Let's go to the next slide. I think we covered that.

16 Again, just by way of background, the  
17 staff in the last SECY paper proposed two options.  
18 One would have required a conventional type  
19 containment for non-light water reactors. The other  
20 option was to allow the possibility of other kinds of  
21 containments provided that there were performance  
22 requirements and criteria that would be established  
23 and would be met.

24 VICE CHAIRMAN WALLIS: Why is it retained  
25 pressure rather than the content, they're assigned to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 retain the fission products.

2 MR. RUBIN: Yes.

3 VICE CHAIRMAN WALLIS: There's nothing  
4 magical about pressure. Pressure doesn't hurt  
5 anybody.

6 MR. RUBIN: Yes. I wouldn't disagree with  
7 that, and so --

8 MEMBER KRESS: That's differentiated from  
9 containment, as you will maybe filter and vent.

10 MR. RUBIN: Right, to just bottle it up.

11 MEMBER KRESS: But, you know, the idea is  
12 --

13 MR. RUBIN: Right. Bottle up everything  
14 that might be released from the reactors. The staff  
15 recommended the latter option which it had done in  
16 previous years, and requested a policy decision, as  
17 well as requested permission to proceed to actually  
18 develop those requirements and criteria.

19 Basically, this Commission did not agree  
20 with either path. They basically felt there wasn't  
21 enough information for them to make a decision, and  
22 they really weren't sure whether or not if Option 2,  
23 if it led to a confinement-type building for an ACGR,  
24 whether or not that would be acceptable. So the staff  
25 was asked by the SRM to give options, options for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 functional performance requirements for the  
2 containment of non-light water reactors, and certainly  
3 ACGRs within that.

4 They specifically asked that we consider  
5 the fuel, and core cooling systems in our analysis,  
6 and we interact with industry and other stakeholders  
7 in developing these options.

8 MEMBE POWERS: Didn't the Commission  
9 recognize that the largest reactors this country has  
10 ever built had confinements?

11 MEMBER KRESS: That's the N reactor.

12 MEMBE POWERS: N reactor and C reactor.

13 MEMBER KRESS: C reactor.

14 MEMBE POWERS: And that those confinements  
15 were in the case of C reactor, were designed to  
16 withstand the over-pressure from a nuclear blast.

17 VICE CHAIRMAN WALLIS: From outside.

18 MEMBE POWERS: Yes. And the other thing  
19 I wondered, does the Commission understand that a  
20 substantial fraction of the plants in Europe are the  
21 vented filtered containment design; that is, they're  
22 design to act as containments up to a point, and then  
23 they vent through a filtration system?

24 MR. RUBIN: I wouldn't want to venture a  
25 guess as to this particular Commission. The intent is

1 in the final SECY paper to apprise them of these kinds  
2 of facts and information.

3 MR. FLACK: Again, these policy issues are  
4 for non-light water reactors, but recognizing that  
5 there are also existing situations --

6 MEMBE POWERS: I'm not sure that a  
7 containment really cares what's inside of it.

8 MR. FLACK: That's true.

9 MR. RUBIN: And I do have a slide that  
10 takes somewhat of a survey, perhaps not including the  
11 reactors you mentioned, of plants worldwide, non-light  
12 water reactors, either existing or proposed, and the  
13 kinds of containments that they have.

14 In terms of where we've gone so far, since  
15 the SECY we've tried to collect documents relevant to  
16 this, documents of the reactors that you just spoke.  
17 We weren't successful, in fact, in retrieving those  
18 documents, but we did get many more in other plants.  
19 We discussed this with our senior management staff to  
20 get their views. We've had a couple of public  
21 meetings well attended by the nuclear industry and  
22 design folks involved today in designing these plants.  
23 And we've prepared a SECY and you have seen a draft of  
24 that. And we've also included what stakeholder  
25 comments, predominantly from the industry, views on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 requirements for containments.

2 MEMBE POWERS: You speak of the industry,  
3 and I'm sure that what you're speaking of is the U.S.  
4 industry, both reactor operators and NPBS suppliers.  
5 Do you try to include the views of say the designers  
6 of the EPR, which has a double containment, and a core  
7 retention device?

8 MR. RUBIN: We haven't specifically  
9 targeted them. We've certainly announced our  
10 meetings. Perhaps the title of the meetings as being  
11 non-light water reactors has caused them not to show  
12 an interest, but at this point we have certainly  
13 gotten the attention of the HTGR folks, both in South  
14 Africa, General Atomics, and DOE, and we've gotten  
15 participation from Liquid Metal Mold Salt Reactor  
16 Design --

17 MEMBE POWERS: Those are good.  
18 Unfortunately, none of those particular vendors have  
19 sold a plant; whereas, the designers of the EPR have,  
20 and their design is double containment core retention  
21 device. It seems to me that that must surely carry  
22 some weight. I mean, if this is the kind of plant  
23 that the public in the western world is willing to  
24 buy, maybe that's one that ought to be put in front of  
25 the Commission so that they're aware of it. It may be

1 telling you something.

2 MR. RUBIN: Let me just kind of jump ahead  
3 a little bit. In terms of the functional areas that  
4 containments serve, there's clearly first and foremost  
5 the containment, retention, reduction of fission  
6 product release function, the mitigative function.  
7 There are other functions, including protective  
8 functions in terms of external events, tornado,  
9 missiles, aircraft, and the like.

10 The focus of this particular paper at this  
11 time is on the function of mitigation of fission  
12 product release. Now I'm not familiar with this  
13 double containment, but in terms of fission product  
14 release, the idea of a conventional leak-type  
15 containment is kind of -- probably the extreme case  
16 that we're considering.

17 Now when you consider the external events,  
18 there may be other kinds of things you want to do to  
19 your containment building system, per se - other kinds  
20 of shells within a shell, let's say. But the focus  
21 right now is on what are the performance requirements  
22 for fission product retention, containment,  
23 mitigation. That's the focus of this paper at this  
24 time, and we will look at the other functions to see  
25 what may flesh out when we look at that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1                   Now the industry has said that the way of  
2     designing these plants, they start out with a let's  
3     say top level objectives of meeting health and safety  
4     criteria or expectations, and then from that they  
5     develop you might say reactor safety requirements,  
6     things like shutting the plant down, containing  
7     fission products, removing heat. Some may be  
8     technology-specific reactor safety requirements, such  
9     as for an ACGR, avoiding chemical attack which doesn't  
10    show up as a reactor safety function on light water  
11    reactors, per se. So you have some variation right  
12    there in one of the top level reactor safety functions  
13    from technology. Then from there --

14                   MEMBE POWERS: My friends in the  
15    metallurgical profession say yes, definitely the light  
16    water people have not looked at chemical attack.

17                   MR. RUBIN: Okay. From there, they then  
18    try to optimize their designs in meeting those reactor  
19    safety functions. And the containment may or may not  
20    show up in some of those key functions. For example,  
21    shutting the plant down, maybe the plant sub-critical,  
22    it may not show up there. It could show up in  
23    removing accident heated. It certainly will show up  
24    in containing fission products and so forth.

25                   VICE CHAIRMAN WALLIS: If you could show,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 really convince me that the fission products could  
2 never get out of the fuel which is made so that they  
3 can never get out in any conceivable event, then you  
4 wouldn't need any containment presumably, because  
5 there's no function to be performed.

6 MR. RUBIN: Well, what then comes in is  
7 the issue of defense-in-depth.

8 VICE CHAIRMAN WALLIS: Okay. As a  
9 performance --

10 MR. RUBIN: There's two major pieces here  
11 to the containment functional performance criteria, in  
12 terms of mitigating fission products.

13 VICE CHAIRMAN WALLIS: It's other function  
14 is a kind of public confidence booster, that you put  
15 it there to make people happier.

16 MR. RUBIN: Well, there has to be a  
17 balance between prevention and mitigation. If for  
18 some reason you fail to prevent that release from the  
19 fuel, should there be some sort of a --

20 VICE CHAIRMAN WALLIS: So you're just  
21 saying if you're not sure that it's going to be  
22 retained.

23 MR. RUBIN: -- defense-in-depth beyond a  
24 confinement, which may not have the same functional  
25 capability to retain fission products that the fuel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 was designed to have. It has a role in terms of  
2 attenuating the concentrations, but it's not as  
3 absolute as the fuel was intended to, so there's an  
4 issue of how much defense-in-depth you want in your  
5 containment. And that's really, in essence, where the  
6 decision lies among the options in terms of fission  
7 product release, in terms of picking an option.

8 Do you believe just what you said and say  
9 if we rely solely on the fuel, you would in principle  
10 say hey, the containment in terms of a confinement-  
11 type concept would reduce fission product sufficiently  
12 to meet the dose criteria. I'm done. Where's your  
13 defense in depth in terms of if fuel were not as  
14 effective as you had assumed, that particular concept  
15 may not give you additional mitigation capability to  
16 compensate for that, so you may want to factor in  
17 additional capability beyond what the dose criteria  
18 requirements would be.

19 And just to jump ahead, the staff is  
20 working on a description of defense-in-depth as it was  
21 described earlier, and that description of defense-in-  
22 depth is expected this summer, and it will be -- I'm  
23 sure it will have as a key feature in there the issue  
24 of defense-in-depth of mitigation and fission product  
25 retention specifically. We plan to use that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 particular description when it's developed as a  
2 yardstick to look at our options.

3 VICE CHAIRMAN WALLIS: Are you going to  
4 have measures of this defense-in-depth so it's not  
5 just a philosophical thing, and argue about it.

6 MR. RUBIN: Well, the paper lays out  
7 qualitatively the kinds of --

8 VICE CHAIRMAN WALLIS: Well, that's the  
9 problem, isn't it?

10 MR. RUBIN: -- defense-in-depth.

11 VICE CHAIRMAN WALLIS: When you get fuel  
12 which is better, and better, and better at retaining  
13 fission products, you can't just go and say well, it's  
14 all irrelevant because we've got to have defense-in-  
15 depth.

16 MR. RUBIN: Well, I mean --

17 VICE CHAIRMAN WALLIS: We'll have a  
18 measure of these things so you can decide when it's  
19 good enough.

20 MS. DROUIN: We have a subcommittee  
21 meeting scheduled in July, I think it's all day, where  
22 we're going to go through the technology neutral  
23 framework, and a large part of that is the defense-in-  
24 depth. And it's going to get into a lot of these  
25 issues.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: We have? July when?

2 MS. DROUIN: I don't remember the exact  
3 date in July.

4 MEMBE POWERS: There was a -- following  
5 the accident at Chernobyl, Energy Secretary Harrington  
6 became very concerned about the energy production  
7 reactors, the Department of Energy's production  
8 reactors. I mean, they're the biggest reactors that  
9 have ever been built in this country, and the public  
10 perception that they did not have containments because  
11 they deliberately had confinements - when the  
12 justification of why the confinement design came up,  
13 I think at both of the sites, but especially Savannah  
14 River, the design philosophy was well articulated, in  
15 which they said they had a peculiar advantage at these  
16 sites, that they had control of the population to a  
17 much greater extent that you ever do for a commercial  
18 reactor. And the advantage of a confinement design is  
19 they knew where the fission products would go, and  
20 they could just clear that path. And it was just  
21 going to contaminate their own site, and it was not  
22 going to get beyond it.

23 That always struck me as a peculiarly  
24 strong feature of these confinement designs, given  
25 that they were strong enough to also serve the other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 requirement of tanks. Meteorites I think would bounce  
2 off some of these confinements. Are you articulating  
3 that kind of advantage of the confinement-type  
4 concepts that you avoid a pressurized release of  
5 fission products when you go to a confinement. And  
6 that if you have a confinement with a filtration  
7 system, you have even greater control over things?

8 MR. RUBIN: Well, you're jumping ahead to  
9 the options. In the options we do go through exactly  
10 those points. In the case of if one were to place a  
11 traditional containment around a HTGR and one were to  
12 have a loss of coolant, you would have some downside  
13 to that on safety, in the sense that you might make  
14 some of the heat removal systems less reliable. And  
15 you also would retain a mode of force for the release  
16 of fission products once those fission products were  
17 released, a day or two later let's say when the core  
18 heated up, whereas a confinement you would release all  
19 that energy. You would not pressurize the  
20 confinement, and then when fuel were to fail in very  
21 some limited manner, let's say, a couple of days  
22 later, there would not be mode of force to carry that  
23 away, so there is definitely advantage. That is  
24 described in the paper, that's described in these  
25 charts.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I don't know if you want me to keep  
2 moving, but that was one of the criteria for  
3 evaluating the various options; that being, is the  
4 option such that it could have a negative impact on  
5 safety in some way? Okay. I won't go through that.  
6 We've been talking a lot about what are the  
7 considerations. This lists some of what I'll call the  
8 generic policy guides that the Commission has set out  
9 to -- that has guided our development and assessment  
10 of the various options. I won't go into those. We're  
11 all familiar with those.

12 And then what I have is another list of  
13 what I'll call Commission policy decisions that are  
14 more specifically directed at non-light water reactor  
15 licensing. And several of these came out in the  
16 recent policy decisions on the SECY on light water  
17 reactors, that being that risk should be considered to  
18 a greater extent, and identifying events to be  
19 considered in the design-basis of containment, things  
20 like using scenario-specific source terms rather than  
21 bounding ones.

22 In the past, prior Commissions have  
23 indicated that the containment requirements should not  
24 be so stated as to discourage accident prevention and  
25 innovation in advanced reactor designs. They should

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 not be so excessive, so to speak. And past Commissions  
2 have also indicated, at least for ACGRs, a desire for  
3 the staff to take a look specifically at air ingress  
4 and core oxidation, and the benefits that might be  
5 derived in terms of prevention from the containment  
6 itself in preventing that kind of an event. So these  
7 are some of the things that we've had as kind of guide  
8 posts for assessment.

9 As was pointed out earlier, there is a  
10 relationship between what the work here and the work  
11 on the framework. The intent is that the requirements  
12 at least that we are developing for containment, the  
13 options, they be technology-neutral risk-informed and  
14 performance-based.

15 Once one gets down to criteria, there's  
16 been an argument within the industry, and I think we  
17 tend to agree with that. Once you get down to the  
18 specific criteria, you need to consider the specific  
19 technology and how the criteria for it makes sense.

20 And also, defense-in-depth, as we  
21 mentioned earlier, that's going to become a kind of a  
22 measure of evaluating each of the options, because  
23 this option seemed to optimize the application of  
24 defense-in-depth compared to another one. And that  
25 will be coming this summer. We'll be able to do that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 hopefully.

2           The outcome will have two possibilities.  
3 One is, of course, to put into the framework the  
4 Commission policy decisions in terms of developing  
5 actual regulations, and also will be of use in making  
6 decisions on COL and design certification applications  
7 on a plant-specific basis.

8           This lists some of the background  
9 documentation we looked at. There certainly was a  
10 lot. I would point out that we also looked at foreign  
11 plants, and operating plants, as well as concepts,  
12 things like the HTTR in Japan, the HTR-10 which is a  
13 pebble bed reactor in China. We looked at some of the  
14 concept plants that are being developed in Japan, and  
15 the containments that are applied in each case. And  
16 also, the DOE reactors that comprise several different  
17 technologies.

18           Let's just go to the next slide. This  
19 then again is basically the list of six functional  
20 areas that a containment can serve in reactor safety.  
21 Again, not all these functions are necessarily  
22 required of a containment. Some of these functional  
23 areas are let's say a collateral benefit of  
24 containment, because it was put there for reasons of  
25 let's say mitigation of fission product release. They

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 certainly have come to be very important in terms of  
2 prevention of damage of bio-equipment due to external  
3 events, external sabotage, security incidents and the  
4 like. So this is a list that I think the industry  
5 would support.

6 I will say on bullet number 2, bullet  
7 number 2, the idea being there that the containment,  
8 at least in terms of some HTGRs, in terms of  
9 preventing or limiting air ingress has a vital role to  
10 limit the amount of air that would be available for  
11 air ingress. If you were to read the safety  
12 evaluation for the HTTR in their concept plants, the  
13 Japanese view the containment's primary purpose for  
14 being there is to limit the amount of air, and to a  
15 lesser extent to mitigate fission product release.  
16 Okay. So on that basis, I wanted to make it more  
17 prominent in terms of its importance.

18 And also, in other systems, such as liquid  
19 metal reactors, the containment provides kind of a way  
20 of containing the loss of coolant in a reactor coolant  
21 pressure boundary so that it doesn't go away and it's  
22 still there to cover the core, so it prevents core  
23 damage in that sense. And certainly, on light water  
24 reactors, there are some core damage prevention  
25 factors involved.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I put the first one in italics because  
2 that is the one that we're really focusing on now in  
3 this preliminary paper.

4 VICE CHAIRMAN WALLIS: Is all this going  
5 to become more specific, such as limit to some value  
6 rather than just reduce --

7 MR. RUBIN: Yes. Well, I'm going to get  
8 to that. This is kind of a generalized statement.  
9 We'll get more specific. Okay.

10 MEMBER APOSTOLAKIS: When you say  
11 potential safety function, so that follows a column,  
12 says containment building system. So shouldn't these  
13 six bullets refer to the containment?

14 MR. RUBIN: That's the intent. In other  
15 words, once you --

16 MEMBER APOSTOLAKIS: The second doesn't.

17 MR. RUBIN: The second bullet?

18 MEMBER APOSTOLAKIS: Core damage.

19 MR. RUBIN: Yes, it does. Well, I thought  
20 I gave you an example. I talked to you about HTGRs as  
21 an example. In fact, I'll just mention it now. Let's  
22 go to the next page, and I'll give you an example of  
23 that.

24 If you go into the advanced HTGR group,  
25 and I think you might find this one interesting, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 last bullet is the GTHTR-300. Okay. This is a plant  
2 on the drawing boards in Japan which is intended to be  
3 the power reactor concept for the next generation.  
4 Let me put this one up. They call that a double  
5 confinement. Okay. You have an HTGR system on the  
6 lower part of the drawing below grade, and above it  
7 you have another volume, and the two are connected by  
8 - you can see a vent valve. And the upper containment  
9 has a secondary vent valve. Okay.

10 The idea being, that if you have a break  
11 in the reactor cooling system, those valves open much  
12 as would a confinement-type space to relieve that  
13 pressure and to relieve that coolant and fission  
14 products that might be the prompt release of fission  
15 products, but then following the depressurization,  
16 those valves close. The reason being is they want to  
17 limit the amount of volume that's available for air to  
18 interact with the core graphite. That's the principal  
19 reason for that design. And, of course, it still  
20 would have the functionality of play-out fission  
21 products due to slow heat-up and releases that would  
22 occur in a delayed fission product release sense.  
23 Okay. The purpose of this design is to prevent core  
24 damage.

25 VICE CHAIRMAN WALLIS: How is this thing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 cooled following an event? How is the K heat removed?

2 MR. RUBIN: Well, as in any modular HTGR,  
3 it's through natural --

4 VICE CHAIRMAN WALLIS: It just sits there.

5 MR. RUBIN: It just sits there in like a  
6 cup of tea, you know, cooling off.

7 VICE CHAIRMAN WALLIS: So part of the  
8 purpose of this thing is also to confine the heat.

9 MR. RUBIN: Oh, yes. Those are the other  
10 functions. The reason I threw this up and explained  
11 it was to try to point out the function of prevent or  
12 limit core damage. This was an example of that second  
13 bullet. That's the basis for this design, is to limit  
14 the amount of air.

15 VICE CHAIRMAN WALLIS: And it shouldn't be  
16 so insulated that it let's it heat up too much. It's  
17 got to --

18 MR. RUBIN: Oh, yes. It still has to  
19 remove heat and all the other functions.

20 MEMBER APOSTOLAKIS: But would they still  
21 have to show here that the release frequency of  
22 radioactivity is 10 to the minus 5 or less, with one-  
23 tenth of that due to the confinement?

24 MR. RUBIN: The confinement would be  
25 taking credit for it in terms of the mechanistic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 source term would then be used to calculate the  
2 releases --

3 MEMBER APOSTOLAKIS: In other words, I  
4 thought the goals that Mary is developing will give  
5 credit to prevention, but up to a limit. You still  
6 want something for the confinement, so that's why I  
7 question that bullet. But now you've explained it, I  
8 understand it better.

9 MR. RUBIN: Okay.

10 MEMBER APOSTOLAKIS: Prevent or limit  
11 potential core damage. We still need something  
12 though.

13 MR. RUBIN: Yes. I think that's  
14 consistent with --

15 CHAIRMAN BONACA:: But that bullet still  
16 is reduce radioactivity release to the environment, so  
17 how is that --

18 MR. RUBIN: It has really two functions.

19 CHAIRMAN BONACA:: What are the functional  
20 requirements of that?

21 MEMBER APOSTOLAKIS: It's a matter of  
22 interpreting the slide. All right.

23 MR. RUBIN: Okay. So anyway, the point  
24 I'm trying to make here is among the non-light water  
25 reactors we see a range of containment choices,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ranging from the traditional confinement vented low  
2 pressure containment in the first two, a traditional  
3 containment in the HTGR, a double confinement which is  
4 a variation to prevent core damage to the air ingress,  
5 moving down to the small liquid metal reactors what we  
6 see there is the 4S reactor from I think Toshiba, and  
7 the STAR, and SSTAR both leak-type pressure retaining-  
8 type reactors. And we believe that the Molten Salt  
9 reactors are going to be much the same as a  
10 traditional-type containment in terms of bottling up  
11 fission products.

12 MEMBER KRESS: That Molten Salt reactor,  
13 that's a Molten Salt cooled reactor?

14 MEMBE POWERS: Yes.

15 MR. RUBIN: Right.

16 MEMBER KRESS: Not the traditional Molten  
17 Salt reactor.

18 MEMBER ROSEN: No, it's not with integral  
19 for fuel.

20 MEMBE POWERS: I didn't know anybody gave  
21 any credence to the traditional one.

22 MEMBER KRESS: At least one person does.

23 MEMBE POWERS: One person does.

24 MR. RUBIN: The question was asked well,  
25 what are the requirements ultimately on containment,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and the key first requirement in all the options, and  
2 I'll like to just introduce to you now what they are,  
3 and these are preliminary subject to refinement,  
4 change, et cetera, is that the on-site and off-site  
5 radionuclide dose acceptance criteria for the event  
6 categories, and the framework is developing curves  
7 that will kind of set some context for that.

8 In the first case, the events that would  
9 be considered in the containment design basis would go  
10 down to let's say the traditional cutoff of 10 to the  
11 minus 5<sup>th</sup> or 10 to the minus 6<sup>th</sup>, a level that is  
12 indicative of -- that does not lead to severe core  
13 damage in light water reactors. That would be the  
14 cutoff for those kinds of events.

15 The second option is the same as the first  
16 option, except that the designer would be forced to  
17 include events of lower probability into his design-  
18 basis analysis; the idea there being that those  
19 additional lower probability events would in some  
20 cases have higher consequences in terms of source  
21 term, and would challenge the containment design more.  
22 And might, in fact, result in additional containment  
23 fission product mitigation capabilities.

24 MEMBER KRESS: I read those two as saying  
25 they're going to now use the whole spectrum of events

1 as the design-basis?

2 MR. RUBIN: Yes. Essentially.

3 MEMBER KRESS: Okay.

4 MR. RUBIN: Okay. So these are kind of a  
5 rationalist spectrum. We're now moving into a  
6 structuralist option in item 3, the idea being there  
7 the requirement again would be you'd have to meet the  
8 dose criteria for the event categories. In this  
9 particular item 3, we would go back to the more  
10 traditional cutoff of frequency. But the containment  
11 would also have to have a capability to handle source  
12 terms that were unexpectedly higher than what would be  
13 predicted from the mechanistic source term analysis.  
14 And we could argue about well, how much higher, and  
15 how much additional mitigation capability. Are we  
16 talking about a couple of decades of additional  
17 mitigative capability to reduce fission products, and  
18 that's TBD. But there would be some additional  
19 requirement there.

20 And a key within this particular option is  
21 that some have called it a hybrid containment design,  
22 is that you have the capability to button-up or seal,  
23 or make low leakage a containment that was initially  
24 a high leakage-type containment. So if there is an  
25 unexpected increase down the road a couple of days

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 later of fission products, you will have already taken  
2 action to seal it up in a way. Okay.

3 The fourth option is again the traditional  
4 conventional containment. Now we tried to establish  
5 some measures to how to compare each of these options  
6 to one another, and so we developed some valuation  
7 metrics, and other considerations.

8 This next page lists what we think are  
9 really important considerations from a safety  
10 regulator's point of view.

11 MEMBER KRESS: Now when you say dose, are  
12 you incorporating some thought of emergency response  
13 there, or is this once fission product radioactivity  
14 gets to a given point at the site boundary or  
15 something?

16 MR. FLACK: I'm assuming this is the Part  
17 100 you're talking about at this point.

18 MEMBER KRESS: So that doesn't have  
19 anything to do with emergency response.

20 MR. RUBIN: No, no, no. The folks who are  
21 working on the framework are trying to develop a  
22 consequence versus frequency curve. Okay. And then  
23 there is going to be some frequency bands that  
24 correspond to abnormal occurrences, design-basis, and  
25 then you have emergency planning-basis events. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And so the idea would be the containment needs to --  
2 for the various events in those bands needs to meet  
3 the consequence criteria that you've established. And  
4 we're trying to do it on a technology-neutral basis,  
5 and specific plants have proposed specific curves for  
6 their plant designs, based on a light water reactor  
7 dose requirements Part 100 and the like. But that's  
8 the idea.

9 MR. FLACK: TBD.

10 MR. RUBIN: TBD on that. Getting back to  
11 Dana's point, would there be any adverse effect on  
12 safety functions. Some of these could have adverse  
13 effects, and we really don't want to get into that  
14 situation.

15 Would the containment option be such that  
16 it could undermine the designer's interest in  
17 preventing accidents or even being innovative? Could  
18 it be so onerous that there'd be no interest in  
19 creating fuel that never fails?

20 The next bullet is much like we talked  
21 about are there features that would come out in the  
22 wash, so to speak, of the containment design that  
23 would serve to prevent or limit core damage simply by  
24 this particular criteria that we would impose. And  
25 you will see some do and some don't.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Is the requirement performance-based and  
2 risk-informed, which is the intent of this exercise.  
3 And would the requirement provide flexibility in the  
4 way it's stated.

5           The other considerations which are perhaps  
6 not from a safety regulation point of view, as  
7 important, but we believe should be brought to the  
8 attention of the Commission, are things like is this  
9 a technology-neutral type of requirement because we  
10 certainly want it to fit within the plans to  
11 incorporate into our new framework. Is it something  
12 that seems to be in consonance with what the designers  
13 are working against now, and have put a lot of design  
14 finalization into, or is this something that's going  
15 to totally create a new requirement for that  
16 containment? Not that that would be all that critical  
17 to a safety regulator, but I think they would be  
18 interested in knowing about that.

19           We give the increased costs associated  
20 with those differences, and would they be commensurate  
21 with the safety benefits that one would perhaps get  
22 out of it? And do we see the various options as  
23 detracting from or adding to public confidence by the  
24 nature of that mitigation capability?

25           With that, I'd like to just quickly go

1 through each of those four options in terms of how  
2 they would be implemented.

3 MR. FLACK: Well, at this point we should  
4 probably have about 10 minutes left.

5 MR. RUBIN: Okay.

6 MR. FLACK: Can you go through them in 10  
7 minutes? It's a lot more detailed as you move into  
8 each of these options, and maybe we should just leave  
9 it up to the Committee whether they want to hear that.

10 MR. RUBIN: Yes. Well, I'm just throwing  
11 it open now. I mean, you can see from the slides,  
12 they're pretty self-explanatory. The first option  
13 again --

14 CHAIRMAN BONACA:: Maybe if there's  
15 anything that you want to emphasize in particular,  
16 without going over them one by one?

17 MR. RUBIN: Well, I mean the options speak  
18 for themselves. I think what we really need to see  
19 ultimately is what level of defense-in-depth do we  
20 want as a regulatory agency in that containment in  
21 terms of a backstop for the uncertainties, the  
22 unknowns that we haven't considered in these designs.  
23 And that defense-in-depth measure will then drive you  
24 toward which option is going to be most optimal.

25 MEMBE POWERS: Let me ask you a question

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of a philosophical nature concerning your options. In  
2 several cases, you say that we're going to use some  
3 deterministic engineering judgment to evaluate some of  
4 these concepts. And we probably will not have  
5 prototypic experimental data on any new containment  
6 design. In other words, you're going to have to rely  
7 on pure analysis for that judgment. Well, I think for  
8 instance, suppose that we just wanted to know how the  
9 radioactive aerosols behaved in a containment or a  
10 confinement design, and we have a lot of codes that  
11 purport to do that, but they have never been tested  
12 against real radioactive aerosol. And so there's a  
13 leap of faith going on there when we do those  
14 analyses. So there presumably has to be a margin  
15 above and beyond these -- I mean, there is no  
16 engineering judgment here because no one has ever seen  
17 radioactive aerosol in a reactor containment. I mean  
18 there's no experience with this. There's just  
19 approximation of codes, so you have to have some sort  
20 of margin beyond what you get from some deterministic  
21 calculation. Is that kind of thinking built into the  
22 development of these options?

23 MR. RUBIN: Well, yes. That was the  
24 intent of the last bullet on each of these slides.  
25 The staff will recommend enhancements to address

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 potential areas of high uncertainty, and would be  
2 subject to Commission endorsement. And so that really  
3 is kind of a caveat to all of these. And in the  
4 previous advance reactor designs I do believe there  
5 were staff recommended enhancements. I'm not sure  
6 they affected the containment, per se. They may or  
7 may not. I'm not that familiar with it, and they were  
8 endorsed by the Commission, and they became part of  
9 the certification of those designs. So that bullet is  
10 part of the process.

11 I can't tell you how it's going to turn  
12 out. I don't know what kind of technology program  
13 they have. They may address it by the time they come  
14 in, but it probably won't.

15 MEMBE POWERS: I think you answered my  
16 question. And I think you'd be remiss if you tried to  
17 go more detailed than this because you don't know what  
18 these guys are going to come up with.

19 MR. RUBIN: And the reason I put that  
20 bullet on there is to make clear that there is a trap  
21 door in a way to even though you start out with a  
22 vented low pressure containment, there may be some  
23 reason even in entertaining that design where you want  
24 to add some additional features or capabilities like  
25 sealing down the road in an event that would be awed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 by that process. But I can't say we will or will not  
2 get to enhancement, but the process allows for it  
3 based on the uncertainties.

4 MR. KING: Spray system in AP-600. That's  
5 the example of what you're talking about.

6 MEMBE POWERS: I mean at that point it was  
7 imposed strictly because of overall uncertainty in  
8 what the analyses were. As we move into these  
9 confinement designs, I worry about things -- I worry  
10 about people being over-enamored in our ability to  
11 predict these things. For instance, a great deal of  
12 stir was created recently over the subject of iodine  
13 formation and the effect of silver. And then all of  
14 a sudden they find out in subsequent experiments they  
15 didn't get all the silver where it's needed to control  
16 the iodine. If you've done analyses in-between these  
17 two, you might get very different confinement designs.  
18 I mean, we're still discovering things because we  
19 can't test it full-scale with full prototypicity. You  
20 know, you're going to discover these things kind of  
21 one at a time, and you have to recognize sometimes  
22 there are substantial changes in your understanding.

23 MR. RUBIN: Well, that's really the issue  
24 of defense-in-depth. You can only solve so much at  
25 the time you're asked to sign on the dotted line, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you want to have something in your back pocket, and  
2 the guidance will give us an indication of what that  
3 needs to be.

4 MEMBE POWERS: I couldn't have said it  
5 better myself.

6 MR. RUBIN: Right. Are there any other  
7 questions?

8 MR. FLACK: So you want to skip the  
9 options and go to the end.

10 MR. RUBIN: Okay. Let me just tell you  
11 where we're headed under the milestones. Following  
12 this meeting, we plan to have another public meeting  
13 in August, and there the industry wants very much to  
14 provide much more substantive presentations on their  
15 bases for the various containment options. And we  
16 will present where we are too.

17 Again, the defense-in-depth description  
18 will be in place in August, and that will give us a  
19 good yardstick to then measure the various options.  
20 We would like to meet one more time on the final  
21 options with the public around the October time frame.  
22 We would then come back to the ACRS with what might be  
23 viewed as the final options and recommendation. And  
24 we will also combine that with a framework. It may  
25 take a whole day, but it will be combined with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 framework. And then we'll put it in a SECY paper by  
2 the end of the year with those proposed options, the  
3 pros and cons, and the recommendations.

4 In summary then, we're at a point where we  
5 have pushed the assessment to a point where we have  
6 some preliminary options that range from you might say  
7 totally rationalist to structuralist. The options at  
8 this point are focused on reducing radioactivity  
9 release to the environment, that particular mitigative  
10 function. We're going to look at the merits of  
11 developing requirements for the other five functional  
12 areas, that's appropriate. And we'll develop those  
13 options again as it makes sense.

14 And again, by the end of the year we'll  
15 have those final options for your review and the  
16 Commission's review. And, hopefully, we will be able  
17 to get a policy decision, at least on the mitigative  
18 aspect of it. Let me just stop there.

19 MR. FLACK: Okay. And that, I guess,  
20 concludes our presentation.

21 MEMBER SIEBER: You didn't do your last  
22 slide.

23 MR. RUBIN: Oh, yes.

24 MS. DROUIN: Sorry. We'll go right to the  
25 very end.

1 MR. FLACK: All right. Agreement of  
2 staff, send letters and form staff recommendations.

3 MEMBE POWERS: Well, I mean the agreement  
4 here is -- certainly leads you to be confident that  
5 this will be the outcome.

6 MR. FLACK: Well, we appreciate that.

7 MEMBER ROSEN: I think there would  
8 probably be 10 plus 1 opinions.

9 MS. DROUIN: We are trying to finish a  
10 draft of the framework in time to get it to the ACRS  
11 in June. We have a time set for a subcommittee  
12 meeting in July. I believe we have it all day. We  
13 have a public workshop scheduled in August. I think  
14 it's a two-day workshop, I think the 17<sup>th</sup> and 18<sup>th</sup>. I  
15 might have the dates wrong. We'd like to then come  
16 back in the November and December time frame to the  
17 Full Committee, where we will be asking for a letter,  
18 and to send the framework up to the Commission in  
19 December, where we would be releasing it for formal  
20 public review and comment. And that's just quickly --

21 MR. FLACK: Things to come.

22 MS. DROUIN: Things to come.

23 MEMBER KRESS: We look forward to it. I  
24 turn the session back to you, Mr. Chairman.

25 CHAIRMAN BONACA:: I thank you for the

1 presentations. We'll take a break until 5 after 4.  
2 Please be back at 5 after 4. We're really running out  
3 of time. We have a lot of work.

4 (Whereupon, the proceedings in the above-  
5 entitled matter went off the record at 3:43 p.m.)  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on  
Reactor Safeguards

511<sup>th</sup> Meeting

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



---

Rebecca Silberman  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

# **STABILIZING THE PRA QUALITY EXPECTATIONS AND REQUIREMENTS**

Presentation to ACRS

April 15, 2004

D. Harrison, S. Magruder, G. W. Parry,

M. Tschiltz, NRR

M. T. Drouin, RES

# PURPOSE OF PRESENTATION

- To present an overview of the draft action plan for response to SRM COMNJD-03-0002 - Stabilizing The PRA Quality Expectations and Requirements
- To seek agreement on approach

# PRA QUALITY

- Defined in RG 1.200
  - For a given application, PRA Quality is determined by the appropriateness of
    - Scope (internal and external initiating events, full power and low power and shutdown operating modes)
    - Level of detail
    - Technical acceptability

# APPROACH IN THE SRM

- Adopts a phased approach to achieving an appropriate quality for licensee PRAs for NRC's risk-informed regulatory decision-making
- Allows continued practical use of risk insights while progressing towards more complete, and technically acceptable PRAs

# SRM DIRECTION

- Directs the staff to develop an action plan to:
  - Define a practical strategy for implementation
  - Address the resolution of technical issues, such as:
    - Model uncertainty
    - Seismic and other external events
    - Human performance issues

# STATUS

- Interoffice (NRR/RES) working group established
- Draft plan made available 3/15
- Soliciting input from stakeholders
  - Conducted two public meetings (2/24 and 3/24), a third planned (5/12)
  - Met with ACRS subcommittee (3/25), will meet full committee (4/15)
  - Letters from NEI, and ASME/ANS
- Final plan due to Commission 7/04

# THE PHASED APPROACH

- The phases are differentiated by the availability of the guidance documents for using PRA in regulatory applications, and establishing that the PRAs are of sufficient quality. These include:
  - industry consensus standards
  - industry guidance documents
  - regulatory guides
- Staff guidance documents addressing performance of reviews are required for implementation.

# PHASE 1

- Phase 1 represents the status quo
- PRA quality judged only in the context of what is needed for the application - no requirement for the review of the base PRA
- All contributors to risk (operational modes and initiating event types) are addressed
- Contributors to risk not in the scope of the PRA model are addressed in a number of ways including qualitative arguments, bounding analysis, and restricting the scope of application

# PHASE 2

- An application type (“issue-specific”) approach to PRA quality
- PRA quality demonstrated by comparison with an applicable consensus standard for those elements required by the application
- All contributors to risk (operational modes and initiating event types, internal, seismic, fire, etc.) are addressed
- All significant risk contributors applicable to the issue are included in the PRA scope
- Significance of a contributor is determined by whether taking it into consideration could change the decision substantially

## PHASE 2 (Cont'd)

- To achieve Phase 2, guidance must exist for
  - Use of PRA in making the decision (e.g., regulatory guides), including definition of scope
  - Assessment of the quality of the base PRA for each scope item used to support the application (e.g., Standards, RG 1.200)

# PHASE 3


- Regulatory framework is in place that enables licensees to develop a base PRA to conform to all the existing Standards in sufficient depth to address all currently envisioned applications
- Phase 3 is scheduled to be completed by December 31, 2008
  - Consistent with schedule for Standards development
- A licensee enters Phase 3 when its base PRA conforms to all the existing Standards in sufficient depth to address all currently envisioned applications


# PHASE 4

- Phase 4 will be reached when a PRA has been developed to the state-of-the-art (e.g., CC III)
- It is recognized that reaching this goal will be resource intensive both for licensees and NRC
- Phase 4 involves direct staff review and approval of licensee PRAs
- This plan does not address Phase 4

# STAFF REVIEW OF BASE PRA

- Phase 1: currently at the discretion of the reviewer but after trial use completed, will rely on peer review in accordance with RG 1.200 with audit for each application
- Phase 2: reliance on RG 1.200 for all significant contributors
- Phase 3: as for Phase 2 but performed one time sufficient to address all applications
- Phase 4: staff review and approval of base PRA





# POTENTIAL POLICY ISSUE #1

- Issue: If a licensee uses a PRA scope greater than that for which standards exist simply to increase the scope of relaxation of requirements, should the submittal be given low priority? Recommendation: Yes
- Pro: - Staff review would be extensive – no agreed upon standards for acceptable quality
  - Incentive to complete standards
- Con: - Potential for disincentive to develop more complete PRAs prior to completion of standards
  - does not reward proactive licensees

## POTENTIAL POLICY ISSUE #2

- Issue: If a licensee submits an application for which all the applicable guidance documents are in place (Phase 2), but do not conform to the guidance, should the application be given low priority (subject to availability of resources) or rejected outright? Recommendation: low priority
- Pro: Rejection would send the message that the submittal would be inadequate, which could be taken to imply that prior applications were approved inappropriately
- Con: Rejection might encourage more development and use of more complete PRAs

# POTENTIAL POLICY ISSUE #3

- Issue: When all guidance for all current and anticipated applications is in place (Phase 3), should every licensee be required to conform to that guidance before submitting any risk-informed submittals? Recommendation: No
- Pro: If a licensee is only interested in a small number of applications, development of a full scale PRA would be an unnecessary burden
- Con: - The availability of PRAs of predictable and consistent quality would be beneficial in analyzing events and performing Phase 3 SDP evaluations
  - If not, there is no forcing function to go to Phase 3

# POTENTIAL POLICY ISSUE #4

- Issue: When all guidance for all current and anticipated applications is in place (Phase 3), should an application that does not conform to the Phase 2 guidance for that application be rejected outright? Recommendation: Yes
- Pro: - Reinforces the Commission's goal for more complete PRAs
  - Increased efficiency in staff review
- Con: Industry could argue that conservative bounding analyses should still be allowed for significant contributors, since they have been allowed in the past

# POTENTIAL POLICY ISSUE #5

- Issue: If the SDOs decline to produce a Standard considered necessary for an application, should NRC develop its own guidance? Recommendation: Yes
- Pro: - Could be performed more quickly and more efficiently than a standard document
  - Staff development of guidance could provide an incentive for industry to develop their own guidance
- Con: Potential for a lack of alignment with industry on a voluntary initiative

## **STAFF ACTIVITIES TO IMPLEMENT THE PHASED APPROACH**

- Supporting development and endorsement of PRA standards
- Updates to regulatory guides (including RG 1.200)
- Development of regulatory guides for new applications (e.g., 50.69, 50.46)
- Developing methods and supporting documents for technical issues (e.g., NUREGs)
- Developing staff implementation guidelines (e.g., SRP, office instructions)

# INDUSTRY ACTIVITIES

- Develop consensus standards:
  - low power and shutdown PRA (2005)
  - Fire PRA (2005)
- Develop guides for applications (e.g., NEI-00-04)
- Provide update to NEI-00-02 (self-assessment process)

# SCHEDULE

- The schedule for transition to Phase 2 and Phase 3 for all current applications is driven by the schedule on which the relevant guidance documents, in particular, Standards, are developed and endorsed.

Table 3.3 Milestones

MILESTONE	PROJECTED COMPLETION DATE
Identify Current Risk-Informed Applications (e.g., 50.69)	July 30, 2004
Identify PRA Quality Needs for Each Risk-Informed Application	December 30, 2004
Revise Application-Specific Guidance to Address PRA Quality	December 30, 2005
PRA Quality (RG 1.200) Pilots for Internal Events	December 30, 2004
Implementation - Quality for Internal Events PRA (Note 1)	September 30, 2005
Alternate Methods & Treatment of Uncertainties NUREG	December 30, 2004
Standards Development - ANS External Events PRA Quality	<i>Completed</i>
NRC Endorsement - ANS External Events Standard	December 30, 2004
Implementation - Quality for External Events PRAs (Note 1)	December 30, 2005
Standards Development - ANS Fire PRA Quality	June 30, 2005
NRC Endorsement - ANS Fire PRA Standard	June 30, 2006
Implementation - Quality for Fire PRAs (Note 1)	June 30, 2007
Standards Development - ANS Low Power & Shutdown PRA	June 30, 2005
NRC Endorsement - ANS Low Power & Shutdown Standard	June 30, 2006
Implementation - Quality for Low Power & Shutdown PRAs	June 30, 2007
Develop Phase 3 Guidance	
<p>Note 1: For the purposes of this draft, it is assumed that the Standards documents will lag the guidance documents for the applications. It is further assumed that a delay of one year between the completion of the quality guidance documents and that time at which each application is expected to conform to those documents is sufficient for the review of the associated PRA elements to be completed. Furthermore, this time delay allows for the staff infrastructure necessary to transition to Phase 2 to be developed.</p>	

# RESOLUTION OF TECHNICAL ISSUES

- Model uncertainty
  - Guidance document (e.g., NUREG) being developed that addresses the issue of treatment of uncertainties (e.g., model) in both the PRA and in decision making
- Seismic and other external events
  - ANS standard on external events under staff review (preliminary staff position for public review and comment this summer)
  - Above document (on uncertainties) also includes guidance for acceptable alternative methods (e.g., bounding, sensitivity analyses) to a PRA
- Human performance issues
  - NUREG on good HRA practices to supplement the PRA (HRA) standard

## **NEXT STEPS**

- Incorporate stakeholder comments
- Finalize plan
- Send to Commission in July



*United States  
Nuclear Regulatory Commission*

---

---

## ACRS FULL COMMITTEE MEETING

Status on rulemaking on 10 CFR 50.46  
(Large break LOCA redefinition)

**Glenn Kelly, NRR**

gbk@nrc.gov

**Eileen McKenna, NRR**

emm@nrc.gov

**April 15, 2004**

# AGENDA

- Purpose
- Background
- Staff Activities
- Technical/regulatory issues and activities to resolve
- Summary and Conclusion

## PURPOSE

- Inform ACRS about staff activities for large break LOCA redefinition rulemaking in response to SRM
- Obtain feedback from committee about technical issues and staff activities to resolve these issues and relationship to the rulemaking

## BACKGROUND

- Option 3 studies of feasibility of changes to requirements in 50.46
- March 31, 2003, SRM tasked staff for two rulemakings:
  - prepare a proposed rule that allows for a risk-informed alternative to the present maximum LOCA break size
  - prepare a proposed rule that would risk-inform the ECCS functional reliability requirements and thus relax the current requirement for large break LOCA with coincident loss-of-offsite power (LOOP).
- SRM contained several other provisions about the rulemaking features (see next slide)

## SRM FEATURES

- Staff to develop rule allowing voluntary risk-informed alternative maximum LOCA break size
- Commission suggests change to definition of LOCA to exclude breaks with low risk contribution.
- Staff must establish “risk cutoff” for defining the maximum LOCA break size (Commission offers examples of possible criteria)
- No changes to functional requirements unless fully risk-informed (For example, no changes to ECCS coolant flow rates or containment capabilities)

## SRM FEATURES (cont.)

- Licensees who seek the benefit of redefinition should be required to use best-estimate (ECCS evaluation) codes
- Once standards are in place, the PRA should be level 2 internal and external-initiating event all-mode PRA, which has been subjected to peer review process and submitted to and endorsed by the NRC.
- Operational changes should be reversible if LOCA frequency re-estimates (to be done every 10 years) make changes unacceptable

## STAFF ACTIVITIES SINCE 50.46 SRM ISSUANCE

- Analyzed SRM direction, intent and implications.
- Obtained stakeholder input which revealed varying expectations on scope of application of redefinition and implementation requirements. Some industry proposals for plant changes include removal of equipment, power uprates, exclusion of breaks from sump blockage consideration.
- Began development of possible rule concepts for implementing LOCA redefinition. The intent is to coherently integrate all aspects of using risk to redefine the design basis, to make changes to the plant, to incorporate high-quality appropriate-scope PRAs, and to ensure that changes are adequately monitored and controlled over the life of the plant.

## STAFF ACTIVITIES (cont.)

- Identified technical and regulatory issues needing further development that would significantly impact on any rulemaking and its implementation.
- Initiated selected research to produce some of the additional information needed to resolve the issues and proceed with rulemaking (e.g., thermal/hydraulic sensitivity studies for selected risk-informed potential changes, such as power uprates).
- Briefed Commission assistants and forwarded Commission paper identifying policy issues for Commission direction and technical issues to be resolved for moving forward with rulemaking. In particular, staff raised issue as to whether rule should be “narrow” (e.g., specific set of changes allowed) or “broad.”

## TECHNICAL AND REGULATORY ISSUES

1. What are the appropriate criteria and needed confidence in elicitation results (due to significant uncertainties) for determining a new maximum (design basis) LOCA break size? For example, given uncertainties what is the technical justification for use of LOCA frequencies developed through an expert elicitation panel for potentially significant changes in plant safety capability?
2. What is the practical effect (with regard to legal, QA, maintenance requirements, reliability/availability, etc.) of removing specific events and SSCs from the design basis? What can be changed in the plant under the rule, and how is it limited or controlled? For instance, should the rule allow for larger magnitude power uprates (not addressed by the elicitation), reductions in ECCS capability, optimizing flows for smaller breaks, changes in ultimate heat sink capacity, reduced RWST boron concentration, containment EQ temperature profile relaxation?

## ISSUES (cont.)

3. Should the rule be very specific about what can be changed, or should it merely provide a process by which changes could be made?

4. What level of mitigation capability should be retained for LOCAs that formerly were in the design basis (e.g., should larger LOCAs not lead to vessel or containment failure with a high conditional probability)? How will this be shown or determined? Uncertainty in core damage and severe accident analyses will need to be addressed.

5. How should adequate defense-in-depth be assured under this rule? To what extent do the guidelines laid out in RG 1.174 need expansion?

## ISSUES (cont.)

6. What limitations should be placed on cumulative increases in plant risk under this rule (and in conjunction with other plant changes made under other processes such as RG 1.174), and how should it be controlled?
7. What is the appropriate scope and quality for a PRA that is used to provide risk insights under this rule? Does this apply regardless of the extent of change to be sought, or could requirements for PRA scope and extent of NRC review vary?
8. How can or should we write the rule to cover future designs (that may not even be light water reactors)?

## STAFF TECHNICAL ACTIVITIES

- Seven activities outlined in paper to:
  - determine criteria to choose maximum break size
  - identify the level of mitigation required for LOCAs beyond new maximum size
  - develop criteria, including metrics, for plant changes for acceptable effect on risk
  - develop criteria to factor total CDF into process, including accounting for less than full-scope PRAs
  - determine if additional DID criteria are needed and develop them
  - provide guidelines on how to meet RG 1.174 DID criteria
  - develop criteria (and basis) to demonstrate adequate mitigation capability
  - determine information to track for individual changes and guidelines for cumulative risk estimates

## STAFF TECHNICAL ACTIVITIES (cont.)

- Ongoing RES work on thermal hydraulics, risk assessment.
- The staff has proposed delaying LOCA/LOOP rulemaking until after completing pilot reviews of exemption requests made under the BWROG's topical report on LOCA/LOOP. This would allow for lessons learned from the pilots and would make effective use of limited staff resources.

## SUMMARY AND CONCLUSION

- Application of redefinition must be carefully designed so that severe accident margins provided by a robust design basis are not reduced too much
- Need to reconcile expectations about purpose of rule, changes that would be accepted, and basis
- Staff paper sent to Commission for policy direction
- Staff activities continue in several areas on technical basis development while awaiting Commission policy direction
- Feedback from committee will be considered along with Commission direction in staff's next steps for technical issue resolution and rulemaking.



**Development of Passive System LOCA  
Frequencies for Risk-Informed Revision  
of 10 CFR 50.46**

---

**Robert L. Tregoning  
Lee Abramson  
US Nuclear Regulatory Commission**

**Advisory Committee on Reactor Safeguards  
April 15, 2004**



## Objectives and Scope

- Develop generic BWR and PWR piping and non-piping passive system LOCA frequency distributions as function of break size and operating time.
  - LOCAs which initiate in unisolable portion of reactor coolant system.
  - LOCAs related to passive component aging, tempered by mitigation measures.
  - Small, medium, and large-break LOCAs examined. Large break category further subdivided to consider LOCA sizes up to complete break of largest RCS piping.
  - Time frames considered: 25 years (current day), 40 years (end of original license), and 60 years (end of life extension).
- Primary focus: frequencies associated with normal operating loads and expected transients.
- Assume that no significant changes will occur in the plant operating profiles.



## Elicitation Insights: BWR & PWR Plants

---

- BWR Plants
  - Thermal fatigue, intergranular stress corrosion cracking (IGSCC), mechanical fatigue, flow accelerated corrosion (FAC) identified as important degradation mechanisms.
  - Increased operating transients (e.g., water hammer) compared to PWR plants.
  - BWR community has more experience identifying and mitigating degradation due to IGSCC experience in the early 1980s.
  - BWR service experience must be carefully evaluated due to preponderance of pre-mitigation IGSCC precursor events.
- PWR Plants
  - Primary water stress corrosion cracking (PWSCC), thermal fatigue, and mechanical fatigue identified as important degradation mechanisms.
  - PWSCC concerns paramount for panel.
    - Near-term frequency increases due to PWSCC are likely before effective mitigation is developed.
    - Most panelists believe that issue will be successfully resolved within the next several years.




## Elicitation Insights: Piping & Non-Piping

- Piping
  - Complete failures of smallest piping are more likely than partial failure of larger piping.
  - Aging may have greatest effect on intermediate-size piping (6 – 14”).
    - Smallest piping is governed by service history failure rates.
    - Largest piping is subject to higher quality inspections and have increased leak-before-break margin.
- Non-Piping.
  - Estimation of non-piping failure frequencies is more challenging than piping.
    - Widely varying operating requirements, design margins, materials, and inspectability.
    - Widely varying failure modes and scales.
    - Generally not same wealth of precursor information as piping.
  - Larger non-piping components (e.g., pressurizer, valve bodies, pump bodies, etc) have bigger design margin compared to piping, but decreased inspection quantity and quality.
  - Smaller non-piping components (e.g., steam generator tubes, CRDM nozzles) are expected to benefit most from improved inspection methods and mitigation programs.



## BWR and PWR Total LOCA Frequencies


- BWR.
  - Decreases are gradual with LOCA size due to IGSCC concerns.
  - Only non-piping failures contribute to largest (41" effective diameter) breaks.
- PWR.
  - Smallest LOCA frequencies are high as due to steam generator and CRDM concerns.
  - Non-piping frequency contributions become important again for largest LOCAs.
- BWR & PWR expected frequencies are similar for effective break diameters between 1 and 10".
- BWR and PWR ratios between means and 95<sup>th</sup> percentiles are similar.





## Comparison with Prior Studies

Plant Type	LOCA Size	Current Day (25 yrs)
		Comparison with NUREG/CR-5750 (Current/CR-5750)
BWR	SB	0.7
	MB	2.6
	LB	0.3
PWR	SB	0.8
	MB	7.2
	LB	0.6



- Frequencies are lower than WASH-1400 estimates.
- Elicitation and NUREG/CR-5750 results are comparable.
  - PWR MB LOCA: Largest difference with NUREG/CR-5750.
  - All other differences are within a factor of 3.



## Summary

- NRC used formal elicitation process to estimate generic BWR and PWR LOCA frequencies as a function of flow rate and operating time considering both piping and non-piping contributions.
- The process developed quantitative estimates for piping and non-piping base cases which were used to anchor subsequent elicitation responses.
- Panelists provided quantitative estimates supported by qualitative rationale.
  - Determined important contributing factors (piping & non-piping systems, degradation mechanisms) governing LOCA frequencies.
  - Provided the relationships between these factors and the base cases.
- Results.
  - Relatively good agreement about important factors contributing to LOCAs.
  - Large uncertainty and variability in quantifying the frequencies associated with these contributing factors.
  - Generally comparable to NUREG/CR-5750 estimates.



# **Non-LWR Policy Issue 6: Containment Functional Performance Requirements**

April 15, 2004

Stuart D. Rubin, NRC/RES

**Pre-decisional**

# Briefing Objective

- Discuss the current status and future plans to develop policy options for functional performance requirements and criteria for non-LWR containment in response to the SRM on SECY-03-0047
- To obtain verbal feedback from the ACRS on the preliminary options, including their advantages and disadvantages

# Policy Decision Background

SECY-03-0047, “Policy Issues Related to Licensing Non-Light Water Reactor Designs” included proposed options and recommended positions sent to the Commission to resolve the non-LWR containment policy issue which had emerged from the Pebble Bed Modular Reactor (PBMR) and the Gas Turbine-Modular Helium Reactor (GT-MHR) pre-application reviews:

## Proposed Options:

- Require a low leakage and is pressure retaining containment building.
- Allow a plant to be licensed without a containment building capable of retaining pressure, provided certain performance criteria are met.

## Recommendation:

- Approve the use of functional performance requirements to determine the acceptability of non-LWR containment building designs.
- If approved, develop the functional performance requirements.

# Policy Decision Background (Cont.)

The Staff Requirements Memorandum (SRM) for SECY-03-0047:

Disapproved the development of functional performance requirements to determine the acceptability of a non-LWR containment building design, because of insufficient information to prejudge the best option. The staff was directed to:

- Develop options for non-LWR containment functional performance requirements and criteria
- Account for such features as core, fuel and cooling system design
- Interact with industry experts and other stakeholders to develop the options
- Submit the options and recommendations to the Commission

# Schedule of Completed Milestones

- SRM issued for SECY-03-0047 Jun 2003
- Staff R&D initiated on containment functions and options Sep 2003
- Public meeting on AR framework and non-LWR containment issue Nov 2003
- Public meeting on non-LWR containment issue Jan 2004
- ACRS full committee meeting to discuss status and SECY **Apr 2004**
- Public meeting on framework and containment issue ~Aug 2004
- Defense in-depth description for framework developed ~Aug 2004
- Public meeting on draft final containment options ~Oct 2004
- ACRS full committee meeting on proposed final options ~Nov 2004
- SECY on framework final containment options/recommendations ~Dec 2004

# Generic Commission Policy Guidance

- Policy on Advanced Nuclear Power Plant Regulation
- Reactor Safety Goals Policy
- Severe Accident Policy
- Use of Probabilistic Risk Assessment Methods in Nuclear Regulatory Activities
- Commission White Paper on Risk-Informed and Performance-Based Regulation

# Non-LWR and Containment-Specific Commission Policy Guidance

- A probabilistic approach for selecting events in the (containment) design basis may be increased.
- Scenario-specific source terms with deterministic engineering judgement to bound uncertainties may be used (to assess containment design adequacy).
- A risk-informed, technology neutral description of defense-in-depth for nuclear power plants should be developed, including its objectives scope and elements.
- Containment performance requirements should not discourage accident prevention.
- For HTGR containment designs, consider a loss of RCPB with air ingress leading to severe graphite oxidation and fuel damage.

# Relation to New Reactor Framework

To the extent possible, containment functional performance requirements and criteria should conform to the new reactor framework:

- Technology-neutral
- Risk-informed
- Performance-based
- Defense-in-depth description

Commission approved requirements and criteria will provide the basis for developing generic regulations and/or making design-specific regulatory decisions for non-LWR licensing.

# NRC and Industry Documents Reviewed

- NRC LWR regulations
- Non-LWR pre-applicant design descriptions and safety analysis reports
- NRC non-LWR preliminary safety evaluation reports
- U.S. DOE Generation IV reactor design information
- Foreign non-LWR design and safety analysis information

# Non-LWR Containment Building System: Potential Safety Functional Areas

- *Reduce radioactivity release to the environment*
- Prevent or limit potential core damage (e.g., HTGR graphite core chemical attack, LMR core uncovering)
- Support accident heat removal (to prevent vital equipment from exceeding design/safety limits)
- Protect vital equipment (e.g., shutdown, heat removal, RCPB) from natural phenomena, internal high energy sources
- Protect on-site workers from radiation
- Provide physical protection (i.e., security) for vital equipment

# Non-LWR Containment Building System Designs

*(Reduce Radioactivity Release to the Environment)*

- Advanced High Temperature Gas Cooled Reactors (HTGRs):
  - MHTGR, GT-MHR, PBMR, VHTGR - vented, low pressure<sup>1</sup>
  - HTR 10 (test reactor) - vented, low pressure
  - HTTR (test reactor) - leak-tight, pressure-retaining
  - GTHTR300 - “double confinement”
- Advanced Small Liquid Metal Reactors (SLMRs):
  - 4S Reactor - leak-tight, pressure-retaining
  - STAR, SSTAR - leak-tight, pressure-retaining
- Advanced Molten Salt Reactors (MSRs):
  - Generation IV - TBD

---

<sup>1</sup>i.e., “confinement”

# Non-LWR Containment Functional Area: *Reduce Radioactivity Release to the Environment*

## Preliminary Options:

- 1: Meets onsite and offsite radionuclide dose acceptance criteria for the event categories<sup>2</sup>
- 2: Meets onsite and offsite radionuclide dose acceptance criteria for the event categories with lower probability<sup>3</sup> events included in the design-basis
- 3: Meets onsite and offsite radionuclide dose acceptance criteria for the event categories with a reserve capacity to reduce releases, including timely establishment of a low leakage barrier
- 4: Meets onsite and offsite radionuclide dose acceptance criteria for the event categories with an essentially leak-tight barrier against radioactivity release to the environment

---

<sup>2</sup> e.g., Events or event sequences with a probability that traditionally does not lead to severe core damage

<sup>3</sup> e.g., Events or event sequences with a probability that is traditionally associated with severe core damage

# Evaluation Metrics for Potential Options

## Evaluation metrics:

- Would dose criteria be met?
- Would safety functions, systems be adversely impacted?
- Would accident prevention, innovation be discouraged?
- Would selected core damage accidents be prevented/limited?
- Would it compensate for uncertainties/unknowns?
- Is it performance-based, risk-informed?
- Would the designer have flexibility?

# Other Considerations for Potential Options

## Other considerations:

- Is it technology-neutral?
- Is it consistent with the approach considered by designers?
- Are any increased costs commensurate with safety benefits?
- Would it support public confidence?

Preliminary Option  
Descriptions and Evaluations

*(Reduce Radioactivity Release  
to the Environment)*

Option 1: Meets onsite and offsite dose acceptance criteria for the event categories

Description:

- Probabilistic approach plus deterministic engineering judgement used to select (containment) design-basis events (e.g., DBEs  $\geq 10^{-6}/\text{yr}$ )
- Mechanistic source term analysis with uncertainties for dose assessment; must meet dose criteria for event categories
- Fuel and SSC performance and fission product transport are well-understood and supported by adequate R&D programs; fuel quality will need to be maintained over the life of plant.
- Staff recommend enhancements to address potential areas of high uncertainty are subject to Commission endorsement for implementation

Option 1: Meets onsite and offsite dose acceptance criteria for the event categories

Evaluation:

- Dose criteria would be met; safety functions are not adversely impacted
- Would not discourage accident prevention incentive or innovation
- Does not specifically address prevention of selected “core damage” accidents
- Margins, time factor, enhancements compensate for uncertainties/unknowns
- Performance-based and risk-informed approach
- Designer would have flexibility for design decisions

Other Considerations:

- Technology-neutral
- Consistent with non-LWR designer approach
- Would not directly result in features that increase costs
- The public may view as not providing sufficient DID for unknowns
- Might result in: VLPC for HTGRs and VHTRs, low leakage containment for LMRs and MSR

Option 2: Meets onsite and offsite dose acceptance criteria for the event categories with lower probability events included in the design-basis

Description:

- Probabilistic approach plus deterministic engineering judgement used to select (containment) design-basis events (e.g., **DBEs  $\geq 10^{-8}$ /yr**)
- Mechanistic source term analysis with uncertainties for dose assessment; must meet dose criteria for event categories
- Fuel and SSC performance and fission product transport are well-understood and supported by adequate R&D programs; fuel quality will need to be maintained over the life of plant
- Staff recommend enhancements to address potential areas of high uncertainty are subject to Commission endorsement for implementation

Option 2: Meets onsite and offsite dose acceptance criteria for the event categories with lower probability events included in the design-basis

Evaluation:

- Dose criteria would be met; safety functions are not adversely impacted
- Would not discourage accident prevention incentive or innovation
- Does not specifically address prevention of selected “core damage” accidents
- Lower probability events may result in design changes or show margins to compensate for uncertainties/unknowns
- Performance-based and risk-informed approach
- Designer would retain flexibility for design decisions

Other Considerations:

- Technology-neutral
- Modifies containment design approach to include lower probability events
- Might result in features that would increase costs
- The public may view as not providing sufficient DID, but more than Option 1
- Might result in: VLPC for HTGRs and VHTRs, low leakage containment for LMRs and MSR

Option 3: Meets onsite and offsite dose acceptance criteria for the event categories with a reserve capacity to reduce releases including timely establishment of a low leakage barrier

Description:

- Probabilistic approach plus deterministic engineering judgement used to select (containment) design-basis events (e.g., DBEs  $\geq 10^{-6}/\text{yr}$ )
- Mechanistic source term analysis with uncertainties for dose assessment; must meet dose criteria for event categories
- Fuel and SSC performance and fission product transport are well-understood and supported by adequate R&D programs; fuel quality will need to be maintained over the life of plant
- Containment building system design must have a reserve capability to meet onsite/offsite dose criteria for postulated bounding containment source terms and have a timely capability to be low leakage at low pressure.
- Performance criteria would be used to address potential areas of uncertainty and completeness, diminishing the need for further enhancements

Option 3: Meets onsite/offsite dose acceptance criteria for the event categories with a reserve capacity to reduce releases. including timely establishment of a low leakage barrier

Evaluation:

- Dose criteria would be met; safety functions are not adversely impacted
- Could discourage accident prevention incentive and innovation
- For HTGRs would provided DID to prevent/limit “core damage” due to air ingress
- Would provide additional margin to compensate for uncertainties/unknowns
- Prescriptive requirement; not performance-based or risk-informed
- Prescriptive requirement reduces flexibility for design & response decisions

Other Considerations:

- Not technology neutral
- Not consistent with selected non-LWR containment design (i.e., HTGRs)
- Safety benefit may not be commensurate with additional costs (i.e., HTGRs)
- The public would likely view as providing more DID than Option 1 or 2
- Would result in a re-sealable VLPC for HTGRs and VHTGRs

Option 4: Meets onsite and offsite radionuclide dose acceptance criteria for the event categories with an essentially leak-tight barrier against radioactivity release to the environment

Description:

- Probabilistic approach plus deterministic engineering judgement used to select (containment) design-basis events (e.g., DBEs  $\geq 10^{-5}/\text{yr}$ )
- Mechanistic source term analysis with uncertainties for dose assessment; must meet dose criteria for event categories
- Fuel and SSC performance and fission product transport are well-understood and supported by adequate R&D programs; fuel quality will need to be maintained over the life of plant
- Containment building system design provides a leak-tight barrier against radioactivity release
- Performance criteria explicitly address potential areas of high uncertainty and completeness making the need for further enhancements unlikely

Option 4: Meets onsite and offsite radionuclide dose acceptance criteria for the event categories with an essentially leak-tight barrier against radioactivity release to the environment

Evaluation:

- Dose criteria would be met
- Safety functions could be adversely impacted (i.e., HTGRs)
- Would discourage accident prevention incentive and innovation
- Would increase DID to prevent/limit HTGR air ingress “core damage”
- Would increase margin to compensate for uncertainties/unknowns
- Would preclude performance-based, risk-informed approach
- Would reduce flexibility for design decisions and accident response options

Other Considerations:


- Technology-neutral
- Not consistent with containment design approach for HTGRs
- Safety benefits may not be commensurate with increased costs (i.e., HTGRs)
- Public would likely view as providing enhanced DID compared to other options
- Would result in a conventional containment for HTGRs, LMRs and MSR

# Schedule of Future Milestones

- |  |           |
|--|-----------|
| • SRM issued for SECY-03-0047                                  | Jun 2003  |
| • Staff R&D begun on containment functions and options         | Sep 2003  |
| • Public meeting on AR Framework and non-LWR containment issue | Nov 2003  |
| • Public meeting on non-LWR containment issue                  | Jan 2004  |
| • ACRS full committee meeting to discuss containment and SECY  | Apr 2004  |
| • Public meeting on framework and containment issue            | ~Aug 2004 |
| • Defense-in-depth description for framework developed         | ~Aug 2004 |
| • Public meeting on draft final containment options            | ~Oct 2004 |
| • ACRS full committee meeting on final options and framework   | ~Nov 2004 |
| • SECY on framework, final containment options/recommendations | ~Dec 2004 |

# Summary

- Preliminary options for reducing radioactivity release to the environment have been developed and evaluated for non-LWR containment building systems.
- The options for the reducing radioactivity release to the environment will be further refined and evaluated with stakeholder interactions and the defense-in-depth description.
- As appropriate, performance options for the other functional areas will be developed and evaluated.
- Final options and recommendations will be provided by the end of CY 2004 for Commission decision.

A spiral-bound notebook with a dark, textured cover. The spiral binding is on the left side. The page is white with a black border. The text is centered on the page.

# Proposed SECY Paper-Response to June 26, 2003 SRM on Non-LWR Policy Issues

Presentation to:

Advisory Committee on Reactor Safeguards

Presented by:

John Flack, Mary Drouin, Stu Rubin, Tom King

April 15, 2004

## PRESENTATION OBJECTIVE

---

- Discuss proposed response to the June 26, 2003 SRM
- Obtain letter from Committee approving staff recommendations

# BACKGROUND

- SECY-03-0047 provided 7 policy issues associated with non-LWR licensing for Commission guidance:
  - 1) Expectations for Safety
  - 2) Defense-in-Depth
  - 3) Use of International Consensus Codes & Standards
  - 4) Probabilistic Licensing Basis
  - 5) Scenario Specific Licensing Source Term
  - 6) Containment vs. Confinement
  - 7) Emergency Preparedness
- June 26, 2003 SRM
  - Approved staff recommendations on Issues 2, 4, 5, and 7
  - Disapproved staff recommendation on Issues 3 and 6
  - Provided direction on Issues 1 and 6

# CURRENT SECY

- SECY- responds to Commission direction on Issues 1 and 6
- Attachment 1 - Provides a summary and status of effort to develop a framework for future plant licensing and a description of defense-in-depth
- Attachment 2 - Summarizes the basis for recommendation on integrated risk issue
- Attachment 3 - Provides a discussion and status of non-LWR containment functional performance requirements.
- Attachment 4 - Summarizes Workshop and key points
- Schedule for SECY
  - SECY due to EDO – 4/23/04

PRE-DECISIONAL

# OVERVIEW OF PROPOSED SECY

---

- SECY addresses the following Commission direction in their 6/26/03 SRM:
  - Issue 1 - provide options for and impacts of requiring modular reactor designs to consider integrated risk from the use of multiple reactor modules
  - Issue 6 - develop options for containment functional performance requirements and criteria , provide options and recommendations.
- SECY also intended to:
  - Provide status summary the effort to develop a risk-informed framework and defense-in-depth description
  - Inform Commission of relevance of integrated risk issue to the early site permit reviews

## OVERVIEW OF PROPOSED SECY (cont.)

---

- SECY recommends the Commission:
  - Approve staff recommendation on the treatment of integrated risk for modular reactors
  - Approve the integration of options for containment functional performance requirements with policy recommendations on framework.

# OPTIONS ON INTEGRATED RISK

PRE-DECISIONAL

# INTEGRATED RISK

- Attachment 2 of SECY
- Issue:
  - should the risk from modular reactors be assessed on a per reactor module or on a per plant (group of modules) basis?
- Options developed based on three factors
  - Risk guidelines for accident prevention and accident mitigation
  - Number of modules at each site
  - Size (MWt) of each module
- Three options identified

## INTEGRATED RISK (cont'd)

- Option 1: No consideration of integrated (cumulative) risk
  - Each module has to meet the risk guidelines for both accident prevention and accident mitigation (consistent with current practice)
  - Number of modules is not considered
  - MWt of each module not considered
  - Potentially underestimating risk to the public
    - population around a site is exposed to the risk from everything on the site

## INTEGRATED RISK (cont'd)


- Option 2: Consideration of integrated risk (frequency only)
  - The risk from all the modules combined has to meet the guidelines for accident prevention and accident mitigation AND each module has to meet the risk guidelines for both accident prevention and accident mitigation equally
  - Number of modules at site considered
  - MWt of module not considered
  - Not consistent with current practice
  - Recognizes accident prevention is important, regardless of MWt power
  - Likely conservative for accident mitigation (does not allow credit for reactor MWt power)

## INTEGRATED RISK (cont'd)

- Option 3: Consideration of integrated risk frequency and reactor power
  - The risk guideline for accident prevention from all modules has to be met
  - The risk guideline for accident mitigation (LERF):
    - Each module has to meet
    - Modules combined have to meet
  - Number of modules at site considered
  - MWt of modules considered
  - Not consistent with current practice
  - Recognizes accident prevention is important, regardless of reactor MWt power
  - More realistic in assessing risk (gives credit for reactor MWt power in accident mitigation)

## INTEGRATED RISK (cont'd)

- Recommendation: Option 3
- Implementation:
  - guidance will need to be developed on implementation
  - consistent with approach currently being taken by modular reactor designers
- This issue is important to the current ESP reviews

A spiral-bound notebook with a dark, textured cover. The spiral binding is on the left side. The page is white with a faint horizontal line near the top. The text is centered on the page.

# OPTION ON CONTAINMENT VERSUS CONFINEMENT

PRE-DECISIONAL

13

# SUMMARY

PRE-DECISIONAL

14

# NEXT STEPS

- Complete draft framework
- Meet with ACRS sub-committee (July)
- Public workshop on framework and containment options (August)
- Meet with ACRS full-committee, letter on framework and containment recommendations (November/December)
- Paper to Commission on framework and containment recommendations (December/January)

# IN CONCLUSION

- ACRS in agreement with staff and prepared to send letter supporting staff recommendations