

April 29, 2004

MEMORANDUM TO: Dan Gillen, Deputy Director
Decommissioning Directorate
Division of Waste Management
and Environmental Protection
Office of Nuclear Material Safety
and Safeguards

FROM: William C. Huffman, Project Manager /RA/
Decommissioning Directorate
Division of Waste Management
and Environmental Protection
Office of Nuclear Material Safety
and Safeguards

SUBJECT: SUMMARY OF APRIL 20, 2004, MEETING WITH PACIFIC GAS & ELECTRIC
AND HOLTEC ON PLANS RELATED TO THE INSTALLATION OF A SINGLE-
FAILURE-PROOF CRANE AT HUMBOLDT BAY

On April 20, 2004, a meeting was held at the U.S. Nuclear Regulatory Commission (NRC) offices in Rockville, Maryland, with representatives of the Pacific Gas & Electric Company (PG&E) and its vendor, Holtec, to discuss information, planning, and status related to the licensing and use of a single-failure-proof crane design at the Humboldt Bay Decommissioning Nuclear Power Plant. The crane will be used to lift, handle, and transfer spent fuel in a fully loaded Holtec cask from the Humboldt Bay spent fuel pool to an independent spent fuel storage installation (ISFSI).

Humboldt Bay currently has an application under review at the NRC for a site-specific licensed ISFSI utilizing the Holtec International HI-STAR dry cask system modified for Humboldt Bay spent fuel. However, Humboldt Bay does not have the capability to lift a fully loaded HI-STAR cask (multipurpose canister and overpack). Holtec has developed a proprietary cask handling system consisting of a davit crane design equipped with strand jack lifting devices that can accomplish the ISFSI cask handling operation within the constraints of the Humboldt Bay site layout and spent fuel pool access. The crane design will have a rated lifting capacity considerably greater than the 90-ton weight of a loaded HI-STAR cask.

As discussed during the meeting, cask handling operations within the refueling building will be conducted under the Humboldt Bay possession-only 10 CFR Part 50 license. Since use of the crane and cask handling operations are not part on the current licensing basis at Humboldt Bay, PG&E plans to submit a license amendment request to incorporate use of the crane and HI-STAR cask. PG&E states that the crane will conform with the guidance in NUREG-0612, Control of Heavy Loads at Nuclear Power Plants, and NUREG-0554, Single Failure Proof Cranes as applicable for this unique crane design. PG&E plans to submit the license amendment request in July 2004 and would expect NRC to complete the licensing action well in advance of the August 2005 schedule for issuance of the ISFSI license.

D. Gillen

-2-

PG&E noted that the crane has been designed to a seismic criteria of 0.5g although the seismic characterization of the site is much greater. PG&E justifies the use of the 0.5g criteria as reasonable based on the maximum seismic capability of the refueling building which currently stores the spent fuel and which will support the crane.

Staff questions during the meeting focused on details related to the seismic analyses, reliability information, and discussions on the pin connections used in the design.

The meeting attendance list and a copy of the non-proprietary slides presented by PG&E are attached. The presentation made by Holtec on the crane design details is proprietary and no handouts of the slides were disseminated by Holtec or retained by the NRC. PG&E filed an affidavit for withholding information for the proprietary portion of this meeting on April 14, 2004 (ADAMS Accession No ML041140382). This meeting was noticed on April 6, 2004. No regulatory decisions were made during the meeting.

Docket Nos.: 50-133 and 72-27

Attachments: Attendance List
Presentation Slides (ADAMS Accession No. ML041190142)

cc: Service List

PG&E noted that the crane has been designed to a seismic criteria of 0.5g although the seismic characterization of the site is much greater. PG&E justifies the use of the 0.5g criteria as reasonable based on the maximum seismic capability of the refueling building which currently stores the spent fuel and which will support the crane.

Staff questions during the meeting focused on details related to the seismic analyses, reliability information, and discussions on the pin connections used in the design.

The meeting attendance list and a copy of the non-proprietary slides presented by PG&E are attached. The presentation made by Holtec on the crane design details is proprietary and no handouts of the slides were disseminated by Holtec or retained by the NRC. PG&E filed an affidavit for withholding information for the proprietary portion of this meeting on April 14, 2004 (ADAMS Accession No ML041140382). This meeting was noticed on April 6, 2004. No regulatory decisions were made during the meeting.

Docket Nos.: 50-133 and 72-27

Attachments: Attendance List
Presentation Slides (ADAMS Accession No. ML041190142)

cc: Service List

DISTRIBUTION:

PUBLIC	DCD r/f	JGreeves	DGillen
CCraig	CBurkhalter	DSolorio	K Manoly HWagage
Steve Jones	John Ma	SO'Conner	JMonninger DTang
RidsNmssDwmDcb	RidsOgcRp		RidsAcrcAcnwMailCenter
RidsNmssPMDOrlando	RidsNmssPMWHuffman		RidsRgn4MailCenter

Package ML041210187

Meeting Summary Accession Number: **ML041210148**

Meeting Slides Accession Number: **ML041190142**

*See previous concurrence

OFFICE	DWMEP/PM	DWMEP	DWMEP/SC
NAME	WHuffman*	CBurkhalter*	CCraig*
DATE	4/29/04	04/29/04	4/28/04

OFFICIAL RECORD COPY

cc:

Mr. Lawrence F. Womack, Vice President,
Power Generation & Nuclear Services
Diablo Canyon Power Plant
P. O. Box 56
Avila Beach, CA 93424

Mr. Roy Willis, Plant Manager
Humboldt Bay Nuclear Power Plant
Pacific Gas & Electric Company
1000 King Salmon Avenue
Eureka, CA 95503

R. Terry Nelson, Director
Fossil Generation
Mail Code N11E
Pacific Gas & Electric Company
P.O. Box 770000
San Francisco, California 94177-0001

Christopher J. Warner, Esq.
Law Department
Pacific Gas & Electric Company
Post Office Box 7442
San Francisco, CA 94120

Chairman, Humboldt County Board
of Supervisors
County Courthouse
825 Fifth Street
Eureka, CA 95501

Mr. Steve Hsu
Radiologic Health Branch
State Department of Health Services
P.O. Box 997414 (MS 7610)
Sacramento, CA 95899-7414

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, CA 94102

Redwood Alliance
P.O. Box 293
Arcana, CA 95521

Dr. Rich Ferguson, Energy Chair
Sierra Club California
1100 11th Street, Suite 311
Sacramento, CA 94814

Mr. Ed Bailey, Radiation Program Director
Radiologic Health Branch
State Department of Health Services
P.O. Box 997414 (MS 7610)
Sacramento, CA 95899-7414

Commissioner
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814

Deputy Attorney General
State of California
110 West A Street, Suite 700
San Diego, CA 92101

Attendance List For
Meeting with Pacific Gas & Electric (PG&E) and Holtec
on Plans Related to the Installation of a Single-failure-proof Crane

April 20, 2004

<u>Name</u>	<u>Organization</u>
Brian Gutherman	Holtec
Eric Lewis	Holtec
Steve Agace	Holtec
Alan Soler	Holtec
Roy Willis	PG&E Humboldt Bay
Larry Pulley	PG&E Humboldt Bay
David Sokolsky	PG&E Humboldt Bay
Terry Grebel	PG&E
Claudia Craig	Decommissioning Directorate, NMSS, NRC
Bill Huffman	Decommissioning Directorate, NMSS, NRC
Steve Jones	Plant Systems Branch, NRR, NRC
Harry Wagage	Plant Systems Branch, NRR, NRC
Angelo Stubbs	Plant Systems Branch, NRR, NRC
David Solorio	Plant Systems Branch, NRR, NRC
John Ma	Mechanical and Civil Engineering Branch, NRR, NRC
Steve O'Connor	Spent Fuel Project Office, NMSS, NRC
David Tang	Spent Fuel Project Office, NMSS, NRC
Bob Tripathi	Spent Fuel Project Office, NMSS, NRC
Scott Atwater	NRC Region 4 (Via Phone Bridge)
Emilio Garcia	NRC Region 4 (Via Phone Bridge)
Audrey Taucher	Fresh Fuel Weekly
Maureen Conley	Platts/McGraw-Hill