

Exelon Generation Company, LLC
 LaSalle County Station
 2601 North 21*Road
 Marseilles, IL 61341–9757

April 26, 2004

10 CFR 50.36a

United States Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555

www.exeloncorp.com

LaSalle County Station, Units 1 and 2 Facility Operating License Nos. NPF-11 and NPF-18 NRC Docket Nos. 50-373 and 50-374

Subject: 2003 Radioactive Effluent Release Report and Triannual Chlorine Survey Report

Enclosed is the Exelon Generation Company, (EGC), LLC, LaSalle County Station 2003 Annual Radioactive Effluent Release Report, submitted in accordance with 10 CFR 50.36a, "Technical specifications on effluents from nuclear power reactors," paragraph (a)(2) and Technical Specification 5.6.3, "Radioactive Effluent Release Report," and the Triannual Chlorine Survey Report.

Should you have any questions concerning this letter, please contact Mr. Glen T. Kaegi, Regulatory Assurance Manager, at (815) 415-2800.

Respectfully,

for

Susan Landahl Plant Manager LaSalle County Station

Attachment

cc: Regional Administrator - NRC Region III NRC Senior Resident Inspector - LaSalle County Station

JE48

CHLORINE SURVEY IN THE VICINITY OF LASALLE COUNTY GENERATING STATION

1. Executive Summary

A triennial survey of potential sources of chlorine was conducted by LaSalle station to ensure compliance with General Design Criteria (GDC) 19 of Appendix A of 10CFR 50. The 3 year survey reevaluates use of chlorine within 5 miles of the plant's Control room and ensures that a chlorine hazard does not exist. The survey also ensure compliance with Regulatory Guides (RG) 1.78 revision 0, "Assumptions for Evaluating the Habitability of a Nuclear Power Plant Control Room During a Postulated Hazardous Chemical Release" and RG 1.95 revision 0, "Protection of Nuclear Power Plant Control Room Operators Against an Accidental Chlorine Release".

A database of potential chlorine sources was built based on facilities identified in previous surveys and updated with information from the Grundy and LaSalle County Emergency Services and Disaster Agencies (ESDA). The database was limited to facilities located between the Marseilles and Dresden Island Locks and included facilities within and outside the five-mile radius of LaSalle Station. A total of fourteen facilities in Grundy and LaSalle Counties fit the criteria and were included in this survey.

Data from seven controlling authorities and fourteen facilities was reviewed and followup contacts were made to confirm the information gathered. The 2004 survey identified four facilities that used and stored chlorine onsite. Two of the four chlorine sites identified are located within the five-mile radius of LaSalle Station. All four facilities reported their chlorine was stored in 150 lb. cylinders. Per Regulatory Guide 1.95 revision 0, storage of single containers of chlorine exceeding 150 lbs would require installation of chlorine detectors and automatic protective features located at the fresh air inlet of control room ventilation.

The results of this survey indicate chlorine is used and stored in cylinders that are not larger than 150 lbs. at facilities in the vicinity of LaSalle Station. Also no chlorine is transported on the Illinois River.

2. Introduction

Licensing of LaSalle County Generating Station required a survey of industries and transportation routes in the site vicinity that may use, store, and/or transport hazardous. chemicals. The original survey, conducted in 1975, revealed anhydrous ammonia and probably chlorine were transported by barge on the Illinois River. The information gathered was not complete enough to conclude that chlorine was not shipped in large quantities by barge on the Illinois River.

A new survey was conducted in January-February 1986 to supplement the information obtained from the 1975 chlorine survey. The information collected by the 1986 survey

_

concluded no special chlorine protection provisions were required at LaSalle Station. In the safety evaluation supporting Amendment No. 38 to Facility Operating License No. NPF-11 and Amendment No. 20 to Facility Operating License No. NPF-18, the U.S. Nuclear Regulatory Commission (NRC) agreed with this conclusion, but recommended a three-year update for the Illinois River chlorine survey. Exelon Corporation committed to the survey update in a letter to the NRC dated March 5, 1986. Surveys have been conducted on a 3 year frequency supporting the conclusion that chlorine is not shipped on the Illinois River in sufficient quantities to present a hazard to the LaSalle Station Control Room. In accordance with this commitment, a new survey has been conducted in 2004.

The following sections describe regulatory guides that form the basis of the control room habitability evaluation, results of previous surveys, the methods and results of current survey, and the conclusion regarding chlorine as a hazard. The results of the current survey and previous surveys fully support the 1986 conclusion that no special chlorine protection measures are required at LaSalle Station.

3. Regulatory Guides

Regulatory Guide 1.78 revision 0, "Assumption for Evaluating the Habitability of a Nuclear Power Plant Control Room during a Postulated Hazardous Chemical Release" identifies chlorine as a hazardous chemical that requires a control room habitability analysis in the event of an accidental chlorine release from stationary or mobile sources near the station. Regulatory Guide 1.95 revision 0, specifically addresses onsite accidental chlorine release. However, it can also be used in analyzing effects of an offsite chlorine release.

Regulatory Position 1 of Regulatory Guide 1.78, states chlorine stored or situated at greater distances than five miles from the control room need not be considered in evaluating habitability of the nuclear power plant control room during a postulated chlorine release. Regulatory Guide 1.78 also specifies frequency, distance, and quantity of chemicals transported or stored with respect to the control room that require a control room habitability analysis. The Regulatory Guide specifies three modes of transportation that must be considered for chlorine manufactured, stored or used by industries in the vicinity of the control room: railroads, highways, and waterways.

4. Earlier Surveys Of Chlorine Shipment

The LaSalle County Final Safety Analysis Report (FSAR) Section 2.1.1 describes the location of the plant and transportation routes near the plant. FSAR Section 2.2.2 describes nearby industrial, transportation, and military facilities. All industrial facilities are located outside of a five-mile radius of the plant, therefore, chlorine used or stored at these facilities need not be considered in evaluating control room habitability. A survey of these industries was conducted in 1975 to determine the shipment of chlorine by three modes of transportation, U.S. Highway 6 and State Highway 47, the nearest highways to the station used by these industries and the Chicago Rock Island and Pacific, the nearest railroad, are all located farther than five miles from the station. Therefore, transportation

2

J. . . .

of chlorine by these two modes of transportation need not be considered in the control room habitability analysis.

FSAR Section 2.2.2.4 describes river traffic on the Illinois River passing the site. Section 2.2.3.1.c concluded the only transportation route potentially carrying chlorine within five miles of the station was the Illinois River, which is located approximately 4.7 miles north of the station. However, the available data on commodities transported on the Illinois River (FSAR Table 2.204) did not differentiate barge shipments of chlorine from other chemicals. The survey found a small quantity of chlorine was used by the Illinois Nitrogen Corporation, located at river mile 248.7, approximately five miles north of the station, however, there was not sufficient information available if it was receiving chlorine supply by barge. In order to expedite the licensing process, chlorine detectors were provided in the control room HVAC system intake air ducts.

To supplement the 1975 survey and to obtain additional specific information on chlorine shipments, a survey was conducted during January-February 1986 to determine whether chlorine was, in fact, transported in barges on the Illinois River.

Information was collected from the U.S. Army Corps of Engineers, the U.S. Coast Guard, and Lockmasters for Starved Rock and Dresden Dams. None of the sources had information suggesting chlorine is transported on the Illinois River. Because none of the barge operators, barge terminals, or chemical companies reported chlorine shipments on the Illinois River and neither of the lockmasters was aware of any chlorine passing through their locks, it was concluded that chlorine was not shipped on the river in significant quantities.

5. Year 2004 Survey of Chlorine Shipments

The criteria used for the 2004 survey limited sites of interest to those located between Marseilles and Dresden Island Locks and included facilities within and outside of the five-mile radius of LaSalle Station. Previous surveys were reviewed and updated from reports from Grundy and LaSalle County ESDA's.

Table 1 shows results of the fourteen barge terminals, chemical companies, water treatment plants, and potential chlorine users contacted. None of the barge terminals located between the closest upstream and downstream dams handle chlorine. None of the chemical companies, water treatment plants or other potential chlorine users sends or receives chlorine on the Illinois River. Four facilities were identified using small quantities of chlorine. Two of those sites are located within five miles of LaSalle Station. All four facilities stated their chlorine is transported and stored in 150 lb. cylinders. CSX operates the closest regularly traveled railroad to LaSalle Station. The railroad is located outside the five-mile radius of LaSalle Station

Table 2 shows the results of seven government agencies, public officials, and trade organizations contacted. The Chlorine Institute reported no chlorine is transported on the Illinois River, and has no knowledge of any chlorine producer or distributor located on

the river. United States Coast guard stated that any company transporting chlorine on a barge is required to notify them and that they have not received such notification for the Illinois River. The Corps of Engineers provided information on quantities and material transported on Illinois River for all 8 locks however they do not segregate chlorine from all other chemical products transported.

LaSalle Station HAZMAT Coordinator reported no chlorine used or stored on-site.

Although four facilities were identified using small amounts of chlorine, there was no indication chlorine is transported on the Illinois River.

6. Conclusion of Findings

The 2004 survey concludes chlorine is not transported in any significant quantities on the Illinois River and within a five-mile radius of LaSalle Station. Small quantities of chlorine are used and stored in 150 lb. cylinders at four sites. Two of the four sites identified are within the five-mile radius of LaSalle Station. Regulatory Guide 1.95 C.3 states that only single container quantities exceeding 150 lb. need to be considered for control room ventilation requiring automatic chlorine protection features. Therefore, the 2004 survey concludes that chlorine detectors are not required for the LaSalle County Station.

Table 1. Barge Terminals Chemical Companies, Water Treatment Plants, and Other Potential Chlorine Users in Towns on the Illinois River in the Vicinity of LaSalle Station

Company	County	Address	Phone	Distance to LaSalle Station	Chlorine Identified?
Cargill Inc.	LaSalle	S. Main Street Seneca POC: Bob Matlock	(815) 357-8741	<5 miles	None
Royster-Clark	LaSalle	2100 E. Broadway Marseilles POC: John Moyer	(815) 795-4151	>5 miles	None
Morris Sewage Treatment Plant	Grundy	N. River Road Morris POC: Junior King	(815) 942-0643	>5 miles	Yes 14 – 150 lb cylinders
PCS Phosphates	LaSalle	P.O. Box 88 Marseilles POC: Don Jackson	(815) 795-5111	>5 miles	None
Reichhold Chemicals, Inc.	Grundy	Dupont Road Seneca POC: Tom Martin	(815) 357-6726	>5 miles	None
Shipyard Terminal and Industrial Park	LaSalle	P.O. Box 380 Seneca POC: George Lamb	(815) 357-6721	<5 miles	None
Marseilles Wastewater Treatment Facility	LaSalle	#2 Spicer Lane Marseilles POC: Don Christiansen	(815) 795-2150	>5 miles and < 5 miles	Yes, 150 lb Cyl. 5 stored in side 14 stored outside 5 mile radius
Village of Seneca Wastewater Treatment Facility	LaSalle	301 W. Union Seneca POC: Paul Rivett	(815) 357-8406	<5 miles	Yes 9 – 150 lb cylinders

Table 1 (continued). Barge Terminals Chemical Companies, Water Treatment Plants, and Other Potential Chlorine Users in Towns on the Illinois River in the Vicinity of LaSalle Station

Company	County	Address	Phone	Distance to LaSalle Station	Chlorine Identified?
ADM/Growmark	LaSalle	Towpath Road Ottawa POC: Gary Boyd	(815) 433-3635	>5 miles	None
Field Container Company	LaSalle	240 Main Street Marseilles POC: Don Frederick	(815) 795-2111	>5 miles	None
CF Industries, Inc	Grundy	737 E. DuPont Road Seneca POC: Ron Witalka	(815) 357-8811	>5 miles	None
Evenson Energies LLC	Grundy	2019 Dunn Road Morris POC: Ginger Younker	(815) 942-5800	>5 miles	None
Explosive Energies, Inc	Grundy	7700 DuPont Road Morris POC: Ginger Younker	(815) 942-5802	>5 miles	None
Orica Nitrogen, LLC	Grundy	7700 W Dupont Road Morris POC: Tony Massa	(815) 357-8711	>5 miles	Yes 6 – 150 lb cylinders

Table 2. Government Agencies, rubic Officials and Trade Organizations	Table 2.	Government .	Agencies,	Public	Officials a	and Trac	de Organizations
---	----------	--------------	-----------	--------	-------------	----------	------------------

Organization	Information that Chlorine is Transported on the Illinois River
Chlorine Institute, Rosslyn VA	None
Illinois Department of Transportation, Hazardous Materials Division, Springfield, IL	None
Lockmaster, Marseilles, Illinois	None
Emergency Services and Disaster Agency of LaSalle County, Ottawa IL	None
Emergency Services and Disaster Agency of Grundy County, Morris IL	None
U.S. Army Corps of Engineers, Planning Division, Rock Island, IL	None
U.S. Coast Guard, Chicago IL.	None

•

7. References

Chlorine Institute, Rosslyn, VA, Mr Jack Ahearn, Personal Conservation with Exelon Corporation on 04/02/04, (703) 741-5762

.

Illinois Department of Transportation, Hazardous Materials Division, Springfield, Illinois, (217) 785-3064, Mr. Terry Moore, Personal Conversation with Exelon Corporation on 03/25/04.

Lockmaster, Marseilles Lock and Dam, Marseilles, Illinois, (815) 795-2593, Mr. Jim Hart, Personal Conversation with Exelon Corporation on 03/24/04.

U.S. Army Corps of Engineers, Planning Division, Rock Island, Illinois, (309) 794-5366, Ms. LaVetta Bear, Personal Conversation with Exelon Corporation on 03/24/04.

Grundy County Emergency Services and Disaster Agency, (815) 941-3212, Mr. Jim Lutz, Meeting with Exelon Corporation on 04/05/04.

LaSalle County Emergency Services and Disaster Agency, (815) 433-5622, Mr. Mike Jobst, Meeting with Exelon Corporation on 03/26/04.

Cargill Inc., Seneca, Illinois, (815) 357-8741, Mr. Bob Matlock, Personal Conversation with Exelon Corporation on 03/23/04.

Royster-Clark, Marseilles, Illinois, (815) 795-4151, Mr. John Moyer, Personal Conversation with Exelon Corporation on 03/23/04.

. . .

Morris Sewage Treatment Plant, Morris, Illinois, (815) 942-0643, Mr. Junior King, Personal Conversation with Exelon Corporation on 03/24/04.

PCS Phosphates, Marseilles, Illinois, (815) 795-5111, Mr. Don Jackson, Personal Conversation with Exelon Corporation on 03/23/04.

Reichold Chemicals, Inc., Seneca, Illinois, (815) 357-6726, Mr. Thomas Martin, Personal Conversation with Exelon Corporation on 03/23/04.

Shipyard Terminal and Industrial Park, Seneca, Illinois, (815) 357-6721, Mr. George Lamb, Personal Conversation with Exelon Corporation on 03/23/04.

Wastewater Treatment Facility, Marseilles, Illinois, (815) 795-2150, Mr. Don Christiansen, Meeting with Exelon Corporation on 03/26/04.

Village of Seneca Wastewater Treatment Facility, Seneca, Illinois, (815) 357-8406, Mr. Paul Rivett, Personal Conversation with Exelon Corporation on 03/24/04.

ADM/Growmark, Ottawa, Illinois, (815) 433-3635, Mr. Gary Boyd, Personal Conversation with Exelon Corporation on 03/24/04.

Field Container Company, Marseilles, Illinois, (815) 795-2111, Mr. Don Frederick, Personal Conversation with Exelon Corporation on 03/31/04.

CF Industries, Inc., Seneca, Illinois, (815) 357-8811, Mr. Ron Witalka, Personal Conversation with Exelon Corporation on 03/24/04.

Evenson Energies, LLC, Morris, Illinois, (815) 942-5800, Ms. Ginger Younker, Personal Conversation with Exelon Corporation on 03/24/04.

Explosive Energies, Inc., Morris, Illinois, (815) 942-5802, Ms. Ginger Younker, Personal Conversation with Exelon Corporation on 03/24/04.

Orica Nitrogen LLC, Morris, Illinois, (815) 357-8711, Mr. Tony Massa, Personal Conversation with Exelon Corporation on 03/24/04.

US Coast Guard, Chicago, Illinois, (630) 986-2155, Ms. Shannon Austin, Personal Conversation with Exelon Corporation on 03/26/04.

LaSalle County Generating Station, Marseilles, (815) 357-6761 x 2943, Mr. Fred Bevington, Personal Conversation with Exelon Corporation on 10/04/00.

.

. .

· .

Supplemental Information

1. Regulatory Limits

a. Gaseous Effluents

- 1) The air dose due to noble gases released in gaseous effluents, from each reactor unit, from the site shall be limited to the following:
 - a) During any calendar quarter: Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and
 - b) During any calendar year: Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.
- 2) The dose to an individual from radioiodines and radioactive materials in particulate form, and radionuclides, other than noble gases, with half-lives greater than eight days in gaseous effluents released, from each reactor unit, from the site shall be limited to the following:
- 3)
- a) During any calendar quarter: Less than or equal to 7.5 mRems to any organ, and
- b) During any calendar year: Less than or equal to 15 mRems to any organ.

b. Liquid Effluents

- 1) The dose or dose commitment to an individual from radioactive materials in liquid effluents released, from each reactor unit, from the site shall be limited:
 - a) During any calendar quarter: Less than or equal to 1.5 mRem to the total body and to less than or equal to 5 mRem to any organ, and
 - b) During any calendar year: Less than or equal to 3 mRem to the total body and to less than or equal to 10 mRem to any organ.

c. Total Dose -

1) The dose or dose commitment to any member of the public, due to releases or radioactivity and radiation, from uranium fuel cycle sources shall be limited to less than or equal to 25 mRem to the body or any organ (except the thyroid, which shall be limited to less than or equal to 75 mRem) over 12 consecutive months.

Supplemental Information (continued)

- 2. Allowable Concentrations
 - a. Gaseous Effluents
 - 1) The dose rate due to radioactive materials released in gaseous effluents from the site shall be limited to the following:
 - a) For noble gases: Less than or equal to 500 mRem/year to the total body and less than or equal to 3000 mRem/year to the skin, and
 - b) For all radioiodines and for all radioactive materials in particulate form, and radionuclides, other than noble gases, with half-lives greater than eight days: Less than or equal to 1500 mRem/year to any organ via the inhalation pathway.

÷

45

b. Liquid Effluents

 The concentration of radioactive material released from the site shall be limited to ten (10) times the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to the following:

<u>Nuclide</u>	<u>DWC (µci/ml)</u>
Kr-85m	2.00E-04
Kr-85	5.00E-04
Kr-87	4.00E-05
Kr-88	9.00E-05
Ar-41	7.00E-05
Xe-131m	7.00E-04
Xe-133m	5.00E-04
Xe-133	6.00E-04
Xe-135m	2.00E-04
Xe-135	2.00E-04

3. Average Energy

Not applicable - average energy is no longer used to determine dose to the public.

- 4. Measurements and Approximations of Total Radioactivity
 - a. Gaseous Effluents
 - 1) Containment Vent and Purge System is sampled by grab sample which is analyzed for principal gamma emitters and H-3.
 - 2) Main Vent Stack is sampled by grab sample, which is analyzed for principal gamma emitters and H-3.
 - 3) Standby Gas Treatment System is sampled by grab sample, which is analyzed for principal gamma emitters.

Supplemental Information (continued)

- 4) All release types as listed in 1 and 2 above, at the vent stack and as listed in 3 above, at the Standby Gas Treatment System whenever there is flow, are continuously sampled by charcoal cartridge and particulate filter paper, which are analyzed for iodines and principal gamma emitters. Particulate filter papers are composited and analyzed for gross alpha, Sr-89 and Sr-90. Noble gases, gross beta and gamma are continuously monitored by noble gas monitors for the vent stack and the standby gas treatment system.
- 5) During the period, a correction factor was determined for Station Vent Stack noble gas sampling, as sampling occurs on the suction side of the pump. Due to sample collection at a slight vacuum, study results showed a 10% reduction in actual sample volume collected, compared to container volume. A corresponding 10% correction for sample volume has been assigned for the associated gas marinelli. This reduction in volume resulted in a 10% increase in noble gas activity and corresponding calculated offsite doses. 2003 YTD noble gas activity data was corrected accordingly, with resultant doses re-calculated. Previously reported noble gas activities and associated doses are assumed to have been 10% biased low. Applying a 10% global correction to previously reported values, in no case resulted in approaching any federal limits. Station Vent Stack noble gas data reported herein and hereafter is reported with the aforementioned correction for suction side sampling.
- b. Liquid Effluents

- 1) Batch waste release tanks are sampled each batch for principal gamma emitters, I-131, dissolved and entrained noble gases, H-3, gross alpha, Sr-89, Sr-90 and Fe-55.
- 2) Continuous releases are sampled continuously in proportion to the rate of flow of the effluent stream and by grab sample. Samples are analyzed for principal gamma emitters, I-131, dissolved and entrained noble gases, H-3, gross alpha, Sr-89, Sr-90 and Fe-55.

5. Batch Releases

b.

a. Gaseous

1)	Number of batch releases:	None
2)	Total time period for batch releases:	N/A
3)	Maximum time period for a batch release:	N/A
4)	Average time period for batch releases:	N/A
5)	Minimum time period for a batch release:	N/A
Liquid		
1)	Number of batch releases:	None
2)	Total time period for batch releases: Min.	N/A
3)	Maximum time period for a batch release: Min.	N/A
4)	Average time period for batch releases: Min.	N/A
5)	Minimum time period for a batch release: Min.	N/A
6)	Average stream flow during periods of release of effluent into a flowing stream: gpm	N/A

Supplemental Information (continued)

6. Abnormal Releases

b.

a. Gaseous

1)	Number of releases:	None
2)	Total activity released:	N/A
Liquid		
1)	Number of releases:	None
2)	Total activity released:	N/A

7. Process Control Program

There were no changes to the Process Control Program during this time period.

8. Effluent Monitoring Instrumentation timeclocks and sample anomalies.

There was one effluent monitoring instrumentation timeclock exceeded during this time period. During the reporting period of August of 2003, it was identified that with the Standby Gas Treatment Wide Range Gas Monitor (SBGT WRGM) voltage regulating transformer bypassed, a Design Basis Accident Loss of Coolant Accident (DBA LOCA) without LOOP could result in an under voltage condition on the SBGT WRGM supply bus, as determined by calculation. This calculated under voltage condition was such that the SBGT WRGM would be rendered inoperable. As a result of this issue, the SBGT WRGM was declared inoperable on 1640 hours 8/15/03 and the preplanned alternate was initiated. A 7-day TRM timeclock was entered as a result. Due to the complexity of the troubleshooting involved, the timeclock to restore the SBGT WRGM to operable status expired on 8/22/03 1640. Additionally, on 8/22/03 the PING-3b air monitor was connected in support of SBGT WRGM troubleshooting efforts. It was identified that isokenetic flow was not maintained through the PING-3b for approximately 4 ½ hours due to a procedural non-compliance issue. Isokenetic flow is required to ensure representative sampling. It should be noted that during this timeframe, SBGT had not been initiated. Therefore, no actual consequences from this issue were encountered.

Supplemental Information (continued)

9. Offsite Dose Calculation Manual Revisions.

An entire copy of the ODCM LaSalle Annex is submitted in accordance with Technical Specification 5.5.1 (refer to Appendix A). Following are change summaries for Rev. 6 and Rev. 7:

Rev 6 changes:

1. [10.1.1 & 10.1.2.5] Require air sampler monitoring of the North Service Building at times of: positive pressure in the TB and when ventilation systems are aligned to support U-2 egress.

2. [10.1.1] Add a clarification statement pertaining to the leakage, which is expected from the access hatches located on the Station Vent Stack. This clarification statement addresses nominal leakage during normal operations when the hatches are closed as well as expected actions during maintenance activities.

3. [Table 12.0-1] Add two additional dose contributors (gaseous and liquid) to the Effluent Compliance Matrix.

4. [Table 12.2.2-2] Add a clarification statement that the applicability of surveillance requirements (iodine sampler and particulate sampler) pertaining to the SBGTS monitoring system is during operation of the SBGTS starting 7 days after SBGTS is placed into operation.

ŝ

5. [12.3.3.C] The bases section has the following added statement: This specification implements Tech Spec 5.5.4.f for liquid effluents.

6. [12.4.5.C] The bases section has the following added statement: This specification implements Tech Spec 5.5.4.f for gaseous effluents.

7. [12.4.8.A] This section currently indicates that the applicability of the gaseous effluent section 12.4.8 is Mode 1, Mode 2 and 3 with any main steam line not isolated and steam jet air ejector (SJAE) <u>not</u> in operation. This statement is not in agreement with TS 3.7.6 and is wrong. The wording has been revised to require the SJAE to be in operation. The applicability statement now reads as follows: "MODE 1. MODES 2 and 3 with any main steam line not isolated and steam jet air ejectors (SJAE) in operation."

8. [12.4.8.B.2 Note*] The note becomes the following: "Not required to be performed until 31 days after any main steam line not isolated and SJAE not in operation. (This note is applicable to surveillance requirements related to determining the release rate of the sum of the activities from noble gases prior to the holdup line to be within the limits of specification 12.4.8.A at certain frequencies).

9. [Table 12.5-1] Add an extra Far Field Indicator Location to the REMP program.

10. Revise Table 12.5-3, Detection Capabilities for Environmental Sample Analysis."

11. [12.5.3.A] Clarify requirements for the Interlaboratory Comparison Program which the REMP vendor is required to participate in. As written, there is confusion as to the types of samples, which are required to be included in this inter-comparison.

12. [12.5.1.A] Should the sample location no longer be available, the NRC notification requirement is changing from 180 days to the next available REOR Report.

Supplemental Information (continued)

Rev 7 changes

• • •

1

- 1. Page 10-2 has been revised to remove 1st paragraph reference to Waste Oil Burning.
- 2. Page 10-6, 10.1.3.3 "Release Mixture" has been revised to add the phrase "taken from table 3-3 of General Electric NEDO-10871, March 1973."
- 3. Table 10-1, entitled "Assumed Composition of the LaSalle Station Noble Gas Mixture", <u>has</u> been revised to reflect actual percentage values as well as decimal equivalents. Also added is a reference to the parent document GE NEDO-10871.
- 4. Page 12-4 Definitions 12.1.2 <u>CHANNEL CALIBRATION</u> added a statement referencing the surveillance requirements section(s) for specific calibration requirements.
- 5. Page 12-12 added sentence at the end of Note 3 to clearly state how requirement is implemented.
- 6. Page 12-16 Changed the note for Channel Functional Test from 4 to 3 to enhance the flow of the notes relative to Table 12.2.2-2. Changed the note for Channel Calibration for the Main Condenser Offgas Treatment System
 - Effluent Monitoring System (Post-Treat) from 3 to 5, changed other notes under Channel Calibration from 3 to 4, consistent with note change for Channel Functional Test.

-ţ

0

- 7. Page 12-18 added note 5 for the Offgas Post-Treat Monitor.
- 8. Table 12.4.1-1, entitled "Radioactive Gaseous Waste Sampling and Analysis Program", has been revised to remove "E. Oil Burner" consistent with action 1 above.

LASALLE COUNTY NUCLEAR POWER STATION EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) UNITS ONE AND TWO DOCKET NUMBERS 50-373 AND 50-374 GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

					Estimated
Units	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Total Error %

A. Fission and Activation Gas Releases

1. Total Release Activity	Ci	5.21E+03	4.38E+03	7.05E+03	7.36E+03	3.50E+01
2. Average Release Rate	uCi/sec	6.70E+02	5.57E+02	8.87E+02	9.26E+02	
3. Percent of Technical Specification Limit	%	*	*	*	*	;

B. Iodine Releases

.

1. Total I-131 Activity	Ci	3.14E-01	2.10E-01	3.32E-01	3.35E-01	3.50E+01
2. Average Release Rate	uCi/sec	4.04E-02	2.67E-02	4.18E-02	+ 4.21E-02	
3. Percent of Technical Specification Limit	%	*	*	*	*	

C. Particulate (> 8 day half-life) Releases

1. Gross Activity	Ci	8.96E-03	1.22E-02	2.57E-02	2.98E-02	3.30E+01
2. Average Release Rate	uCi/sec	1.15E-03	1.55E-03	3.23E-03	3.75E-03	
3. Percent of Technical Specification Limit	%	*	*	*	*	
3. Gross Alpha Activity	Ci	6.91E-05	<1.00E-11	1.43E-05	<1.00E-11	

D. Tritium Releases

1. Total Release Activity	Ci	3.50E+01	2.28E+01	4.10E+01	3.71E+01	2.10E+01
2. Average Release Rate	uCi/sec	4.50E+00	2.90E+00	5.16E+00	4.67E+00	
3. Percent of Technical Specification Limit	%	*	*	*	*	

"*" This information is contained in the Radiological Impact on Man section of the report.

LASALLE COUNTY NUCLEAR POWER STATION EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) GASEOUS EFFLUENTS-ELEVATED RELEASE Unit 1 and Unit 2 Continuous Mode

Units	1st Qtr	2nd Qtr	3 rd Qtr	4th Qtr

•

.

č

1. Fission and Activation Gas Releases

Ar-41	Ci	6.66E-04	2.63E-04	<1.00e-4	<1.00e-4
Kr-85	Ci	<1.00e-4	<1.00e-4	<1.00e-4	<1.00e-4
Kr-85m	Ci	8.60E+02	1.15E+03	1.43E+03	1.42E+03
Kr-87	Ci	1.84E+02	2.30E+02	3.96E+02	6.03E+02
Kr-88	Ci	1.24E+03	1.82E+03	2.30E+03	2.40E+03
Xe-131m	Ci	<1.00e-4	<1.00e-4	3.42E-03	<1.00e-4
Xe-133	Ci	1.41E+03	1.01E+03	1.29E+03	1.23E+03
Xe-133m	Ci	4.94E+00	<1.00e-4	1.88E-01	<1.00e-4
Xe-135	Ci	8.08E+02	3.89E+01	1.11E+02	1.66E+02
Xe-135m	Ci	2.02E+02	2.15E+01	3.66E+02	4.59E+02
Xe-138	Ci	4.97E+02	1.07E+02	1.16E+03	1.08E+03
TOTAL	Ci	5.21E+03	4.38E+03	7.05E+03	7.36E+03

2. Iodine Releases

I-131	Ci	3.14E-01	2.10E-01	3.32E-01	3.35E-01
I-132	[:] Ci	2.01E-01	1.97E-01	3.14E-01	2.71E-01
I-133	🕴 Ci	4.78E-01	4.85E-01	8.21E-01	7.77E-01
I-134	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
I-135	Ci	4.00E-01	4.29E-01	7.12E-01	6.47E-01
TOTAL IODINE	Ci	1.39E+00	1.32E+00	2.18E+00	2.03E+00
TOTAL I-131, I-133, I-135	Ci	1.19E+00	1.12E+00	1.87E+00	1.76E+00

3. Particulate (>8 day half-life) Releases

Cr-51	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Mn-54	Ci	<1.00e-11	<1.00e-11	7.08E-05	<1.00e-11
Co-57	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Fe-55	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Co-58	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Fe-59	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Co-60	Ci	4.03E-04	1.72E-04	1.81E-04	2.30E-04
Zn-65	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Sr-89	Ci	2.53E-03	2.49E-03	9.34E-03	9.82E-03
Sr-90	Ci	<1.00e-11	<1.00e-11	<1.00e-11	4.23E-05
Zr-95	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Mo-99	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Ru-103	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Sn-117m	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Cs-134	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
Cs-137	Ci	<1.00e-11	<1.00e-11	<1.00e-11	1.06E-04
Ba\La-140	Ci	5.74E-03	9.22E-03	1.54E-02	1.89E-02
Ce-141	Ci	2.85E-04	3.29E-04	7.54E-04	6.94E-04
Ce-144	Ci	<1.00e-11	<1.00e-11	<1.00e-11	<1.00e-11
TOTAL PARTICULATES	Ci	8.96E-03	1.22E-02	2.57E-02	2.98E-02

4. Tritium Releases

1. Total Release Activity	Ci	3.50E+01	2.28E+01	4.10E+01	3.71E+01
					-

LASALLE COUNTY NUCLEAR POWER STATION EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) LIQUID RELEASES UNIT 1 and UNIT 2 SUMMATION OF ALL LIQUID RELEASES

					Estimated
Units	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Total Error %

A. Fission and Activation Products

1. Total Activity Released	Ci	<lld< th=""><th><lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<>	<lld< th=""><th>N/A</th></lld<>	N/A
2. Average Concentration Released	uCi/ml	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td></lld<></td></lld<>	<lld< td=""><td></td></lld<>	
3. Percent of Applicable Limit	%	*	*	*	*	

B. Tritium

1. Total Activity Released	Ci	<lld< th=""><th><lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<>	<lld< th=""><th>N/A</th></lld<>	N/A
2. Average Concentration Released	uCi/ml	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td></lld<></td></lld<>	<lld< td=""><td></td></lld<>	
3. Percent of Applicable Limit	%	* .	*	* ;	*	

C. Dissolved Noble Gases

1. Total Activity Released	Ci	<lld< th=""><th><lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<>	<lld< th=""><th>N/A</th></lld<>	N/A
2. Average Concentration Released	uCi/ml	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td>r</td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td>r</td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td>r</td></lld<></td></lld<>	<lld< td=""><td>r</td></lld<>	r
3. Percent of Applicable Limit	%	*	*	*	*	

D. Gross Alpha

1. Total Activity Released (estimate)	Ci	<lld< th=""><th><lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th>N/A</th></lld<></th></lld<>	<lld< th=""><th>N/A</th></lld<>	N/A
2. Average Concentration Released	uCi/ml	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""><td></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td></td></lld<></td></lld<>	<lld< td=""><td></td></lld<>	
3. Percent of Applicable Limit	%	*	*	*	*	

E. Volume of Liquid Waste to Discharge	liters	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A
F. Volume of Dilution Water	liters	0.00E+00	0.00E+00	0.00E+00	0.00E+00	N/A

"*" This information is contained in the Radiological Impact on Man section of the report.

LASALLE COUNTY NUCLEAR POWER STATION EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) LIQUID RELEASES UNIT 1 and UNIT 2 BATCH MODE

Nuclides From Batch Releases	Units	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr
H-3	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cr-51	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Mn-54	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Fe-55	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-58	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Fe-59	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Co-60	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zn-65	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-89	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sr-90	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Nb-95	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Zr-95	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Mo-99	Ci	<lld< td=""><td><lld .<="" td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld></td></lld<>	<lld .<="" td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Tc-99m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ag-110m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sb-122	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Sb-124	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
I-131	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cs-134	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Cs-137	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ba\La-140	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ce-141	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Ce-144	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
W-187	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
TOTAL	Ci	None	None	None	None

Xe-131m	Ci	<lld< th=""><th><lld< th=""><th><lld< th=""><th><lld< th=""></lld<></th></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""><th><lld< th=""></lld<></th></lld<></th></lld<>	<lld< th=""><th><lld< th=""></lld<></th></lld<>	<lld< th=""></lld<>
Xe-133	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-133m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
Xe-135m	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>
TOTAL	Ci	None	None	None	None

"<" Indicates activity of sample is less than LLD given in uCi/ml

•

;

LASALLE COUNTY NUCLEAR POWER STATION EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) LIQUID RELEASES UNIT 1 and UNIT 2 CONTINUOUS MODE

Nuclides From Continuous Releases	Units	l st Qtr	2nd Qtr	3rd Qtr	4th Qtr
Gross Alpha	Ci	<1.00E-07	<1.00E-07	<1.00E-07	<1.00E-07
Н-3	Ci	<1.00E-05	<1.00E-05	<1.00E-05	<1.00E-05
Cr-51	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Mn-54	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Fe-55	Ci	<1.00E-06	<1.00E-06	<1.00E-06	<1.00E-06
Co-58	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Fe-59	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Co-60	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Zn-65	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Sr-89	Ci	<5.00E-08	<5.00E-08	<5.00E-08	<5.00E-08
Sr-90	Ci	<5.00E-08	<5.00E-08	<5.00E-08	<5.00E-08
Nb-95	, Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Zr-95	- Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Mo-99	·Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Tc-99m	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Ag-110m	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Sb-122	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Sb-124	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
I-131	Ci	<1.00E-06	<1.00E-06	<1.00E-06	<1.00E-06
Cs-134	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Cs-137	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Ba\La-140	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Ce-141	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
Ce-144	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
W-187	Ci	<5.00E-07	<5.00E-07	<5.00E-07	<5.00E-07
TOTAL	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>

Xe-131m	Ci	<1.00E-05	<1.00E-05	<1.00E-05	<1.00E-05
Xe-133	Ci	<1.00E-05	<1.00E-05	<1.00E-05	<1.00E-05
Xe-133m	Ci	<1.00E-05	<1.00E-05	<1.00E-05	<1.00E-05
Xe-135	Ci	<1.00E-05	<1.00E-05	<1.00E-05	<1.00E-05
Xe-135m	Ci	<1.00E-05	<1.00E-05	<1.00E-05	<1.00E-05
TOTAL	Ci	<lld< td=""><td><lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""><td><lld< td=""></lld<></td></lld<></td></lld<>	<lld< td=""><td><lld< td=""></lld<></td></lld<>	<lld< td=""></lld<>

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

.

.

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS FIRST QUARTER

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL

1.	Spent resins, filter sludges, evaporator bottoms, etc.						
	a.	Quantity shipped cu.m.	0.00E+00				
	b.	Total activity Ci	0.00E+00				
	с.	Major nuclides (estimate %)	N/A				
	d.	Shipment type	N/A				
	e.	Solidification agent	None				
2.	Dry com contamin	pressible waste, nated equipment, etc.					
	a.	Quantity shipped cu.m.	6.60E+02				
	b.	Total activity Ci	3.22E+00				
	c.	Major nuclides (estimate %)					

Mn-54	7.32E+00
Fe-55	4.41E+01
Co-60	2.26E+01
Ni-63	2.21E+01
Zn-65	1.55E+00

d. Shipment type

LSA

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS FIRST QUARTER

3.	Other					
	a.	Quantity shipped	i cu.m.		3.62E+01	
	b.	Total activity	Ci		2.97E+00	
	с.	Major nuclides (estimate %)			
			Mn-54 Fe-55 Co-60 Ni-63 Zn-65	1.12E+0 1.37E+0 4.58E+0 2.10E+0 6.70E+0	1 1 1 1 0	
	d.	Shipment type			LSA	
4.	Irradiate	d Components				
	a.	Quantity shipped	l 'cu.m		0.00E+00	
	b.	Total activity	Ci		0.00E+00	
	c.	Major nuclides	(estimate %)		N/A	
	đ.	Number of ship	nents		0	
	e.	Mode of Transp	ortation		. N/A	
	f.	Destination			N/A	
5.	Solid Wa	aste Disposition				
		<u>1</u>	lumber of Sh	<u>ipments</u>	Transportation Mode	Destination
			7		Truck	ALARON Corporation
			3		Truck	Barnwell Waste
]	FOTAL THIS	S QUARTER	4 14		Truck	Duratek- Bear Creek, TN

Estimated total error % for spent resins, filter sludges, evaporator bottoms, etc. (Jan-Dec) 2.50E+01 Estimated total error % for dry compressible waste, contaminated equipment, etc. (Jan-Dec) 2.50E+01 Estimated total error % for irradiated components (Jan-Dec) N/A

B. IRRADIATED FUEL SHIPMENTS

None

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS SECOND QUARTER

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL

1. Spent resins, filter sludges, evaporator bottoms, etc.

,

2.

a.	Quantity shipped	cu.m.			1.45E+01
b.	Total activity	Ci			3.21E+01
c.	Major nuclides (estin	nate %)			
		Mn-54 Fe-55 Co-60 Zn-65		2.46E+01 1.02E+01 6.13E+01 1.57E+00	
d.	Shipment type				LSA
e.	Solidification age	nt			None
Dry c conta	compressible waste, minated equipment, e	tc.			
a.	Quantity shipped	cu.m.			5.44E+02
b.	Total activity	Ci			2.94E-01
c.	Major nuclides (e	stimate %)			
		Mn-54 Fe-55 Co-60 Ni-63 Zn-65	1.15 1.36 4.52 2.06 7.03	E+01 E+01 E+01 E+01 E+01 E+00	

d. Shipment type

LSA

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS SECOND QUARTER

3.	Other						
	a.	Quantity shipped	cu.m.			5.65E+00	
	b.	Total activity	Ci			4.41E+00	
	с.	Major nuclides (e	estimate %)				
			Mn-54 Fe-55 Co-60 Ni-63 Zn-65	1.02E+0 1.37E+0 4.69E+0 2.20E+0 5.89E+0	1 1 1 1 0		
	d.	Shipment type				LSA	
4.	Irradiate	ed Components					
	a.	Quantity shipped	cu.m			0.00E+00	
	b.	Total activity	Ci			0.00E+00	
	c.	Major nuclides (estimate %)			N/A	
	d. e. f. •	Number of shipm Mode of Transpo Destination	ients rtation			N/A N/A N/A	
5.	Solid W	aste Disposition					
		Nur	nber of Shir	oments	Transpor	tation Mode	Destination
			3		T	ruck	ALARON Corporation
					1	INCK	Duraton-Dour Oroon, 111

TOTAL THIS QUARTER

Estimated total error % for spent resins, filter sludges, evaporator bottoms, etc. (Jan-Dec) 2.50E+01

Truck

Envirocare of Utah

3

12

Estimated total error % for dry compressible waste, contaminated equipment, etc. (Jan-Dec) 2.50E+01 Estimated total error % for irradiated components (Jan-Dec) N/A

B. IRRADIATED FUEL SHIPMENTS

None

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS THIRD QUARTER

SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL

1.	Spent resins, filter sludges, evaporator bottoms, etc.					
	a.	Quantity shipped	cu.m.	1.55E+01		
	b.	Total activity	Ci	3.51E+01		
	c.	Major nuclides (estimate %	6)			
		Mn-54 Fe-55 Co-60 Zn-65	2.35E+01 1.03E+01 6.24E+01 1.47E+00			
	d.	Shipment type	LSA			
	f.	Solidification agent	N/A			
2.	Dry con	pressible waste, contamina	ted equipment, etc.			
	a.	Quantity shipped	cu.m.	2.66E+02		
	b.	Total activity	Ci	1.30E-01		
	c.	Major nuclides (estimate %	6)			
		Mn-54 Fe-55 Co-60 Ni-63 Zn-65	1.16E+01 1.36E+01 4.50E+01 2.05E+01 7.07E+00			

d. Shipment type LSA

:

_

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS THIRD QUARTER

Truck

Truck

Duratek-Bear Creek, TN Envirocare of Utah

3.	Other						
	a.	Quantity shipped	cu.m.		0	.00E+00	
	b.	Total activity	Ci		0	.00E+00	
	c.	Major nuclides (estimate	%)		N	J/A	
	d.	Shipment type			N	J/A	
4.	Irradiat	ted Components					_
	a.	Number of shipments		0			
	b.	Mode of Transportation		N/A			
	c.	Destination			N	J/A	
5.	Solid V	Vaste Disposition					
		N	umber of Shipm	<u>ients</u>	Transport	tation Mode	Destination
			4		Т	ruck	ALARON Corporation

TOTAL THIS OUARTER

Estimated total error % for spent resins, filter sludges, evaporator bottoms, etc. (Jan-Dec) 2.50E+01

Estimated total error % for dry compressible waste, contaminated equipment, etc. (Jan-Dec) 2.50E+01

2

3

9

Estimated total error % for irradiated components (Jan-Dec) N/A

B. IRRADIATED FUEL SHIPMENTS

None

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS FOURTH QUARTER

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL

1. Spent resins, filter sludges, evaporator bottoms, etc.

2.

a.	Quantity shipped		cu.m.	3.14E+01
b. c.	Total activity Major nuclides (e	stimate %)	Ci	4.37E+01
		Mn-54 Fe-55 Co-60 Zn-65	2.08E+01 2.40E+01 5.09E+01 1.64E+00	
d.	Shipment type			LSA
e.	Solidification age	nt		None
Dry co contar	ompressible waste, ninated equipment, e	tc.		
a.	Quantity shipped	cu.m.		1.09E+02
b.	Total activity	Ci		2.10E-02
c.	Major nuclides (e	stimate %)		
		Mn-54 Fe-55 Co-60 Ni-63 Zn-65	1.14E+01 1.37E+01 4.54E+01 2.07E+01 6.93E+00	

d. Shipment type

LSA

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003) SOLID WASTE AND IRRADIATED FUEL SHIPMENTS FOURTH QUARTER

			2		Truck	Envirocare of Utah				
			1 8		Truck Truck	ALARON Corporation Duratek-Bear Creek, TN				
			Number of Shipments	<u>Tran</u>	sportation Mode	Destination				
5.	Solid W	aste Dispositi	on							
	c.	Destination			N/A					
	b.	Mode of Tra	nsportation		N/A					
	a. Number of shipments				0					
4.	Irradiate	ed Component	s							
	d.	Shipment typ	be		N/A					
	c.	Major nuclid	les (estimate %)		N/A					
	b.	Total activity	/ Ci		0.00E+00					
	a.	Quantity ship	oped cu.m.		0.00E+00					
3.	Other (0	Dil for incinera	ation)							

Estimated total error % for spent resins, filter sludges, evaporator bottoms, etc. (Jan-Dec) 2.50E+01

Estimated total error % for dry compressible waste, contaminated equipment, etc. (Jan-Dec) 2.50E+01

Estimated total error % for other irradiated components (Jan-Dec) N/A

B. IRRADIATED FUEL SHIPMENTS

None

RADIOLOGICAL IMPACT ON MAN MAXIMUM DOSES RESULTING FROM RELEASES AND COMPLIANCE STATUS

-

AIRBORNE Effluents - 10CFR50 Listing

.

31-mar-2004 08:45:10

STATION: LASALLE STATION UNIT: 1 PERIOD: 01/01/03 12/31/03 NAME: ODCMLAS REPORT: ANNUAL MODE: ACTUAL

_ _

LASALLE STATION UNIT ONE

ACTUAL 2003 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 INFANT RECEPTOR

TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
GAMMA AIR (MRAD) BETA AIR (MRAD) TOT. BODY (MREM) SKIN (MREM) ORGAN (MREM)	7.09E-02 (WSW) 3.04E-03 (ESE) 5.36E-02 (WSW) 5.67E-02 (WSW) 5.91E-03 (ESE)	8.49E-02 (WSW) 2.80E-03 (ESE) 6.42E-02 (WSW) 6.75E-02 (WSW) 3.93E-01 (ESE)	1.31E-01 (WSW) 4.66E-03 (ESE) 9.92E-02 (WSW) 1.05E-01 (WSW) 8.05E-01 (ESE)	1.38E-01 (WSW) 5.19E-03 (ESE) 1.04E-01 (WSW) 1.10E-01 (WSW) 2.70E-01 (ESE)	4.25E-01 (WSW) 1.57E-02 (ESE) 3.21E-01 (WSW) 3.39E-01 (WSW) 1.47E+00 (ESE)
THIS IS A	THYROID REPORT FOR THE (THYROID CALENDAR YEA	THYROID AR 2003	THYROID	THYROID

COMPLIANCE STATUS - 10CFR 50 APP. I INFANT RECEPTOR

----- % OF APP I. -----

	QTRLY	1ST QTR	2ND QTR	3RD QTR	4TH QTR	YRLY	웅 OF
	OBJ	JAN-MAR	APR-JUN	JUL-SEP	OCT-DEC	OBJ	APP. I
GAMMA AIR (MRAD)	5.0	1.42	1.70	2.63	2.75	10.0	4.25
BETA AIR (MRAD)	10.0	0.03	0.03	0.05	0.05	20.0	0.08
TOT. BODY (MREM)	2.5	2.14	2.57	3.97	4.16	5.0	6.42
SKIN (MREM)	7.5	0.76	0.90	1.40	1.47	15.0	2.26
ORGAN (MREM)	7.5	0.08	5.24	10.73	3.61	15.0	9.83
		THYROID	THYROID	THYROID	THYROID		THYROID

RESULTS	BASED	UPON:	ODCM	ANNEX	REV	/ISION	3.0	MAY 2003	1
			ODCM	SOFTWA	ARE	VERSION	1.1	January	1995
			ODCM	DATABA	ASE	VERSION	1.1	January	1995

•

LASALLE STATION UNIT ONE

ACTUAL 2003 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 CHILD RECEPTOR

TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
GAMMA AIR (MRAD) BETA AIR (MRAD) TOT. BODY (MREM) SKIN (MREM) ORGAN (MREM)	7.09E-02 (WSW) 3.04E-03 (ESE) 5.36E-02 (WSW) 5.67E-02 (WSW) 4.95E-03 (ESE)	8.49E-02 (WSW) 2.80E-03 (ESE) 6.42E-02 (WSW) 6.75E-02 (WSW) 3.95E-01 (ESE)	1.31E-01 (WSW) 4.66E-03 (ESE) 9.92E-02 (WSW) 1.05E-01 (WSW) 8.09E-01 (ESE)	1.38E-01 (WSW) 5.19E-03 (ESE) 1.04E-01 (WSW) 1.10E-01 (WSW) 2.72E-01 (ESE)	4.25E-01 (WSW) 1.57E-02 (ESE) 3.21E-01 (WSW) 3.39E-01 (WSW) 1.48E+00 (ESE)
THIS IS A	THYROID REPORT FOR THE (THYROID CALENDAR YEA	THYROID AR 2003	THYROID	THYROID

COMPLIANCE STATUS - 10CFR 50 APP. I CHILD RECEPTOR

----- % OF APP I. -----

GAMMA AIR (MRAD) BETA AIR (MRAD)	QTRLY OBJ 5.0 10.0	1ST QTR JAN-MAR 1.42 0.03	2ND QTR APR-JUN 1.70 0.03	3RD QTR JUL-SEP 2.63 0.05	4TH QTR OCT-DEC 2.75 0.05	YRLY OBJ 10.0 20.0	% OF APP. I 4.25 0.08
TOT. BODY (MREM) SKIN (MREM) ORGAN (MREM)	2.5 7.5 7.5	2.14 0.76 0.07	2.57 0.90 5.27	3.97 1.40 10.79	4.16 1.47 3.63	5.0 15.0 15.0	6.42 2.26 9.88
		THYROID	THYROID	THYROID	THYROID		THYROID

RESULTS BASED UPON: ODCM ANNEX REVISION 3.0 MAY 2001 ODCM SOFTWARE VERSION 1.1 January 1995 ODCM DATABASE VERSION 1.1 January 1995

LASALLE STATION UNIT ONE

ACTUAL 2003 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 TEENAGER RECEPTOR

TYPE		(1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN		3RD DUARTER DUL-SEP	(4TH QUARTER OCT-DEC	ANNUAL
GAMMA AIR (MRAD) BETA AIR (MRAD) TOT. BODY (MREM) SKIN (MREM) ORGAN (MREM)			7.09E-02 (WSW) 3.04E-03 (ESE) 5.36E-02 (WSW) 5.67E-02 (WSW) 3.83E-03 (NNE)	8.49E-0 (WSW) 2.80E-0 (ESE) 6.42E-0 (WSW) 6.75E-0 (WSW) 2.37E-0 (NNE)	2 1 3 4 (2 9 (2 1 (2 1 (1 4 (.31E-01 WSW) .66E-03 ESE) .92E-02 WSW) .05E-01 WSW) .86E-01 NNE)		1.38E-01 (WSW) 5.19E-03 (ESE) 1.04E-01 (WSW) 1.10E-01 (WSW) 1.64E-01 (NNE)	4.25E-01 (WSW) 1.57E-02 (ESE) 3.21E-01 (WSW) 3.39E-01 (WSW) 8.92E-01 (NNE)
THIS :	IS A	REPORT	THYROID FOR THE	THYROID CALENDAR) T YEAR	HYROID 2003	•	THYROID	THYROID

COMPLIANCE STATUS - 10CFR 50 APP. I TEENAGER RECEPTOR

----- % OF APP I. -----

	QTRLY	1ST QTR	2ND QTR	3RD QTR	4TH QTR	YRLY	% OF
	OBJ	JAN-MAR	APR-JUN	JUL-SEP	OCT-DEC	OBJ	APP. I
GAMMA AIR (MRAD)	5.0	1.42	1.70	2.63	2.75	10.0	4.25
BETA AIR (MRAD)	10.0	0.03	0.03	0.05	0.05	20.0	0.08
TOT. BODY (MREM)	2.5	2.14	2.57	3.97	4.16	5.0	6.42
SKIN (MREM)	7.5	0.76	0.90	1.40	1.47	15.0	2.26
ORGAN (MREM)	7.5	0.05	3.17	6.49	2.18	15.0	5.94
		THYROID	THYROID	THYROID	THYROID		THYROID

RESULTS	BASED	UPON:	ODCM	ANNEX R	REVISION	3.0	MAY 2001	L
			ODCM	SOFTWAR	RE VERSION	11.1	January	1995
			ODCM	DATABAS	E VERSION	11.1	January	1995
ACTUAL 2003 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 ADULT RECEPTOR

TYPE			1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
GAMMA AIR (MRAD) BETA AIR (MRAD) TOT. BODY (MREM) SKIN (MREM) ORGAN (MREM)			7.09E-02 (WSW) 3.04E-03 (ESE) 5.36E-02 (WSW) 5.67E-02 (WSW) 3.76E-03 (NNE)	8.49E-02 (WSW) 2.80E-03 (ESE) 6.42E-02 (WSW) 6.75E-02 (WSW) 2.48E-01 (NNE)	1.31E-01 (WSW) 4.66E-03 (ESE) 9.92E-02 (WSW) 1.05E-01 (WSW) 5.07E-01 (NNE)	1.38E-01 (WSW) 5.19E-03 (ESE) 1.04E-01 (WSW) 1.10E-01 (WSW) 1.71E-01 (NNE)	4.25E-01 (WSW) 1.57E-02 (ESE) 3.21E-01 (WSW) 3.39E-01 (WSW) 9.29E-01 (NNE)
THIS	IS A	REPORI	THYROID FOR THE	THYROID CALENDAR YEA	THYROID R 2003	THYROID	THYROID

•

COMPLIANCE STATUS - 10CFR 50 APP. I ADULT RECEPTOR

----- % OF APP I. -----

	QTRLY	1ST QTR	2ND QTR	3RD QTR	4TH QTR	YRLY	% OF
	OBJ	JAN-MAR	APR-JUN	JUL-SEP	OCT-DEC	OBJ	APP. I
GAMMA AIR (MRAD)	5.0	1.42	1.70	2.63	2.75	10.0	4.25
BETA AIR (MRAD)	10.0	0.03	0.03	0.05	0.05	20.0	0.08
TOT. BODY (MREM)	2.5	2.14	2.57	3.97	4.16	5.0	6.42
SKIN (MREM)	7.5	0.76	0.90	1.40	1.47	15.0	2.26
ORGAN (MREM)	7.5	0.05	3.30	6.76	2.28	15.0	6.20
		THYROID	THYROID	THYROID	THYROID		THYROID

RESULTS	BASED	UPON:	ODCM	ANNEX	RE	/ISION	3.0	MAY 200:	1
			ODCM	SOFTWA	RE	VERSION	1.1	January	1995
			ODCM	DATABA	SE	VERSION	1.1	January	1995

AQUATIC Effluents- 10CFR50 Listing

31-mar-2004 08:49:00

STATION: LASALLE STATION UNIT: 1 PERIOD: 01/01/03 12/31/03 NAME: ODCMLAS REPORT: ANNUAL MODE: ACTUAL

ACTUAL 2003 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 INFANT RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

			QTRLY OBJ	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-DEC	YRLY OBJ	% OF APP. I
TOTAL	BODY	(MREM)	1.5	0.00	0.00	0.00	0.00	3.0	0.00
CRIT.	ORGAN	(MREM)	5.0	0.00	0.00	0.00	0.00	10.0	0.00

RESULTS	BASED	UPON:	ODCM	ANNEX F	REVISION	3.0	MAY 2001	L
			ODCM	SOFTWAR	RE VERSION	1.1	January	1995
			ODCM	DATABAS	SE VERSION	1.1	January	1995

2003 ANNUAL REPORT PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM * PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 INFANT RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

COMPLIANCE STATUS - 40 CFR 141

TYPE	ANNUAL LIMIT	% OF LIMIT
TOTAL	4.0 MREM	0.000
INTERNAL ORGAN	4.0 MREM	0.000

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS	BASED	UPON:	ODCM	ANNEX	REV	VISION	3.0	MAY 2001	L
			ODCM	SOFTWA	ARE	VERSION	1.1	January	1995
			ODCM	DATABA	ASE	VERSION	1.1	January	1995

ACTUAL 2003 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 CHILD RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0 0E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0 0E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

.

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

			QTRLY OBJ	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-DEC	YRLY OBJ	% OF APP. I
TOTAL	BODY	(MREM)	1.5	0.00	0.00	0.00	0.00	3.0	0.00
CRIT.	ORGAN	(MREM)	5.0	0.00	0.00	0.00	0.00	10.0	0.00

RESULTS	BASED	UPON:	ODCM	ANNEX I	REV	ISION	3.0	MAY 2003	L
			ODCM	SOFTWAI	RE	VERSION	1.1	January	1995
			ODCM	DATABAS	SE	VERSION	1.1	January	1995

2003 ANNUAL REPORT PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM * PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 CHILD RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0. 00E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

COMPLIANCE STATUS - 40 CFR 141

TYPE	ANNUAL LIMIT	% OF LIMIT
TOTAL	4.0 MREM	0.000
INTERNAL ORGAN	4.0 MREM	0.000

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS	BASED	UPON:	ODCM	ANNEX	REV	VISION	3.0	MAY 2001	Ļ
			ODCM	SOFTWA	RE	VERSION	1.1	January	1995
			ODCM	DATABA	SE	VERSION	1.1	January	1995

ACTUAL 2003 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 TEENAGER RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNU AL
TOTAL BODY	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0 0E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. ------

			QTRLY OBJ	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-DEC	YRLY OBJ	% OF APP. I
TOTAL	BODY	(MREM)	1.5	0.00	0.00	0.00	0.00	3.0	0.00
CRIT.	ORGAN	(MREM)	5.0	0.00	0.00	0.00	0.00	10.0	0.00

RESULTS	BASED	UPON:	ODCM	ANNEX	REV	ISION	3.0	MAY 2001	L
			ODCM	SOFTW	ARE	VERSION	1.1	January	1995
			ODCM	DATAB	ASE	VERSION	1.1	January	1995

2003 ANNUAL REPORT PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM * PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 TEENAGER RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

COMPLIANCE STATUS - 40 CFR 141

4.0 MREM	0.000
4.0 MREM	0.000
	4.0 MREM 4.0 MREM

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS	BASED	UPON:	ODCM	ANNEX RI	EVISION	3.0	MAY 2001	L
			ODCM	SOFTWAR	E VERSION	1.1	January	1995
			ODCM	DATABASI	VERSION	1.1	January	1995

_____ _

ACTUAL 2003 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 ADULT RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNU AL
TOTAL	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

	ł	QTRLY OBJ	1ST QTR JAN-MAR	2ND QTR APR-JUN	3RD QTR JUL-SEP	4TH QTR OCT-DEC	YRLY OBJ	% OF APP. I
TOTAL BODY	(MREM)	1.5	0.00	0.00	0.00	0.00	3.0	0.00
CRIT. ORGAN	(MREM)	5.0	0.00	0.00	0.00	0.00	10.0	0.00

RESULTS	BASED	UPON:	ODCM	ANNEX	RE\	/ISION	3.0	MAY 200	1
			ODCM	SOFTWA	ARE	VERSION	1.1	January	1995
			ODCM	DATABA	ASE	VERSION	1.1	January	1995

2003 ANNUAL REPORT PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM * PERIOD OF RELEASE - 01/01/03 TO 12/31/03 CALCULATED 03/31/04 ADULT RECEPTOR

DOSE TYPE	1ST QUARTER JAN-MAR	2ND QUARTER APR-JUN	3RD QUARTER JUL-SEP	4TH QUARTER OCT-DEC	ANNUAL
TOTAL	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
INTERNAL ORGAN	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

THIS IS A REPORT FOR THE CALENDAR YEAR 2003

COMPLIANCE STATUS - 40 CFR 141

TYPE	ANNUAL LIMIT	% OF LIMIT
TOTAL	4.0 MREM	0.000
INTERNAL ORGAN	4.0 MREM	0.000

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS	BASED	UPON:	ODCM	ANNEX RE	VISION	3.0	MAY 2001	L
			ODCM	SOFTWARE	VERSION	1.1	January	1995
			ODCM	DATABASE	VERSION	1.1	January	1995

******* * DELIVER TO HEALTH PHYSICS * ****** 31-mar-2004 08:48:14 Total Effective Dose Equivalent - 10CFR20 Listing STATION: LASALLE STATION UNIT: 1 01/01/03 12/31/03 PERIOD: ODCMLAS NAME: ANNUAL REPORT: ACTUAL MODE: For ADULT dose calculations, the included pathways are: INHALATION MILK PRODUCE VEGETABLES MEAT GROUND DEPOSITION FISH WATER SKYSHINE WHOLE BODY

Airborne Effluents are complete from 01/01/03 to 12/31/03 Aquatic Effluents are complete from 01/01/03 to 12/31/03 Skyshine entries are complete from 01/01/03 to 12/31/03

10 CFR 20 COMPLIANCE ASSESSMENT PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03 CALCULATED 03/31/04

1. <u>10 CFR 20.1301 (a)(1) Compliance</u> Total Effective Dose Eqivalent, mrem/yr <u>6.83E-01</u>

10 CFR 20.1301 (a)(1) limit mrem/yr _____100.0 % of limit _____0.68

Compliance Summary - 10CFR20

	lst	2nd	3rd	4th	% of
	Qtr	Qtr	Qtr	Qtr	Limit
TEDE	1.41E-01	1.58E-01	1.85E-01	1.98E-01	0.68

RESULTS BASED UPON: ODCM ANNEX REVISION 3.0 MAY 2001 ODCM SOFTWARE VERSION 1.1 January 1995 ODCM DATABASE VERSION 1.1 January 1995

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 03/31/04

2. <u>10 CFR 20.1301 (d)/40 CFR 190 Compliance</u>

		Dose (mrem)	Limit (mrem)	% of Limit
Whole Body (DDE)	Plume Skyshine Ground Total	3.21E-01 3.18E-01 2.09E-03 6.41E-01	_25.0	2.56
Organ Dose (CDE)	Thyroid Gonads Breast Lung Marrow Bone Remainder	$\frac{8.66E-01}{1.60E-02}$ $\frac{1.61E-02}{1.61E-02}$ $\frac{1.62E-02}{1.63E-02}$ $\frac{1.63E-02}{1.68E-02}$	75.0 25.0 25.0 25.0 25.0 25.0 25.0	$ \begin{array}{r} 1.16\\ 0.06\\ 0.06\\ 0.06\\ 0.06\\ 0.07\\ 0.07\\ 0.07\\ \end{array} $
	CEDE	<u>4.18E-02</u>		
	TEDE	<u>6.83E-01</u>	100.0	0.68

RESULTS BASED UPON: ODCM ANNEX REVISION 3.0 MAY 2001 ODCM SOFTWARE VERSION 1.1 January 1995 ODCM DATABASE VERSION 1.1 January 1995 31-mar-2004 08:50:06

Total Effective Dose Equivalent - 10CFR20 Listing

STATION: LASALLE STATION UNIT: 2 PERIOD: 01/01/03 12/31/03 NAME: ODCMLAS REPORT: ANNUAL MODE: ACTUAL

For ADULT dose calculations, the included pathways are: INHALATION MILK PRODUCE VEGETABLES MEAT GROUND DEPOSITION FISH WATER SKYSHINE WHOLE BODY

Airborne Effluents are complete from to Aquatic Effluents are complete from to Skyshine entries are complete from 01/01/03 to 12/31/03

10 CFR 20 COMPLIANCE ASSESSMENT PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03 CALCULATED 03/31/04

1. <u>10 CFR 20.1301 (a) (1) Compliance</u>

Total Effective Dose Eqivalent, mrem/yr _____2.86E-01 10 CFR 20.1301 (a)(1) limit mrem/yr _____100.0 % of limit _____0.29

Compliance Summary - 10CFR20

	lst	2nd	3rd	4th	% of
	Qtr	Qtr	Qtr	Qtr	Limit
TEDE	4.68E-02	8.88E-02	6.07E-02	8.96E-02	0.29

RESULTS BASED UPON: ODCM ANNEX REVISION 3.0 MAY 2001 ODCM SOFTWARE VERSION 1.1 January 1995 ODCM DATABASE VERSION 1.1 January 1995

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 03/31/04

2. <u>10 CFR 20.1301 (d)/40 CFR 190 Compliance</u>

		Dose (mrem)	Limit (mrem)	% of Limit
Whole Body (DDE)	Plume Skyshine Ground Total	0.00E+00 2.86E-01 0.00E+00 2.86E-01	25.0	1.14
Organ Dose (CDE)	Thyroid Gonads Breast Lung Marrow Bone Remainder	0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00	$\begin{array}{r} 75.0 \\ 25.0 \\ 25.0 \\ 25.0 \\ 25.0 \\ 25.0 \\ 25.0 \\ 25.0 \\ 25.0 \end{array}$	$ \begin{array}{r} 0.00\\ 0.00$
	CEDE	<u>0.00E+00</u>		
	TEDE	<u>2.86E-01</u>	100.0	0.29

RESULTS BASED UPON: ODCM ANNEX REVISION 3.0 MAY 2001 ODCM SOFTWARE VERSION 1.1 January 1995 ODCM DATABASE VERSION 1.1 January 1995

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003)

METEOROLOGICAL DATA

.

MURRAY & TRETTEL, INC.

Friday, January 30th, 2004

Mr. Mike Wolfe Rad Protection LaSalle Station Exelon Nuclear 2601 N. 21st Road Marseilles, IL 61341

Dear Mr. Wolfe:

Enclosed are copies of the LaSalle Station meteorological site quarterly joint-frequency wind rose tables for 2003. They are being sent pursuant to the Specification for Meteorological Data and Meteorological Monitoring Services & Maintenance (MET1), 3.3.2,3.3.3, METSPECS/18/15 and METSPECS/18/41, Table 2a, format of wind rose table.

At this time, we would like to request the 2003 effluent data for your nuclear plant. The effluent data is required to process the 2003 annual report on the Meteorological Monitoring Program as per Specification No. MET1 3.3.4.

In order to expedite the annual report generation, please forward the 2003 effluent data from your plant to:

Mail: Tom Begley Murray & Trettel, Inc 414 W. Frontage Road Northfield, IL 60093 Fax: 1-847-446-8130

E-mail: mt@weathercommand.com

If you have any questions, please contact Tom Begley @ (847) 446-7800 x 175.

Sincerely,

Tom Begley Environmental Meteorologist

Enclosures

or

414 WEST FRONTAGE ROAD • NORTHFIELD, IL • 60093 PHONE: (847) 446-7800 • FAX: (847) 446-8130 E-MAIL: <u>MT@WEATHERCOMMAND.COM</u> • INTERNET: <u>HTTP://WWW.WEATHERCOMMAND.COM</u>

Period of Record: January - March 2003 Stability Class - Extremely Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind	Wind Speed (in mph)							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total	
N	0	O	0	. 0	0	0	0	
NNE	Ο.	0	l	0	0	0	1	
NE	0	0.	0	. 5	0	0	5	
ENE	0	0		Ο.	· 0 ·	0	0	
E	0	0	0 ·	• 0 .	0	0	0	
ESE	0	· · · ·	· · 0		0	0	0	
SE	• 0	0	0	0	.0	0	0	
SSE	0	0	1	. 0	0	. 1	2	
S	0	0	0	0	0	0	0	
SSW	0	0	· 0	0	0	. 0	0	
SW	0	0	· 1	. 3 ·	3	. O ·	7	
WSW.	0.	0	0	· 0	· 3	0	3	
W	O	0.	0	0	0	0	0	
WNW	0	0	. 0	0	2	0	2	
NW .	0	0	0	0	0	. 0	0	
NNW	• 0	Ō	. 0	· 0	0	0	0	
Variable	0	0 .	0	0	0	0	0	
Total	0	0	3	8	8	1	20	

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

		Wind Speed (in mph)							
Wind Direction	· 1-3	4-7	8-12	13-18	19-24	> 24	Total		
N	0	0	0	• 0	0	0	0		
NNE	0	0	1	0	0	0	1		
NE	0	0	0	0	2	0	2		
ENE	0.	Ò	l	0	0	0	1		
Е	0	0	0	0	O	0	0		
ESE	0	0	0	0	0	0	0		
SE	0	0	1	0	· 0 ·	0	1		
SSE.	0	l	3	0	O	 1 .	5		
S	0	2	. 3	0	1	0	6		
SSW	0	0	1	1	3 ·	0	5		
SW	0	0	· 5	б.	l	0	12		
wsw	0	0	0	.0	4	0	4		
W	0	0.	0	1	2	0	3		
WNW	. O .	0	. 1	: 2	1	0	4		
NW	0	0	1	. 1 [.]	2	0.	4		
NNW	0	0	0	0	0	0	0		
Variable	0	0	0	. 0	0	0	0		
Total	0		17	11	16	1	48		

Period of Record: January - March 2003 Stability Class - Moderately Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Wind Speed (in mph)							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	0	2	1	0.	0	3
NNE	0	1	2	3	0	0	6
NE	0	Ο.	2	O	2	0	4
ENE	0	0	0	0	0	0	0
Е	0	0	0	1	0	0.	1
ESE	0	1	0.	0	. 0	0.	1
SE	0	2	1	0	. 0	Ó	3
SSE	0	2	2	0	2	· 1	7
S ·	0	2	4	2 .	0	0	8
SSW	0	0	l	1	1	0	3
SW	0	2	· 2	7	4	0	15
WSW	0	0	2	4	3	1	10
W	0	0	2	4	3	0	9
WNW	0	2	1	8	6	0	17
NW	0	0	. 4	4.	0	0	8
NNW	0	1	5	0	0	ò	6
Variable	0.	0	0	· 0	0	0	0
Total	0	13	30	35	.21	2	101

Period of Record: January - March 2003 Stability Class - Slightly Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 0

. •

. –	. Wi	nds Mea	sured at	33 Feel	t.	•	• • • •	
Mind		W	ind Speed	i (in mpl	n)		· · ·	•
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total	••••
N	1	16	· 42	36	6	0	101	
NNE	0	19	31	25	o	O	75	· · ·
NE	1	5	15	24	44	l	90	
ENE	0	2	6	10	7	0	25	• •
Е	0	5	8	10	0	0.	23	. ·
ESE	1	3	0	0	· 0	0	4	
SE	0	7	6	5	2	0	20	· · ·
SSE	1	7	6	2	1 .	1	18	
S	0	8.	. 17	17	• 4	0	46	
SSW	1	8.	8	·8	l	0	26	•
SW	1	7	26	31	10	1	76	
WSW	2	4	10	13	15	2	46	• • •
W	2	9	1.8	13	14	· 0	56	•••
WNW	1	17	41	48	39	7	153	· ·. ·
NW	2	9	46	27	9	6	99	·• ·
NNW	1	16	. 64	89	4	0	174	•
Variable	0	0 ·	0	0	· 0	0	Ŏ	
Total	14	142	344	358	156	18	1032	· · ·

n

Period of Record: January - March 2003 Stability Class - Neutral - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

					-		•		
Wind	Wind Speed (in mph)								
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total		
N	3	14	6	. 4	0	0	27		
NNE	2	7	: 7	. 2	. 0	 0	18		
NE	1	· 3	6	· 3 .	10	0	23		
ENE	0	4	7	2	0	0 ·	13		
E	1	13	13	6	0	0 [.]	33		
ESE	1	• 7	8	2	0	· 0	18		
SE	· 1	14	13	. 1	1	0	. 30		
SSE	1	7	. 9	. 5	0	0	. 22		
S	2	7	. 5	21	4	. 0	39		
SSW	2	9	17	16	· • 4	0	48 .		
SW	1	8	25	17	2	1	54		
wsw	0	6	11	17	5	0	39		
W	0	. 4	14	11	5	0	34		
WNW	2	15	25	35	7	14	98		
NW	0	16	26	3	2	0	47		
NNW	1	12	· 7	5	0	0	25		
Variable	0	.	. 0	0	· 0	0	. 0 .		
Total	18	146	199	150	40	15	568		

Period of Record: January - March 2003 Stability Class - Slightly Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

0

Period of Record: January - March 2003 Stability Class - Moderately Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind		. Wi	nd Speed	i (in mph	1)		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	1	0	: • 0	0	0	1
NNE	0	0	0	0	. O	0	0
NE	1	2	0	0	0	0	3
ENE	1	1	5	0	. O	0	7
E	1	8	5 ·	. 0	· 0	0	14
ESE	0	14	7	0	.0	O	21
SE	1.	· 7	9	2	0	· 0	19
SSE	· 0	6.	l	1	0	0	8
S	0	4	2	2	0	· 0	8
SSW	0	5	. 4	2	· 1	0	12
SW	. 0.	2	12	3	0	0	17
wsw	0	6	17	3	1	0	27
W	1	9	9	. 8	1	0	28
WNW	1	12	12	б	3	0 ·	34
NW	0	5	12	2	0	0	19
NNW	0	1	0	0	• 0	0	1
Variable	0	· `0	0	0	0	0	0
Total	6	83	95	29	6	0	219

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

3

,

Period of Record: January - March 2003 Stability Class - Extremely Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind		Wind Speed (in mph)											
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total	•.					
N	0	0	0	0	0	0	0						
NNE	0	· 0	0	0	0	· · 0	. 0	•					
NE	0	0	0	0	0	0	0						
ENE	0	` 1	· 0 ·	0	0	0	. 1	•					
E	0	1.	2	0	0	0	3						
ESE	0	2	3	· o [:]	0	. 0	-5						
SE	0	3	5	0	0	0	8	· • •					
SSE	0	5	3	0	0	0 ·	8	·					
S	0	10	28	0	· . 0	0	38	•					
SSW	· 0	5	21	1	0	. 0	27	•					
SW	0	6	20	: 0	• 0	0	26						
WSW	0	5	6	. 0	0	0	11						
W	0	14	10	. 3	0	0	27						
WNW	0	9	2	. 0	0	. 0	11						
NW	0	3	2	0	0	0	. 5						
NNW	0	0	0	· 0	0	0	0	•					
Variable	. 0	0	0	0	0	0	. 0						
Total	· 0	64	102	4	0	0	170	• •					

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

	LM	.nas Meas	ured at	375 reet	C			
Wind		Wi	nd Speed	d (in mpl	h)	•	· .	
Direction	1-3	4-7	8-12	13-18 ·	19-24	> 24	Total	
N	0	0.	0	. 0	0	0	. 0	
NNE	· 0	0	0	0	0	0	0	
NE	0	0	0	0	0	0		
ENE	0	0	0	0	0	0.	0 ·	•.
Е	0	0	0	0	0	0	0	•
ESE	. 0	0	. O	0	0	0	0	· *
SE	0	0	· 0	0	. 0	0	Ο.	•
SSE	Ò	0	0	0	0	0	0	
S	0	0	0	0	0	0	0	÷
SSW	0	0	0	0	0	0	0	•
SW	0	• 0	0	1	. 0	0	1	•
WSW	0	0	0	·0	. 0	0	0	
W	0	0	0	0	0	0	0	•
WNW	0	0	Ο	0	0	0	· 0 ·	
NW	0	0	Ō	. 0	0	0	0	
NNW	0	0	.0	0	0 ·	0	: 0	
Variable	0	0 .	0	0	. 0	0	. 0	. • .
Total	0	· 0 ·	0	1	Ò	· 0	1	

Period of Record: January - March 2003 Stability Class - Extremely Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

the d	Wind Speed (in mph)										
Direction	1-3	4-7	8-12 [°]	13-18	19-24	> 24	Total	·.			
N	0	0	0	0	. 0	0	· 0				
NNE	0	0	0	0	0	0	0				
NE	0	0	0	0	1	O	1				
ENE .	0	0	0	0	0	0	0				
Ε	0	0	· 0	0	0	0	O	•			
ESE	0 ·	0	0	0	0	0	0				
SE	· 0	0	Ó	o	0	0	O .	:			
SSE	0	0	0	0	0	0	0				
S	0	0	0	0	0	0	0	•			
SSW	0	0	0	0	· 0	0	0	•			
SW	0	0	0	· 1	0	0.	1	•			
WSW	0	0	0	0	0	0	0				
W	0	0	0	· 0	. 0	0	0	• ·			
WNW	0	0	0	0	0	0	0	·			
NW	0	0	0	0	0	· 0	О	•			
NNW	0	0	0	Ο	O	o .	0	: •.			
Variable	0	0	• 0	. 0	0	· 0	0	•			
Total	0	0	0	1	l	0	2	•			

Period of Record: January - March 2003 Stability Class - Moderately Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

		nus meas	bureu ac	575 1660	- .	•	•	
Wind		. Wi	nd Speed	i.(in mpl	1)	. • •	•	•
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total	
N	0	0	0	0	0	0	0	
NNE	0	0	0	0	0	. 0	0	
NE	0	0	0	0	3	0.	3	·
ENE	0	0	0	0	0	0	0	· ·
Е	0	0	0	0	0	0	0	•
ESE	0	0	0	0	0	0	0	·
SE	· 0	0	. 0	. 0	0	0	0	••
SSE	0	0	0	• 0	Ö	0	0	• • •
S	0 ·	0	1	O	0	Q.	1	
SSW	0.	Ò	0	0	0	0 ·	0	•
SW	0	0	0	0	1	2	3	••••
WSW	0	0	. 0	. 0	. · O	2	2	•
W	0	0	. 0	0	0	0 .	0	
WNW	0	0	0	0	0	. 0	0	•
NW	0	0.	· 0	0	0	. 1	l	
NNW	0	. 0	0	0	0	0	0	•
Variable	0	0	0	0	· 0 ·	. 0	0	
Total	0	0	1	0	4	5.	10	

2

Period of Record: January - March 2003 Stability Class - Slightly Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Stability (Period o Class - No Win	f Record eutral nds Meas	l: Januar ured at	ry - Marc - 37 375 Feet	ch 2003 75Ft-33Ft :	Delta-1	r (F)	•
174 7	•	Wi	nd Speed	l (in mpl	1) ·		•	
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total	• •
 N	0	5	 9	37	30	26	107	•
NNE	0	4	29	10	28	3	74	
NE	0	1	8	25	16	65 ·	115	
ENE	1	3	11	. 8	5	21	49	•
Ε	0	3	6	· 8	6	0	23	•
ESE	0	2	3	2	2	0	9	• •
SE	1	7	4	.1	· 2	1	16	
SSE	0	8	13	5	3	7 ·	36	• •
S	1	11	. 21	13	13	4	63	•
SSW .	1	1	. 9	13	10	5	39	· .
SW	0	8	18	35	32	19	112	•
WSW	1	3	6	13	17	19	59	
W	0	6	12	17	11 .	13	59	
WNW	2	10	24	34	39	59	168	÷
NW	1	8	33	49	52	33	176	•••
NNW	0	11	40	54	45	. 8	158	
Variable	0	0	0	· 0	0	0	0	•
Total	· 8	91	246	324	311	283	1263	

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

· · · ·	Wi	nds Mea	asured at	375 Fee	t	Derca	. (.,	•
Wind		Ţ	Wind Speed	l (in mp	h)			•
Direction	1-3	4-7	8-12	13-18 	19-24	> 24	Total	
N	0	· 3	. 3	12	0	0	18	· • ,
NNE	0	4	3	4	1	0	12	•
NE .	2	1	4	3	7	1	18	· · ·
ENE	0	4	· 4	1	3	0	12	
E	· 1	• 4	4	3	2	5	19 ·	•
ESE	1	6,	10	9	ı	5	32	· • •
SE	· 0	3	6	11	. 7	0	27	
SSE	0	2	7	10	8	5	32	•
S	1	. 0	· 4 ·	4	6	16	31	••• •
SSW	• 0	2	7	· 7	9	29	54	
SW	0	0	3	9	17	25 [°]	54	•
WSW	0	· 1	4	3	· · 9	19	36	· ·
W	0	3	5	1	9	23	41	· · .
WNW	0	3	3	10	13	53	82	
NW	0	1	14	18	25	18	76	
NNW	2	. 5	5	11	4	5	32	
Variable	0	0	0	0	0	0	0.	
Total	7	42	86	116	121	204	576	

2

Period of Record: January - March 2003 Stability Class - Slightly Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Wind		W	ind Speed	d (in mp)	h)	. <i>.</i>	•
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	0	1	0	0	0	1
NNE	0	0	0	. 0	. O	0	0
NE	0	1	0	0	Ο	0	1
ENE	· 0	0	0	0	2	1	3
E.	0	1	3	2	2	0	8
·ESE	0	. 0	0	2	2	2	6
SE	0	0	2	3	4	4	13
SSE	. 0	0	··· 2	. 3	7	8	20
S	0	0	3	6	2	2	13
SSW	0	2	0	5	6	. 10	23
SW	0	. 0	0	4	· . 4	10	18
WSW	0	1	2	8	3	8	22
W	0	0	. 8	7	7	12	. 34 .
WNW	0	0	2	. 2	11	13	28
NW	0	2	2	15	4	. 3	26
NNW	0	· 0	1	· 6 ·	l	0	8
Variable	0	0	0	0	. 0	0	0
Total	0	7	26	63	. 55	73	224

Period of Record: January - March 2003 Stability Class - Moderately Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 2 Hours of missing stability measurements in all stability classes:

Period of Record: January - March 2003 Stability Class - Extremely Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Wind		Wi	ind Speed	l (in mpl	h)			·
Direction	1-3	4-7	8-12	13-18	19-24	> 24 [°]	Total	· .
N	0	0	0	0	· 0	0	0	
NNE	0	0	· 0	. 0	0	ο	0	· ·
NE	0	О	. 0	0	0	0	· · O	
ENE	0	· 0	0	ο	. 0	0	0	
Е	0	· 0	0	0	0	0	· 0 ·	
ESE	0	0	o	1.	0	· `0	1	• .
SE	0	1	0	0	0	0	1	· · ·
SSE	ο	0	0	1	l	0	2	· ·
S	0	0	2	1	2	4	9	
SSW	0	0 ·	1	4	7	· 9	21	
SW	1	. 1	· 1	1	9	11	24	•
WSW	0	1	0	3	6	1	11	•
W	0	0	1	1	0	0	2	•
WNW	0	· 0 ·	0	1	2	2	5	•
NW	0	0 ·	. 0	1	0	· 0	1	. •
NNW	· 0	1	0	1	0	· 0	2	:
Variable	. 0	. 0	0	· 0	0	0	0	·
Total	1	4	. 5	15	27	27	79	

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes:

Period of Record: April - June 2003 Stability Class - Extremely Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

	. W1	nas Meas	sured at	33 Feet			
Wind		Wi	nd Speed	(in mph	1)		• .
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	2	2	3	0	. 0	· 7
NNE	0	0	7	2	0	0	9
• NE	0	0	17	1	1	0	19
ENE	0	0	6	.3	1	0	10
E	0	0	1	0	3	0	4
ESE	0	0	0	. 0 .	0	0	0
SE	0	0	1 .	0	_ 1	0	2
SSE	0	0	4	· 1	· · O	· 0	5
S	0	Ο	· 1	4	• 0	0	- 5
SSW	0	. 0	_ 4	9	3	0	16
SW	0	1	0	1	3	0	5
WSW	0	0	· 3 ·	. 1	11	0	15
W ·	0	0	4	0	0	0	4
WNW	0	0	0	3.	0	· 3	6
NW	0	0	. 0	Ó	0	0	0
NNW	0	0	2	5	2	0	9
Variable	0	0	. 0	0	0	0	0
Total	0	3	52	33	25	3	116

Period of Record: April - June 2003 Stability Class - Moderately Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

. 0

Mind	Wind Speed (in mph)										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
. N	0	 8	5	3	0	0	. 16				
NNE	0	7	8	1	0	0	16				
NE	0	12	13	1	1	0	27				
ENE	0	4	9	4	0	0	17				
Е	1	2	2	. 4	1	0	. 10				
ESE	· 0	3	i	Ο.	• 0	. 0	.4				
SE	• 0	2	2	0.	2	• 0	6				
SSE	· 0	` 0 .	2	5	0	0	· 7				
S	0	0	1	l	3	0	5				
SSW	0	0	6 [.]	3	4	3	16				
SW	0	1	1	2.	. 4	0	· 8				
WSW	· 0	1	2	4	· 1·	. 0	8				
W	0	0	5	2	2	O	9				
WNW	ο	l	2	1	2	3	9				
NW	. 0	1	7	7	1	0	16				
NNW	0	1	8	5.	. 3	· 0	17				
Variable	0	0	0	0	0	0	0				
Total	1	43	74	43	24	6	191				

Period of Record: April - June 2003 Stability Class - Slightly Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes: 0

Period of Record: April - June 2003 Stability Class - Neutral - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

. •

:

117 i	Wind Speed (in mph)										
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total				
N	3	27	37	5	0	0	72				
NNE	2	34	73	5	0	0	114				
NE	1	34	46	34	5	O	120				
ENE	1	26	33	54	13	10	137				
E	1	7	17	19	15	1	60				
ESE	0	3	6	7	6	ı	23				
SE	1	· 2 ·	11	12	3	2	31				
SSE	2	6	. · 7	[.] 6	0	0	21				
S	2	4	11	11	5	0	33				
SSW	1	3	8	3	3	1	19				
SW	0	· 4	5 ·	10	6	1	26				
WSW	1	2	10	10	6	8	37				
W	0	5	17	10	7	7 _:	46				
WNW	1	5	11	11	15	Ο.	43				
NW	0	7	11	14	2	0	34				
NNW	2	12	25	12	5	0	56				
Variable	0.	0.	0	0	0	0	0				
Total	18	181	328	223	91	31	872				

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:
Wind		. W.	ind Speed	d (in mph	1)	•	
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Tota
N	1	39	11	2	0	0	53
NNE	0	37	25	1 .	· 0	0.	63
NE	0	10	40	· 8	0	0	58
ENE	1	2	.31	23	0	0	57
E	0	17	43	. 14	1	· 0	75
ESE	0	5	· 9	0	2	0	16
SE	1	0	. 3	4	1	0 ·	9
SSE	0	5	· 4	7	1	0	17
S.	1	5	7.	.7	5	1	26
SSW	· 0	6	б	· 9	6	3	30
SW	1.	. 7	21	6	2	0	37
wsw	1	4	14	4	0	_ 1	24
W	1.	5	5	4	0	4	19
WNW	0	2	2	1.	6	4	15
NW	0	3	· 7	2	0	0	12
NNW	0	. 7	10	2	0 ·	· · · 0 ·	19
Variable	0	0	0	. 0	0	. O	0
Total	7	154	238	94	24	13	530

Period of Record: April - June 2003 Stability Class - Slightly Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: April - June 2003 Stability Class - Moderately Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind			-	 -	•	•	
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
			. .	•••••	•••••• ·		
N	1	10	. 1	0	0	0	12
NNE	0	16	0	0	0	0	16
NE	2	· . O	. 0	0.	0	0	2
ENE	1	1	0	0	0	0	2
Е	1	8	23	· 0	· 0	0	32
ESE	0	. 10	4	1	. 0	0	15
SE .	0	6	2	1 ·	0 [.]	0	· 9
SSE	0	7	3	l	0	· 0	11
S	l	4	17	4	0	0	26
SSW	0	. 2	7	4 .	4	0	17
SW	0	5	6	14	. 0	• 0 •	25
wsw	2	5	6	0	0	0	13
W	2	4	1	• 0	0	0	7
WNW	1	3	3	2	Ó	0	9
NW	0	7	1	0	0	0	8
NNW	0	7	1	. O	0	0	8
Variable	· 0	0	· 0	0	0	0 ·	0
Total	11	95	75	27	4	0	212

Wind Speed (in mph)

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: April - June 2003 Stability Class - Extremely Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Wind	Wind Speed (in mph)								
Direction	1-3	4-7	8-12	13-18 	19-24	> 24	Total		
N	0	0	0	. 0	0	0	0		
NNE	0	0	0	. 0	. 0	. O	0		
NE	0	0	<u></u> 0	. 0	0	· O	0		
ENE	0	0 .	0	0	0	0	0		
E	0	0	0	0 [°]	. 0	. 0	0		
ESE	0	0	0	· 0 ·	0	0	0		
SE	. 0	0	0	. 0	0	0	0		
SSE	0	0	. 0	0	0	· 0	0		
S	0	0	0	0	0	0	0		
SSW	0	0	· 0	0	0	0	0		
SW	0	0	 O ·	0	0	0	0		
WSW	0	0	. 0	0	0	. o	0		
W	0	0	0	0	0	0	0		
WNW	0	0	. 0	0	0	· 0	0		
NW	0	0	0	0	0	0	0		
NNW	· 0	0	0	Ò	0	0	0		
Variable	0	0	0	. 0 .	0	. 0	0		
Total	0	0	0	0	0	0	0		

Period of Record: April - June 2003 Stability Class - Extremely Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: April - June 2003 Stability Class - Moderately Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

		•	-	· ·		
1-3	4-7 	8-12	13-18	19-24	> 24	Total
ò	0	0	0	0 . 0	0	0
0	0	0	1	0	0	1
0	0	0	: 0	. 0	0.	0
0	0	0	0	0	0	0
0	0	.0	0	0	0	0
. 0	0	.0	0	0	0	0
0	0	. . 0	0	0	0	0
· 0	0	· O ·	0	0	0	0
0	0	. 0	. 0	· 0	• 0 ·	0
Ο.	. 0	0	. 0	2	· 3	5
0	0	0	0	1	2	3
0	0	0	2	0	0	2
0	0	· 0	0	· 0	0	0
0	0	0	. 0	0	0	0
0	. 0	0	. 0 .	0	. • O	0
0	0	. 0	0	0	0	0
0	0	0	0 ,	. 0	0	0
0	0	0	3	3	5	11
		$\begin{array}{cccc} 1-3 & 4-7 \\ 0 & 0 \\ $	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$

Wind Speed (in mph)

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

. •

Wind	Wind Speed (in mph)							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total	
N	0	0	0	1	1	0 ·	2	
NNE	0	0	2	6	0	0	8	
NE	0	. 0	2	3	5	. 0	10	
ENE	· 0	0	0	_ 2	. O	0	2	
E	0	0	. 0	0	Ο.	l	1	
ESE	0	0	0	0	Q	0	0	
SE	0	0	0		· · · O	0	0	
SSE	0	. 0	0	. 0	Ó	0	0	
S	0	0	0	0	0	0	0	
SSW	0	0	0.	. 4	. 8	2	14	
SW	. 0	0	0	. 2	. 4	5	11	
WSW	0	0	· 0	1	2	ļ	4	
W	0	0	. 0	l	· 0	4	5	
WNW	0	0	0	l	2	0	3	
NW	0	0	0	· 0 ·	0	0	0	
NNW	0	0 .	· 0	0.	1	0	1	
Variable	0	0	. 0	0	0	Q	0	
Total	0	0	. 4	21	23	13	61	
			• • •	• •				

Period of Record: April - June 2003 Stability Class - Slightly Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

	W:	inds Mea	asured at	.375 Feet		·	
Wind		·	Nind Speed	d (in mp)	n)		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	Ô	12	27	24	15	· 3	81
NNE	3	. 10	. 27	59	7	0	106
. NE	0	20	47	. 76	34	. 7	184
ENE	3	19	46	62 :	51	25	206
Е	0	8	12	24	24	15	83
ESE	1	6	6	16	4	13	46
SE	1	. 4	8	11	9	. 10	43
SSE	2	4.	7	17	2	0	32
S	2	4	: 7	14	7	4	38
SSW	0	0	7	17	15	20	59
SW	2	1	5	11	10	17	46
WSW	0	1	. 6	, 13	13	17	50
W	0	3	14	11	16	22	66
WNW	. 1	. 1	12	. 9	7	13	43
NW	1	5	18	22	20	21	87
NNW	0	7	22	17	6	9	61
Variable	0	0	0	0	0	0	0
Total	16	105	271	403	240	196	1231

Period of Record: April - June 2003 Stability Class - Neutral - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 25 Hours of missing stability measurements in all stability classes:

1

•

. .

· · · · ·

Period of Record: April - June 2003 Stability Class - Slightly Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes:

Wind	Wind Speed (in mph)							
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total	
N	0	0.	3	2	1	0	6	
NNE	0	1	1	6 ^{:*}	1	0	9	
NE	1	1 ·	1	2	1	· · 1	7	
ENE	0	0	1	3	2	0	6	
E	0	2	2	1	2	З	10	
ESE	1	2	3	11	. 5	· 2	24	
SE	0	0	3	12	3	2	20	
SSE	0	1	2	2	2	2	9	
S	0	0	3	2	6	3	14	
SSW	0	1	2	2	6	19	30	
SW	0	· O	3	11	3	19	36	
WSW	1	0	2	5.	. 2	5	15	
W	0	1.	5	2	2	0	10	
WNW	0	1	. 0	l	6	·· 0	8	
NW	0	O	. O	5	13	3	21	
NNW	l	2	2	1	0	0	6	
Variable	0	0	0	.0.	0	0	0	
Total	4	12	33	68	55	59	231	

Period of Record: April - June 2003 Stability Class - Moderately Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: April - June 2003 Stability Class - Extremely Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

111 - J		Wi	nd Speed	d (in mpl	n)		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	0	0	0	. 0	0	0
NNE	. 0	0	. 0	0	0	0	· 0
NE	0	. 0	· 0	0	. . .	0	0
ENE	0	Ο.	0	. 0	0	0	0
E	0	0	0	0	·. O	0	0
ESE	0	O	0	0	0	0	0
SE	O	0	0	4	. 0	2	6
SSE	0	1.	0	3	1	3	8
S	0	1	0	4	2	. 3	10
SSW	0	0	2	4.	6	15	27
SW	O	0	0	2	6	10	18
WSW	0	0	· 2	5	3	· 2	12
W	0	2	3	1	2	. 0	8
WNW	0	1	. 1	2	5	. 0	9
NW	1	0	o .	0.	1	0	2
NNW	0	0	0	0	. 0	· 0 .	0
Variable	0	.0	0	0	0	0	0
Total	1	5	8	25	26	35	100

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2003 Stability Class - Extremely Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

· .. ·

Wind	•		. *	-	•		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
		 · · ·		•••••			
N	0	0	0	0	0	· 0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	· 0	0	0
ENE	0	0 .	. O	0	0	0	0
E	0	0	· O .	0	0	· 0	0
ESE	0	O	0	0	0	0	0
SE	0	. 0	0	0	0	0	0
SSE	0	0	• 0	0	0	0	0
S	_ 0	· 0	0	· 0	· 1	0	1
SSW	0	0	O	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	• 0	0	0	0	0
W	0	0	0	0	0	1	1
WNŴ	0	0	0	0	1	1	2
NW	0	Ö	0.	0	0	0	0
NNW	0	. 0	0	0	0	0	0
Variable	0	0	0	. • 0	0	0	0
Total	0	0	0	. 0	2	2	4

Wind Speed (in mph)

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2003 Stability Class - Moderately Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
	 .						
N	0	0	1	. 0	0	. 0	1
NNE	0	0	• 0	0	0.	. 0	0
NE	0	0 ·	0	1	0	0.	l
ENE	0	0	1	0	0	0	·l
E	0	. 0	0	0	0 ·	0	0
ESE	• 0.	0	0	0.	• 0	0	0
SE	0	0	<u></u> 0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	2	. 3	_ 1	0	6
SSW	0	0	3	l	0	. 0	4
SW	0	0	0	2.	2	0	4
WSW	0	0	0	3	1.	0	4
W	0	0	• O	0	0	· 2	2
WNW	0	0.	0	. 3	1	0	4
NW	0	0	0	2	· 3 ·	0	5
NNW	0	0	. 0	0	0.	0	0
Variable	0	0	. 0 .	0	. 0	0	0
Total	0	0	7	15	8	2 ·	32

Wind Speed (in mph)

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2003 Stability Class - Slightly Unstable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet • : .

.

Mind	Wind Speed (in mph)								
Direction	1-3	4-7 	8-12	13-18	19-24	> 24	Total		
N .	0	1	4	0	0	0	5		
NNE	0	. 0	. 0	0 .	. 0	0	0		
NE	0	2	0	1	. 0	0	3		
ENE	0	0	l	0	0	0	1		
E	0	0	4	0	· 0	0	4		
ESE	0	0	. 2	0	l	0	3		
SE	0	. 0	6	0	0 [`]	O .	6		
SSE	0	0	0	0	0	· O	0		
S	0	0	i	. 5	2	0	8		
SSW	0	0	. 2	2	• 0 _	1	5		
SW	0	0	7	0	2	l	10		
WSW	0	0	3	2	1	Ο.	6		
W	0	0 ·	3	4	1	2	10		
WNW	0	0	6	11	. · 2	1	20		
NW	0	0	1	2	1	0	. 4		
NNW	0	2	1.	1	0	Ο.	4		
Variable	0	0	· 0	0	0	0	0		
Total	0	5	41	28	10	5	89		

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2003 Stability Class - Neutral - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind		·	· •,	· · ·	•		
Direction	1-3	4-7 	8-12	13-18	19-24	> 24	Total
N	0	23	17	2	0	0.	42
NNE	0	8	7	. 3	0	0	18
NE	0 ·	5	7	· 8	_ 1	Ο	21
ENE	1	7	6	. 5	0	0	19
Е	0	2	21	12	2	0	37
ESE	1	12	11	3	0	0	27
SE	· 1	· 6	10	3	· · 0	0	20
SSE	0	2	. 9	13	7	1	32
S ,	1	1.	12	12	4	1	31
SSW	1	1	20	20	20	• 0	62
SW	4	3	12	22	2	3	46
WSW	1	. 13	14	10	2	2	42
W	1	18	. 28	25 ·	29	12	113
WNW	l	14	27	34	30	3	109
NW	1	12	28	43	12	0	96
NNW	1	17	39	28	12	1	98
Variable	0	0	0	0	. 0	0	0
Total	14	144	268	243	121	. 23	813

Wind Speed (in mph)

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2003 Stability Class - Slightly Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

· Wind			Wind Spee	ed (in mpl	h)		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	2	14	17	1	• 0	0	34
NNE	2	· 9	. 9	1	0	0	21
NE	0	3	8	· 4	0	0	15
ENE	1	8	22	1	. [.] . O	0	32
E	0	11	36	13	. O	0	60
ESE	0	.14	12	· 4	0	0	30
SE	1	14	13	6	1	О	35
SSE	2	15	21	17	11	2	68
S	· 0	1	26	20	20	2	69
SSW	2	. 8	17	41	22	5	95
SW	3	7	16	15	2	0	43
WSW	· · 4	. 10	. 18	10	2	1	45
W	· 2	10	14	. 4	1	2	33
WNW	· 1	10	31	13 g	15	6	76
NW	2	13	34	3	0	. 0	52
NNW	1	6	13	1	5	. 1	27
Variable	0	0	0	•••0	0	0	0
Total	23	153	307	154	79	19	735

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

·. .

	Wi	nds Mea	sured at	33 Feet	2	•	. ,
Mind		. W:	ind Speed	l (in mpl	n)	••	
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N							
19	0	. 0	т Э	, .	· 0·		, ,
	0.	· -	د	ـــــــــــــــــــــــــــــــــــــ	. 0	Ū	5
NE	0	1	0.	0	. 0	• 0	1
ENE	0	1	• . 2	0	0	. 0 ·	3
Е	1	13	22	2	0	0	38
ESE	0	13	9	· 4	0	· 0	26
SE	0	. 6	9	3	0	· · · 0	18
SSE	0	2	ġ	2	· 1	0	14
S	0	2	6	5	1	0	14
SSW	0	9	· 4	6	0	0	19
SW	0	8	19	18	0	0	. 45
WSW	0	14	13	3	. 0	0	30
W	2	13	13	3	• 0	. 0	31
WNW	l	12	20	2	0	0	35
NW	0	· 0	7	0	0	0	7
NNW	0	· 7	0	1	0	• 0	8
Variable	0	0	0	0	. 0	0	0
Total	. 4	108	137	50	2	0	301

Period of Record: October - December2003 Stability Class - Moderately Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

• :

.

Period of Record: October - December2003 Stability Class - Extremely Stable - 200Ft-33Ft Delta-T (F) Winds Measured at 33 Feet

Wind Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
						••••••••	
N	0	6	0	0	0	0	6
NNE	. 0	0	. 0	0	· 0 ·	0	0
NE	0	0.	0	0	0	., 0	0
ENE	0	1	0	0	0	· 0	1
Е	0	5	5	0	• 0	0	10
ESE	Ó	13	5	0	0	0	18
SE	0	22	7	0	0	· 0	29
SSE	0	24	2	0	· 0	0	26
S	0	. 5	7	0	0	0	12
SSW	0	. б	14.	2	. O	0	22
SW	0	13	22	0	0	0	35
wsw	0	6	15 ·	2	0	0	23
W	0	16	18	Ö	. 0	• 0	34
WNW	0	6	1	0	0	0	7
NW	0	2	0	Ō	0	0	2
NNW	0	2	0	0 ·	0	0	2
Variable	0	· 0	0	. 0	0	0	0
Total	0	127	96	4	0	0	227
					•		

Wind Speed (in mph)

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

Period of Record: October - December2003 Stability Class - Extremely Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

. .

		wi	nd Speed		- · 1)		
Wind Direction	1-3	4-7	8-12	13-18 	19-24	> 24	Total
N	. 0	0	0	0	0 -	. 0	0
NNE	0	· · O · ·	. 0	0	o	0	0
NE	0	0	0	0	0	0	0
ENE	0	ο	Ō	0	0	0	0
. E	0	0	0	Ο.	0	0	0
ESE	0	0	·· 0	0	o [:]	· 0	0
SE	0	. O	0	<u>,</u> 0	0	0	0
SSE	0	0	0	0	0	0	0
S .	0	. 0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	O	0	0	0	0
WSW	0	0	· 0	0	. 0	o .	0
W	0	0	1	0.	• 0	0	1
WNW	0	0	. 0	: 1	0	0	1
NW	0	0	0	0	0	· O	0
NNW	0	0 ·	[;] 0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	. 0	0	1	1	. 0	0	2

Period of Record: October - December2003 Stability Class - Moderately Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

4

.

·		Wi	.nd Speed	l (in mpl	n)		
Wind Direction	1-3 [.]	4-7	8-12	13-18	19-24	> 24	Total
N	0	0	0	0	0	0	0
NNE	0	0	0	Ο	0	0	0
NE	0	0	0	Ο.	0	0	0
ENE	0	• 0	0	0	0	0	0
E	0	0	0 .	0	0	0	0
ESE	0	0	0	o .	0	0	0
SE	0	0	Ο.	, O	.0	0	0
SSE	0	0	0 [`]	0	1	0	1
S	0	0 [°]	· 0	, , 0	l	0	1
SSW	0	0	0	0	0	0	0
SW	0	0	· 1	0	0	0	1
WSW	0	0.	0	1	0	0	1
W	0	0	1	1	0	1	3
WNW .	0	0	1	0	1	0	2
NW	0	0.	0	0	0	0.	0
NNW	0	0	· 0 .	· 0	0	O · ·	0
Variable	0	0.	• 0	0	0	0	0
Total	0	0	3	2	3	1	9

Period of Record: October - December2003 Stability Class - Slightly Unstable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

4

•

.

•	Period	of	Record	l: Octo	ober	c 1	Decemb	er2003		
Stability	Class	- Ne	utral		•.	· `	- 375	Ft-33Ft	Delta-T	(F)
		Wiı	ids Mea	sured	at	375	Feet	,		

Wind		Ŵ	ind Speed	d (in mpl	n)		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
. N	0	8	25	• • 9	2	0	44
NNE	0	9	4	6	6	0	25
NE	0	6	7	12	14	2	41
ENE	0	5	11	14	7	D	37
E	0	· 0	13	29	11	7	60
ESE	0	6	10	15	6	3	40
SE	1.	1	13	5	5	6	31
SSE	0	4	17	13	16	12	62
S	1	1	· 9	28	12	10	61
SSW	0	0	11	24	21	33	89
SW	2	4	9	19	13	19	66
WSW	0	5	8	14	19	. 11	57
W	1	10	16	24	14	44	109
WNW	1	12	23	33	25	35	129
NW	0	6	31	47	58	52	194
NNW	0	, 11	. 24.	18	7	8	68
Variable	0	0	0	0	0	0	. O
Total	6	88	231	310	236	242	1113

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes: 4

.

.

			•		•		
Wind		W:	ind Speed	l (in mp	h)		
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	4	7	10	11	0	32
NNE	0	3	. 4	16	7	0	30
NE	0	1	6	. 3	1	. 1 .	12
ENE	l	0	3	8	5	Ö	17
Е	. 2	4	5	7	15 [.]	2	35
ESE	0	5	10	6	15	2	38
SE	· 1	1	3	6	9	6	26
SSE	0	З	. 7	4	11	18	43
S	0	• 1	3	5	18	37	64
SSW	0	1	2	2 ·	12	79	96
SW	1	2	8	7	9	20	47
WSW	1	3	5	11	. 8	7	35
W	0	4	12	16	18	9	59
WNW	0	6	4	11	15	25	61
NW	1	2	7	11	.27	14	62
NNW	1	4	2	10	.11	0	28
Variable	0	0	0	0	0	0	0
Total	8	44	88	133	192	220	685

Period of Record: October - December2003 Stability Class - Slightly Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 1 Hours of missing stability measurements in all stability classes:

Uind		Wj	nd Spee	d (in mp)	h)	• •	
Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	. 0	0	· 0	2	б	0	8
NNE	0	0	· 8	4	0	· 0	12
NE	0	0	Ĺ	4	1	0	6
ENE	0	0	0	0	0	0	0
E	0	1	• • 0	3	2	0	6
ESE	0	O	. 4	4	· 5	3	16
SE .	0	1	. 3	10	6	5	25
SSE	0	0	· · O	3	6	5	14
S	0	1	. 1	. O [.]	2 .	. 9	13
SSW	0	0	. 2	0	2	7	11
SW	0	1	2	7	· 5	20	35
WSW	0	0	1.	. 0	4.	11	16
W	0	1 .	· 6	3	10	7	27
WNW	0	2	2	6	-18	7	35
NW	0	1	1	3	8	7	20
NNW	0	0	l	1	2	0 [.]	4
Variable	0	Ο.	0.	0	0	0	0
Total	0	. 8	· 32 ·	50	77	81	248

Period of Record: October - December2003 Stability Class - Moderately Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

		Wi	nd Speed	l (in mpl	- 1)	 	
Wind Direction	1-3	4-7	8-12	13-18	19-24	> 24	Total
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	. 0	0	0
ENE	0	0	0	0	0	Ο.	0
E	0	. 0	· · 0	0	0	0.	0
ESE	0	0	0	0	1	2	3
SE	0	0	· · Ò	2	. 2	. 2	6
SSE	0	0	0	3	6	. 4	13
S	0	0 .	1	10	15	10	36
SSW	0	0	. 0	2	. 5	. 7	14
SW	0	. O	1.	8	6	11	26
WSW	0	0	4	4	5	5	18
W	0	2	1.	0	. 2	,ı	6
WNW	0	ο	0	2	14	· 4	20
NW	0	0	· 1	· 0	2	O	3
NNW	.0	Ο	0 ·	0	0	. 0	0
Variable	0	0	0	0	0	· 0	0
Total	0	2	8	31	58	46	145

Period of Record: October - December2003 Stability Class - Extremely Stable - 375Ft-33Ft Delta-T (F) Winds Measured at 375 Feet

Hours of calm in this stability class: 0 Hours of missing wind measurements in this stability class: 0 Hours of missing stability measurements in all stability classes:

LaSalle Nuclear Station 33 ft. Wind Speed and Direction January-March, 2003 200Ft-33Ft Delta-T (F)

Number of Observations - 2158 Values are Percent Occurrence

SPEED							- WIND	D DIREC	TION C	LASSES	;							•••	•••••	STAB	Ility c	LASSES	 .		
CLASS	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSŴ	W.	WNW	NW	NNW	TOTAL	EÚ	MU	SU	N	SS	MS	ES	TOTAL
							•								•				•						
													•				• •								
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
C SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					
A N	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0 0	0.00	0.00	0.00			•	0.00				
L SS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			•		0.00			
M MS	0.00	0.00	0.00	0.00	0.00	.0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	•					0.00		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							0.00	
														•											0.00
	0.00	0.00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	n nn	0 00	0.00	0 00	0 00	0 00	0 00	0.00	0 00							
EU	0.00	0.00 n no	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
1 01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	· 0.00		0.00	0 00		•			
1.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.65				
2 22	0.03	0.00	0.05	0.00	0.00	0.05	0.05	0.05	0.00	0.00	0.05	0.00	0.00	0.03	0.00	0.05	0.83				0.00	0.83			
5 55 MS	0.14	0.05	0.05	0.05	0.05	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.05	0.05	0.00	0.00	0.28					0.00	0 28		
FS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	· 0.00							0.00	
	0.00	0.00	•.••					·····.													٠				1.76
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.14		0.14						
4 SU	0.00	0.05	0.00	0.00	0.00	0.05	0.09	0.09	0.09	0.00	0.09	0.00	0.00	0.09	0.00	0.05	0.60			0.60					
- N	0.74	0.88	0.23	0.09	0.23	0.14	0.32	0.32	0.37	0.37	0.32	0.19	0.42	0.79	0.42	0.74	6.58				. 6.58				
7 SS	0.65	0.32	0.14	0.19	0.60	0.32	0.65	0.32	0.32	0.42	0.37	0.28	0.19	0.70	0.74	0.56	6.77					6.7 7			
MS	0.05	0.00	0.09	0.05	0.37	0.65	0.32	0.28	0.19	0.23	0.09	0.28	0.42	0.56	0.23	0.05	• 3.85					•	3.85		
ES	0.00	0.00	0.00	0.05	0.05	0.09	0.14	0.23	0.46	0.23	0.28	0.23	0.65	0.42	0.14	0.00	2.97							2.97	
																	•								20.90
														•											
EU	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.14	0.14	•						
MU	0.00	0.05	0.00	0.05	0.00	0.00	0.05	0.14	0.14	0.05	0.23	0.00	0.00	0.05	0.05	0.00	0.79		0.79						
8 SU	0.09	0.09	0.09	0.00	0.00	0.00	0.05	0.09	0.19	0.05	0.09	0.09	0.09	0.05	0.19	0.23	1.39			1.39					
- N	1.95	1.44	0.70	0.28	0.37	0.00	0.28	0.28	0.79	0.37	1.20	0.46	0.83	1.90	2.13	2.97	15.94				15.94				
1 SS	0.28	0.32	0.28	0.32	0.60	0.37	0.60	0.42	0.23	0.79	1.16	0.51	0.65	1.16	1.20	0.32	9.22					9.22			
2 MS	0.00	0.00	0.00	0.23	0.23	0.32	0.42	0.05	0.09	0.19	0.56	0.79	0.42	0.56	0.56	0.00	4.40					•	4.40		
ES	0.00	0.00	0.00	0.00	0.09	0.14	0.23	0.14	1.30	0.97	0.93	0.28	0.46	·0.09	0.09	0.00	4.73							4.73	
														•								•			36.61
												·													
EU	0.00	0.00	0.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.14	0.00	0.00	0.00	0.00	0.00	0.3/	0.37							
1 MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.28	0.00	0.05	0.09	0.05	0.00	.0.51	•	0.51	1					
3 50	0.05	0.14	0.00	0.00	0.05	0.00	0.00	0.00	0.09	0.05	0.32	0.19	0.19	0.3/	0.19	0.00	1.02		•	1.62	10 50				
- N	1.67	1.16	• 1.11	0.46	0.46	0.00	0.23	0.09	0.79	0,37	1.44	0.60	0.60	2.22	1.25	4.12	10.59		-		10.59	6 00			
1 55	0.19	0.09	U.14	0.09	0.28	0.09	0.05	0.23	0.9/	0.74	0.79	0.79	0.51	1.02	0.14	. U.23	0.95		•			0.90	1 24		
8 MS	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.05	0.09	0.09	0.14	.0.14	0.3/	0.20	0.09	0.00	1.34			• .			1.34	n 10	
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	V.14	0.00	0.00		0.19		•					0.15	27 57
																						•			

LaSalle Nuclear Station 33 ft. Wind Speed and Direction

.

January-March, 2003 200Ft-33Ft Delta-T (F)

							•				•														
SPEEL)	•••••					- WIND	DIREC	TION C	LASSES	•••••	•••••	•••••						•••••	STABI	LITY	CLASSES	•	• • • • •	
CLASS	i N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	EU	MJ	SU	N	S S	MS	ES	TOTAL
																					. ·				
							•						•				· .		•						
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.14	0.14	0.00	0.09	0.00	0.00	0.37	0.37	•						
1 MU	0.00	0.00	0.09	0.00	0.00	0.00	0.00	0.00	0.05	0.14	0.05	0.19	0.09	0.05	0.09	0.00	0.74		0.74			•			
9 20	0.00	0.00	0.09	. 0.00	0.00	0.00	0.00	0.09	0.00	0.05	0.19	0.14	0.14	0.28	0.00	0.00	0.97			0.97					
- N	0.28	0.00	2.04	0.32	0.00	0.00	0.09	0.05	0.19	0.05	0.46	0.70	0.65	1.81	0.42	0.19	7.23				7.23	·			
2 SS	0.00	0.00	0.46	0.00	0.00	0.00	0.05	0.00	0.19	0.19	0.09	0.23	0.23	0.32	0.09	0.00	1.85					1.85			
4 MS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.05	0.05	U.14	0.00	0.00	0,28	•					0.28		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					•		0.00	11.45
																	•								11.45
C 11	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 05	0 00	0 00	0.00	0 00	0 00	0.00	0 00	0.00	0.05	0.05							
C MI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	.0.00	0.05	0.05	0 05						
ייזיט דיכוו	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05		0.05	0 00					
1 30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.03			0.03	0 83				
2 55	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.05	0.05	0.00	0.65	0.20	0.00	0.00				0.00	0 70			
2 JJ	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			•		0.70	0 00		
23	0.00	0.00	0 00	0 00	0 00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0 00	0 00	. 0 00	0.00	0.00						0.00	0 00	
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	0.00	•						0.00	1.71
									•				•												
														• •					•						
тот	6.12	4.68	5.89	2.18	3.43	2.27	3.75	3.24	6.72	5.61	9.59	6.49	7.28	14.78	8.43	9.55	100.00	0.93	2.22	4,68	47.82	26.32	10.15	7.88	100.00
																		.•							
Wind	Direc	ction t	y Stat	ility																	•				
	N	NNE	NE	ENE	ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	-\$1	ABILI1	Y CLAS	SES-				
						•				•				•											
	0.00	0.05	0.23	0.00	0.00	0.00	0.00	0.09	0.00	0.00	0.32	0.14	0.00	0.09	0.00	0.00	0.93	Ext	remely	Unsta	ble				
	0.00	0.05	0.09	0.05	0.00	0.00	0.05·	0.23	0.28	0.23	0.56	0.19	0.14	0.19	0.19	0.00	2.22	Moo	leratel	y Unst	able				
	0.14	0.28	0.19	0.00	0.05	0.05	0.14	0.32	0.37	0.14	0.70	0.46	0.42	0.79	0.37	0.28	4.68	S11	ghtly	Unstab	ole				
	4.68	3.48	4.17	1.16	1.07	0.19	0.93	0.83	2.13	1.20	3.52	2.13	2.59	7.09	4.59	8.06	47.82	Neu	itral						
	1.25	0.83	1.07	0.60	1.53	0.83	1.39	1.02	1.81	2.22	2.50	1.81	1.58	4.54	2.18	1.16	26.32	S11	ight1y	Stable	•				
	0.05	0.00	0.14	0.32	0.65	0.97	0.88	0.37	0.37	0.56	0.79	1.25	1.30	1.58	0.88	0.05	10.15	Mod	leratel	y Stat	le				
	0.00	0.00	.0.00	0.05	0.14	0.23	0.37	0.37	1.76	1.25	1.20	• 0.51	1.25	0.51	0.23	0.00	·7.88	Ext	remely	' Stabl	e	• •			
. WINC	UIrec	CION D	y wind	speed									·				•								
	N	AVA/E	NC	ENE	F	FCF	C.	CCE	c	CCLI	ແມ	ມແມ	u	LANJ	88.5	ADATA	τοτλι	-111							
	N	NNE	ΝĽ	ENE	C	ESE	36	225	3	22M	24	MCM	n	PUTP	RW	nuw	TUTAL	- 14	ing ore		0363-				
	0 00	0.00	0.00	0.00	0 00	0 00	0 00	0 00	n 'nn	0 00	0.00	0 00	0 00			0.00	0 00		۲.	I M					
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	.00 1 74		U A -	26-	noh.				
	0.13	1.05	0.14	0.00	0.09	1 20	U.U9	1 20	1 62	0.14 1 25	1 12	0.03	1 47	0.17 2 EE	1 52	1 20	20 00		362	7 6 -	n∼n noh				
	1.44	1.20	U.40	0.3/	1.20	1.20	1.00	1.30	1.00	2 41	1.10	0.5/ 2 12	2 16	2.00	1.00 A 22	3 62	36 61		76-	12.5 -	anh				
	2.32	1 30	1.0/	U.00	1.30	0.03	1.02	1.10	2.73	2.41	3 10	1 71	2.40 1 95	0.00 V E0	1 71	0.02 A 36	27 57	• ,	12.6 -	18.5	nnh.				
	1.30	1.09	2 40	0.00	0.79	0.03	0.3/	0.3/	1.33	1.04 0 /6	0.10	1 ./1	1 16	2 60	1 50	0 10	11 45		18.6 -	24.5	nob				
	0.20	0.00	0.05	0.32	0.00	0.00	0.14	0.14	0.44	0.40	0.53	0 14	1.10	0.07	0.00	.0.00	1 71			24.5 m	nnh.	••			

LaSalle Nuclear StationJanuary-March. 2003375 ft. Wind Speed and Direction375Ft-33Ft Delta-T (F)

Number of Observations - 2155 Values are Percent Occurrence . • SPEED WIND DIRECTION CLASSES ----- STABILITY CLASSES ------NE ENE E ESE SE SSE S SSW SW WSW W WNW NW NNW TOTAL EU MU SU N CLASS. N NNF SS MS ES TOTAL 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0 00 0.00 0.00 0.00 . 0.00 0.00 0.00 0.00 0.00 - N 0.00 0.00 0.00 0.05 0.00 0.05 0.00 0.05 0.00 0.05 0.00 0.05 0.00 0.09 0.05 0.00 0.37 0.37 0.32 0.32 0.00 0.00 0.05 0.05 0.74 0.00 0.00 0.00 0.00 0.00 0.00 - N 0.23 0.19 0.05 0.14 0.14 0.09 0.32 0.37 0.51 0.05 0.37 0.14 0.28 0.46 0.37 0.51 4.22 4.22 7 SS 0.14 0.19 0.05 0.19 0.19 0.28 0.14 0.09 0.00 0.09 0.00 0.05 0.14 0.14 0.05 0.23 1.95 1.95 0.32 0.32 ES 0.00 0.00 0.00 0.00 0.00 0.00 0.05 0.00 0.00 0.00 0.05 0.05 0.00 0.00 0.00 0.05 0.19 0.19 6.68 0.00 0.00 0.05 - N 0.42 1.35 0.37 0.51 0.28 0.14 0.19 0.60 0.97 0.42 0.84 0.28 0.56 1.11 1.53 1.86 11.42 11.42 1 55 0.14 0.14 0.19 0.19 0.19 0.46 0.28 0.32 0.19 0.32 0.14 0.19 0.23 0.14 0.65 0.23 3.99 3.99 2 MS 0.05 0.00 0.00 0.14 0.00 0.09 0.09 0.14 0.00 0.00 0.09 0.37 0.09 0.09 0.05 1.21 1.21 0.23 0.23 16.89 0.05 0.00. - N 1.72 0.46 1.16 0.37 0.37 0.09 0.05 0.23 0.60 0.60 1.62 0.60 0.79 1.58 2.27 2.51 15.03 15.03 1 SS 0.56 0.19 0.14 0.05 0.14 0.42 0.51 0.46 0.19 0.32 0.42 0.14 0.05 0.46 0.84 0.51 5.38 5.38 8 MS 0.00 0.00 0.00 0.00 0.09 0.09 0.14 0.14 0.28 0.23 0.19 0.37 0.32 0.09 0.70 0.28 2.92 2.92 ES 0.00 0.00 0.00 0.00 0.00 0.05 0.00 0.05 0.05 0.19 0.05 0.14 0.05 0.05 0.05 0.05 0.70 0.70

24.13

						•																		
				ł	LaSall	e Nucle	ear Sta	ation							Januai	ry-Maro	ch. 201	03						
				:	375 ft	. Wind	Speed	and D	irectio	n					375Ft-	-33Ft (Delta-T	(F)	•					
									•				•									-		
SPEED							- WIN		TTON (I ASSES				• •			•			CT 4D		-	~	
CLASS	N N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	EU	MU	SU		22	З С МS	 F2
																							110	
	0.00	0.00	0.00	0.00	0.00		0.00									•		. <u>.</u>				• •		
1 141	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
9 50	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05		0.05	0 10				
- N	1.39	1.30	0.74	0.23	0.28	0.09	0.09	0.14	0.60	0.46	1 48	0.00	0.00	1.81	2 41	2 19	14 43			0.19	14 42			
2 SS	0.00	0.05	0.32	0.14	0.09	0.05	0.32	0.37	0.28	0.42	0.79	0.42	0.42	0.60	1.16	0.19	5.61				14,43	5 61		
4 MS	0.00	0.00	0.00	0.09	0.09	0.09	0.19	0.32	0.09	0.28	0.19	0.14	0.32	0.51	0.19	0.05	2.55						2 55	
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.09	0.32	0.42	0.28	0.00	0.09	0.00	0.00	1.25						2.00	1.25
							• .		•						•			•						
EU	0.00	0.00	0.00	0.00	0.00	0.00	. 0 .00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	•					
GMU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0 <u>0</u>	0.00	0.00	0.00	0.00	0.00	0.00		.0.00		•			
TSU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.09	0.00	0.00	0.05	0.00	0.23		·	0.23				
N	1.21	0.14	3.02	0.97	0.00	0.00	0.05	0.32	0.19	0.23	0.88	0.88	0.60	2.74	1.53	0.37	13.13				13.13			
2.55	0.00	0.00	0.05	0.00	0.23	0.23	0.00	0.23	0.74	1.35	1.16	0.88	1.07	2.45	0.84	0.23	9.47	•				9.47		
4 105	0.00	0.00	0.00	0.05	0.00	0.09	0.19	0.37	0.09	0.46	0.45	0.37	0.56	0.60	0.14	0.00	3.39						3.39	
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.19	0.42	0.51	0.05	0.00	0.09	0.00	0.00	1.25							1.25
																	•							
TOT	5.85	3.99	6.40	2.97	2.32	2.23	2.65	4.18	5.43	6.36	9.88	6.03	6.31	13.13	12.99	9.28	100.00	0.05	0.09	0.46	58.61	26.73	10.39	3.67
																					••			
			·													•	•		•					

- . --

SS MS ES TOTAL

.

:

.

•.

0.09 0.46 58.61 26.73 10.39 3.67 100.00

24.08

27.47

Wind Direction by Stability

N .	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	STABILITY CLASSES-
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	ò.00	0.00	0.00	0.00	0.00	0.05	Extremely Unstable
0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.09	Moderately Unstable
0.00	0.00	0.14	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.14	0.09	0.00	0.00	0.05	0.00	0.46	Slightly Unstable
4.97	3.43	5.34	2.27	1.07	0.42	0.74	1.67	2.92	1.81	5.20	2.74	2.74	7.80	B.17·	7.33	58.61	Neutral
0.84	0.56	0.84	0.56	0.88	1.48	1.25	1.48	1.44	2.51	2.51	1.67	1.90	3.81	3.53	1.48	26.73	Slightly Stable
0.05	0.00	0.05	0.14	0.37	0.28	0.60	0.93	0.60	1.07	0.84	1.02	1.58	1.30	1.21	0.37	10.39	Moderately Stable
0.00	0.00	0.00	0.00	0.00	0.05	0.05	0.09	0.42	0.97	1.11	0.51	0.09	0.23	0.05	0.09	3.67	Extremely Stable

Wind Direction by Wind Speed

N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W *	WNW	NW	NNW	TOTAL	-WIND SPEED CLASSES-
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	CALM
0.00	0.00	0.09	0.05	0.05	0.05	.0.05	0.00	0.09	0.05	0.05	0.05	0.00	0.09	0.05	0.09	0.74	< 3.5 mph
0.37	0.37	0.14	0.32	0.37	0.37	0.51	0.46	0.51	0.23	0.42	0.28	0.42	0.60	0.51	0.79	6.68	3.6 - 7.5 mph
0.60	1.48	0.56	0.70	0.60	0.60	0.56	1.02	1.44	0.79	1.02	0.56	1.Ż1	1.35	2.27	2.13	16.89 -	7.6 - 12.5 mph
2.27	0.65	1.30	0.42	0.60	0.65	0.70	88.0	1.11	1.35	2.37	1.25	1.21	2.18	3.85	3.34	24.13	12.6 - 18.5 mph
1.39	1.35	1.25	0.46	0.46	0.23	0.60	0.88	1.07	1.48	2.92	1.62	1.25	3.02	3.76	2.32	24.08	18.6 - 24.5 mph
1.21	0.14	3.06	1.02	0.23	0.32	0.23	0.93	1.21	2.45	3.11	2.27	2.23	5.89	2.55	0.60	27.47	> 24.5 mph

April-June, 2003 LaSalle Nuclear Station ۰. 200Ft-33Ft Delta-T (F) 33 ft. Wind Speed and Direction

										Numbe	r of C	bserva	tions	- 218	2 ·		• •	•			•				
										Value	. dre	Percen		rrence		•			•						
SPEED							- WIND		TION C	LASSES										STAB		LASSES			
CLASS	N	NNE	ŃE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	EU	MU	SU	N	SS	MS	ES	TOTAL
										•	·											•			
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		•					
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
C SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					
A N	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				
LSS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					0.00			
MMS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	· 0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						0.00		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					•		0.00	0.00
									•					•											0.00
	0.00	0 00	0.00	n nà	0 00	0 00	0 00	0 00	0.00	0 00	0 00		0 00	0 00	n nn	0 00	0 00	0 00	•			•			
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0 00	•	•				
1.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0 05		•			
1 20	0.00	0.00	-0.05	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00 0 09	0.03	•	•	0.05	0 82	· •			
2 22 6	0.14	0.00	0.00	0.05	0 00	0 00	0.05	0.00	0.05	0.00	0.05	0.05	0.05	0.00	0.00	0.00	0.32				0.02	0.32			
5 55 MS	0.05	0.00	0.00	0.05	0.05	0.00	0.00	0.00	0.05	0.00	0.00	0.09	0.09	0.05	0.00	0.00	0.50			·		0,00	0.50		
FS	0 00	0 00	0.00	0.00	0.00	0.05	0.05	0.00	0.05	0.00	0.05	0.05	0.00	0.05	0.00	0.00	0.27							0.27	
	0.00	0.00																				۰.			1.97
							••••																		
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	. 0.00	0.00	0.00	0.14		0.14						
4 SU	0.37	0.32	0.55	0.18	0.09	0.14	0.09	0.00	0.00	0.00	0.05	0.05	0.00	0.05	0.05	0.05	1.97			1.97					
- N	1.24	1.56	1.56	1.19	0.32	0.14	0.09	0.27	0.18	0.14	0.18	0.09	0.23	0.23	0.32	0.55	8.30				8.30				
7 SS	1.79	1.70	0.46	0.09	0.78	0.23	0.00	0.23	0.23	0.27	0.32	0.18	0.23	0.09	0.14	0.32	7.06		• •			7.06			
MS	0.46	0.73	0.00	0.05	0.37	0.46	0.27	0.32	0.18	0.09	0.23	0.23	0.18	0.14	0.32	0.32	4.35						4.35		
ĖS	0.14	0.09	0.00	0.05	0.09	0.41	0.32	0.64	0.46	0.55	0.69	0.18	0.46	0.27	0.09	0.05	4.49							4.49	
							·						٠												26.31
EU	0.05	0.37	0.09	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.05	0.05	0.73	0.73							
MU	0.09	0.32	0.78	0.27	0.05	0.00	0.05	0.18	0.05	0.18	0.00	0.14	0.18	0.00	0.00	0.09	2.38		2.38						
8 SU	0.23	0.37	0.60	0.41	0.09	0.05	0.09	0.09	0.05	0.27	0.05	0.09	0.23	0.09	0.32	0.37	3.39			3.39					
- N	1.70	3.35	2.11	1.51	0.78	0.27	0.50	0.32	0.50	0.37	0.23	0.46	0.78	0.50	0.50	1.15	15.03		• •		15.03	•			
1 SS	0.50	1.15	1.83	1.42	1.97	0.41	0.14	0.18	0.32	0.27	0.96	0.64	0.23	0.09	0.32	0.46	10.91		•			10.91	<u> </u>		
2 MS	0.05	0.00	0.00	0.00	1.05	0.18	0.09	0.14	0.78	0.32	0.27	0.27	0.05	0.14	0.05	0.05	3.44	•					3.44	~ ~ ~	
ES	0.00	0.00	0.00	0.00	0.05	0.09	0.23	0.50	0.41	0.32	0.69	0.64	0.27	.0.18	0.05	0.00	3,44							3.44	20.22
							•																		39.32
					0.00	0.00		0 00	0 00	0.00		0 10			0 00	0 00	1 65	1 65							
EU	0.05	0.09	0.14	0.00	0.00	0.00	0.00	0.00	0.09	0.00	0.41	0.10	0.09	0.00	0.00	0.00	1 2 1	1.03	1 61						
1 MU	0.14	0.09	0.05	U.14	0.00	0.00	0.00	0.00	0.10	0.41	0.00	0.00	0.00	0.14	0.00	0.23	1 07	•	1.01	1 07					
350	0.14	0.05	U.UD	0.10	0.10	0.00	0.00	0.23	0.00	0.14	0.03	0.10	0.09	0.03	0.52	0.23	10 22			1, <i>31</i>	10 22				
• N	0.23	0.23	1.50	2.4/	0.0/	0.32	0.55	0.27	V.5U	0.14	0.40	0.40	0.40	0.00	0.04	0.00	4 31		•		10.22	.: 4 31			
а мс Т 22	0.03	0.05	0.3/	1.00	0.04	0.00	0.10	0.02	0.32 0 1R	0 19	0.64	0.00	.0.00	0.09	0.00	0,00	-1.24						1,24		
67 0 23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.10	0.00	0.09	0.00	0.00	0.00	0.00	0,00	0.14							0.14	
ĽJ	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00		VIA T								21.04

÷

33 ft. Wind Speed and Direction

------ WIND DIRECTION CLASSES ------SPEED ----- STABILITY CLASSES ------NNE NE ENE E ESE SE SSE S SSW SW WSW W WNW NW NNW TOTAL EU MU SU CLASS N N SS MS ES TOTAL 1 MU 0.00 0.00 0.05 0.05 0.14 0.00 0.05 0.00 0.00 0.14 0.14 0.50 0.00 0.00 0.00 0.09 1.15 1.15 9 SU 0.00 0.00 0.05 0.00 0.05 0.00 0.09 0.00 0.14 0.18 0.18 0.05 0.09 0.09 0.05 0.14 1.10 1.10 - N 0.00 0.00 0.23 0.60 0.69 0.27 0.14 0.00 0.23 0.14 0.27 0.27 0.32 0.69 0.09 0.23 4.17 4.17 1.10 1.10 0.18 0 00 B.71 0.23 0.23 0.14 0.14 0.27 0.27 N 0.00 0.00 0.00 0.46 0.05 0.05 0.09 0.00 0.00 0.05 0.05 0.37 0.32 0.00 0.00 0.00 1.42 1.42 0.60 0,60 0.00 0.00 0.00 0.00 2.66 TOT 7.56 10.54 10.63 10.40 8.48 3.21 3.21 3.94 5.41 6.28 6.92 5.59 4.86 4.49 3.39 5.09 100.00 3.62 5.32 8.75 39.96 24.29 9.72 8.34 100.00 Wind Direction by Stability N NNE NE ENE E ESE SE SSE S SSW SW WSW W WWW NW NNW TOTAL -STABILITY CLASSES-0.09 0.46 0.27 0.14 0.05 0.00 0.00 0.00 0.09 0.92 0.78 0.27 0.23 0.23 0.05 0.05 3.62 Extremely Unstable 0.32 0.41 0.87 0.46 0.18 0.00 0.09 0.23 0.23 0.73 0.23 0.69 0.18 0.27 0.00 0.41 5.32 Moderately Unstable 0.73 0.73 1.24 0.78 0.46 0.18 0.27 0.32 0.23 0.73 0.37 0.37 0.41 0.41 0.73 0.78 8.75 Slightly Unstable 3.30 5.22 5.50 6.28 2.75 1.05 1.42 0.96 1.51 0.87 1.19 1.70 2.11 1.97 1.56 2.57 39.96 Neutral 2.43 2.89 2.66 2.61 3.44 0.73 0.41 0.78 1.19 1.37 1.70 1.10 0.87 0.69 0.55 0.87 24.29 Slightly Stable 0.55 0.73 0.09 0.09 1.47 0.69 0.41 0.50 1.19 0.78 1.15 0.60 0.32 0.41 0.37 0.37 9.72 Moderately Stable 0.14 0.09 0.00 0.05 0.14 0.55 0.60 1.15 0.96 0.87 1.51 0.87 0.73 0.50 0.14 0.05 8.34 Extremely Stable Wind Direction by Wind Speed ESE SE SSE SSW SW NW NNU TOTAL -WIND SPEED CLASSES-N NNF NE ENE Ε S NSW WNW CALM

April-June, 2003

200Ft-33Ft Delta-T (F)

 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00
 0.00

LaSalle Nuclear Station 375 ft. Wind Speed and Direction

.

.

.

e

April-June, 2003 375Ft-33Ft Delta-T (F)

Number of Observations - 2156 Values are Percent Occurrence

SPEED							- WINE	DIREC	TION C	LASSES								· 		STAR		1 455F5			
CLASS	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	NSM	W.	WNW	NW	NNW	TOTAL	FU	MI	SU	N	دعد ۲۷	MS	FS	τοται
					_				-					•••••	••••	•••••					••	•••		20	101712
																	•								
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.Ö0	•		•				
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	.0.00		0.00						
C SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					
AN	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				
LSS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					0.00			
MMS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0 00	0.00	0 00	0 00	0.00	0 00		•				0 00		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	D.00	0.00	0.00	0.00	0.00	0.00	· 0 00	0.00	0.00					۲	0.00	0 00	
	••••			••••	••••																	•		0.00	0 00
											•														0.00
· FU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	.0.00	0.00	0 00	0.00	0 00	0 00	•						
MI	0 00	0 00	0.00	0.00	0 00	0.00	0 00	0 00	0 00	0 00	0 00	0.00	0 00	0.00	0 00	0 00	0.00	0.00	0 00						
1 51	0 00	0.00	0.00	0.00	0.00	0 00	0 00	0.00	0 00	0.00	0.00	0.00	· 0 .00	0.00	0.00	0.00	0.00		0.00	0 00		•			
· _ N	0.00	D 14	0.00	0.00	n nn	0.00	0.05	n ng	n ng	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					•••			
2 55	0.00	0.14	0.00	0.14	0.00	0.05	0.00	0.05	0.05	0.00	ñ nn ¹	0.00	0.00	0.00	0.00	0.00	0.74	•			0.74	0 22			
3 33 MC	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.03	0.00	0.05	0.00	0.00	0.00	0.00	0.00 n'nn	0.00	0.25					0.23	0 10		
гы гс	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.15						0.19	0.05	
ĽЭ	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.05							0.05	1 01
																		• •				•			1.21
5 11	0 00	0 00	0.00	0 00	0 00	0 00	0 00		0 00	0.00		0 00	0 00	o oo	n nà	0 00	0.00	0 00							
50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		•					
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
4 50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	.0.00	0.00			0.00					
- N	0.56	0,46	0.93	0.88	0.37	0.28	0.19	0.19	0.19	0.00	0.05	0.05	0,14	0.05	0.23	0.32	4.87				4.87				
7 \$\$	0.00	0.09	0.09	0.09	0.23	0.09	0.00	0.09	0.05	0.09	0.09	0.14	0.00	0.00	0.09	0.05	1.21					1.21			
MS	0.00	0.05	0.05	0.00	0.09	0.09	0.00	0.05	0.00	0.05	0.00	0.00	0.05	0.05	0.00	0.09	0.56					•	0.56		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.05	0.00	0.00	0.00	0.09	0.05	0.00	0.00	0.23							0.23	
													•												6.85
	•														•										
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		·					
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	•	•				
8 SU	0.00	0.09	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.19			0.19					
- N	1.25	1.25	2.18	2.13	0.56	0.28	0.37	0.32	0.32	0.32	0.23	0.28	0.65	0.56	0.83	1.02	12.57				12.57	•			
1 SS	0.05	0.37	1.07	0.60	0.56	0.14	0.14	0.00	0.05	0.05	0.23	0.23	0.09	0.09	0.23	0.19	4.08				·	4.08			
2 MS	0.14	0.05	0.05	0.05	0.09	0.14	0.14	0.09	0.14	0.09	0.14	0.09	0.23	0.00	0.00	0.09	1.53					•	1.53		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.00	0.09	. 0.14	0.05	0.00	0.00	0.37							0.37	
											•										•				18.74
											•											• •			
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			•				
1 MU	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.00	0.00	0.00	0.00	0.14		0.14						
3 SU	0.05	0.28	0.14	0.09	0.00	0.00	0.00	0.00	0.00	0.19	0.09	0.05	0.05	0.05	0.00	0.00	0.97			0.97					
- N	1.11	2.74	3.53	2.88	1.11	0.74	0.51	0.79	0.65	0.79	0.51	0.60	0.51	0.42	1.02	0.79	18.69	• •	·		18.69				
1 SS	0.32	1.48	1.58	1.67	0.79	0:37	Ó.19	0.05	0.19	0.19	0.37	0.19	0.19	0.23	0.32	0.05	8.16					8.16			
8 MS	0.09	0.28	0.09	0.14	0.05	0.51	0.56	0.09	0.09	0.09	0.51	0.23	0.09	0.05	0.23	0.05	[.] 3.15						3.15		
٤S	0.00	0.00	0.00	0.00	0.00	0.00	0.19	0.14	0.19	0.19	0.09	0.23	0.05	0.09	0.00	0.00	-1.16		•					1.16	
	•							-												•					32.28

LaSalle Nuclear Station 375 ft. Wind Speed and Direction

.

April-June, 2003 375Ft-33Ft Delta-T (F) .

DEED								1 NTDF/	-	-1 ACCES										CT AD	** ***				
1 455		NNE	NC.	ENE	г.	5 55	CL		с 1100 (1.011				414.0 Å	TOTAL			SIAB	ILITY	CLASSE:	· · · · ·		
	N		NE	ENE	E	ESE	SE	225	3.	22M	28	M2M	W	WNW	NW	NNW	IUIAL	EU	MU	·SU	. N	S S	MS	ES	TOTA
FU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0 00	0 00	0 00		0 00	0 00	0 00	0 00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	·0.05	0.00	0.00	0.00	0.00	0.00	0.14	0.00	0.14						
SU	0.05	0.00	0.23	0.00	0.00	0.00	0.00	0.00	0.00	0.37	0.19	0.09	0.00	0.09	0.00	0.05	1.07		0.14	1.07	•				
N	0.70	0.32	1.58	2.37	1.11	0.19	0.42	0.09	0.32	0.70	0.46	0.60	0.74	0.32	0.93	0.28	11.13				11.13	}.			
SS	0.28	0.14	1.30	0.51	0.70	0.46	0.19	0.05	0.14	0.46	0.37	0.65	0.42	0.28	0.05	0.05	6.03					6.03			
MS	0.05	0.05	0.05	0.09	0.09	0.23	0.14	0.09	0.28	0.28	0.14	0.09	0.09	0.28	0.60	0.00	2.55	•					2.55		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.09	0.28	0.28	0.14	0.09	0.23	0.05	0.00	1.21				. •	•.		1.21	
																				•					22.1
																						•			
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				•			
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.14	0.09	0.00	0.00	0.00	0.00	0.00	0.23	•	0.23						
SU	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.09	0.23	0.05	0.19	0.00	0.00	0.00	0.60			0.60					
N	0.14	0.00	0.32	1.16	0.70	0.60	0.46	0.00	0.19	0.93	0.79	0.79	1.02	0.60	0.97	0.42	9.09				9.09	, ,			
SS	0.14	0.05	0.09	0.05	0.19	0.05	0.05	0.14	0.65	0.93	0.88	0.14	0.23	0.56	0.23	0.14	4.50					4'.50			
MS	0.00	0.00	0.05	0.00	0.14	0.09	0.09	0.09	0.14	0.88	0.88	0.23	0.00	0.00	0.14	0.00	2.74						2.74		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.14	0.14	0.70	0.46	0.09	0.00	0.00	0.00	0.00	.1.62							1.62	
																									18.7
						·														•					
															•	_		••••••							
от	4.92	7.93	13.45	12.85	6.82	4.41	3.76	2.64	3.94	8.07	7.24	5.19	5.06	4.0 8	6.03	3.62	100.00	0.00	0.51	2.83	57.10	24.21	10.71	4.64	100.
Wind	Direc	tion t	oy Stal	oility																					
	N	NNF	NF	FNF	F	ESE	SF	SSF	s	554	SW	wsw	¥	UNU	NJ	NNW	TOTAL	-51	ARTI TT	γn	SSES.	•			
					•			,	Ū	0011	011			1111			101/12				00,00-				
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Ext	remely	Unst	able				
	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.23	0.14	0.09	0.00	0.00	.0.00	0.00	0.51	Mod	eratel	y Uns	table	•			
	0.09	0.37	0.46	0.09	0.05	0.00	0.00	0.00	0.00	0.65	0.51	0.19	0.23	0.14	0.00	0.05	2.83	S11	ghtly	Unsta	ble				
	3.76	4.92	8.53	9.55	3.85	2.13	1.99	1.48	1.76	2.74	2.13	2.32	3.06	1.99	4.04	2.83	57.10	Neu	tral			•			
	0.79	2.18	4.13	2.92	2.46	1.16	0.56	0.37	1.07	1.81	1.95	1.35	0.93	1.16	0.93	0.46	24.21	S11	ghtly	Stabl	e				
	0.28	0.42	0.32	0.28	0.46	1.11	0.93	0.42	0.65	1.39	1.67	0.70	0.46	0.37	0.97	0.28	10.71	Mod	eratel	y Sta	ble				
	0.00	0.00	0.00	0.00	0.00	0.00	0.28	0.37	0.46	1.25	0.83	0.56	0.37	0.42	0.09	0.00	.4.64	Ext	remely	' Stab	le	· ·			
	•	•										•						•							
lind	Direc	tion b	y Wind	l Speed															•						
					_				_			•													
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNM	NW	NNW.	TOTAL	-WI	ND SPE	ED CL	ASSES	•			
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0Ó	0.00	0.00	0.00	0.00	0.00		CA	ŁM					
•	0.00	0.19	0.05	0.14	0.00	0.14	0.05	0.14	0.09	0.09	0.09	0.05	0.00	0.05	0,09	0.05	1.21		<	3.5	mph	-			
	0.56	0.60	1.07	0.97	0.70	0.46	0.19	0.37	0.28	0.14	0.14	0.19	0.28	0.14	0.32	0.46	6.86		3.6 -	7.5	mph				
	1.44	1.76	3.39	2.78	1.21	0.56	0.65	0.42	0.51	0.56	0.60	0.70	1.11	0.70	1.07	1.30	18.74		7.6 -	12.5	mph				
	1.58	4.82	5.33	4.78	1.95	1.62	1.44	1.07	1.11	1.44	1.58	1.39	0.8B	0.83	1.58	0.88	32.28	1	2.6 -	18.5	mph				
	1.07	0.51	3.15	2.97	1.90	0.88	0.74	0.28	0.83	2.18	1.48	1.58	1.35	1.21	1.62	0.37	22.12	1	8.6 -	24.5	mph				
ļ	0.28	0.05	0.46	1.21	1.07	0.74	0.70	0.37	1.11	3.66	3.34	1.30	1.44	1.16	1.35	0.56	18.78		>	24.5	mph				
											-				•		•								

•

::

.

LaSalle Nuclear Station 33 ft. Wind Speed and Direction October-December, 2003 200Ft-33Ft Delta-T (F)

Number of Observations - 2201 Values are Percent Occurrence

																				•					
SPEED							WIND	D DIRE	CTION	CLASSES	5						•			STAB		CLASSES		•	
224 13	N	NNE	NE	ENE		ECE	55	CCE	c	CCLI	cu	LICLI	U	LB.I.F	1.74	A1677.7	TOTAL	C 11							TOTAL
66755	n			CUC.		LJL	30	JJL	5	224	JH	won.	'n		t i M	111144	TUTAL	60	гu	30	n	22	гo	5	TUTAL
								•																	
FII	n nn	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	. ი იი	0 00	0 00	0 00							
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	.0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
C SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		•	0.00					
A N	0 00	0 00	0 00	0.00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0.00	0 00	. 0 . 00	•			0.00				
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00	-0.00		۰.		0.00				
L 35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					0.00			
m ms	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					•	0.00		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			•	•			0 00	
																								0.00	
														•							• .				0.00
													•												
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	.0.00	0.00	0.00	0.00	0.00	0.00	0.00		•		•			
MI	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0.00	•	0 00						
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
1 SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					·.
- N	0.00	0.00	0.00	0.05	0.00	0.05	0.05	0.00	0.05	· 0.05	0.18	0.05	0.05	0.05	0.05	0.05	0.64				0.64				
3 55	0 09	0 09	0 00	0.05	0 00	0.00	0.05	0 09	0 00	0 09	0 14	0 18	0 09	0.05	0 09	0 05	1 04	·				1.04			
0.00	0.07	0.05	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.05	0.14	0.10	0.05	. 0.05	0.05	0.05	1.04					1.04			
ms	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.05	0.00	0.00	0.18						0.18		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							0.00	
														•			·								1 86
																									1.00
																•									
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	• 0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00			·			
A CI1	0 05	0.00	n ng	0.00	0.00	0 00	0 00	0.00	0 00	0.00	0 00	0.00	0.00	0.00	0 00	0.00	0.22			0 22					
4 30	0.05	0.00	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	.0.23			0.23					
- N	1.04	0.35	0.23	0.32	0.09	0.55	0.27	0.09	0.05	0.05	0.14	0.59	0.82	0.64	0.55	0.77	6.54				6.54				
7 SS	0.64	0.41	0.14	0.36	0.50	0.64	0.64	0.68	0.05	0.36	0.32	0.45	0.45	0.45	0.59	· 0.27	6.95					6.95			
MS	0 27	0.05	0 05	0.05	0.59	0.59	0.27	0.09	0 09	0 41	0.36	0 64	0 59	0.55	0 00	0.32	4 91						4 91		
50	0.27	0.00	0.00	0.00	0.00	0.05	1 00	1 00	0.02	0.75	0.00	0.07	0.05	0.00	0.00	0.02		•					4.51		
5	0.2/	0.00	0.00	0.05	0.23	0.59	1.00	1.09	0.23	0.27	0.59	0.2/	0.73	0.27	0.09	0.09	. 5.77		•		•			5.77	
							·					•													24.40
								•								-									
FH	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0.00	0 00	0 00	0 00	0 00	0 00	0 00	0 00							
20	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.05	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.09	0.14	0.00	0.00	0.00	0.00	0.00	0.00	0.32	•	0.32			•			
8 SU	0.18	0.00	0.00	0.05	0.18	0.09	0.27	0.00	0.05	0.09	0.32	0.14	0.14	0.27	0.05	0.05	1.86			1.86					
- N	0 77	0 32	0.32	0.27	0 95	0.50	0 45	0 41	0.55	0 91	0.55	0 64	1 27	1 23	1 27	1 77	12 18				12 18				
1	0.77	0.02	0.02	1 00	1 64	0.00	0.10	0.05	1 10	0.77	0.00	0.00	A. C.	1 41		0.50	10.00				12.10	10.00			
1 55	0.77	0.41	0.35	1.00	1.64	0.55	0.59	0.95	1.18	0.77	0.73	0.82	0.64	1.41	1,54	0.59	13.95					13.95			
2 MS	0.05	0.14	0.00	0.09	1.00	0.41	0.41	0.41	0.27	0.18	0.86	0.59	0.59	0.91	0.32	0.00	6.22						6.22		
ES	0.00	0.00	0.00	0.00	0.23	0.23	0.32	0.09	0.32	0.64	1.00	0.68	0.82	0.05	0.00	0.00	4.36		÷					4.36	
				••••						••••															20.00
																	•			•					38.89
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	•		-				
1 1 1	0.00	0.00	0 00	0.00	0.00	0.00	0.00	0.00	0.14	0 00	0.00	0.14	0.00	0.14	0.00	0.00	0.00		0 00						
1 10	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.14	0.05	0.09	U.14	0.00	0.14	0.09	0.00	0.00	•	0.00						
3 SU	0.00	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.23	0.09	0.00	0.09	0.18	0.50	0.09	0.05	1.27			1.27					
- N	0.09	0.14	0.36	0.23	0.55	0.14	0.14	0.59	0.55	0.91	1.00	0.45	1.14	1.54	1.95	1.27	11.04		-		11.04				
1 55	0 05	0.05	0 10	0.05	0 60	n 19	0 27	0 77	0 01	1.96	0 60	0 15	0 19	0 60	0 1/	0 05	7 00				•	7 00			
1 33	0.00	0.00	0,10	0.00	0.00	0.10	0.21	0.11	0.71	1.00	0.00	0.45	0.10	0.03	0.17	0.03	7.00						o o-		
8 M2	U.00	0.05	0.00	0.00	0.09	U.18	U.14	0.09	0.23	0.27	0.82	0.14	U.14	0.09	0.00	0.05	2.2/					••	2.2/		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.00	0.09	0.00	0.00	0.00	0.00	0.18							0.18	
	•																								22.44

LaSalle Nuclear Station 33 ft. Wind Speed and Direction October-December, 2003 200Ft-33Ft Delta-T (F)

.

SPEE)						WIN		א אחזדי	1 45559										STADI					
71 AS	;	NNE	NF	ENE	F	FSF	SE	5 01100 0	، ۲۰۰۱		, כער ער	Licu	บ	LINIJ	มเม	· NNL	TOTAL	511	MT 1	رانا 1941 -	.LIIT '	CLA33E3			TOTAL
	,	1111	ne	606	•	LJL		550	5	554	Jn		. •		., 114	11110		20	rio.	30	Ň	33	сл	25	IUIAL
													·												
FU	0.00	0.00	0 00	0.00	0.00	0.00	0.00	0 00	0.05	0 00	0 00	0 00	0 00	0.05	0 00	0 00	0 09	0 09							
1 MI	0.00	0.00	0 00	0.00	0.00	0.00	0.00	0 00	0.05	0 00	0.00	0.05	0 00	0.05	0.14	0.00	0.36	0.05	ò 36						
9 51	0 00	0 00	0.00	0.00	0.00	0.05	0 00	0.00	0.09	0 00	0.09	0.05	0.05	0.00	0.05	0.00	0.00	•		0 45					
- N	0.00	0 00	0.05	0.00	0.09	0.00	0 00	0.32	0.18	0.00	0.09	0.00	1.32	1.36	0.55	0.00	5 50		•	0.45	5 50				
2 55	0.00	0 00	0.00	0.00	0 00	0.00	0.05	0.50	0 91	1 00	0.09	0.05	0.05	0.68	0.00	0.00	3 59				5.50	3 59			
4 MS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.05	0 00	0 00	0.00	0.00	0.00	0.00	0.20	n n9					0.07	n ng		
FS	0 00	0 00	0.00	0.00	0.00	0.00	0.00	0.00	0 00	0 00	0.00	0.00	0 00	0.00	0.00	0.00	0.00					•	0.05	0 00	
	0.00	0.00	0.00				0100	0.00		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							0.00	10 09
														-											10.05
FII	0 00	0 00	0 00	0 00	0 00	0.00	0 00	0 00	0 00	0 00	0 00	0 00	0.05	0 05	0 00	0 00	0 09	0 09							
G MI	0.00	0.00	0 00	0 00	0.00	0.00	0 00	0.00	0 00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.05	0 09	•					
TSU	0 00	0 00	0 00	0 00	0 00	0 00	0 00	0.00	0 00	0.05	0.05	0.00	0.09	0.05	0.00	0.00	0.03			0.23		•			
. 00 N	0.00	0.00	0 00	0 00	0.00	0 00	0 00	0.05	0.05	0.00	0 14	0.00	0.55	0.14	0.00	0.00	1 0.20			0.20	1 04				
2 55	0.00	0.00	0.00	0.00	0 00	0 00	0 00	0.09	0.00	0.00	0 00	0.05	0.00	0.27	0.00	0.05	0.86	•			1.04	0 R6			
4 MS	0.00	0.00	0.00	0.00	0 00	0.00	0 00	0 00	0 00	0 00	0.00	0.05	0.00	0.0	0.00	0.00	0.00					0.00	0 00		
FS	0.00	0.00	0 00	0 00	0 00	0.00	0.00	0 00	0.00	· n no	0.00	0.00	0.00	0.00	0.00	0.00	0.00						0.00	0 00	
20	0.00	0.00	0.00				0.00	0.00	0.00	0.00	0.00	0.00		0.00	0.00	0.00	0.00							0.00	2 32
													•	•											2.02
																	•		•	•					
TOT	4.32	2.00	1.86	2.59	6.77	4.73	4.91	6.36	6.41	9.40	8.31	6.82	10.18	11.49	7.54	6.32	100.00	0.18	. 1.45	4.04	36.94	33.39	13.68	10.31	100.00
																		••••							
Winc	Direc	tion b	y Stab	ility																					
			-	•																					
	N	NNE	NE	ENE	ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	-51	ABILIT	IY CLAS	SES-				
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.05	0.09	0.00	0.00	0.18	Ext	remely	Unsta	ble				
	0.05	0.00	0.05	0.05	0.00	0.00	0.00	0.00	0.27	0.18	0.18	0.18	0.09	0.18	0.23	0.00	1.45	Mod	leratel	ly Unst	able				
	0.23	0.00	0.14	0.05	0.18	0.14	0.27	0.00	0.36	0.23	0.45	0.27	0.45	Ó.91	0.18	0.18	4.04	\$11	ghtly	Unstat	le				
	1.91	0.82	0.95	0.86	1.68	1.23	0.91	1.45	1.41	2.82	2.09	1.91	5.13	4.95	4.36	4.45	36.94	Neu	tral						
	1.54	0.95	0.68	1.45	2.73	1.36	1.59	3.09	3.13	4.32	1.95	2.04	1.50	3.45	2.36	1.23	33.39	S11	ghtly	Stable	<u>.</u>				
	0.32	0.23	0.05	0.14	1.73	1.18	0.82	0.64	0.64	0.86	2.04	1.36	1.41	1.59	0.32	0.36	13.68	Mod	leratel	ly Stat	ole	· .			
	0.27	0.00	0.00	0.05	0.45	0.82	1.32	1.18	0.55	1.00	i.59	1.04	1.54	0.32	0.09	0.09	10.31	Ext	remely	/ Stabl	e				
						• •					• •			• .			•								
														·											
Wind	Direc	tion b	y Wind	Speed																					
									•																
	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	. MNM	NW	· NNW	TOTAL	-W]	ND SPE	EED CL/	SSES-				
															•		· ·		•						
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		CA	LM					
	0.09	0.09	0.00	0.09	0.05	0.05	0.09	0.09	0.05	0.14	0.32	0.23	0.23	0.14	0.14	0.09	1.86		∶<	3.5 m	nph	•			
	2.27	0.82	0.50	0.77	1.41	2.36	2.18	1.95	0.41	İ.09	1.41	1.95	2.59	1.91	1.23	1.54	24.40		3.6 -	7.5 n	nph				
	1.82	0.86	0.68	1.45	4.00	1.77	2.04	1.86	2.45	2.73	3.45	2.86	3.45	3.86	3,18	2.41	38.89		7.6 -	12.5 r	nph				
	0.14	Ò.23	0.64	0.27	1.23	0.50	0.55	1.45	2.04	3.27	2.59	1.36	i.64	2,86	2.27	1.41	22.44	, 1	2.6 -	18.5 n	iph				
	0.00	0.00	0.05	0.00	0.09	0.05	0.05	0.86	1.32	1.91	0.36	0.27	1.41	2.23	0.73	0.77	10.09	1	8.6 -	24.5 m	nph				
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.14	0.14	0.27	0.18	0.14	0.86	0.50	0.00	0.09	2.32		>	24.5 m	nph				
												•		٠		•			•						

• • • •

.

.

.

LaSalle Nuclear Station 375 ft. Wind Speed and Direction

October-December, 2003 375Ft-33Ft Delta-T (F)

.

.

•

Number of Observations - 2202 Values are Percent Occurrence

			•												•										
SPEEC	·						WING			CLASSES	5									- STABI		CLASSES			
CLASS	N	NNE	NE	. ENE	Ę	ESE	SE	SSE	S	SSW	SW	WSW	. W	WNW	NW	NNW	TOTAL	EU	MU	SU	N	SS	MS	ES	TOTAL
			•														•	•							
C 14	0 00	0 00	0 00	0 00	0.00	0.00	0 00								0 00		• •					•			
50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
FU 6 CU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
6 50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	. 0.00	. 0.00	0.00	0.00	0.00			0.00					
AN	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	•	••	••	0.00				
L 22	0.00	0.00	0.00	0.00	··U.UU	0.00	0.00	0.00	0.00	0.00.		0.00	0.00	0.00	0.00	0.00	0.00	•				0,00			
m mo	0.00	0.00	0.00	0.00	0.00	-0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						0.00		
. 52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							0.00	
																									0.00
					0.00			o oo					• ••	• ••											
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	•					
1 50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					
- N	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.05	0.00	0.09	0.00	0.05	0.05	0.00	0.00	0.27			•	. 0.27				
3 \$\$	0.00	0.00	0.00	0.05	0.09	0.00	0.05	0.00	0.00	0.00	0.05	0.05	0.00	0.00	0.05	0.05	0.36			·		0.3 6			
MS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	•	•				0.00		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				•			0.00	
																									0.64
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
4 SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	• 0.00			0.00	••••				
- N	0.36	0.41	0.27	0.23	0.00	0.27	0.05	0.18	0.05	0.00	0.18	0.23	0.45	0.54	0.27	0.50	4.00		•		4.00	٠			
7 SS	0.18	0.14	0.05	0.00	0.18	0.23	0.05	0.14	0.05	0.05	0.09	0.14	0.18	0.27	0.09	0.18	2.00	•		•		2.0 0			
MS	0.00	0.00	0.00	0.00	0.05	0.00	0.05	0.00	0.05	0.00	0.05	0.00	0.05	0.09	0.05	0.00	0.36				•		0.36		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.00	0.00	0.00	0.09							0.09	
					·																				6.45
										• .	•														
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	•						
MJ	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.05		0.05						
8 SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.05	0.05	0.00	0.00	0.14			0.14	·				
- N	1.14	0.18	0.32	0.50	0.59	0.45	0.59	0.77	0.41	0.50	0.41	0.36	0.73	1.04	1.41	1.09	10.49				10.49				
1 SS	0.32	0.18	0.27	0.14	0.23	0.45	0.14	0.32	0.14	0.09	0.36	0.23	0.54	0.18	0.32	0.09	4.00					4.0 0			
2 MS	0.00	0.36	0.05	0.00	0.00	0.18	0.14	0.00	0.05	0.09	0.09	0.05	0.27	0.09	0.05	0.05	1.45	•					1.45		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.05	0.18	0.05	0.00	0.05	0.00	0.36				•			0.36	
																									16.49
												• •													
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
1 MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.05		0.05		•	• •			
3 SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.05	0.00	0.00	0.00	0.09			0.09					
- N	0.41	0.27	0.54	0.64	1.32	0.68	0.23	.0.59	1.27	1.09	0.86	0.64	1.09	1,50	2.13	0.82	14.08				14.08				
1 SS	0.45	0.73	0.14	0.36	0.32	0.27	0.27	0.18	0.23	0.09	0.32	0.50	0.73	0.50	0.50	0.45	6.04					6.04			
8 MS	0.09	0.18	0.18	0.00	0.14	0.18	0.45	0.14	0.00	0.00	0.32	0.00	0.14	0.27	0.14	0.05	2.27	·.				۰.	2.27		
ES	0.00	0.00	0.00	0.00	0.00	·0.00	0.09	0.14	0.45	0.09	0.36	0.18	0.00	0.0 9	0.00	0.00	1.41		•					1.41	
												•	•				•	•		•	• •				23.93

.

·•

• •

		LaSalle Nuclear Station 375 ft. Wind Speed and Direction													Octobe 375Ft-	er-Deco -33Ft (ember. Delta-T	2003 (F)							•	
														• •									•		•	• .
SPEEC)					•••••	WIN	D DIRE	CTION	CLASSES	5									- STAB	ILITY	CLASSES			•	
CLASS	N	NNE	NE	ENE	E	EŚE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	EU	MU	SU	N	`∙ SS	MS	ES	TOTAL	•
																							•		· ·	
EU	0.00	0.00	0.00	0.00	0.0 0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00								:.
1 MU	0.00	0.00	0:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	•						•
9 SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.05	• 0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.14			0.14					•	
- N	0.09	0.27	0.64	0.32	0.50	0.27	0.23	0.73	0.54	0.95	0.59	0.86	0.64	1.14	2.63	0.32	10.72				10.72					
2.55	0.50	0.32	0.05	0.23	0.68	0.68	0.41	0.50	0.82	0.54	0.41	0.36	0.82	0.68	1.23	0.50	8.72					8.72				
4 FS	0.00	0.00	0.00	0.00	0.09	0.05	0.09	0.27	0.68	0.09	0.23	0.23	0.45	0.82	0.30	0.09	2 63						3.50	2 63	•	•
	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.20	0.00	0.20	0.27	0.20	0.05		0.05	0.00								2.05	25.70	, ,
								•							•		•							•		
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				• .				
GMU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00			· ·			•	
TSU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.00	0.05			0.05						
N 22 C	0.00	0.00	0.09	0.00	0.32	0.14	0.27	0.54	0.45	1.50	0.86	0.50	2.00	1.59	2,36	0.36	10.93				10.99	0.00		•		·
4 MS	0.00	0.00	0.00	0.00	0.00	0.14	0.23	0.23	0.41	0.32	0.91	0.50	0.32	0.32	0.32	0.00	3.68					5.55	3.68			
ES	0.00	0.00	0.00	0.00	0.00	0.09	0.09	0.18	0.45	0.32	0.50	0.23	0.05	0.18	0.00	0.00	2.09	•					0.00	2.09	•	
										•								•	•				. :	. •	.26.79).
																	•.				•	•	•	•	•	
тот	2 01	2 04	2 68	2 15	1 50	A A1	. 4 00	6.04	7 05	0 5Å	. 7 95	5 77	0 21	11 26	12 67	A 5A	100 00	0 00	0.00	0.41	50 FA	91 11	11 20	C E 0	100.00	, ·
101	5.01	5.04	2.00	2.4J	۹.55	4.41	4.00	0.04	7.55	3.04	7.35	5.77	7.51	11.20	12.07	4.04	100.00	0.00	0.05	0.41	30.34	51.11	11,20	0.00	100,00	'
																										٠
Wind	Direc	tion b	y Stab	ility																			•			
				ENC	-	for			~		C 11						70741	~ ~						•		
	N	NNE	NE	ENE	E	LOC	SE	33E	2	228	24	M2M	W	MUM	NW	NNW	IUTAL	-51	ABILI		55F2-					
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Ext	remely	v Unst	able					
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.05	0.00	0.00	0.09	Hod	erate	ly Uns	table				•	
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.05	0.00	0.05	0.05	0.14	0.09	0.00	0.00	0.41	S11	ght1y	Unstal	ole		•			
	2.00	1.14	1.86	1.68	2.72	1.82	1.41	2.82	2.77	4.04	3.00	2.59	4.95	5.86	8.81	3.09	50.54	Neu	tral				•	•••	• •	
	1.45	1.36	0.54	0.77	1.59	1.73	1.18	1.95	2.91	4.35	2.13	1.59	2.68	2.77	2.82	1.27	31.11	511 Mod	ghtly onsta	Stable Stable	e -1-	•.		•		. ·
	0.35	0.54	0.27	0.00	0.27	0.73	1.14	0.64	1.63	0.50 -0.64	1.59	0.73	1,23	1.59	0.91	0.18	11.20 6.58	Fixt	erate recelu	ly Sta. v Stah	Die Io					
	0.00	0.00	0.00	0.00	0.00	0.14	0.27	0.55	1.05	0.04		0.02	0.27		0.14	0.00	0.50			5100	10	•			•	
																		•							•	•
Wind	Direc	tion by	y Wind	Speed		•											•				•	• .		••		
				FNF	-		. cr		~	CC 11	C 11	1.001					TOTAL									
	N	NNE	NE	ENE	Ł	ESE	SE	22F	2	22M	2M	M2M	W	· WNW	NW	NNW	IUIAL	-Wi	NU SPI		ASSES-					
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		C A	LM						
	0.00	0.00	0.00	0.05	0.09	0.00	0.09	0.00	0.05	0.00	0.14	0.05	0.05	0.05	0.05	0.05	0.64		· ` <	3.5	πph	•		• .		
	0.54	0.54	0.32	0.23	0.23	0.50	0.14	0.32	0.14	0.05	0.32	0.36	0.77	0.91	0.41	0.68	6.45		3.6 -	7.5	nph				••••	
	1.45	0.73	0.64	0.64	0.82	1.09	0.86	1.09	0.64	0.68	0.95	·0.82	1.68	1.36	1.82	1.23	16.49	•	7.6 -	12.5	nph			•.	•	•
	0.95	1.18	0.86	1.00	1.77	1.14	1.04	1.04	1.95	1.27	1.86	1.36	2.00	2.41	2.77	1.32	23.93	1	2.6 -	18.5	πph		•	·		
	0.86	0.59	0.73	0.54	1.27	1.23	1.00	1.82	2.18	1.82	1.50	1.63	2.00	3.32	4.31	0.91	25.70	1	8.6 ·	24.5	mph.					• •
	0.00	0.00	0.14	0.00	U.41	U.4 5	0.80	1.77	3.00	5.72	5.10	1.54	2.02	3.22	3.32	0.30	20.19		,	24.3	npri			•		•

•

.

. <u>.</u>
LaSalle Nuclear Station 33 ft. Wind Speed and Direction January-December. 2003 200Ft-33Ft Delta-T (F)

Number of Observations - 8746 Values are Percent Occurrence

. •

														•											
SPEED							WIN	D DIRE	CTION (CLASSES	;									STAB		LASSES	•••••		
CLASS	N	NNE	NE	ENE	ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	Na	NNW	TOTAL	EU	MU	SU	N	SS	MS	ES	TOTAL
																		•			•		• •		. •
												•										• •		•	
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0,00	0.00	0.00	0.00	0.00							
MU	0.Ö0	0.00	0.00	0.00	0.00	0.00	0.00	·0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00				•		
C SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00		•			
A N	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				· ·
L SS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0,00	0.00	0.00	0.00					0.00	•		
m ms	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						0.00		
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					۰.		0.00	
																									0.00
	•												•					•				•			
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.Ó0	0.00	•				•	•	
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						•
1 SU	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01			0.01					· ·
- N	0.05	0.09	0.03	0.06	0.02	0.05	0.06	0.06	0.05	0.03	0.11	.0.09	0.06	0,05	0.05	0.07	0.91	•	•		0.91				
3 SS	0.09	0.08	0.03	0.02	0.01	0.02	0.06	0.06	0.06	0.08	0.09	0.10	0.07	0.06	0.02	0.02	0.88					0.88		• •	•
MS	0.03	0.01	0.03	0.05	0.03	0.01	0.03	0.00	0.03	0.02	0.03	0.03	0.10	0.05	0.02	0.00	0.50						0.50		
ES	0.00	0.00	0.00	0.Ò1	0.01	0.03	0.01	0.00	0.03	0.03	0.01	0.02	0.03	0.02	0.00	0.00	0.23							0.23	•
																	•••••								2.54
					•																				
FU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.02	0.02	0.02	0.00	0.01	0.00	0.01	0.00	0.13	••••	0.13	•	•				· · ·
4 SU	0.18	0.13	0.19	0.09	0.05	0.10	0.08	0.05	0.09	0.02	0.06	0.02	0.05	0.11	0.05	0.14	1.41			1.41					•
- N	0.98	1.03	0.75	0.54	0.34	0.33	0.30	0.33	0.27	0.23	0.30	0.35	0.51	0.51	0.43	0.63	7.86				7.86				
7 SS	1.13	0:90	0.30	0.23	0.58	0.40	0.42	0.43	0.26	0.35	0.43	0.40	0.43	0.49	0.47	0.38	7.63	•				7.63		•	
MS	0.27	0.30	0.05	0.06	0.51	0.57	0.39	0.29	0.33	0.38	0.45	0.41	0.63	0.58	0.17	0.22	5.60						5.60		•
ES	0.16	0.02	.0.00	0.03	0.17	0.57	0.82	1.01	0.78	0.62	0.74	0.45	0.80	0.35	0.11	0.05	6.69							6.69	
									••••			••••													29 30
EU	0.01	0.13	0.03	0.02	0.01	0.00	0.00	0.01	0.00	0.03	0.06	· 0.00	0.01	0.00	0.01	0.01	0.34	0.34	·						
MU	0.11	0.10	0.27	0.17	0.03	0.05	0.03	0.11	0.09	0.14	0.15	0.11	0.11	0.10	0.02	0.03	1.66		1.66					•	
8 SU	0.19	0.16	0.23	0.17	0.13	0.05	0.17	0.19	0.11	0.17	0.17	0.17	0.21	0.31	0.21	0.25	2.89			2.89		•			
- N	1.35	1.39	1.10	0.75	0.74	0.32	0.46	0.34	0.63	0.57	0.61	0.57	0.91	1.06	1.12	1.58	13.51				13.51				
1 SS	0.50	0.59	0.91	0.98	1.25	0.35	0.42	0.46	0.59	0.71	1.04	0.67	0.58	0.87	0.90	0.51	11.37					11.37			
2 MS	0.02	0.03	0.00	0.11	0.79	0.29	0.25	0.18	0.39	0.32	0.54	0.57	0.37	0.42	0.24	0.02	4.55						4.55		•
ES	0.00	0.00	0.00	0.00	0.10	0.15	0.21	0.30	0.62	0.57	0.79	0.55	0.42	0.08	0.03	0.00	3.82			•				3.82	۰.
	••••									••••			••••				••••	:				•			38 14
																									00.1
FII	0.01	U US	0 09	0 00	0 00	0 00	0 00	0 02	0 03	0 16	0.18	0 07	0 03	0 08	0 00	0 00	0 71	0 71		•					•
1 MI	0.01	0.02	0.03	0.03	0 01	0.00	0.00	0.03	0.00	0 15	0 19	0.07	0.15	0.16	0.06	0.06	1 13	0.71	1 13						•
3 (1)	0.05	0.02	0.00	0.05	0.06	0.00	0 01	0.07	0.10	0 14	0.13	0.05	0.21	0.30	0 17	0.07	1 60		1.10	1.60					
_ N	n //q	0.32	0.00	1 112	0 47	0.00	0.01	0.26	0.10	0.14	0.29	0.10	ידא מ	1 28	1 07	1 55	10.85			1.00	10 85				
1 55	0.99	0.00	0.31	0.37	0 40	0.10	0.17	0.33	0.50	0.75	0.4R	0.40	0.07	· 0 58	0 10	n na	4 94		•		10.00	4 94			
2 MC 7 22	0.00	0.03	0.17	0.07	0.70	0.06	0.10	0.05	0.02	0.00	0.40	0.71	0.14	0.00	0.10	0.05	1 22					7.27	1 23		• •
21	0.00	0.01	0.00	0.00	0.02	0.00	0.07	in nn	0.10	0.14	0 02	0.07	0.14	. 0 00	0.02	0.01	0 13						1.20	0.13	
CJ	5.00	0.00	0.00	0.00	0.00		0.00	0.00	0.01	0.00	0.0C	0.02	0.00		0.00	0.00	0.10								20 59

LaSalle Nuclear Station

January-December, 2003 200Ft-33Ft Delta-T (F)

33 ft. Wind Speed and Direction

SPEEI)	•••••					WIN	D DIRE	CTION	LASSES	5						-			STAR	אדד נ	CI ASSES				
CLAS	5 N	NNE	NE	ENE	Ē	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNM	TOTAL	Eυ	MU	รบ	N	SS	, MS	ES	TOTAL	
											•		•				•									
EU	0.00	0.00	0.01	0.01	0.01	0.00	0.00	0.00	0.01	0.05	0.11	0.06	0.02	0.09	0.00	0.00	0.38	0.38		·	·					
1 MU	0.00	0.00	0.03	0.01	0.03	0.00	0.01	0.00	0.02	0.07	0.07	0.18	0.05	0.03	0.06	0.02	0.59		0.59				•			
9 SU	0.00	0.00	0.03	0.00	0.01	0.01	0.02	0.02	0.06	0.06	0.11	0.06	0.08	0.11	0.02	0.03	0.64			0.64		•				
- N	0.07	0.00	0.57	0.23	0.19	0.07	0.06	0.09	0.15	0.27	0.21	0.26	0.62	0.98	0.29	0.25	4.31				4.31	`				
2 SS	0.00	0.00	0.11	0.00	0.01	0.02	0.03	0.14	0.33	0.38	0.07	0.09	0.07	0.35	0.02	0.06	1.69					1.69			•	•
4 MS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.06	0.00	0.01	0.01	0.03	0.00	0.00	0.14						0.14			
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	•				•	•••	0.00		
																							•	••••	7.75	
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.03	0.01	0.00	0.01	0.02	0.00	0.00	0.09	0.09								•
GMU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.02	0.03	0.00	0.00	0.07		0.07						•	
t su	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.05	0.01	0.01	0.02	0.05	0.00	0.00	0.15			0.15						
N	0.00	0.00	0.01	0.11	0.01	0.01	0.02	0.02	0.01	0.01	0.06	0.14	0.22	0.11	0.07	0.01	0.82				0.82					
2 SS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.03	0.09	0.01	0.02	0.07	0.27	0.00	0.01	0.54					0.54				
4 HS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					0.01	0.00			
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					•		0.00		•
•																						•			1.67	
							•		·								•	•								
													•					•								
TOT	5.85	5.50	5.97	5.15	6.04	3.66	4.36	4.94	6.52	7.27	8.55	6.68	7.97	9.71	5.76	6.08	100.00	1.52	3.58	6.70	38.27	27.04	12.03	10.86	100.00	
																			•							
																									•	
Wind	Direc	tionb	y Stab	ility													•							•		÷
			-	-	•							•												•	•	•
	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WŚW	W	WNW	NW	NNW	TOTAL	-ST/	ABILIT	Y ĊLAS	SES-		•			
												•						•								
	0.02	0.15	0.14	0.03	0.02	0.00	0.00	0.05	0.05	0.27	0.37	0.13	0.08	0.19	0.01	0.01	1.52	Exti	remely	Unsta	ble			•		•
	0.17	0.13	0.34	0.22	0.08	0.05	0.05	0.17	0.24	0.38	0.43	0.39	0.34	0.33	0.15	0.11	3.58	Hode	eratel	y Unst	able	•••				
	0.42	0.33	0.49	0.31	0.25	0.16	0.29	0.34	0.39	0.43	0.48	0.42	0.56	0.88	0.45	0.49	6.70	Slig	htly	Unstat	le					
	2.94	2.89	3.38	2.72	1.78	0.90	i.18	1.11	1.61	1.57	2.16	1.90	3.00	4.00	3.03	4.09	38.27	. Neut	tral	•						
	1.81	1.62	1.53	1.60	2.25	0.87	1.06	1.44	1.90	2.45	2.13	1.70	1.45	2.63	1.52	1.07	27.04	· S11	ghtly	Stable		•	·			
	0.33	0.35	0.08	0.22	1.36	0.93	0.74	0.53	0.89	0.91	1.42	1.10	1.25	1.21	0.46	0.25	12.03	Mode	eratel	y Stat	le					
	0.16	0.02	0.00	0.05	0.29	0.75	1.04	1.30	1.44	1.26	1.57	1.04	1.29	0.46	0.15	0.05	10.86	Exti	remely	Stab]	e	•				
													•				•									
Wind	Direc	tion b	y Wind	Speed																			•		••	
																			·					•	. •	• •
	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	· W	WNW	NW	NNW	TOTAL	-WI	ND SPE	ED CL/	SSES-	. .	• •			•
											•	•	•							·			·		•	
	0.00	0.00	0.00	0.00	0.00	o	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		CA	LM						
	0.17	0.18	0.10	0.14	0.09	0.11	0.16	0.11	0.17	0.17	0.25	0.25	0.26	0.17	0.09	0.09	2.54	•	<	3.5 r	nph		•			
	2.76	2.38	1.29	0.95	1.66	1.98	2.01	2.12	1.76	1.62	2.00	1.64	2.44	2.06	1.25	1.41	29.30		3.6 -	7.5 г	noh					
	2.20	2.41	2.55	2.22	3.05	1.20	1.54	1.60	2.44	2.52	3.35	2.65	2.62	2.85	2.54	2.41	38.14		7.6 -	12.5 r	noh				•	
	0.66	0.53	1.25	1,47	0.96	0.25	0.49	0.77	1.52	1.90	2.29	1.30	1.46	2.53	.1.43	1.78	20.59	1	2.6 -	18.5 r	nohi				•	
						-																				
	0.07	0.00	0.77	0,25	0.26	0.10	0.13	0.26	0.58	0.88	0,57	0.66	0.85	1.61	0.39	0.37	7.75	· 18	8.6 -		noh		·		· .	
	0.07	0.00 0.00	0.77 0.01	0.25 0.11	0.26 0.01	0.10 0.01	0.13	0.26	0.58 0.05	0.88 0.18	0.57 0.09	0.66 0.17	0.85 0.34	1.61	0.39 0.07	0.37 0.02	7.75	. 18	8.6 - >	24.5 n 24.5 n	nph noh		•		· .	

• •

LaSalle Nuclear Station 375 ft. Wind Speed and Direction

January-December, 2003 375Ft-33Ft Delta-T (F)

Number of Observations - 8719 Values are Percent Occurrence

SPEED)						WIN!		CTION	CLASSES		• • • • • • •								STAR	11 TY (232241			
CLASS	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NH	NNW	TOTAL	FU	MU	SU	N	SS	MS	FS	TOTAL
											•					•									
													•						·	·					•
EU	0.00	0.00	0.00	0.00	0.00	0.00	·0.00	0.00	0.00	0.00	0.00	` 0.0 0	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						• .
C SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00		•			
A N	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				•
L SS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					0.00			
m ms	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				•		0.00		•
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					•.		0.00	• •
						•																•			0.00
																		•							
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				•	• •		
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00			•			
1 SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	. 0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					· .
- N	0.01	0.03	0.02	0.07	0.02	0.01	0.05	0.05	0.06	·0.01	0.07	0.02	0.02	-0.06	0.03	[.] 0.01	0.55				0.55				
:3 SS	0.00	0.02	0.02	0.01	0.05	0.02	0.01	·0.01	0.01	0.03	0.02	0.01	0.00	0.00	0.02	0.05	0.30					0.30		•	
MS	0.01	0.00	0.02	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.00	0.00	0.01	0.08				•		0.08		••.
ES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.01	0.00	0.01	0.00	0.03						·	0.03 ·	
									•							•									0.96
									•																•
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00							
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						••
4 SU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	·0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					•
- N	0.47	0.40	0.49	0.49	0.24	0.26	0.23	0.39	0.29	0.10	0.25	0.21	0.30	0.32	0.41	0.44	5.30				5.30				•
7 SS	0.11	0.14	0.08	0.10	0.22	0.17	0.13	0.15	0.08	0.09	0.10	0.15	0.14	0.16	0.10	0.16	2.09					2.09			
MS	0.02	0.05	0.05	0.00	0.10	0.03	.0.01	0.01	0.05	0.05	0.06	0.09	0.08	0.06	0.07	0.07	0.79				•		0.79		
FS	0.00	0.00	0 00	0.00	0.00	0.00	0.01	0.02	0.02	0.01	0.01	0.03	0.08	0.02	0.00	0.02	0.24		·					0 24	
				••••		••••																			8.42
																						••			
EU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00.	0.00	•						•
MU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.01		0.01						
8 SU	0.00	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.01	0.01	0.02	0.00	0.01	0.01	0.01	0.00	· 0.15			0.15		•	•		•. •
- N	1.02	1.04	0.94	0.96	0.61	0.49	0.38	0.63	0.58	0.46	0.46	0.32	0.70	1.01	1.09	1.16	11.86				11.86				
1 55	0 16	0.28	0 46	0.38	0.37	0.33	0 19	0 21	0 13	0.16	0.26	0.33	0.32	0.18	0.36	0.21	4.32					4.32			
2 MS	0.06	0.16	0.07	0 01	0.08	0 17	0 13	0 16	0 22	0.06	0.10	0 14	0.25	0 16	0.09	0.09	1.95						1.95		
51.2	0.00	0.10	0.00	0.01	n nn	0 00	0 00	0.03	0 07	0.06	0 07	0 14	0.08	0.02	0.02	0.01	0.52	•				•		0 52	:
-	0.00		0.00	0.00	0.00	0.00		0.00	0.07	0.00	0.07	V. 14	0.00	0.02	0.02	0.01	0.02							0.02	18 81
								•					·			·							••	•	10.01
. EU	0 00	0 00	n nn	0 00	0 00		0 00	0 00	0 00	0 00	n nı	0 00	0.00	0 00	0.00	0 00	0 01	0 01					•		•
1 MI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.05	0.01	0 06						
2 CH -	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00 A. A.	0.01	0.02	0.00	0.01	0.00	0.00	0.00			0 22		•		•	
3 30 .	1.01	1.00	0.03	1 42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.03	0.01 1 17	1 21	1 00	15 62			0.32	15 62			•	
- N	1.01	1.08	1.60	1.4J	0.00	0.39	0.34	0.03	0.00	0.00	0.77	0.00	0.94	1.1/	1.01	1.03	10.02				10.02	7 95	•		•
1 22	0.39	0.92	0.0/	0.79	0.41	0.30	0.29	0.21	0.31	0.20	0.4/	0.38	0.30	0.02	0.01	0.33	1.20					1.20	2 46		
o no Fi	0.08	0.13	0.15	0.10	0.15	0.24	0.39	0.21	0.24	0.1/	0.33	0.21	0.29	0.28	0.3/	0.14	J.40						J.40	1 20	• • •
5	0.00	0.00	0.00	0.00	0.00	0,02	0.09	0.23	U.22	U.22	0.24	U.10	0,05	0.11	0.01	0.01	1.30						÷	1.30	20 10

LaSalle Nuclear Station 375 ft. Wind Speed and Direction

SPEED ----- WIND DIRECTION CLASSES ------ STABILITY CLASSES ---CLASS NE ENE E ESE SE SSE S. SSW NNF SW WSW W WNW NW NNW TOTAL EU MU SU SS N MS ES TOTAL 0.05 0.05 9 SU 0.01 0.00 0.09 0.00 0.00 0.00 0.00 0.03 0.02 0.10 0.08 0.02 0.00 0.03 0.00 0.01 0.41 0.41 - N 0.55 0.47 0.92 0.97 0.48 0.16 0.24 0.30 0.42 0.72 0.88 0.73 0.72 1.10 1.69 0.73 11.10 11.10 2 SS 0.31 0.18 0.46 0.33 0.45 0.30 0.24 0.29 0.46 0.46 0.57 0.47 0.54 0.57 0.76 0.30 6.69 6.69 4 MS 0.08 0.01 0.02 0.09 0.13 0.18 0.23 0.21 0.19 0.24 0.30 0.16 0.30 0.57 0.36 0.06 3.13 · 3.13 ES 0.00 0.00 0.00 0.00 0.00 0.03 0.05 0.25 0.41 0.32 0.32 0.19 0.09 0.24 0.03 0.00 1.95 1.95 23.33 0.00 0.00 0.06 0.06 0.22 N 0.33 0.03 0.85 0.53 0.25 0.18 0.19 0.22 0.24 0.72 0.69 0.56 0.95 1.30 1.25 0.30 8.60 8,60 2 SS 0.05 0.01 0.05 0.02 0.13 0.09 0.09 0.33 0.81 1.66 0.92 0.39 0.49 1.11 0.46 0.13 6.74 6.74 4 MS 0.00 0.00 0.01 0.01 0.06 0.11 0.18 0.23 0.21 0.57 0.70 0.36 0.25 0.23 0.15 0.00 3.07 3.07 ES 0.00 0.00 0.00 0.00 0.00 0.07 0.05 0.17 0.34 0.44 0.40 0.13 0.02 0.07 0.00 0.00 1.69 1.69 20.38

January-December, 2003

375Ft-33Ft Delta-T (F)

TOT 4.69 5.08 7.24 6.35 4.61 3.66 3.52 4.97 6.20 7.88 8.53 5.98 7.10 9.34 9.53 5.32 100.00 0.01 0.17 1.10 53.03 27.40 12.49 5.79 100.00

Wind Direction by Stability

				•								•	• •				
N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	-STABILITY CLASSES-
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	. 0.01	Extremely Unstable
0.00	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.06	0.05	0.02	0.01	0.01	0.00	0.00	0.17	Moderately Unstable
0.02	0.10	0.15	0.03	0.01	0.00	0.00	0.03	0.03	0.19	0.23	0.08	0.10	0.06	0.03	0.01	1.10	Slightly Unstable
3.39	3.06	5.02	4.46	2.47	1.50	1.43	2.21	2.40	2.82	3.34	2.52	3.64	4,95	6.08	3.73	53.03	Neutral
1.02	1.55	1.73	1.64	1.62	1.27	0,95.	1.19	1.80	·2.67	2.35	1.73	1.85	2.55	2.31	1.17	27.40	Slightly Stable
0.25	0.34	0.32	0.22	0.52	0.76	0.94	0.81	0.91	1.09	1.50	0.96	1.17	1.30	1.03	0.37	12.49	Moderately Stable
0.00	0.01	0.00	0.00	0.00	0.13	0.19	0.71	1.07	1.04	1.06	0.65	0.33	0.47	0.08	0.05	5.79	Extremely Stable

Wind Direction by Wind Speed

N	NNE	· NE	ENE	Έ.	ESE	SE	SSE	· S	SSW	SW	WSW	W	WNW	NW	NNW	TOTAL	-WIND SPEED CLASSES-
							•				•	·				•	
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	CALM
0.02	0.06	0.07	0.08	0.07	0.05	0.06	0.06	0.07	0.05	0.11	0.05	0.03	0.06	0.07	0.07	0.96	< 3.5 mph
0.61	0.58	0.62	0.60	0.56	0.47	0.38	0.57	0.44	0.25	0.42	0.48	0.60	0.56	0.58	0.69	8.42	3.6 - 7.5 mph
1.24	1.53	1.49	1.36	1.06	1.00	0.70	1.03	1.01	0.75	0.92	0.93	1.38	1.39	1.57	1.47	18.81	7.6 - 12.5 mph
1.49	2.20	2.65	2.35	1.42	1.01	1.11	1.27	1.57	1.51	2.10	1.47	1.66	2.10	2.60	1.57	28.10	12.6 - 18.5 mph
0.95	0.67	1.50	1:40	1.06	0.68	0.76	1.08	1.51	1.87	2.17	1.58	1.65	2.52	2.83	1.10	23.33	18.6 - 24.5 mph
0.38	0.05	0.91	0.56	0.45	0.46	0.52	0.95	1.61	3.45	2.81	1.47	1.78	2.71	1.87	0.42	20.38	> 24.5 mph

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2003)

APPENDIX A OFFSITE DOSE CALCULATION MANUAL

Revision 7 December 2003

LASALLE ANNEX INDEX

CHAPTER 10

Revision 7

p:\procupgd\approved\odcm\ls10r7.0

CHAPTER 10

RADIOACTIVE EFFLUENT TREATMENT AND MONITORING

Table of Contents

<u>NUME</u>	BER		PAGE				
10.1	AIF	RBORNE RELEASES	1				
	1.	System Description Condenser Offgas Treatment System Ventilation Exhaust Treatment System 	1 2 2				
	2.	 Radiation Monitors Station Vent Stack Effluent Monitor Standby Gas Treatment System Effluent Monitor Reactor Building Ventilation Monitors Condenser Air Ejector Monitors Turbine Building Trackway and North Service Building 	2 2 3 3 3 4				
	3.	 Alarm and Trip Setpoints Setpoint Calculations Reactor Building Vent Effluent Monitor Condenser Air Ejector Monitors Station Vent Stack Effluent Monitor Standby Gas Treatment Stack Monitor Release Limits Release Mixture Conversion Factors HVAC Flow Rates 	4 4 4 4 5 5 5 6 6 6				
	4.	Allocation of Effluents from Common Release Points	7				
	5.	Dose Projections	7				
10.2	LIC	QUID RELEASES	7				
	 System Description Radwaste Discharge Tanks Cooling Pond Blowdown Radiation Monitors Liquid Radwaste Effluent Monitor Service Water Effluent Monitors 						
		3. RHK Heat Exchanger Cooling Water Effluent Monitors	8				

CHAPTER 10

RADIOACTIVE EFFLUENT TREATMENT AND MONITORING

Table of Contents (Cont'd)

NUMBER

<u>PAGE</u>

	З.	Alarm and	d Trip Setpoints	8
		1. S	etpoint Calculations	. 8
		1	. Liquid Radwaste Effluent Monitor	. 8
		2	. Service Water Effluent Monitors	8
		3	. RHR Heat Exchanger Cooling Water Monitors	. 9
		2. E	Discharge Flow Rates	9
		1	. Release Tank Discharge Flow Rate	9
		2	. Recommended Release Tank Flow Rate	9
		3. F	Release Limits	10
		4. F	elease Mixture	10
		5. C	Conversion Factors	10
		6. L	iquid Dilution Flow Rates	10
	4.	Allocation	of Effluents from Common Release Points	10
	5.	Projected	Doses for Releases	10
10.3	SOLI		OF WASTE/PROCESS CONTROL PROGRAM	10

CHAPTER 10

LIST OF TABLES

NUMBER		PAGE
10-1	Assumed Composition of the LaSalle Station Noble Gas Effluent	10-11

LIST OF FIGURES

NUMBER		PAGE
10-1	Simplified Gaseous Radwaste and Gaseous Effluent Flow Diagram	10-12
10-2	Simplified Liquid Radwaste Processing Diagram	10-14
10-3	Simplified Liquid Effluent Flow Diagram	10-15
10-4	Simplified Solid Radwaste Processing Diagram	10-16

.

Revision 7 December 2003

CHAPTER 10

RADIOACTIVE EFFLUENT TREATMENT AND MONITORING

10.1 AIRBORNE RELEASES

10.1.1 System Description

A simplified gaseous radwaste and gaseous effluent flow diagram are provided in Figure 10-1.

The airborne release point for radioactive effluents is the ventilation stack which is classified as a stack in accordance with the definitions in Section 4.1.4 and the results in Table A-1 of Appendix A.

In addition, the standby gas treatment system effluent is released through a separate stack inside the ventilation stack. This release point has the same location and classification as the ventilation stack.

Exfiltration to the environment from the Turbine Building has been identified at times of positive pressure in the Turbine Building. Within 20 hours of the turbine building being at positive pressure continuous air sampling shall be in place in the south Turbine Building trackway to monitor releases through this pathway. The releases through the trackway door and other potential release paths contain insignificant levels of contamination when compared to the Station Vent Stack which has a 1,000,000 cfm typical stack flow compared to the Trackway flow rate of 40,000 scfm and conservatively estimated as a total of 80,000 scfm to account for pathways other than the trackway. In addition, typical releases from LaSalle Station have not exceeded 0.02% of the 10CFR50 Appendix I dose limits. Any identified release via this pathway is a ground level release and should be considered in dose calculations. See Figure 10-1 for further information.

Exfiltration to the environment from the North Service Building may occur due to changes in the ventilation system. Within 20 hrs of the turbine building being at positive pressure, air sampling shall be performed at times when the ventilation systems are aligned to support unit 2 egress. This air sampling is designed to ensure evaluation of releases emanating from the Turbine Building in accordance with ODCM 10.1.2.5.

The station vent stack is equipped with three access hatches at elevations 853', 888' and 1055'. Nominal leakage from these access hatches is expected at an approximated value of up to 1000 SCFM. Resultant doses due to this nominal leakage are negligible when compared to the SVS flow of 1.00 E6 SCFM and have been calculated as such. Doses due to this nominal leakage are therefore accounted for in the gaseous effluent stream and do not require further calculation.

During maintenance activities in which the hatch(es) would be opened, however, the lower elevation hatches (elevations 853' and 888') are classified as vent or "mixed mode" release pathways. These release pathways should be monitored during the maintenance activity period, with resultant releases calculated as mixed mode. Monitoring may be accomplished by determining flow at the point of release and conservatively utilizing the normal effluent release activity levels (at the SVS WRGM sample location). Flow via this pathway should be determined by measurement or engineering calculation. Release activities can be determined from the normal effluent sample point, assuming isokinetic flow at the release pathway. Alternately, grab sampling may be used to ensure representative sampling at the point of release.

The higher elevation hatch at 1050' remains as a stack (elevated) release pathway and can be monitored via the SVS instrumentation and methodology.

Airborne releases to the environment may result if a fire occurs in a contaminated material warehouse. In the event of a fire in a contaminated material warehouse this pathway would be considered a ground level release and should be quantified and considered in dose calculations.

10.1.1.1 Condenser Offgas Treatment System

The condenser offgas treatment system is designed and installed to reduce radioactive gaseous effluents by collecting non- condensable off-gases from the condenser and providing for holdup to reduce the total radioactivity by radiodecay prior to release to the environment. The daughter products are retained by charcoal and HEPA filters. The system is described in Section 11.3.2.1 of the LaSalle UFSAR.

10.1.1.2 Ventilation Exhaust Treatment System

Ventilation exhaust treatment systems are designed and installed to reduce gaseous radioiodine or radioactive material in particulate form in selected effluent streams by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters prior to release to the environment. Such a system is not considered to have any effect on noble gas effluents. The ventilation exhaust treatment systems are shown in Figure 10-1.

Engineered safety features atmospheric cleanup systems are not considered to be ventilation exhaust treatment system components.

- 10.1.2 Radiation Monitors
- 10.1.2.1 Station Vent Stack Effluent Monitor

Monitor 0PLD5J (Wide Range Noble Gas Monitor) continuously monitors the final effluent from the station vent stack.

The monitor system has isokinetic sampling, gaseous grab sampling, iodine and particulate sampling, tritium sampling, and postaccident sampling capability.

In normal operation the low-range noble gas channel is on line and active. The mid-range channel replaces the low-range channel at a concentration of 0.01 μ Ci/cc png⁺ and the high-range channel replaces the mid-range channel at a concentration of 10 μ Ci/cc png.

The low-range and mid/high-range iodine and particulate samplers operate in a similar manner. In normal operation the low-range samplers are on line. At a concentration of 0.001 μ Ci/cc png the mid/high-range samplers are brought on line, and at a concentration of 0.1 μ Ci/cc png the low-range sample pump is turned off.

No automatic isolation or control functions are performed by this monitor. Pertinent information on this monitor is provided in the LaSalle UFSAR Section 11.5.2.2.1.

10.1.2.2 Standby Gas Treatment System Effluent Monitor

Monitor 0PLD2J (Wide Range Noble Gas Monitor) continuously monitors the final effluent from the standby gas treatment system (SGTS) stack.

^{*} To facilitate use of the wide range gas monitors on the Station Vent Stack and Standby Gas Treatment System Stack in post-accident dose assessment, the output of each is expressed in units of pseudo noble gas (png) activity. Pseudo noble gas is a fictitious radionuclide defined to have emission characteristics representative of a post-accident noble gas mix. Upon decay, a pseudo noble gas nuclide emits one gamma ray with energy 0.8 MeV and one beta particle with endpoint energy 1.68 MeV and average energy 0.56 MeV.

The SGTS stack monitor has isokinetic sampling, gaseous grab sampling, particulate and iodine sampling, and post accident sampling capability.

In normal operation the low range noble gas channel is on line and active. The mid-range channel replaces the low-range channel at a concentration of 0.01 μ Ci/cc png and the high-range channel replaces the mid-range channel at a concentration of 10 μ Ci/cc png.

The low-range and mid/high-range iodine and particulate samples operate in a similar manner. In normal operation, the low-range samples are on-line. At a concentration of 0.001 μ Ci/cc png the mid/high-range samplers are brought on-line, and at a concentration of 0.1 μ Ci/cc png the low-range sample pump is turned off.

No automatic isolation or control functions are performed by this monitor.

Pertinent information on this monitor is provided in the LaSalle UFSAR Section 11.5.2.2.2.

10.1.2.3 Reactor Building Ventilation Monitors

Monitors 1(2)D18-NOO9 continuously monitor the effluent from the Unit 1(2) reactor building. On high alarm, the monitors automatically initiate the following actions:

- A. Shutdown and isolation of the reactor building vent system
- B. Startup of the standby gas treatment system
- C. Isolation of primary containment purge and vent lines

Pertinent information on these monitors is provided in LaSalle UFSAR Section 11.5.2.1.1.

10.1.2.4 Condenser Air Ejector Monitors

Monitors 1(2)D18-N002/N012 (pre-treatment) and 1(2)D18-N903A/B (post-treatment) continuously monitor gross gamma activity downstream of the steam jet air ejector and prior to release to the main stack.

On "high-high" alarm monitor 1(2)D18-N903A/B automatically initiates closure of valve 1(2)N62-F057 thus terminating the release.

Pertinent information on these monitors is found in LaSalle UFSAR Sections 11.5.2.1.2 and 11.5.2.1.3.

10.1.2.5 Turbine Building Trackway and North Service Building

In order to quantify releases via either the (1) Turbine Building Trackway or (2) North Service Building (when the ventilation systems are aligned to support the unit 2 egress) at times of positive pressure in the Turbine Building, airborne sampling shall be continuously collected using an air sampler appropriately located. The air sampler collecting shall begin within 20 hours of the turbine building being at positive pressure, and then continuously for as long as the turbine building remains at positive pressure. The samples collected should be counted on a weekly basis. Air sampling to identify noble gas, iodine and particulate monitoring (either as a grab sampler or continuous sampling) is designed to ensure evaluation of releases emanating from the Turbine Building.

The curie content of any contaminated material warehouse is maintained current by site administrative procedures. If a fire were to occur, the actual curie content of the warehouse would be used in determining the ground level release.

Revision 7 December 2003

[cps]

- 10.1.3 Alarm and Trip Setpoints
- 10.1.3.1 Setpoint Calculations
- 10.1.3.1.1 Reactor Building Vent Effluent Monitor

The setpoint for the reactor building vent effluent monitor is established at 10 mR/hr.

10.1.3.1.2 **Condenser Air Ejector Monitors**

Pre-Treatment Monitor

The high trip setpoint is established at 1.5 times the normal full power background rate, including nitrogen-16 (N-16) to help ensure that effluents are maintained ALARA.

The high-high trip setpoint is established at < 100 μ Ci/sec per MW-th \cong 3.4E+05 μ Ci/sec per Technical Specification 3.7.6.

Post-Treatment Monitor

The off-gas isolation setpoint is conservatively set at or below one-half the release limit calculated using the more conservative value obtained from equations 10-3 and 10-4 below.

The off gas isolation setpoint is converted into the monitor units of counts per second (cps) as follows: (10-2)

$$P \le Q_{SVS} \times E \times \left[R_{png} / R_{OG} \right] \div F_{OG}$$

Ρ **Off-gas Post-treatment Monitor Isolation Setpoint**

> The off-gas post-treatment monitor setpoint which initiates isolation of flow of off-gas to the station vent stack.

Qsvs Actual Station Vent Stack High Alarm Setpoint [µCi/sec of png]

The actual high alarm setpoint of the Station Vent Stack wide range gas monitor in units of µCi/sec of png (pseudo noble gas). This is determined by using Equations 10-3 and 10-4 and then converting the result to units of µCi/sec of png.

- Ε Efficiency of the Off-Gas Post Treatment Monitor [cps/(µCi/sec of off gas mix)]
- Response of the Station Vent Stack WRGM to Pseudo Noble Gas Rpng [cpm per μCi/cc of pseudo noble gas]
- R_{OG} Response of the Station Vent Stack WRGM to Off Gas [cpm per µCi/cc of off gas] [cc/sec]
- Fog Maximum Off-Gas Flow Rate
- 10.1.3.1.3 Station Vent Stack Effluent Monitor

The high alarm setpoint for the station vent stack effluent monitor is conservatively set at or below one-half the calculated release limit calculated using the more conservative value obtained from equations 10-3 and 10-4 below. These equations yield the release limit in units of µCi/sec of the mix specified in Section 10.1.3.3. For consistency with the monitor readout, this calculated

Revision 7 December 2003

release limit is converted to units of μ Ci/sec of pseudo noble gas before being entered into the monitor data base.

10.1.3.1.4 Standby Gas Treatment Stack Monitor

The high alarm setpoint for the standby gas treatment system effluent monitor is conservatively set at or below one-half the release limit calculated using the more conservative value obtained from equations 10-3 and 10-4 below. These equations yield the release limit in units of μ Ci/sec of the mix specified in Section 10.1.3.3. For consistency with the monitor readout, this calculated release limit is converted to units of μ Ci/sec of pseudo noble gas before being entered into the monitor data base.

10.1.3.2 Release Limits

Alarm and trip setpoints of gaseous effluent monitors are established to ensure that the release rate limits of RETS are not exceeded. The release limit Q_{ts} is found by solving Equations 10-3 and 10-4.

(1.11)
$$Q_{ts} \sum \{f_i \,\overline{S}_i\} \le 500 \, \text{mrem/yr}$$
 (10-3)

 $Q_{is} \Sigma \{ \overline{L_i} f_i (X / Q)_s \exp(-\lambda_i R / 3600 U_s) \dagger + (1.11)(f_i) S_i \} < 3000 \ mrem \ / \ yr \ ^{(104)}$

The summations are over noble gas radionuclides i.

f_i Fractional Radionuclide Composition:

The release rate of noble gas radionuclide i divided by the total release rate of all noble gas radionuclides.

Q_{ts} Total Allowed Release Rate, Stack [μCi/sec of ODCM mix] Release

The total allowed release rate of all noble gas radionuclides released as stack releases in units of μ Ci/sec of the mix specified in section 10.1.3.3.

+ exp (-λ_iR/3600 U_s) is conservatively set equal to 1.0 for purposes of determining setpoints.

The remaining parameters in Equation 10-3 have the same definitions as in Equation A-8 of Appendix A. The remaining parameters in Equation 10-4 have the same definition as in Equation A-9 of Appendix A.

Equation 10-3 is based on Equation A-8 of Appendix A and the RETS restriction on whole body dose rate (500 mrem/yr) due to noble gases released in gaseous effluents (see Section A.1.3.1 of Appendix A). Equation 10-4 is based on Equation A-9 of Appendix A and the RETS restriction on skin dose rate (3000 mrem/yr) due to noble gases released in gaseous effluents (see Section A.1.3.2 of Appendix A).

The more conservative solution from Equations 10-3 and 10-4 is used as the limiting noble gas release rate.

Calibration methods and surveillance frequency for the monitors will be conducted as specified in the RETS.

10.1.3.3 Release Mixture

In the determination of alarm and trip set points, the radioactivity mixture in the exhaust air is assumed to have the radionuclide composition in Table 10-1, taken from Table 3-3 of GE NEDO-10871, March 1973.

10.1.3.4 Conversion Factors

The conversion factors used to establish gaseous effluent monitor setpoints are obtained as follows.

Station vent stack effluent monitor.

Calibrations compare the response of station detectors to that of a reference detector using NIST traceable sources. Conversion factors for the station detectors are obtained from the response to noble gas or solid sources.

. Condenser air ejector monitor.

Pretreatment Monitor

The value is determined using noble gas radionuclides identified in a representative sample, and the offgas release rate and monitor response at the time the sample is taken.

. Post-treatment Monitor

The value is determined using noble gas radionuclides identified in a representative sample, and the offgas concentration and monitor response at the time the sample is taken.

. Standby gas treatment system monitor.

Calibrations compare the response of station detectors to that of a reference detector using NIST traceable sources. Conversion factors for the station detectors are obtained from the response to noble gas or solid sources.

10.1.3.5 HVAC Flow Rates

The main stack flow rate is obtained from either the process computer or Monitor RM-23.

The SGTS flow rate is obtained from either the process computer or chart recorders in the main control room.

10.1.4 Allocation of Effluents from Common Release Points

Radioactive gaseous effluents released from the main chimney are comprised of contributions from both units. Under normal operating conditions, it is difficult to allocate the radioactivity between units due to fuel performance, in-plant leakage, power history, and other variables. Consequently, no allocation is normally made between the units. Instead, the entire release is treated as a single source.

10.1.5 Dose Projections

Because the gaseous releases are continuous, the doses are routinely calculated in accordance with the RETS.

10.2 LIQUID RELEASES

10.2.1 System Description

A simplified liquid radwaste and liquid effluent flow diagram are provided in Figures 10-2 and 10-3.

The liquid radwaste treatment system is designed and installed to reduce radioactive liquid effluents by collecting the liquids, providing for retention or holdup, and providing for treatment by filter or demineralizer for the purpose of reducing the total radioactivity prior to release to the environment. The system is described in Section 11.2.2 of the LaSalle UFSAR.

10.2.1.1 Radwaste Discharge Tanks

There are two discharge tanks (1(2)WF05T, 25,000 gallons each) which receive water for discharge to the Illinois River via the cooling lake blowdown.

10.2.1.2 Cooling Pond Blowdown

Cooling Pond Blowdown is the liquid discharge line to the Illinois River. The Cooling Pond Blowdown has a flow monitoring device as well as a compositor to meet the sampling requirements of ODCM Table 12.3.1-2.

- 10.2.2 Radiation Monitors
- 10.2.2.1 Liquid Radwaste Effluent Monitor

Monitor 0D18-K907 monitors all releases from the release tanks. On hi-hi alarm the monitor automatically initiates closure of valves 0WL067 and trips the radwaste discharge pump to terminate the release.

Pertinent information on the monitor and associated control devices is provided in LaSalle UFSAR Section 11.5.2.3.3.

10.2.2.2 Service Water Effluent Monitors

Monitors 1/(2)D18-K912 continuously monitor the service water effluent. On high alarm service water discharge may be terminated manually. No control device is initiated by these monitors.

Pertinent information on these monitors is provided in LaSalle UFSAR 11.5.2.3.2.

10.2.2.3 RHR Heat Exchanger Cooling Water Effluent Monitors

Instrument channels 1/(2)D18-N906/8 continuously monitor the RHR heat exchanger cooling water effluent. On high alarm the operating loop may be terminated manually and the redundant loop brought on line. No control device is initiated by these monitors.

Pertinent information on these monitors is provided in LaSalle UFSAR Section 11.5.2.3.4.

- 10.2.3 Alarm and Trip Setpoints
- 10.2.3.1 Setpoint Calculations

Alarm and trip setpoints of liquid effluent monitors at the principal release points are established to ensure that the limits of RETS are not exceeded in the unrestricted area.

10.2.3.1.1 Liquid Radwaste Effluent Monitor

The monitor setpoint is found by solving equation 10-5 for the total isotopic activity.

-

		$P < K \times [\Sigma C_i^T / \Sigma (C_i^T / 10 \times DWC_i)] \times [(F^d + F_{max}^r)/F_{max}^r]$	(10-5)
	Р	Release Setpoint	[cpm]
	K	$[\Sigma (K_i \times C_i \times W_i) / \Sigma C_i^T]$ [cpm/µCi/ml]	[cpm/µCi/ml]
	K,	Counting efficiency for radionuclide i	[cpm/µCi/ml]
	Wi	Weighting Factor	
	C_i^T	Concentration of radionuclide i in the release tank.	
	F_{\max}^{r}	Maximum Release Tank Discharge Flow Rate The maximum flow rate is 45 gpm.	[gpm]
	DWC	Derived Water Concentration of radionuclide i	[µCi/ml]
		The concentration of radionuclide i given in Appendix B, Table 2 10CFR20.1001-2402.	2, Column 2 to
	10	Multiplier associated with the limits specified in 12.3.1.A.	
	F^{d}	Dilution Flow	[gpm]
10.2.3.1.2	Servic	e Water Effluent Monitors	
	The m cpm).	onitor setpoint is established at two times the background count i	rate (not to exceed 10000
10.2.3.1.3	RHR H	leat Exchanger Cooling Water Monitors	
	The m cpm).	onitor setpoint is established at two times the background count i	rate (not to exceed 10000
10.2.3.2	Discha	arge Flow Rates	
10.2.3.2.1	Releas	se Tank Discharge Flow Rate	
	Prior to	o each batch release, a grab sample is obtained.	
	The re	sults of the analysis of the sample determine the discharge rate of	of each batch as follows:
	F ^r max =	= 0.1 x [F ^d / Σ (C _i / 10xDWC _i)]	(10-6)
	The su	ummation is over radionuclides i.	
	0.1	Reduction factor for conservatism.	
	F ^r max	Maximum Permitted Discharge Flow Rate	[gpm]

.

-

		The maximum permitted flow rate from the radwaste discharge tank.	
	F⁴	Dilution Flow	[gpm]
	Cı	Concentration of Radionuclide i in the Release Tank	[µCi/mL]
		The concentration of radioactivity in the radwaste discharge tank based on measurements of a sample drawn from the tank.	
	DWCi	Maximum Permissible Concentration of Radionuclide i	[µCi/ml]
•		The concentration of radionuclide i given in Appendix B, Table 2, Column 2 to 10CFR20.1001-2402.	
	10	Multiplier associated with the limits specified in 12.3.1.A.	
	MF	Multiplication Factor	
		F ^r _{max} < 0.5; MF = 3	
		0.5 < F ^r _{max} < 5; MF = 5	
		5 < F ^r _{max} ; MF = 7.5	
	Recom	mended Release Tank Flow Rate.	
	F ^r _{rec} =	F ^r max X MF	(10-7)
	F ^r rec	recommended discharge flow rate	(gpm)
	F ^r max	maximum permitted discharge flow rate	(gpm)
	MF	multiplication factor.	

10.2.3.2.2

10.2.3.3 Release Limits

Release limits are determined from RETS. Calculated maximum permissible discharge rates are divided by 10 for conservatism and to ensure that release concentrations are well below applicable derived water concentrations (DWC).

10.2.3.4 Release Mixture

For the liquid radwaste effluent monitor the release mixture used for the setpoint determination is the radionuclide mix identified in the grab sample isotopic analysis plus four additional radionuclides. The additional radionuclides are H-3, Fe-59, Sr-89, and Sr-90. The quantities to be added are obtained from the most current analysis for these four radionuclides.

For all other liquid effluent monitors no release mixture is used because the setpoint is established at "two times background."

10.2.3.5 Conversion Factors

The readout for the liquid radwaste effluent monitor is in CPM. The calibration constant is based on the detector sensitivity to Cs-137/Ba-137 and an energy response curve.

10.2.3.6 Liquid Dilution Flow Rates

A conservative maximum blowdown flowrate of 20,000 gpm is used for all radwaste discharge calculations unless actual blowdown flow is determined to be less.

10.2.4 Allocation of Effluents from Common Release Points

Liquid releases from the Station will be allocated one half to Unit 1 and one half to Unit 2. Other potential pathways (i.e., RHR) are allocated to their respective unit.

10.2.5 Projected Doses for Releases

Doses are not calculated prior to release. Dose contributions from liquid effluents are determined in accordance with the RETS and station procedures.

10.3 SOLIDIFICATION OF WASTE/PROCESS CONTROL PROGRAM

The process control program (PCP) contains the sampling, analysis, and formulation determination by which solidification of radioactive wastes from liquid systems is ensured.

Figure 10-4 is a simplified diagram of solid radwaste processing.

.

. ----

TABLE 10-1

Assumed Composition of the LaSalle Station Noble Gas Effluent (From GE NEDO - 10871 Table 3.3)

Nuclide	T1/2	uCi/s @ T=0	Contribution	% Contribution
Kr83m	1.86h	3.40E+03	4.50E-03	0.45%
Kr85m	4.4h	6.10E+03	8.08E-03	0.81%
Kr85	10.74h	2.00E+01	2.65E-05	0.00%
Kr87	76m	2.00E+04	2.65E-02	2.65%
Kr88	2.79h	2.00E+04	2.65E-02	2.65%
Kr89	3.18m	1.30E+05	1.72E-01	17.22%
Kr90	32.3s	2.80E+05	3.71E-01	37.08%
Xe131m	11.96d	1.50E+01	1.99E-05	0.00%
Xe133m	2.26d	2.90E+02	3.84E-04	0.04%
Xe133	5.27d	8.20E+03	1.09E-02	1.09%
Xe135m	15.7m	2.60E+04	3.44E-02	3.44%
Xe135	9.16h	2.20E+04	2.91E-02	2.91%
Xe137	3.82m	1.50E+05	1.99E-01	19.87%
Xe138	14.2m	8.90E+04	1.18E-01	11.79%
Total		7.55E+05	1.00E+00	100.00%

.



p:/procupga/approvea/oacm/is for/.u



p:\procupgd\approved\odcm\ls10r7.0

p:\procupgd\approved\odcm\\s10r7.0

10-14



:

LASALLE

Revision 7 December 2003

Revision 7 December 2003





* = Abandoned in Place

.

• •

p:\procupgd\approved\odcm\ls10r7.0

CHAPTER 11

Revision 6 April 2003

:

LaSalle Annex Index

Revision 6

1

..

•1

1

.

p:\procupgd\approved\odcm\ls11r6

..

.

·

.

11-11

CHAPTER 11 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM TABLE OF CONTENTS

<u>CHAPTER</u>	TITLE	PAGE
11	Radiological Environmental Monitoring Program	11-1
	LIST OF TABLES	
NUMBER	TITLE	PAGE
11-1	Radiological Environmental Monitoring Program	11-2
•		
	LIST OF FIGURES	
NUMBER	TITLE	PAGE
11-1	Fixed Air Sampling Sites and Outer Ring TLD Locations	11-9
11-2	Inner Ring TLD Locations	11-10
11-3	Ingestion and Waterborne Exposure Pathway	

p:\procupgd\approved\odcm\ls11r6

Sample Locations

Revision 6 April 2003

CHAPTER 11

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

The Radiological Environmental Monitoring Program for the environs around LaSalle Station is given in Table 11-1.

Figures 11-1 through 11-3 show sampling and monitoring locations.

1

Table 11-1 Radiological Environmental Monitoring Program

	_			•	
Exposure Pathway and/or Sample		Sample or Monitoring Loca	tion	Sampling or Collection Frequency	Type and Frequency <u>of Analysis</u>
1. <u>Airborne</u> <u>Radioiodine and</u> <u>Particulates</u>	a.	Indicators-Near Field L-01, Nearsite No. 1, 1.5 mi NNW L-03, Onsite No. 3, 1.0 mi ENE L-05, Onsite No. 5, 0.3 mi ESE L-06, Nearsite No. 6, 0.4 mi WSW	(2.4 km R) (1.6 km D) (0.5 km F) (0.6 km M)	Continuous sampler operation with particulate sample collection weekly, or more frequently if required by dust loading, and radioiodine canister collection biweekly.	Radioiodine Canisters:I-131 analysis biweekly on near field and control samples ¹ .Particulate Sampler:Gross beta analysis following weekly filter change ² and gamma isotopic analysis ³ quarterly on composite filters by location on near field and control samples. ¹
	b.	Indicators-Far Field			
		L-04, Rte 170, 3.2 mi E L-07, Seneca, 5.2 mi NNE L-08, Marseilles, 6.0 mi NNW L-11, Ransom, 6.0 mi S	(5.1 km E) (8.4 km B) (9.7 km R) (9.7 km J)		
	C.	<u>Controls</u>			
		L-10, Streator, 13.5 mi SW	(21.7 km L)	- · · · · · · · · · · · · · · · · · · ·	

Exposure Pathway				Sampling or	Type and Frequency			
and/or Sample		Sample or Monitoring Location		Collection Frequency	<u>of Analysis</u>			
2	Direct Radiation	a Indicators-Inner Ring		Quarterly	Gamma dose on each TLD			
<u> </u>	Direct Madiation	a. $\underline{\text{Indicators}}$ finite range	(0.8 km A)	Quarterly	Gannia dose on each TLD			
		L = 101 - 1, 0.5 miN	(0.0 km A)		quarterly.			
		L = 101 - 2, $0.5 min$	(0.0 km P)					
		L = 102 - 1, $0.0 minimize$	(1.0 km D)					
1		L = 102 - 2, $0.0 minime$	(1.0 KIII D)					
		L = 103 - 1, $U.7 mine$	(1.1 Km C)					
		L-103-2, 0.7 MINE	(1.1 Km C) (1.2 km D)					
1		L-104-1, 0.8 mi ENE	(1.3 KM D)					
		L = 104 - 2, 0.8 mi ENE	(1.3 Km D)					
		L-105-1, 0.7 mi E	(1.1 KM E)					
		L-105-2, 0.7 mi E	(1.1 KM E)					
		L-106-1, 1.4 mi ESE	(2.2 km F)					
		L-106-2, 1.4 mi ESE	(2.2 km F)					
		L-107-1, 0.8 mi SE	(1.3 km G)	• ·				
		L-107-2, 0.8 mi SE	(1.3 km G)					
		L-108-1, 0.5 mi SSE	(0.8 km H)					
		L-108-2, 0.5 mi SSE	(0.8 km H)					
		L-109-1, 0.6 mi S	(1.0 km J)					
		L-109-2, 0.6 mi S	(1.0 km J)					
		L-110-1, 0.6 mi SSW	(1.0 km K)					
		L-110-2, 0.6 mi SSW	(1.0 km K)					
		L-111b-1, 0.8 mi SW	(1.3 km L)					
		L-111b-2, 0.8 mi SW	(1.3 km L)					
		L-112-1, 0.9 mi WSW	(1.4 km M)					
		L-112-2, 0.9 mi WSW	(1.4 km M)					
1		L-113a-1, 0.8 mi W	(1.3 km N)					
		L-113a-2, 0.8 mi W	(1.3 km N)					
1		L-114-1, 0.9 mi WNW	(1.4 km P)					
		L-114-2, 0.9 mi WNW	(1.4 km P)					
		L-115-1, 0.7 mi NW	(1,1 km Q)					
		L-115-2, 0.7 mi NW	(1.1 km Q)					
		L-116-1, 0.6 mi NNW	(1.0 km R)					
1		L-116-2, 0.6 mi NNW	(1.0 km R)					

Table 11-1 (Cont'd) Radiological Environmental Monitoring Program

Revision 6 April 2003

Exposure Pathway		Sampling or	Type and Frequency			
and/or Sample	Sample or Monitoring Lo	cation Collection Frequency	of Analysis			
	h Indiantan Outra Bia -					
2. Direct Radiation	b. <u>Indicators</u> -Outer Ring	1 AX				
(Contra)	L-201-3, 4.0 mi N (6.4	km A)				
	L-201-4, 4.0 mi N (6.4	km A)				
	L-202-3, 3.6 mi NNE (5.8	km B)				
	L-202-4, 3.6 mi NNE (5.8	km B)				
	L-203-1, 4.0 mi NE (6.4	km C)				
	L-203-2, 4.0 mi NE (6.4	km C)				
	L-204-1, 3.2 mi ENE (5.	2 km D)				
	L-204-2, 3.2 mi ENE (5	2 km D)				
	L-205-1, 3.2 mi ESE (5	2 km F)				
	L-205-2, 3.2 mi ESE (5	2 km F)				
	L-205-3, 5.1 mi E (8	2 km E)				
1	L-205-4, 5.1 mi E (8.	2 km E)				
	L-206-1, 4.3 mi SE (6	9 km G)				
	L-206-2, 4.3 mi SE (6	9 km G)				
	L-207-1, 4.5 mi SSE (7.	2 km H)				
	L-207-2, 4.5 mi SSE (7.	2 km H)				
	L-208-1, 4.5 mi S (7.	2 km J)				
	L-208-2, 4.5 mi S (7.	2 km J)				
	L-209-1, 4.0 mi SSW (6	4 km K)				
	L-209-2, 4.0 mi SSW (6	4 km K)				
	L-210-1, 3.3 mi SW (5	3 km L)				
	L-210-2, 3.3 mi SW (5	3 km L)				
	L-211-1, 4.5 mi WSW (7.2	2 km M)				
	L-211-2, 4.5 mi WSW (7.2	2 km M)				
	L-212-1, 4.0 mi WSW (6	4 km M)				
	L-212-2, 4.0 mi WSW (6)	4 km M)				
	L-213-3, 4.9 mi W (7	9 km N)				
	L-213-4, 4.9 mi W (7	9 km N)				
	1-214-3 51 mi WNW (8	2 km P)				
	1-214-4 51 mi WNW (8	2 km P)				
	1-215-3 50 mi NW (8	$0 \text{ km } \Omega$				
	1-215-4 50 mi NW (8	$0 \text{ km} \Omega$				
	L_{216-3} , 5.0 mi NNN/ (8	0 km R)				
	$I_{-216-4} = 5.0 \text{ mi} \text{ NNIM}$ (8)	0 km R)				
1						

Table 11-1 (Cont'd) Radiological Environmental Monitoring Program

Revision 6 April 2003

.

Table 11-1 (Cont'd) Radiological Environmental Monitoring Program

	Exposure Pathway and/or Sample		Sample or Monitoring Location	Sampling or Collection Frequency	Type and Frequency of Analysis
2.	Direct Radiation	C.	Other		
	(Conta)		Indicators		
			One at each of the airborne location given in part 1.a and 1.b.		
		d.	<u>Controls</u>		
			One at each airborne control location given in part 1.c.		

-

.

۰.

. ..

Revision 6 April 2003

Exposure Pathway and/or Sample Sample or Monitoring Location		Sample or Monitoring Location	Sampling or Collection Frequency	Type and Frequency of Analysis	
3. <u>V</u>	Vaterborne				
а	<u>Ground/Well</u>	а.	Indicators	Quarterly	Gamma isotopic ³ and
			L-27, LSCS Onsite Well at Station L-28, Marseilles Well, 7.0 mi NW (11.3 km Q)		thitum analysis quarterly.
b	. Drinking Water		There is no drinking water pathway within 6.2 mi (10 km) downstream of station.		
с	. <u>Surface Water</u>	a.	Indicator L-40, Illinois River downstream, 5.2 mi NNW (8.4 km R)	Weekly grab sample	Gross beta and gamma isotopic analysis ³ on monthly composite; tritium analysis on quarterly
d	. <u>Control</u>	а.	<u>Control</u> L-21, Illinois River at Seneca,	Weekly grab sample	Composite. Gross beta and gamma isotopic analysis ³ on monthly composite; tritium analysis on quarterly
e	. <u>Sediments</u>	a.	4.0 mi NE (6.4 km C) Indicators	Semiannually	composite. Gamma isotopic analysis ³ semiannually.
			L-40, Illinois River downstream, 5.2 mi NNW (8.4 km R) L-41, Illinois River downstream 4.6 mi NNW (7.4 km A)		

Table 11-1 (Cont'd) Radiological Environmental Monitoring Program

.

.

Revision 6 April 2003

Exposure Pathway and/or Sample		Sample or Monitoring Location		Sampling or Collection Frequency	Type and Frequency of Analysis			
4.	Inc	<u>aestion</u>						
	a.	Milk	a.	Indicators		Biweekly: May through October; monthly:	Gamma isotopic ³ and I-131 analysis ⁴ biweekly May	
				At the time of this revision, there are within 6.2 miles which consistently p	e no dairies produce milk.	November through April	through October, monthly November through April.	
			b.	<u>Controls</u>				
				L-42, Biros Dairy, 14.2 mi E (22.9	km E)			
						1998 a		
	b.	<u>Fish</u>	a.	Indicator			•	
				L-35, Marseilles Pool of Illinois Rive 6.5 mi NW	er, (10.5 km Q)	Two times annually	Gamma isotopic analysis ³ on edible portions of each	
				L-34, LaSalle Lake 2 mi E	(3.2 km E)			
			b.	<u>Control</u>				
				L-36, Illinois River upstream of discharge, 4.3 mi NNE	(6.9 km B)			
	C.	Food Products	a.	Indicators				
				Two samples from each of the four within 6.2 miles of the station, if ava	major quadrants ilable.	Annually	Gamma isotopic analysis ³ and I-131 analysis each	
			b.	Sample locations for food products may vary based on availability and therefore are not required to be identified here but shall be taken. <u>Controls</u>			sample.	
				Two samples within 9.3 to 18.6 mile if available.	es of the station,			

Table 11-1 (Cont'd) Radiological Environmental Monitoring Program

Table 11-1 (Cont'd) Radiological Environmental Monitoring Program

- ¹ Far field samples are analyzed when near field results are inconsistent with previous measurements and radioactivity is confirmed as having its origin in airborne effluents released from the station, or at the discretion of the Radiation Protection Director.
- ² Airborne particulate sample filters shall be analyzed for gross beta radioactivity 24 hours or more after sampling to allow for radon and thoron daughter decay. If gross beta activity in air particulate samples is greater than 10 times the yearly mean of control samples, gamma isotopic analysis shall be performed on the individual samples.
- ³ Gamma isotopic analysis means the identification and quantification of gamma emitting radionuclides that may be attributable to the effluents from the station.
- ⁴ I-131 analysis means the analytical separation and counting procedure are specific for this radionuclide.

Revision 6 April 2003




p:\procupgd\approved\odcm\ls11r6

Revision 6 April 2003

LASALLE



Revision 7 December 2003

LASALLE ANNEX INDEX CHAPTER 12

Revision 7



p:\procupgd\approved\odcm\LS12R7.0

Revision 7 December 2003

PAGE

12-1

CHAPTER 12

1

į

RADIOLOGICAL EFFLUENT TECHNICAL STANDARDS

12.0

RADIOACTIVE EFFLUENT TECHNICAL STANDARDS (RETS) TABLE OF CONTENTS

12.1	DEFINITIONS			
12.2	INSTRUMENTATION	12-8		
	 Radioactive Liquid Effluent Monitoring Instrumentation Radioactive Gaseous Effluent Monitoring Instrumentation 	on 12-8		
12.3	LIQUID EFFLUENTS	12-19		
	 Concentration Dose Liquid Waste Treatment System 	12-19 12-25 12-27		
12.4	GASEOUS EFFLUENTS	12-29		
	 Dose Rate Dose - Noble Gases Dose - Iodine-131, Iodine-133, Tritium, and Radionuclide Form Gaseous Radwaste Treatment System Ventilation Exhaust Treatment System Venting or Purging Total Dose Main Condenser Dose Limits for Members of the Public 	12-29 12-35 es in Particulate 12-36 12-38 12-39 12-40 12-41 12-43 12-44		
12.5	RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM			
	 Monitoring Program Land Use Census Interlaboratory Comparison Program 	12-45 12-56 12-57		
12.6	REPORTING REQUIREMENTS			
	1. Annual Radiological Environmental Operating Report 2. Radioactive Effluent Release Report	12-58 12-59		

- **Radioactive Effluent Release Report** 2.
- **Offsite Dose Calculation Manual (ODCM)** 12-60 3. 4. 12-61
- Major Changes to Radioactive Waste Treatment Systems

Revision 7 December 2003

PAGE

CHAPTER 12

RADIOACTIVE EFFLUENT TECHNICAL STANDARDS (RETS) · LIST OF TABLES

12.0-1	Effluent Compliance Matrix	12-2
12.0-2	REMP Compliance Matrix	12-3
12.1-1	Frequency Notation	12-7
12.2.1-1	Radioactive Liquid Effluent Monitoring Instrumentation	12-9
12.2.1-2	Radioactive Liquid Effluent Monitoring Instrumentation Surveillance Requirements	12-11
12.2.2-1	Radioactive Gaseous Effluent Monitoring Instrumentation	12-14
12.2.2-2	Radioactive Gaseous Effluent Monitoring Instrumentation Surveillance Requirements	12-16
12.3.1-1	Allowable Concentration (AC) of Dissolved or Entrained Noble Gases Released from the Site to Unrestricted Areas in Liquid Waste	12-20
12.3.1-2	Radioactive Liquid Waste Sampling and Analysis Program	12-21
12.4.1-1	Radioactive Gaseous Waste Sampling and Analysis Program	12-30
12.5-1	Radiological Environmental Monitoring Program	12-48
12.5-2	Reporting Levels for Radioactivity Concentrations in Environmental Samples	12-54
12.5-3	Detection Capabilities for Environmental Sample Analysis	12-55

.

12-iii

.

NOTE

The requirements of TSR 3.0.b apply to Chapter 12.

.

.

12.0 RADIOLOGICAL EFFLUENT TECHNICAL STANDARDS

Chapter 12 of the LaSalle Station ODCM is a compilation of the various regulatory requirements, surveillances and bases, commitments and/or components of the radiological effluent and environmental monitoring programs for LaSalle Station. To assist in the understanding of the relationship between effluent regulations, ODCM equations, RETS (Chapter 12 section) and related Technical Specification requirements, Table 12.0-1 is a matrix which relates these various components. The Radiological Environmental Monitoring Program fundamental requirements are contained within this chapter, with LaSalle specific information in Chapter 11 and a supplemental matrix in Table 12.0-2.

p:\procupgd\approved\odcm\LS12R7.0

۰.

;

•

Regulation	Dose to be compared to limit		ODCM Equation	RETS	Technical Specification
10CFR50 Appendix I	1.	gamma air dose and beta air dose due to airborne radioactivity in effluent plume.	A-1 A-2	12.4.2	5.5.4.h
	1.a	whole body and skin dose due to airborne radioactivity in effluent plume are reported only if certain gamma and beta air dose criteria are exceeded.	A-6 A-7	N/A	N/A
	1.b	Projected doses due to gaseous release, when averaged over 31 days, exceed 0.3 mrem to any organ.	N/A	12.4.5	5.5.4.f
	1.c	Projected doses due to liquid release, when averaged over 31 days, exceed 0.06 mrem to the total body or 0.2 mrem to any organ.	N/A	12.3.3	5.5.4.f
	2.	CDE for all organs and all four age groups due to iodines and particulates in effluent plume. All pathways are considered.	A-13	12.4.3	5.5.4.i
	3.	CDE for all organs and all four age groups due to radioactivity in liquid effluents.	A-29	12.3.2	5.5.4.d
10CFR20	1.	TEDE, totaling all deep dose equivalent components (direct, ground and plume shine) and committed effective dose equivalents (all pathways, both airborne and liquid-borne). CDE evaluation is made for adult only using FGR 11 database.	A-38	12.4.9	5.5.4.c
40CFR190 (now by reference, also part of	1.	Whole body dose (DDE) due to direct dose, ground and plume shine from all sources at a station.	A-35	12.4.7	5.5.4.j
10CFR20)	2.	Organ doses (CDE) to an adult to all pathways.	A-13		
Technical Specifications	1.	"Instantaneous" whole body (DDE), thyroid (CDE) and skin (SDE), dose rates to an adult due to radioactivity in airborne effluents. For the thyroid dose, only inhalation is considered.	A-8 A-9 A-28	12.4.1	5.5.4.g 5.5.4.b
	2.	"Instantaneous" concentration limits for liquid effluents.	A-32	12.3.1	
Technical Specifications	1.	Radioactive Effluent Release Report	NA	12.6.2	5.6.3

TABLE 12.0-1 EFFLUENT COMPLIANCE MATRIX

p:\procupgd\approved\odcm\LS12R7.0

.

Revision 7 December 2003

Table 12.0-2

REMP Compliance Matrix

Regulation	Component	RETS	Technical Specification
10CFR50 Appendix I Section IV.B.2	Implement environmental monitoring program.	12.5.1	N/A
10CFR50 Appendix I Section IV.B.3	Land Use Census	12.5.2	N/A
10CFR50 Appendix I Section IV.B.2	Interlaboratory Comparison Program	12.5.3	N/A
10CFR50 Appendix I Section IV B.2 and Technical Specifications	Annual Radiological Environmental Operating Report	12.6.1	5.6.2

;

Revision 7 December 2003

12.1 DEFINITIONS

- 12.1.1 <u>ACTION</u> ACTION shall be that part of a requirement which prescribes remedial measures required under designated conditions.
- 12.1.2 <u>CHANNEL CALIBRATION</u> A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds with the necessary range and accuracy to known values of the parameter which the channel monitors. The CHANNEL CALIBRATION shall encompass the entire channel, including the required sensor, alarm, display, and trip functions, and shall include the CHANNEL FUNCTIONAL TEST. Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an inplace qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel. The CHANNEL CALIBRATION may be performed by any series of sequential, overlapping or total channel steps so that the entire channel is calibrated.

For specific calibration requirements refer to surveillance requirements section for the applicable instrumentation.

- 12.1.3 <u>CHANNEL CHECK</u> A CHANNEL CHECK shall be the qualitative assessment, by observation, of channel behavior during operation. This determination shall include, where possible, comparison of the channel indication and status to other indications or status derived from independent instrument channels measuring the same parameter.
- 12.1.4 <u>CHANNEL FUNCTIONAL TEST</u> A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated signal into the channel as close to the sensor as practical to verify OPERABILITY including required alarm, interlock, display, and trip functions, and channel failure trips. The CHANNEL FUNCTIONAL TEST may be performed by any series of sequential, overlapping, or total channel steps so that the entire channel is tested.
- 12.1.5 DOSE EQUIVALENT I-131 DOSE EQUIVALENT I-131 shall be that concentration of I-131, (microcuries/gram), that alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Table III of TID-14844, AEC 1962, "Calculation of Distance Factors for Power and Test Reactor Sites;" Table E.7 of Regulatory Guide 1.109, Rev. 1, NRC, 1977; or ICRP 30, Supplement to Part 1, pages 192-212, Table titled, "Committed Dose Equivalent in Target Organs or Tissues per Intake of Unit Activity."
- 12.1.6 <u>FREQUENCY</u> Table 12.1-1 provides the definitions of various frequencies for which surveillances, sampling, etc. are performed unless defined otherwise. The provisions of Technical Specifications SR 3.0.2 and SR 3.0.3 are applicable to the frequencies except that they do not apply to the frequencies associated with the Radiological Environmental Monitoring Program (Section 12.5).
- 12.1.7 <u>GASEOUS RADWASTE TREATMENT SYSTEM</u> A GASEOUS RADWASTE TREATMENT SYSTEM shall be any system designed and installed to reduce radioactive gaseous effluents by collecting primary coolant system offgases from the primary system and providing for delay or holdup for the purpose of reducing total radioactivity prior to release to the environment.
- 12.1.8 <u>MEMBER(S) OF THE PUBLIC</u> means an individual except when that individual is receiving an occupational dose.
- 12.1.9 <u>MODE</u> A MODE shall correspond to any one of the inclusive combination of mode switch position, average reactor coolant temperature, and reactor pressure vessel head closure bolt tensioning specified in Table 12.1-2 with fuel in the reactor vessel.

- 12.1.10 OCCUPATIONAL DOSE means the dose received by an individual in the course of employment in which the individual's assigned duties involve exposure to radiation and/or to radioactive material from licensed and unlicensed sources of radiation, whether in the possession of the licensee or other person. Occupational dose does not include dose from background radiation as a patient from medical practices, from voluntary participation in medical research programs, or as a member of the public.
- 12.1.11 <u>OPERABLE OPERABILITY</u> A system, subsystem, division, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified function(s), and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, division, component or device to perform its function(s) are also capable of performing their related support function(s).
- 12.1.12 <u>PROCESS CONTROL PROGRAM</u> The PROCESS CONTROL PROGRAM (PCP) shall contain the current formulas, sampling, analyses, test, and determinations to be made to ensure that processing and packaging of solid radioactive wastes based on demonstrated processing of actual or simulated wet solid wastes shall be accomplished in such a way as to assure compliance with 10 CFR Parts 20, 61, and 71, State regulations, burial ground requirements, and other requirements governing the disposal of solid radioactive waste.
- 12.1.13 <u>PURGE PURGING</u> PURGE or PURGING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is required to purify the confinement.
- 12.1.14 <u>RATED THERMAL POWER (RTP)</u> RTP shall be a total reactor core heat transfer rate to the reactor coolant of 3489 Mwt.
- 12.1.15 <u>SITE BOUNDARY</u> The SITE BOUNDARY shall be that line beyond which the land is neither owned, nor leased, nor otherwise controlled by the licensee.
- 12.1.16 <u>SOLIDIFICATION</u> SOLIDIFICATION shall be the conversion of radioactive wastes from liquid systems to a homogeneous (uniformly distributed), monolithic, immobilized solid with definite volume and shape, bounded by a stable surface of distinct outline on all sides (free-standing).
- 12.1.17 <u>SOURCE CHECK</u> A SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to a radioactive source.
- 12.1.18 <u>THERMAL POWER</u> THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.
- 12.1.19 <u>UNRESTRICTED AREA BOUNDARY</u> means an area, access to which is neither limited nor controlled by the licensee.
- 12.1.20 <u>VENTILATION EXHAUST TREATMENT SYSTEM</u> A VENTILATION EXHAUST TREATMENT SYSTEM shall be any system designed and installed to reduce gaseous radioiodine or radioactive material in particulate form in effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters for the purpose of removing iodines or particulates from the gaseous exhaust system prior to the release to the environment (such a system is not considered to have any effect on noble gas effluents). Engineered Safety Feature (ESF) atmospheric cleanup systems are not considered to be VENTILATION EXHAUST TREATMENT SYSTEM components.

p:\procupgd\approved\odcm\LS12R7.0

- 12.1.21 <u>VENTING</u> VENTING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is not provided or required during VENTING. Vent, used in system names, does not imply a VENTING process.
- 12.1.22 Definitions Peculiar to Estimating Dose to Members of the Public Using the ODCM Computer Program.

• • •

- a. ACTUAL ACTUAL refers to using known release data to project the dose to members of the public for the previous time period. This data is stored in the database and used to demonstrate compliance with the reporting requirements of Chapter 12.6.
- b. PROJECTED PROJECTED refers to using known release data from the previous time period or estimated release data to forecast a future dose to members of the public. This data is not incorporated into the database.

. . . .

Revision 7 December 2003

TABLE 12.1-1

FREQUENCY NOTATION

NOTATION	EREQUENCY
S - Shiftly	At least once per 12 hours.
D - Daily	At least once per 24 hours.
W - Weekly	At least once per 7 days.
M - Monthly	At least once per 31 days.
Q - Quarterly	At least once per 92 days.
SA - Semiannually	At least once per 184 days.
A - Annually	At least once per 366 days.
E - Sesquiannually	At least once per 18 months.
B - Refueling cycle	At least once per 24 months.
S/U - Startup	Prior to each reactor startup.
P - Prior	Prior to each radioactive release.
N.A.	Not applicable.

Table 12.1-2 (Page 1 of 1)

MODES

MODE	TITLE	REACTOR MODE SWITCH POSITION	AVERAGE REACTOR COOLANT TEMPERATURE (°F)
1	Power Operation	RUN	N/A
2	Startup	Refuel ^(a) or Startup/Hot Standby	N/A
3	Hot Shutdown ^(a)	Shutdown	> 200
4	Cold Shutdown ^(a)	Shutdown	≤ 200
5	Refueling ^(b)	Shutdown or Refuel	NA

(a) All reactor vessel head closure bolts fully tensioned.

(b) One or more reactor vessel head closure bolts less than fully tensioned.

12.2 INSTRUMENTATIO	Ν
---------------------	---

12.2.1 Radioactive Liquid Effluent Monitoring Instrumentation

Operability Requirements

- 12.2.1.A The radioactive liquid effluent monitoring instrumentation channels shown in Table 12.2.1-1 shall be OPERABLE with their alarm/trip setpoints set to ensure that the limits of Section 12.3.1.A are not exceeded. The alarm trip setpoints of these channels shall be determined in accordance with the ODCM Chapter 10.
- Applicability: At all times, when flow is present in the system.

Action:

- a. With a radioactive liquid effluent monitoring instrumentation channel alarm/trip setpoint less conservative than required, immediately suspend the release of radioactive liquid effluents monitored by the affected channel or declare the channel inoperable.
- b. With less than the minimum number of radioactive liquid effluent monitoring instrumentation channels OPERABLE, take the ACTION shown in Table 12.2.1-1. Restore the inoperable instrumentation to OPERABLE status within the time specified in the ACTION or, explain in the next Radioactive Effluent Release Report why this inoperability was not corrected within the time specified.

Surveillance Requirements

12.2.1.B Each radioactive liquid effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations at the frequencies shown in Table 12.2.1-2.

Bases

12.2.1.C The radioactive liquid effluent monitoring instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The alarm/trip setpoints for these instruments shall be calculated in accordance with the procedures in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of RETS. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

ा • •

TABLE 12.2.1-1

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

	INSTRUMENT	MINIMUM CHANNELS OPERABLE	ACTION
1.	GAMMA SCINTILLATION MONITOR PROVIDING ALARM AND AUTOMATIC TERMINATION OF RELEASE		
	a. Liquid Radwaste Effluent Line	1	100
2.	GAMMA SCINTILLATION MONITORS PROVIDING ALARM BUT NOT PROVIDING AUTOMATIC TERMINATION OF RELEASE		
	 a. Service Water System Effluent Line (Unit 1) b. Service Water System Effluent Line (Unit 2) c. RHR Service Water (Line A) Effluent Line (Unit 1) d. RHR Service Water (Line A) Effluent Line (Unit 2) e. RHR Service Water (Line B) Effluent Line (Unit 1) f. RHR Service Water (Line B) Effluent Line (Unit 2) 	1 1 1 1 1	101 101 101 101 101 101
3.	FLOW RATE MEASUREMENT DEVICES		
	a. Liquid Radwaste Effluent Line b. Cooling Pond Blowdown Pipe*	1 1	102 102

* Same as River Discharge Blowdown Pipe.

.

11

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

TABLE 12.2.1-1 (Continued)

TABLE NOTATION

- ACTION 100 With the number of OPERABLE channels less than required by the Minimum Channels OPERABLE requirement, effluent releases may continue for up to 14 days provided that prior to initiating a release:
 - a. At least two independent samples are analyzed in accordance with Section 12.3.1.B.1, and
 - b. At least two technically qualified members of the Facility Staff independently verify the release rate calculations and discharge line valving;

Otherwise, suspend release of radioactive effluents via this pathway.

- ACTION 101 With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 All days provided that, at least once per 8 hours, grab samples are collected and analyzed of for principal gamma emitters and I-131 at a lower limit of detection as specified in Table 12.3.1-2. If effluent releases continue via this pathway beyond 30 days, continue to collect and analyze samples, then explain in the next Radioactive Effluent Release Report why this inoperability was not corrected within the time specified.
- ACTION 102 With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, actual radioactive releases in progress via this pathway may continue provided the flow rate is estimated at least once per 4 hours. Pump curves for Instrument 3a, or for known valve positions for Instrument 3b, may be used to estimate flow. Actual releases of radioactive effluent will not be initiated without an OPERABLE channel.

TABLE 12.2.1-2

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

INSTRUMENT			CHANNEL CHECK	SOURCE <u>CHECK</u>	CHANNEL FUNCTIONAL IESI	CHANNEL <u>CALIBRATION</u>
1.	GAM AUT	IMA SCINTILLATION MONITOR PROVIDING ALARM AND OMATIC TERMINATION OF RELEASE				
	a.	Liquid Radwaste Effluents Line	D 4	Р	Q(1)	B(3)
2.	gam Not	IMA SCINTILLATION MONITORS PROVIDING ALARM BUT PROVIDING AUTOMATIC TERMINATION OF RELEASE				
	a.	Service Water System Effluent Line (Unit 1)	D	М	Q(2)	B(3)
	b.	Service Water System Effluent Line (Unit 2)	D	Μ	Q(2)	B(3)
	C.	RHR Service Water (Line A) Effluent Line (Unit 1)	D	Μ	Q(2)	B(3)
	d.	RHR Service Water (Line A) Effluent Line (Unit 2)	D	Μ	Q(2)	B(3)
	e.	RHR Service Water (Line B) Effluent Line (Unit 1)	D	Μ	Q(2)	B(3)
	f.	RHR Service Water (Line B) Effluent Line (Unit 2)	D	Μ	Q(2)	B(3)
3.	FLO	W RATE MEASUREMENT DEVICES				
	a.	Liquid Radwaste Effluent Line	D(4)	N.A.	Р	В
	b.	Cooling Pond Blowdown Pipe	D(4)	N.A.	Q	E

1.1.1.1.1

p:\procupgd\approved\odcm\LS12R7.0

.

.

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

TABLE 12.2.1-2 (Continued)

TABLE NOTATION

- (1) The CHANNEL FUNCTIONAL TEST shall also demonstrate that automatic isolation of this pathway and control alarm annunciation occurs if any of the following conditions exist:
 - 1. Instrument indicates measured levels above the alarm/trip setpoint.
 - 2. Loss of power.
 - 3. Instrument alarms on downscale failure.
 - 4. Instrument controls not set in Operate or High Voltage mode.
- (2) The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
 - 1. Instrument indicates measured levels above the alarm setpoint.
 - 2. Loss of power.

Ŧ.

- 3. Instrument alarms on downscale failure.
- 4. Instrument controls not set in Operate or High Voltage mode.
- (3) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference radioactive standards certified by the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities with NIST. These standards shall permit calibrating the system over its intended range of energy and measurement range. For subsequent CHANNEL CALIBRATION, the initial reference radioactive standards or radioactive sources that have been related to the initial calibration shall be used, in order to demonstrate linearity of the original calibration. This transfer calibration, combined with signal inputs, satisfies channel calibration and functional test requirements as implemented by station procedures.
- (4) CHANNEL CHECK shall consist of verifying indication of flow during periods of release. CHANNEL CHECK shall be made at least once per 24 hours on days in which continuous, periodic, or batch releases are made.

12.2 INSTRUMENTATION

12.2.2 Radioactive Gaseous Effluent Monitoring Instrumentation

Operability Requirements

12.2.2.A The radioactive gaseous effluent monitoring instrumentation channels shown in Table 12.2.2-1 shall be OPERABLE with their alarm/trip setpoints set to ensure that the limits of Section 12.4.1.A are not exceeded. The alarm/trip setpoints of these channels shall be determined in accordance with the ODCM.

Applicability: As shown in Table 12.2.2-1.

Action:

- a. With a radioactive gaseous effluent monitoring instrumentation channel alarm/trip setpoint less conservative than required, immediately suspend the release of radioactive gaseous effluents monitored by the affected channel or declare the channel inoperable.
- b. With less than the minimum number of radioactive gaseous effluent monitoring instrumentation channels OPERABLE, take the ACTION shown in Table 12.2.2-1.

Surveillance Requirements

12.2.2.B Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations at the frequencies shown in Table 12.2.2-2.

Bases_

12.2.2.C The radioactive gaseous effluent monitoring instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The alarm/trip setpoints for these instruments shall be calculated in accordance with the procedures in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of RETS.

Revision 7 December 2003

.

TABLE 12.2.2-1 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

iN	STRUM	IENT		MINIMUM CHANNELS <u>OPERABLE</u>	APPLICABILITY	ACTION
1.	MAIN	CONDENSER OFFGAS TREATMENT SYSTEM	· · · · · · · · · · · · · · · · · · ·			
	EFFL	UENT MONITORING SYSTEM				
	а.	Noble Gas Activity Monitor – Providing	. •	2	**	110
		Alarm and Automatic Termination of Release	•			
		(1(2) D18-N903A, K901A, K601A, R601) and/or (1(2) D18-N903B, K901B, K601B, R601)	۰.			
2.	MAIN	STACK MONITORING SYSTEM				
	а.	Noble Gas Activity Monitor (0D18-N514, R517, R518 Low Range V (0D18-N515, R517, R518 Mid Range WRGM)	NRGM) or	1	*	110
	b.	Iodine Sampler (Grab Sampler)		1	*	111
	с.	Particulate Sampler (Grab Sampler)		1	*	111
	d.	Effluent System Flow Rate Monitor (0FT-VR019, 0FY-VR019 and	19A,			
		0FR-VR019, 0D18-K510, 0D18-R518)		1	*	112
	e.	Sampler Flow Rate Monitor (Low: 0D18-N527, 0D18-N528, 0D18- 0D18-N530, 0D18-N531, 0D18-R518)	R518; Mid/Hi:	1	*	112
3.	COI (P	NDENSER AIR EJECTOR RADIOACTIVITY MONITOR rior to Input to Holdup System)				
	a.	Noble Gas Activity Monitor (1(2) D18-N002, K613, R604) (1(2) D1 R605)	8-N012, K600,	1	#	113
4.	SBC	GTS MONITORING SYSTEM				
	а.	Noble Gas Activity Monitor (0D18-N511, R515, R516 Low Range V (0D18-N512, R515, R516 Mid Range WRGM)	WRGM) or	1		110
	b.	Iodine Sampler (Grab Sampler)		1	##	111
	c.	Particulate Sampler (Grab Sampler)	_ · • •,•	1	##	111
	d.	Effluent System Flow Rate Monitor (1(2)FT-VG009, 1(2)FY-VG009 VG009)	9, 1(2)FR-	1	##	112
	e.	Sampler Flow Rate Monitor (Low: 0D18-N521, 0D18-N522, 0D18- 0D18-N524, 0D18-N525, 0D18-R516)	R516; Mid/Hi:	1	##	112
	1_					

¹Equipment Part Number (EPN) numbers or monitor types are provided in parentheses "()".

4

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION TABLE 12.2.2-1 (Continued) TABLE NOTATION

* At all times.

- ** During effluent releases via this pathway.
- # During operation of the main condenser air ejector.
- ## During operation of the SBGTS.
- ACTION 110 a. For the Main Condenser Offgas Treatment System Effluent Monitoring System:

With only one channel OPERABLE, place the inoperable channel in a tripped condition within 1 hour.

With no channel OPERABLE, effluent releases via this pathway may continue for up to 30 days provided grab samples are taken at least once per 8 hours and these samples are analyzed for noble gas gamma emitters within 24 hours. (See NOTE below.)

- b. For the Low/Mid Range of the Main Stack Monitoring System or SBGTS Monitoring System:
- With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided grab samples are taken at least once per 8 hours and these samples are analyzed for noble gas gamma emitters within 24 hours at a lower limit of detection as specified in Table 12.4.1-1. (See NOTE below.)
- ACTION 111 With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided that within 4 hours after the channel has been declared inoperable, samples are continuously collected with auxiliary sampling equipment as required in Table 12.4.1-1. (See NOTE below.)
- ACTION 112 With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided the flow rate is estimated at least once per 4 hours. (See NOTE below.)
- ACTION 113 With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, the output from the charcoal adsorber vessels may be released to the environment for up to 72 hours provided:
 - a. The offgas treatment system is not bypassed, and
 - b. The offgas treatment delay system noble gas activity effluent downstream monitor is OPERABLE;

Otherwise, be in at least Mode 2 with the main steam isolation valves closed within 12 hours.

NOTE: For Actions 110 through 112 above, effluent releases may continue beyond the 30 days as long as the applicable sampling requirements are met. Explain in the next Radioactive Effluent Release Report why the inoperability was not corrected within the time specified.

「「「「「「」」 LASALLE

· · · ·

:

Revision 7 December 2003

.

TABLE 12.2.2-2

		RADIOACTIVE GASEOUS EFFLUENT_MO		RUMENTATION			ODEDATIONAL
INS	STRUI	MENT	CHANNEL <u>CHECK</u>	SOURCE <u>CHECK</u>	FUNCTIONAL TEST	CHANNEL CALIBRATION	CONDITIONS FOR WHICH SURVEILLANCE REQUIRED
1.	MA E	IN CONDENSER OFFGAS TREATMENT SYSTEM					
	а.	Noble Gas Activity Monitor - Providing Alarm and Automatic Termination of Release	D	D	Q(1)	B(<u>5</u>)	**
_				: 1			
2.	MAIN	I STACK MONITORING SYSTEM		• 51			
	а.	Noble Gas Activity Monitor	D	м	Q(34)	B(4 3)	*
	b.	Iodine Sampler	Ŵ	N.A.	N.A.	N.A.	*
	C.	Particulate Sampler	W	N.A.	N.A.	N.A.	*
	d.	Effluent System Flow Rate Monitor	D	N.A.	Q	В	*
	e.	Sampler Flow Rate Monitor	D	N.A.	Q	В	*
3.	CON	DENSER AIR EJECTOR RADIOACTIVITY MONITOR					
	a.	Noble Gas Activity Monitor	D	M	Q(2)	B(<u>4</u> 3)	#
4.	SBG	TS MONITORING SYSTEM					
				and the state			
	а.	Noble Gas Activity Monitor	¹ D	М	Q(<u>3</u> 4)	B(<u>4</u> 3)	##
	b.	Iodine Sampler	W	N:A.	N.A.	N.A.	##
	C.	Particulate Sampler	W	N.A. ^{•••}	N.A.	N.A.	##
	d.	Effluent System Flow Rate Monitor	D	N.A.	Q	В	##
	e.	Sampler Flow Rate Monitor	D	Ń.A.	Q	В	##

BADIOACTIVE CASEOUS EEELUENT MONITODING INSTRUMENTATION SUBVEILLANCE DEOLUBEMENTS

p:\procupgd\approved\odcm\LS12R7.0

12-16

• .

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TABLE 12.2.2-2 (Continued)

TABLE NOTATION

* At all times.

- ** During effluent releases via this pathway.
- # During operation of the main condenser air ejector.
- ## During operation of the SBGTS. For instruments 4.b and 4.c, not required to be performed until 7 days after SBGTS is placed in operation.
- (1) The CHANNEL FUNCTIONAL TEST shall also demonstrate the automatic isolation capability of this pathway for the following conditions:
 - 1. Upscale.
 - 2. Inoperative.
 - 3. Downscale.
- (2) The CHANNEL FUNCTIONAL TEST for the log scale monitor shall also demonstrate that control room alarm annunciation occurs for the following conditions:
 - 1. Upscale.
 - 2. Inoperative.
 - 3. Downscale.
- (3) The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exists:
 - 1. Instrument indicates measured levels above the alarm setpoint.

ļ

2. Loss of Counts

- (4) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference radioactive standards certified by the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities with NIST. These standards shall permit calibrating the system over its intended range of energy and measurement range. For subsequent CHANNEL CALIBRATION, the initial reference radioactive standards or radioactive sources that have been related to the initial calibration shall be used.
- (5) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference radioactive standards certified by the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities with NIST. These standards shall permit calibrating the system over its intended range of energy and measurement range. For subsequent CHANNEL CALIBRATION, the initial reference radioactive standards or radioactive sources that have been related to the initial calibration shall be used, in order to demonstrate linearity of the original calibration. This transfer calibration, combined with signal inputs, satisfies channel calibration and functional test requirements as implemented by station procedures.

- **1**

12.3 LIQUID EFFLUENTS

12.3.1 Concentration

Operability Requirements

12.3.1.A The concentration of radioactive material released from the site shall be limited to ten (10) times the concentration value in Appendix B, Table 2, Column 2 to 10CFR20.1001-20.2402 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to the concentrations specified in Table 12.3.1-1.

Applicability: At all times. Action:

With the concentration of radioactive material released from the site exceeding the above limits, immediately restore the concentration to within the above limits.

Surveillance Requirements

- 12.3.1.B.1 The radioactivity content of each batch of radioactive liquid waste shall be determined prior to release by sampling and analysis in accordance with Table 12.3.1-2. The results of pre-release analyses shall be used with the calculational methods in the ODCM to assure that the concentration at the point of release is maintained within the limits of Section 12.3.1.A.
- 12.3.1.B.2 Post-release analyses of samples composited from batch releases shall be performed in accordance with Table 12.3.1-2. The results of the previous post-release analyses shall be used with the calculational methods in the ODCM to assure that the concentrations at the point of release were maintained within the limits of Section 12.3.1.A.
- 12.3.1.B.3 The radioactivity concentration of liquids discharged from continuous release points shall be determined by collection and analysis of samples in accordance with Table 12.3.1-2. The results of the analyses shall be used with the calculational methods in the ODCM to assure that the concentrations at the point of release are maintained within the limits of Section 12.3.1.A.
- 12.3.1.B.4 Identify outside temporary liquid holdup tanks within the site and restrict the quantity of radioactive material contained in specified tanks to provide assurance that in the event of an uncontrolled release of the tanks contents, the resulting concentrations would be less than the limits of Section 12.3.1.A. Refer to LaSalle Technical Specification 5.5.9.b.

Bases_

12.3.1.C This requirement is provided to ensure that the concentration of radioactive materials released in liquid waste effluents from the site will be less than ten (10) times the concentration levels specified in Appendix B, Table 2, Column 2 to 10CFR20.1001-2402. This limitation provides additional assurance that the levels of radioactive materials in bodies of water outside the site will result in exposure within (1) the Section II.A design objectives of Appendix I, 10 CFR 50, to an individual, and (2) the limits of 10 CFR 20.1301 to the population. In addition, this limit is associated with 40 CFR 141 which states concentration limits at the nearest downstream potable water supply.

Revision 7 December 2003

TABLE_12.3.1-1

ALLOWABLE CONCENTRATION (AC) OF DISSOLVED OR ENTRAINED NOBLE GASES RELEASED FROM THE SITE TO UNRESTRICTED AREAS IN LIQUID WASTE

NUCLIDE	AC(μCi/ml)*
Kr 85 m	2E-4
85	5E-4
87	4E-5
88	9E-5
Ar 41	7E-5
Xe 131 m	7E-4
133 m	5E-4
133	6E-4
135 m	2E-4
135	2E-4

^{*} Computed from Equation 20 of ICRP Publication 2 (1959), adjusted for infinite cloud submersion in water, and R = 0.01 rem/week, $p_w = 1.0 \text{ gm/cm}^3$, and $P_w/P_t = 1.0$.

Revision 7 December 2003

TABLE 12.3.1-2

RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM							
LIQUID RELEASE TYPE	SAMPLING FREQUENCY	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LOWER LIMIT OF DETECTION (LLD) (µCi/ml) ^ª			
A. Batch Waste Release Tanks ^d	P Each Batch	P Each Batch	Principal Gamma Emitters ^f	5x10 ⁻⁷			
			I-131	1x10 ⁻⁶			
	P One Batch/M	М	Dissolved and Entrained Gases (Gamma Emitters)	1x10 ⁻⁵			
	P Each Batch	M Composite ^b	H-3	1×10 ⁻⁵			
	4-		Gross Alpha	1x10 ⁻⁷			
	P Each Batch	Q Composite ^b	Sr-89, Sr-90	5x10 ⁻⁸			
			Fe-55	1x10 ⁻⁶			
B. Continuous Releases ^e	Continuous ^c	W Composite ^c	Principal Gamma Emitters ¹	5x10 ⁻⁷			
Cooling Pond Blowdown							
			I-131	1x10 ⁻⁶			
	M Grab Sample	М	Dissolved and Entrained Gases (Gamma Emitters)	1x10 ⁻⁵			
	Continuous ^c	M Composite ^c	Н-3	1x10 ⁻⁵			
			Gross Alpha	1x10 ⁻⁷			
	Continuous ^c	Q Composite ^c	Sr-89, Sr-90	5x10 ⁻⁸			
			Fe-55	1x10 ⁻⁶			

.

.

RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

TABLE 12.3.1-2 (Continued)

TABLE NOTATION

a. The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

4.66 s_b

E.V.2.22x10⁶.Y.exp (-λΔt)

LLD =

Where:

- LLD is the "a priori" lower limit of detection as defined above (as microcurie per unit mass or volume),
- s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute),
- E is the counting efficiency (as counts per transformation),
- V is the sample size (in units of mass or volume),

2.22x10⁶ is the number of transformations per minute per microcurie,

- Y is the fractional radiochemical yield (when applicable),
- λ is the radioactive decay constant for the particular radionuclide and for composite samples, and
- Δt is the elapsed time between midpoint of sample collection and time of counting (for plant effluents, not environmental samples). For batch samples taken and analyzed prior to release, Δt is taken to be zero.

The value of s_b used in the calculation of the LLD for a detection system shall be based on the actual observed variance of the background counting rate or of the counting rate of the blank samples (as appropriate) rather than on an unverified theoretically predicted variance. Typical values of E, V, Y, and Δt shall be used in the calculation.

Alternate LLD Methodology

An alternate methodology for LLD determination follows and is similar to the above LLD equation:

LLD =
$$\frac{(2.71 + 4.65\sqrt{B}) \cdot \text{Decay}}{\text{E q b Y t } (2.22 \times 10^{6})}$$

TABLE 12.3.1-2 (Continued) RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM TABLE NOTATIONS

Where:

B = background sum (counts)

E = counting efficiency

q = sample quantity (mass or volume)

b = abundance (if applicable)

Y= fractional radiochemical yield or collection efficiency (if applicable)

t= count time (minutes)

 2.22×10^6 = number of disintegrations per minute per microCurie

$$2.71 + 4.65\sqrt{B} = k^2 + (2k\sqrt{2}\sqrt{B})$$
, and k = 1.645

(k=value of the t statistic from the single-tailed t distribution at a significance level of 0.95 and infinite degrees of freedom. This means that the LLD result represents a 95% detection probability with a 5% probability of falsely concluding that the nuclide is present when it is not or that the nuclide is not present when it is.)

Decay = $e^{\lambda\Delta t} [\lambda RT/(1-e^{-\lambda RT})][\lambda T_d /(1-e^{-\lambda Td})]$ if applicable

 λ = radioactive decay constant (units consistent with Δt , RT and T_d)

 Δt = "delta t", or the elapsed time between sample collection or the midpoint of sample collection and the time the count is started, depending on the type of sample (units consistent with λ)

RT = elapsed real time, or the duration of the sample count (units consistent with λ)

 T_d = sample deposition time, or the duration of analyte collection onto the sample media (units consistent with λ)

The LLD may alternately be determined using installed radioanalytical software, if available. In addition to determining the correct number of channels over which to total the background sum, utilizing the software's ability to perform decay corrections (i.e. during sample collection, from sample collection to start of analysis, and during counting), this alternate method will result in a more accurate determination of the LLD.

It should be recognized that the LLD is defined as a before the fact limit representing the capability of a measurement system and not as an after the fact limit for a particular measurement.

p:\procupgd\approved\odcm\LS12R7.0

RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

TABLE 12.3.1-2 (Continued)

TABLE NOTATION

- b. A composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sample employed results in a specimen which is representative of the liquids released.
- c. To be representative of the quantities and concentrations of radioactive materials in liquid effluents, samples shall be collected in proportion to the rate of flow of the effluent stream. Prior to analyses, all samples taken for the composite shall be thoroughly mixed in order for the composite sample to be representative of the effluent release.
- d. A batch release is the discharge of liquid waste of a discrete volume. Prior to sampling for analyses, each batch shall be isolated, and then thoroughly mixed to assure representative sampling.
- e. A continuous release is the discharge of liquid wastes of a nondiscrete volume; e.g., from a volume of system that has an input flow during the continuous release.
- f. The principal gamma emitters for which the LLD specification applies exclusively are the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141, and Ce-144. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, at the 95% confidence level, together with the above nuclides, shall also be identified and reported.

- ;

12.3 LIQUID EFFLUENTS

12.3.2 Dose

24) 23

12.3.2.A	The dose or dose commitment to an individual from radioactive materials in liquid effluents released, from each reactor unit, from the site shall be limited:				
	a. During any calendar quarter to less than or equal to 1.5 mrem to the total body and to less than or equal to 5 mrem to any organ, and				
	b. During any calendar year to less than or equal to 3 mrem to the total body and to less than or equal to 10 mrem to any organ.				
APPLICAB	<u>[Y</u> : At all times.				
ACTION					
Surveillanc	a. With the calculated dose from the release of radioactive materials in liquid effluents exceeding any of the above limits, prepare and submit to the Commission, pursuant to 10CFR50, Appendix I, Section IV.A, a report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases of radioactive materials in liquid effluents during the remainder of the current calendar quarter and during the subsequent three calendar quarters, so that the cumulative dose or dose commitment to an individual from these releases is within 3 mrem to the tota body and 10 mrem to any organ. The Report shall also include the radiological impact on finished drinking water supplies at the nearest downstream drinking water source. The Report is due to the NRC within 30 days from the end of the quarter in which the release occurred.				
12.3.2.B	<u>Dose Calculations</u> - Cumulative dose contributions from liquid effluents shall be determined in accordance with the ODCM at least once per 31 days, when liquid discharges are performed.				
Bases					
12.3.2.C	This requirement is provided to implement the requirements of Sections II A III A				

Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I," April 1977.

This requirement applies to the release of radioactive materials in liquid effluents from each reactor at the site. For units with shared radwaste treatment systems, the liquid effluents from the shared are proportioned among the units sharing that system.

2011

1.4.4

: -

.

٠.

p:\procupgd\approved\odcm\LS12R7.0

÷

.:

• ;

12.3 LIQUID EFFLUENTS

12.3.3 Liquid Waste Treatment System

Operability Requirements

12.3.3.A The liquid radwaste treatment system shall be OPERABLE. The appropriate portions of the system shall be used to reduce the radioactive materials in liquid wastes prior to their discharge when the projected doses due to the liquid effluent from each reactor unit, from the site, when averaged over 31 days, would exceed 0.06 mrem to the total body or 0.2 mrem to any organ.

Applicability: At all times.

Action:

- a. With the liquid radwaste treatment system inoperable for more than 31 days or with radioactive liquid waste being discharged without treatment and in excess of the above limits, prepare and submit to the Commission within 30 days a Special Report which includes the following information:
 - 1. Identification of the inoperable equipment or subsystems and the reason for inoperability,
 - 2. Action(s) taken to restore the inoperable equipment to OPERABLE status, and
 - 3. Summary description of action(s) taken to prevent a recurrence.

Surveillance Requirements

- 12.3.3.B.1 Doses due to liquid releases shall be projected at least once per 31 days when releases are to be performed, in accordance with the methods in the ODCM.
- 12.3.3.B.2 The liquid radwaste treatment system shall be demonstrated OPERABLE by operating the liquid radwaste treatment system equipment for at least 30 minutes at least once per 92 days unless the liquid radwaste system has been utilized to process radioactive liquid effluents during the previous 92 days.

. -----

Bases	
12.3.3.C	The OPERABILITY of the liquid radwaste treatment system ensures that this system will be available for use whenever liquid effluents require treatment prior to release to the environment. The requirement that the appropriate portions of this system be used when specified provides assurance that the releases of radioactive materials in liquid effluents will be kept "as low as is reasonably achievable." A system bypass allows connection to portable waste treatment equipment. This enables the efficient processing of liquid radwaste through the use of state-of-the-art radwaste processing technology. The portable radwaste treatment system when a portable waste treatment is not used, Surveillance Requirement 12.3.3.B.2 may be extended to 180 days. This specification implements the requirements of 10 CFR Part 50.36a. General Design Criterion 50 of Appendix A to 10 CFR Part 50 and the design objective given in Section II.0 of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the liquid radwaste treatment system were specified as a suitable fraction of the dose design objectives set forth in Section II.A of Appendix I, 10 CFR Part 50, for liquid effluents. This specification implements Technical Specification Section 5.5.4.f for liquid effluents.

.

.

: ...

12.4 GASEOUS EFFLUENTS

12.4.1 Dose Rate

Operability Requirements

12.4.1.A The dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the SITE BOUNDARY, shall be limited to the following:

- a. For noble gases: Less than or equal to a dose rate of 500 mrem/yr to the total body and less than or equal to a dose rate of 3000 mrem/yr to the skin, and
- b. For iodine-131, for iodine-133, for tritium, and for all radionuclides in particulate form with half lives greater than 8 days: Less than or equal to a dose rate of 1500 mrems/yr to any organ via the inhalation pathway.

Applicability: At all times.

Action:

With the dose rate(s) exceeding the above limits, immediately decrease the release rate to within the above limit(s).

Surveillance Requirements

12.4.1.B.1 The dose rate due to noble gases in gaseous effluents shall be determined to be within the above limits in accordance with the methodology and parameters of the ODCM by obtaining representative samples and performing analyses in accordance with the sampling and analysis program specified in Table 12.4.1-1. 12.4.1.B.2 The dose rate due to iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives greater than eight days, in accordance with the methodology and parameters of the ODCM by obtaining representative samples and performing analyses in accordance with the sampling and analysis program specified in Table 12.4.1-1. Bases 12.4.1.C This specification is provided to ensure that the dose at any time at the site boundary from gaseous effluents from all units on the site will be within the annual dose limits of RETS for unrestricted areas. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of an individual in an unrestricted area, either within or outside the site boundary exceeding the limits specified in 10CFR20.1301. For individuals who may at times be within the site boundary, the occupancy of the individual will be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the site boundary. The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates above background to an individual at or beyond the site boundary to less than or equal to a dose rate of 500

mrem/year to the total body or to less than or equal to a dose rate of 3000 mrem/year to the skin. These release rate limits also restrict, at all times, the corresponding thyroid dose rate above background via the inhalation pathway to less than or equal to a dose rate of 1500 mrem/year.

This specification applies to the release of radioactive effluents in gaseous effluents from all reactors at the site. For units within shared radwaste treatment systems, the gaseous effluents from the shared system are proportioned among the units sharing that system.

p:\procupgd\approved\odcm\LS12R7.0

TABLE 12.4.1-1 RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM

GASEOUS RELEASE TYPE	SAMPLING FREQUENCY	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LOWER LIMIT OF DETECTION (LLD) (µCi/ml) ^ª
A. Containment Vent and Purge System ^h	P Each Purge ^b Grab Sample	P Each Purge [⊳]	Principal Gamma Emitters ⁹	1x10 ⁻⁴
			H-3	1x10 ⁻⁶
B. Main Vent Stack	M ^b Grab Sample	Mp	Principal Gamma Emitters ^g	1x10 ⁻⁴
	W ^{ь,e} Grab Sample	W ^{b,e}	Н-3	1x10 ⁻⁶
C. Standby Gas Treatment System	D ^c Grab Sample	Dc	Principal Gamma Emitters ⁹	1x10 ⁻⁴
D. Main Vent Stack And Standby Gas Treatment System ^c	Continuous ^f	W ^d Charcoal Sample	I-131	1x10 ⁻¹²
			I-133	1x10 ⁻¹⁰
	Continuous ^f	W ^d Particulate Sample	Principal Gamma Emitters ⁹	1x10 ⁻¹¹
			(I-131, Others)	
	Continuous ^f	M Composite Particulate Sample	Gross Alpha	1x10 ⁻¹¹
	Continuous ^f	Q Composite Particulate Sample	Sr-89,Sr-90	1x10 ⁻¹¹
	Continuous	Noble Gas Monitor	Noble Gases Gross Beta or Gamma	1x10 ⁻⁶

.

TABLE 12.4.1-1 (Continued)

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM

TABLE NOTATION

a. The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

4.66 S_b

LLD = $E \cdot V \cdot 2.22 \times 10^6 \cdot Y \cdot \exp(-\lambda \Delta t)$

Where:

LLD is the "a priori" lower limit of detection as defined above (as microcurie per unit mass or volume),

- s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute),
- E is the counting efficiency (as counts per transformation),
- V is the sample size (in units of mass or volume),

2.22x10⁶ is the number of transformations per minute per microcurie,

- Y is the fractional radiochemical yield (when applicable),
- λ is the radioactive decay constant for the particular radionuclide, and
- Δt is the elapsed time between midpoint of sample collection and time of counting (for plant effluents, not environmental samples).

The value of s_b used in the calculation of the LLD for a detection system shall be based on the actual observed variance of the background counting rate or of the counting rate of the blank samples (as appropriate) rather than on an unverified theoretically predicted variance. Typical values of E, V, Y, and Δt shall be used in the calculation.

Alternate LLD Methodology

An alternate methodology for LLD determination follows and is similar to the above LLD equation:

LLD = $\frac{(2.71 + 4.65\sqrt{B}) \cdot \text{Decay}}{\text{E q b Y t } (2.22 \times 10^6)}$
TABLE 12.4.1-1 (Continued) <u>RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM</u> <u>TABLE NOTATION</u>

Where:

.

B = background sum (counts)

E = counting efficiency

q = sample quantity (mass or volume)

b = abundance (if applicable)

Y= fractional radiochemical yield or collection efficiency (if applicable)

t= count time (minutes)

 2.22×10^6 = number of disintegrations per minute per microCurie

 $2.71 + 4.65\sqrt{B} = k^2 + (2k\sqrt{2}\sqrt{B})$, and k = 1.645

(k=value of the t statistic from the single-tailed t distribution at a significance level of 0.95 and infinite degrees of freedom. This means that the LLD result represents a 95% detection probability with a 5% probability of falsely concluding that the nuclide is present when it is not or that the nuclide is not present when it is.)

Decay = $e^{\lambda \Delta t} [\lambda RT/(1-e^{-\lambda RT})] [\lambda T_d / (1-e^{-\lambda Td})]$ if applicable

 λ = radioactive decay constant (units consistent with Δt , RT and T_d)

 Δt = "delta t", or the elapsed time between sample collection or the midpoint of sample collection and the time the count is started, depending on the type of sample (units consistent with λ)

RT = elapsed real time, or the duration of the sample count (units consistent with λ)

 T_d = sample deposition time, or the duration of analyte collection onto the sample media (units consistent with λ)

The LLD may alternately be determined using installed radioanalytical software, if available. In addition to determining the correct number of channels over which to total the background sum, utilizing the software's ability to perform decay corrections (i.e. during sample collection, from sample collection to start of analysis, and during counting), this alternate method will result in a more accurate determination of the LLD.

It should be recognized that the LLD is defined as a before the fact limit representing the capability of a measurement system and not as an after the fact limit for a particular measurement.

Sampling and analyses shall also be performed following shutdown, startup, or a thermal power change exceeding 20 percent of rated thermal power in 1 hour unless (1) analysis shows that the dose equivalent I-131 concentration in the primary coolant has not increased more than a factor of 5, and (2) the noble gas activity monitor shows that effluent activity has not increased by more than a factor of 3.

p:\procupgd\approved\odcm\LS12R7.0

TABLE 12.4.1-1 (Continued) RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM TABLE NOTATION

- c. Whenever there is flow through the SBGTS. (If SBGT is run more than 10 minutes in a 24 hour period then it must be run a minimum of 5 hours. The 5 hour run is required to meet the sample requirements for iodine and particulates.) When SBGT equipment is started and shutdown, ensure noble gas iodine and particulate samples are taken.
- d. Samples shall be changed at least once per 7 days and the analyses completed within 48 hours after removal from the sampler. Sampling shall also be performed within 24 hours following each shutdown, startup, or thermal power level change exceeding 20% of rated thermal power in one hour. This requirement does not apply if 1) analysis shows that the dose equivalent I-131 concentration in the primary coolant has not increased by more than a factor of 5, and 2) the noble gas activity monitor shows that effluent activity has not increased by more than a factor of 3. When samples collected for 24 hours are analyzed, the corresponding LLDs may be increased by a factor of 10.

e. Tritium grab samples shall be taken at least once per 7 days from the plant vent to determine tritium releases in the ventilation exhaust from the spent fuel pool area whenever spent fuel is in the spent fuel pool. If there is no spent fuel in the fuel pool, sampling and analysis of tritium grab samples shall be performed at least monthly.

f. The ratio of the sample flow rate to the sampled stream flow rate shall be known for the time period covered by each dose or dose rate calculation made in accordance with Sections 12.4.1.A, 12.4.2.A and 12.4.3.A.

- g. The principal gamma emitters for which the LLD specification applies include the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emissions and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144 for particulate emissions. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, at the 95% confidence level, together with the above nuclides, shall also be identified and reported.
- h. The drywell tritium and noble gas sample results are valid for 30 hours from sample time if 1) the drywell radioactivity monitors have not indicated an increase in airborne or gaseous radioactivity, and 2) the drywell equipment and floor drain sump pumps run times have not indicated an increase in leakage in the drywell since the sample was taken, and 3) conditions are such that activity can be calculated for the radionuclide concentration at the time of the release.

If there is any reason to suspect that gaseous radioactivity levels have changed in the drywell that would compromise the calculated, or estimated, radionuclide concentrations at the time of the release, since the last sample (30 hours), a new sample and analyses should be requested prior to starting a drywell purge to meet the intent of providing current analyses to reflect actual activity released to the environment. If a known steady state leakage condition exists in the drywell it is possible to calculate a safe and accurate release package. Final release quantification will be based on calculated radionuclide concentrations at the time of the actual release.

If the drywell is <u>purged</u> in accordance with the ODCM definition, both noble gas and tritium analyses must be completed before the purge begins. If the drywell is simply <u>vented</u> in accordance with the ODCM definition, no sample is required before venting.

p:\procupgd\approved\odcm\LS12R7.0

· · ·

12.4 GASEOUS EFFLUENTS

12.4.2 Dose - Noble Gases

, , <u>f</u> , , ,

٠

Operability Reg	uirements
12.4.2.A	The air dose due to noble gases released in gaseous effluents, from each reactor unit, from the site shall be limited to the following:
	a. During any calendar quarter: Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and
	b. During any calendar year: Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.
	Applicability: At all times.
	Action:
	 With the calculated air dose from radioactive noble gases in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission, pursuant to 10CFR50, Appendix I, Section IV.A, a report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases and the proposed corrective actions to be taken to assure that subsequent releases will be in compliance with the above limits. This report is due to the NRC within 30 days from the end of the quarter in which the release occurred.
Surveillance Re	equirements
12.4.2.B	Dose Calculations - Cumulative dose contributions for the current calendar quarter and current calendar year shall be determined in accordance with the ODCM at least once per 31 days.
Bases	·
12.4.2.C	This specification is provided to implement the requirements of Sections II.B, III.A and IV.A of Appendix I, 10 CFR Part 50. The Operability Requirements are the guides set forth in Section II.B of Appendix I. The ACTION statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents will be kept "as low as is reasonably achievable." The Surveillance Requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The dose calculations established in the ODCM for calculating the doses due to the actual release rates of radioactive noble gases in gaseous effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I, "Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors," Revision I, July 1977. The ODCM equations provided for determining the air doses at the site boundary are based upon the historical average atmospheric conditions.

12.4 GASEOUS EFFLUENTS

ŗ,

12.4.3 Dose - Iodine-131, Iodine-133, Tritium, and Radionuclides in Particulate Form

Operability Requirements

- 12.4.3.A The dose to a MEMBER OF THE PUBLIC from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released, from each reactor unit, to areas at and beyond the SITE BOUNDARY shall be limited to the following:
 - a. During any calendar quarter: Less than or equal to 7.5 mrems to any organ and,
 - b. During any calendar year: Less than or equal to 15 mrems to any organ.

Applicability: At all times.

Action:

a. With the calculated dose from the release of iodine-131, iodine-133, tritium, and radionuclides in particulate form with half lives greater than 8 days, in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission, pursuant to 10CFR50, Appendix I, Section IV.A, a report that identifies the cause(s) for exceeding the limit and defines the corrective actions that have been taken to reduce the releases and the proposed correction actions to be taken to assure that subsequent releases will be in compliance with the above limits. This report is due to the NRC within 30 days from the end of the quarter in which the released occurred.

Surveillance Requirements

۰. د ب

12.4.3.B Cumulative dose contributions for the current calendar quarter and current calendar year for iodine-131, iodine-133, tritium, and radionuclides in particulate form with half lives greater than 8 days shall be determined in accordance with the methodology and parameters in the ODCM at least once per 31 days.

-

Bases	
Bases 12.4.3.C	The specification is provided to implement the requirements of Sections II.C, III.A and IV.A of Appendix I, 10 CFR Part 50. The Operability Requirements are the guides set forth in Section II.C of Appendix I. The ACTION statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." The ODCM calculational methods specified in the Surveillance Requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data, such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The ODCM calculational methods for calculating the doses due to the actual release rates of the subject materials are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I, "Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision 1, July 1977. These equations also provide for determining the actual doses based upon the historical average atmospheric conditions. The release rate specifications for radioidines, radioactive materials in particulate form and radionuclides other than noble gases are dependent on the existing radionuclide pathways to man, in
	the unrestricted area. The pathways which were examined in the development of these calculations were: 1) individual inhalation of airborne radionuclides, 2) deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, 3) deposition onto grassy areas where milk animals and meat producing animals graze with consumption of the milk and meat by man, and 4) deposition on the ground with subsequent exposure of man.

•

-

12.4 GASEOUS EFFLUENTS

12.4.4 Gaseous Radwaste Treatment System

Operability Requirements

12.4.4.A	operation.	JS RADWASTE (OFF-GAS) TREATMENT SYSTEM shall be in
,	Applicability:	Whenever the main condenser air ejector system is in operation.
	Action:	
	a. With inope withir	the GASEOUS RADWASTE (OFF-GAS) TREATMENT SYSTEM erable for more than 7 days, prepare and submit to the Commission a 30 days, a Special Report which includes the following information:
	1.	Identification of the inoperable equipment or subsystems and the reason for inoperability.
		$T_{\rm eff} = T_{\rm eff} + T_{e$
	ette 2. 1	Action(s) taken to restore the inoperable equipment to
•	2 1 1	OPERABLE status, and
	• • • •	n i i i i i i i i i i i i i i i i i i i
	3.	Summary description of action(s) taken to prevent a recurrence.
		2

Surveillance Requirements

12.4.4.B The GASEOUS RADWASTE TREATMENT SYSTEM shall be verified to be in operation at least once per 7 days.

Bases____

1 2 2

> 12.4.4.C The OPERABILITY of the GASEOUS RADWASTE TREATMENT SYSTEM and the VENTILATION EXHAUST TREATMENT SYSTEM ensures that the system will be available for use whenever gaseous effluents require treatment prior to release to the environment. The requirement that the appropriate portions of these systems be used, when specified, provides reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable". This specification implements the requirements of 10 CFR Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50, and the design objectives given in Section II,0 of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the systems were specified as a suitable fraction of the dose design objectives set forth in Sections II.B and II.C of Appendix I, 10 CFR Part 50, for gaseous effluents.

12.4 GASEOUS EFFLUENTS

12.4.5 Ventilation Exhaust Treatment System

Operability Requirements

12.4.5.A The appropriate portions of the VENTILATION EXHAUST TREATMENT SYSTEM shall be OPERABLE and be used to reduce radioactive materials in gaseous waste prior to their discharge when the projected doses due to gaseous effluent releases from each reactor unit, from the site, when averaged over 31 days, would exceed 0.3 mrem to any organ.

Applicability: At all times.

Action:

With the VENTILATION EXHAUST TREATMENT SYSTEM inoperable for more than 31 days, and with gaseous waste being discharged without treatment and in excess of the above limits, prepare and submit to the Commission within 30 days, a Special Report which includes the following information:

- 1.Identification of the inoperable equipment or subsystems and the reason7.1for inoperability,
 - 2. Action(s) taken to restore the inoperable equipment to OPERABLE status, and
 - 3. Summary description of action(s) taken to prevent a recurrence.

Surveillance Requirements

.

é

- 12.4.5.B.1 Doses due to gaseous releases from the site shall be projected at least once per 31 days in accordance with the ODCM.
- 12.4.5.B.2 The VENTILATION EXHAUST TREATMENT SYSTEM shall be demonstrated OPERABLE by operating the VENTILATION EXHAUST TREATMENT SYSTEM equipment for at least 30 minutes, at least once per 92 days unless the appropriate system has been utilized to process radioactive gaseous effluents during the previous 92 days.
- Bases

 12.4.5.C
 The OPERABILITY of the GASEOUS RADWASTE TREATMENT SYSTEM and the VENTILATION EXHAUST TREATMENT SYSTEM ensures that the system will be available for use whenever gaseous effluents require treatment prior to release to the environment. The requirement that the appropriate portions of these systems be used, when specified, provides reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable". This specification implements the requirements of 10 CFR Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50, and the design objectives given in Section II,0 of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the systems were specified as a suitable fraction of the dose design objectives set forth in Sections II.B and II.C of Appendix I, 10 CFR Part 50, for gaseous effluents. This specification implements Technical Specification 5.5.4.f for gaseous effluents.

12.4 GASEOUS EFFLUENTS

12.4.6 Venting or Purging

Operability Requirements

- 12.4.6.A VENTING or PURGING of the containment drywell shall be through the Primary Containment Vent and Purge System or the Standby Gas Treatment System.
 - Applicability: Whenever the drywell is vented or purged.

Action:

a. With the requirements of the above specification not satisfied, suspend all VENTING and PURGING of the drywell.

Surveillance Requirements

The containment drywell shall be determined to be aligned for VENTING or 12.4.6.B.1 147 · PURGING through the Primary Containment Vent and Purge System or the · · · Standby Gas Treatment System within 4 hours prior to start of and at least once •. •. per 12 hours during VENTING or PURGING of the drywell. · · . . r 12.4.6.B.2 Prior to use of the Purge System through the Standby Gas Treatment System in MODE 1, 2 or 3 assure that: Both Standby Gas Treatment System trains are OPERABLE, and а. b. Only one of the Standby Gas Treatment System trains is used for PURGING. **Bases** 12.4.6.C This specification provides reasonable assurance that releases from drywell purging operations will not exceed the annual dose limits of 10CFR20 for unrestricted areas.

12.4 GASEOUS EFFLUENTS

12.4.7 **Total Dose**

. :

1 . 1

: .m

1 · · ·

5

Operability Requirements

12.4.7.A The dose or dose commitment to any member of the public, due to releases of radioactivity and radiation, from uranium fuel cycle sources shall be limited to less than or equal to 25 mrem to the total body or any organ (except the thyroid, which shall be limited to less or equal to 75 mrem) over 12 consecutive months.

> Applicability: At all times.

Action:

With the calculated doses from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of Sections 12.3.2.A.a, 12.3.2.A.b. 12.4.2.A.a, 12.4.2.A.b, 12.4.3.A.a or 12.4.3.A.b, prepare and submit a Special Report to the Director, Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, within 30 days, which defines the corrective action to be taken to reduce subsequent releases to prevent recurrence of exceeding the limits of Section 12.4.7.A. This Special Report shall include an analysis which estimates the radiation exposure (dose) to a member of the public from uranium fuel cycle sources (including all effluents pathways and direct radiation) for a 12 consecutive month period that includes the release(s) covered by this report. If the estimated dose(s) exceeds the limits of Section 12.4.7.A, and if the release condition resulting in violation of 40 CFR 190 has not already been corrected, the Special Report shall include a request for a variance in accordance with the provisions of 40 CFR 190 and including the specified information of 40 CFR 190.11. Submittal of the report is considered a timely request, and a variance is granted until staff action on the request is complete. The variance only relates to the limits of 40 CFR 190, and does not apply in any way to the requirements for dose limitation of 10 CFR Part 20, as addressed in other sections of this technical specification.

Surveillance Requirements

12.4.7.B Dose Calculations - Cumulative dose contributions from direct radiation and liquid and gaseous effluents shall be determined in accordance with Sections 12.3.2.B, 12.4.2.B and 12.4.3.B, and in accordance with the ODCM.

	Bases	·
	12.4.7.C	This specification is provided to meet the dose limitations of 40 CFR 190. The specification requires the preparation and submittal of a Special Report whenever the calculated doses from plant radioactive effluents exceed twice the design objective doses of Appendix I. For sites containing up to 4 reactors, it is highly unlikely that the resultant dose to a member of the public will exceed the dose limits of 40 CFR 190 if the individual reactors remain within the reporting requirement level. The Special Report will describe a course of action which should result in the limitation of dose to a member of the public for 12 consecutive months to within the 40 CFR 190 limits. For the purpose of the Special Report, it may be assumed that the dose commitment to the member of the public from other uranium fuel cycle sources is negligible, with the exception that dose contributions from other nuclear fuel cycle facilities at the same site or within a radius of 5 miles must be considered. If the dose to any member of the public is estimated to exceed the requirements of 40 CFR 190, the Special Report with a request for a variance (provided the release conditions resulting in violation of 40 CFR 190 until NRC staff action is completed. An individual is not considered a member of the public during any period in which he/she is engaged in carrying out any operation which is part of the nuclear fuel cycle.
· · ·		
• •.		

Ν

- .

.

.

12.4 GASEOUS EFFLUENTS

12.4.8 Main Condenser

Operability Requirements

12.4.8.A The release rate of the sum of the activities from the noble gases measured prior to the holdup line shall be limited to less than or equal to 3.4×10^5 microcuries/second after decay of 30 minutes.

Applicability: MODE 1. MODES 2 and 3 with any main steam line not isolated and steam jet air ejectors (SJAE) in operation.

Action:

With the release rate of the sum of the activities from the noble gases prior to the holdup line exceeding 3.4×10^5 microcuries/second after decay of 30 minutes, restore the release rate to within its limit within 72 hours or either isolate all main steam lines or isolate the SJAEs in the next 12 hours, or be in MODE 3 in the next 12 hours and MODE 4 in the next 24 hours.

	110/10	TE nouio u	6-0 ° T	 IIOAC .		-
			- ··	 		
-						

Surveillance I	Requirements	<i>.</i>			· ·				
12.4.8.B.1	The radioactivity rate	of noble g	ases	prior to	b the	holdup	line shall	be continuous	ly
	monitored in accorda	nce with th	ne OD	CM ar	nd Ta	ble 12.	2.2-2 .		

- 12.4.8.B.2 *The release rate of the sum of the activities from noble gases prior to the holdup line shall be determined to be within the limits of specification 12.4.8.A at the following frequencies by performing an isotopic analysis of a representative sample of gases taken prior to the holdup line.
 - a. At least once per 31 days.
 - b. Within 4 hours following an increase, as indicated by the off gas pretreatment Noble Gas Activity Monitor, of greater than 50%, after factoring out increases due to changes in THERMAL POWER level, in the nominal steady state fission gas release from the primary coolant.

* Not required to be performed until 31 days after any main steam line not isolated and SJAE in operation.

In accordance with surveillance requirements contained within ODCM Chapter 12 item number 12.4.8.B.1 and 2, this specification provides reasonable assurance that the releases from the main condenser will not exceed the requirements of the LaSalle Technical Specifications 3.7.6. In addition, a sample is required within 4 hours if the increase is not due to thermal power changes. If the cause is known and not fuel related and less than 1 hour in duration, then no sample is required. [This is based on interpretation letter from W. R. Huntington to Operating Engineers. Shift Engineers and F.R. Lawless, dated May 24, 1984.]

12.4.9 Dose Limits for Members of the Public

Operability Requirements

12.4.9.A The licensee shall conduct operations such that the TEDE to individual MEMBERS OF THE PUBLIC does not exceed 100 mrem in a year. In addition, the dose in any unrestricted area from external sources does not exceed 2 mrem in any one hour. The Effluents Program shall implement monitoring, sampling, and analysis of radioactive liquid and gaseous effluents in accordance with 10CFR20.1302 and with the methodology and parameters in the ODCM.

Applicability: At all times.

Action:

- 1. If the calculated dose from the release or exposure of radiation meets or exceeds the 100 mrem/year limit for the MEMBER OF THE PUBLIC, prepare and submit a report to the Commission in accordance with 10CFR20.2203.
- 2. If the dose in any unrestricted area from external sources of radiation meets or
- exceeds the 2 mrem in any one hour limit for the MEMBER OF THE PUBLIC,
- prepare and submit a report to the Commission in accordance with 10CFR20.2203.

Surveillance Requirements

12.4.9.B Calculate the TEDE to individual MEMBERS OF THE PUBLIC annually to determine compliance with the 100 mrem/year limit in accordance with the ODCM. In addition, evaluate and/or determine if direct radiation exposures exceed 2 mrem in any hour in unrestricted areas.

Bases_

3

...

12.4.9.C This section applies to direct exposure of radioactive materials as well as radioactive materials released in gaseous and liquid effluents. 10CFR20.1301 sets forth the 100 mrem/year dose limit to members of the public; 2 mrem in any one hour limit in the unrestricted area; and reiterates that the licensee is also required to meet the 40CFR190 standards. 10CFR20.1302 provides options to determine compliance to 10CFR20.1301. Compliance to the above operability requirement is based on 10CFR20, 40CFR190 and LaSalle Station Technical Specification 5.5.4.g.

p:\procupgd\approved\odcm\LS12R7.0

12.5 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

12.5.1 Monitoring Program

Operability Requirements

12.5.1.A The Radiological Environmental Monitoring Program shall be conducted as specified in Table 12.5-1.

Applicability: At all times.

Action:

: 14

1.

With the Radiological Environmental Monitoring Program not being conducted as specified in Table 12.5-1, prepare and submit to the Commission, in the Annual Radiological Environmental Operating Report required by Technical Specification 5.6.2, a description of the reasons for not conducting the program as required and the plans for preventing a recurrence.

Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability, malfunction of sampling equipment, if a person/business who participates in this program goes out of business or no longer can provide sample, or contractor omission which is corrected as soon as discovered. If the equipment malfunctions, corrective actions shall be completed as soon as practical. If a person/business supplying samples goes out of business, a replacement supplier shall be found as soon as possible. All deviations from the sampling schedule shall be described in the Annual Radiological Environmental Operating Report.

2. With the level of radioactivity as the result of plant effluents in an environmental sampling medium at a specified location exceeding the reporting levels of Table 12.5-2 when averaged over any calendar quarter, prepare and submit to the Commission within 30 days, a Special Report that identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce radioactive effluents so that the potential annual dose* to a MEMBER OF THE PUBLIC is less than the calendar year limits of Section 12.3.2, 12.4.2, or 12.4.3. When more than one of the radionuclides in Table 12.5.2 are detected in the sampling medium, this report shall be submitted if:

 $\frac{\text{concentration (1)}}{\text{reporting level (1)}} \neq \frac{\text{concentration (2)}}{\text{reporting level (2)}} \geq 1.0$

When radionuclides other than those in Table 12.5-2 are detected and are the result of plant effluents, this report shall be submitted if the potential annual dose* to A MEMBER OF THE PUBLIC from all radionuclides is equal to or greater than the calendar year limits of Section 12.3.2, 12.4.2, or 12.4.3. This report is not required if the measured level of radioactivity was not the result of plant effluents; however, in such an event, the condition shall be reported and described in the Annual Radiological Environmental Operating Report required by Section 12.6.1.

^{*}The methodology and parameters used to estimate the potential annual dose to a MEMBER OF THE PUBLIC shall be indicated in this report.

12.5 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (Continued)

3. If the sample type or sampling location(s) as required by Table 12.5-1 become(s) permanently unavailable, identify suitable alternative sampling media for the pathway of interest and/or specific sampling locations for obtaining replacement samples and add them to the Radiological Environmental Monitoring Program as soon as practicable. The specific locations from which samples were unavailable may then be deleted from the monitoring program.

Prepare and submit a controlled version of the ODCM in the next available annual REOR report including a revised figure(s) and table reflecting the new location(s) with supporting information identifying the cause of the unavailability of samples and justifying the selection of new location(s) for obtaining samples.

12.5.1.B	The radiological environmental monitoring program samples shall be collected pursuant to Table 12.5-1 from the specific locations given in the table and figure(s) in the ODCM, and shall be analyzed pursuant to the requirements of Table 12.5-1 and the detection capabilities required by Table 12.5-3.			
· ·	A AND SOLUTION AND A STREAM			
Bases	n n n n n n n n n n n n n n n n n n n			
12.5.1.C	The Radiological Environmental Monitoring Program required by this section provides representative measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides that lead to the highest potential radiation exposures of MEMBERS OF THE PUBLIC resulting from the station operation. This monitoring program implements Section IV.B.2 of Appendi I to 10 CFR Part 50 and thereby supplements the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and the modeling of the environmental exposure pathways.			

Guidance for this monitoring program is provided by the Radiological Assessment Branch Technical Position on Environmental Monitoring. The initially specified monitoring program will be effective for at least the first 3 years of commercial operation. Following this period, program changes may be initiated based on operational experience.

The required detection capabilities for environmental sample analyses are tabulated in terms of the lower limits of detection (LLDs). The LLDs required by Table 12.5-3 are considered optimum for routine environmental measurements in industrial laboratories. It should be recognized that the LLD is defined as a before the fact limit representing the capability of a measurement system and not as an after the fact limit for a particular measurement.

Detailed discussion of the LLD, and other detection limits, can be found in HASL Procedures Manual, <u>HASL-300</u> (revised annually), Currie, LA., "Limits for Qualitative Detection and Quantitative Determination - Application to Radiochemistry," <u>Anal_Chem_40</u>, 586-93 (1968), and Hartwell, J.K., "Detection Limits for Radioanalytical Counting Techniques," Atlantic Richfield Hanford Company Report <u>ARH-SA-215</u> (June 1975).

4

4

...

12.5 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (Continued)

Interpretations_

. Hara

• • • •

.

. .

ċ

. . .

1

14 4 12.5.1.D Table 12.5-1 requires "one sample of each community drinking water supply downstream of the plant within 10 kilometers." Drinking water supply is defined as water taken from rivers, lakes, or reservoirs (not well water) which is used for drinking.

· :

:

.

·· •

Revision 7 December 2003

TABLE 12.5-1							
RADIOLOGICAL ENVIRONMENTAL	MONITORING PROGRAM						
	(1) · · · · · · · · · · · · · · · · · · ·						

EXPOSURE PATHWAY	NUMBER OF REPRESENTATIVE	SAMPLING AND	TYPE AND FREQUENCY OF
AND/OR SAMPLE	SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾	COLLECTION FREQUENCY	ANALYSIS
1. Airborne Radioiodine and Particulates	 Samples from a total of eight locations: a. Indicator- Near Field Four samples from locations within 4 km (2.5 mi) in different sectors. b. Indicator- Far Field Four additional locations within 4 to 10 km (2.5 to 6.2 mi) in different sectors. c. Control One sample from a control location within 10 to 30 km (6.2 to 18.6 mi). 	Continuous sampler operation with particulate sample collection weekly (or more frequently if required due to dust loading) and radioiodine canister collection biweekly.	Radioiodine Canister: I-131 analysis biweekly on near field and control samples. ⁽²⁾ Particulate Sampler: Gross beta analysis following weekly filter change ⁽³⁾ and gamma isotopic analysis ⁽⁴⁾ quarterly on composite filters by location on near field and control ⁽²⁾ samples.

1 6 4 4

. .

• .

•

-

Revision 7 December 2003

TABLE 12.5-1 (Continued) RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
2. Direct Radiation ⁽⁵⁾	Forty routine monitoring stations either with a thermoluminescent dosimeter (TLD) or with one instrument for measuring dose rate continuously, placed as follows:	Quarterly ····	Gamma dose on each TLD quarterly.
	a. Indicator- Inner Ring (100 Series TLD)		
	One in each meteorological sector, in the general area of the SITE BOUNDARY (within 0.1 to 2.0 mi; 0.2 to 3.2 km)		
	 Indicator- Outer Ring (200 Series TLD) One in each meteorological sector, within 4.8 to 10 km (3 to 6.2 mi); and 	۰. <u>-</u>	
	 Other One at each Airborne location given in part 1.a. and 1.b. The balance of the TLDs to be placed at special interest locations beyond the Restricted Area where either a 		
	MEMBER OF THE PUBLIC or Commonwealth Edison employees have routine access. (300 Series TLD)		

. . . .

TABLE 12.5-1 (Continued) RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

EXPOSURE PATHWAY AND/OR SAMPLE		S	NUMBER OF REPRESENTATIVE AMPLES AND SAMPLE LOCATIONS ⁽¹⁾	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
2.	Direct Radiation ⁽⁵⁾ (Cont'd)	d.	Control One at each Airborne control location given in part 1.c	Quarterly	Gamma dose on each TLD quarterly.
3.	Waterborne a. Ground/Well	a.	Indicator Samples from two sources only if likely to be affected. ⁽⁶⁾	Quarterly	Gamma isotopic ⁽⁴⁾ and tritium analysis quarterly.
	b. Drinking ⁽⁷⁾	а.	Indicator One Sample from each community Drinking water supply that could be Affected by the station discharge within 10 km (6.2 mi) downstream of discharge.	Weekly grab samples.	Gross beta and gamma isotopic analyses ⁽⁴⁾ on monthly composite; tritium analysis on quarterly Composite. I-131 analysis on each composite when the dose calculated for the consumption of water is greater than 1 mrem per year.
	c. Surface Water ⁽⁷⁾	·	If no community water supply (Drinking Water) exists within 10 km downstream of discharge then surface water sampling shall be performed.	Weekly grab samples.	Gross beta and gamma isotopic analyses ⁽⁴⁾ on monthly composite; tritium analysis on quarterly composite.
		a.	Indicator One sample downstream		

.

se ...

.

Revision 7 December 2003

EXPOSURE PATHWAY AND/ OR SAMPLE		NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾		SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS	
d.	Control Sample ⁽⁷⁾	а.	Control One surface sample upstream discharge.	Weekly grab samples.	Gross beta and gamma isotopic analyses ⁽⁴⁾ on monthly composite; tritium analysis on quarterly composite.	
e.	Sediment	а.	Indicator At least one sample from downstream ⁽⁷⁾ area within 10 km (6.2 mi).	Semiannually.	Gamma isotopic analysis ⁽⁴⁾ semiannually.	
4.	Ingestion a. Milk ⁽⁸⁾	а. b.	Indicator Samples from milking animals from a maximum of three locations within 10 km (6.2 mi) distance. Control One sample from milking animals at a control location within 10 to 30 km (6.2 to 18.6 mi).	Biweekly ⁽⁹⁾ when animals are on pasture (May through October), monthly at other times (November through April).	Gamma isotopic ⁽⁴⁾ and I-131 ⁽¹⁰⁾ analysis on each sample.	

TABLE 12.5-1 (Continued) RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

• •

Revision 7 December 2003

TABLE 12.5-1 (Continued) RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

.-

EXPOSURE PATHWAY AND/OR SAMPLE		NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾		SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
b.	Fish	a.	Indicator Representative samples of commercially and recreationally important species in discharge area. Representative samples from the	Two times annually.	Gamma isotopic analysis ⁽⁴⁾ on edible portions
		b.	Control Representative samples of commercially and recreationally important species in control locations upstream of discharge.	an ang g Tan Manang	Commo instanio ⁽⁴⁾ and 1 121
c.	Food Products	а.	Indicator Two representative samples from the principal food pathways grown in each of four major quadrants within 10 km (6.2 mi), if available: At least one root vegetable sample ⁽¹¹⁾ At least one broad leaf vegetable (or vegetation) ⁽¹¹⁾	Annually	Analysis on each Sample.
		b.	Control Two representative samples similar to Indicator samples grown within 15 to 30 km (9.3 to 18.6 mi), if available.		

TABLE 12.5-1 (Continued) RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM TABLE NOTATIONS

- (1) Specific parameters of distance and direction from the centerline of the midpoint of the two units and additional description where pertinent shall be provided for each and every sample location in Table 12.5-1, except for vegetation. For vegetation, due to location variability year to year, the parameters of distance and direction shall be provided in the Annual Environmental Operating Report.
- (2) Far field samples are analyzed when the respective near field sample results are inconsistent with previous measurements and radioactivity is confirmed as having its origin in airborne effluents from the station, or at the discretion of the Radiation Support Director.
- (3) Airborne particulate sample filters shall be analyzed for gross beta radioactivity 24 hours or more after sampling to allow for radon and thoron daughter decay. If gross beta activity in air particulate samples is greater than 10 times the yearly mean of control samples, gamma isotopic analysis shall be performed on the individual samples.
- (4) Gamma isotopic analysis means the identification and quantification of gamma emitting radionuclides that may be attributable to the effluents from the station.
- (5) One or more instruments, such as a pressurized ion chamber, for measuring and recording dose rate continuously may be used in place of, or in addition to, integrating dosimeters. Film badges shall not be used as dosimeters for measuring direct radiation. The 40 locations is not an absolute number. The number of direct radiation monitoring stations may be reduced according to geographical limitations; e.g., If a station is adjacent to a lake, some sectors may be over water thereby reducing the number of dosimeters which could be placed at the indicated distances. The frequency of analysis or readout for TLD systems will depend upon the characteristics of the specific system used and should be selected to obtain optimum dose information with minimal fading.
- (6) Groundwater samples shall be taken when this source is tapped for drinking or irrigation purposes in areas where the hydraulic gradient or recharge properties are suitable for contamination.
- (7) The "downstream" sample shall be taken in an area beyond but near the mixing zone. The "upstream sample" shall be taken at a distance beyond significant influence of the discharge. Upstream samples in an estuary must be taken far enough upstream to be beyond the station influence.
- (8) If milking animals are not found in the designated indicator locations, or if the owners decline to participate in the REMP, all milk sampling may be discontinued.
- (9) Biweekly refers to every two weeks.
- (10) I-131 analysis means the analytical separation and counting procedure are specific for this radionuclide.
- (11) One sample shall consist of a volume/weight of sample large enough to fill contractor specified container.

. ,

.

TABLE 12.5-2

REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES REPORTING LEVELS

	WATER	AIRBORNE PARTICULATE	FISH		MILK	FOOD PRODUCTS
ANALYSIS	(pCi/l)	OR GASES (pCi/m3)	(pCi/kg, wet)	(pCi/l)	(pCi/kg, wet)	
Н-3	20,000 ⁽¹⁾					
Mn-54	1,000		30,000			
Fe-59	400		10,000			
Co-58	1,000		30,000			
Co-60	300		10,000			
Zn-65	300		20,000			
Zr-Nb-95	400		- ,			
I-131	2 ⁽²⁾	0.9		•	3	100
Cs-134	30	10	1,000		60	1,000
Cs-137	50	20	2,000		70	2,000
Ba-La-140	200				300	

(1) (2) For drinking water samples. This is 40 CFR Part 141 value. If no drinking water pathway exists, a value of 30,000 pCi/I may be used.

If no drinking water pathway exists, a value of 20 pCi/I may be used.

TABLE 12.5-3

,

DETECTION CAPABILITIES FOR ENVIRONMENTAL SAMPLE ANALYSIS^(a)

LOWER LIMIT OF DETECTION (LLD)^(b)

ANALYSIS	WATER (pCi/l)	AIRBORNE PARTICULATE OR GASES (pCi/m3)	FISH (pCi/kg, wet)	MILK (pCi/l)	FOOD PRODUCTS (pCi/kg, wet)	SEDIMENT/SOIL (pCi/kg, dry)
Gross Beta	4	0.01				
H-3	2000			·		
Mn-54	15		130			
Fe-59	30		260			
Co-58,60	15		130	5, s		
Zn-65	30		260			
Zr-95	30					
Nb-95	15					
I-131	1 ^c	0.07		1	60	
Cs-134	15	0.05	130	15	60	150
Cs-137	18	0.06	150	18	80	180
Ba-140	60			60		
La-140	15			15		

(a) All peaks identified at the 95% confidence level, shall also be analyzed and reported.

Most restrictive ODCM LLD requirement or technical requirement. The reported minimum detectable concentration (MDC) shall be \leq these values. If no drinking water pathway exists, a value of 15 pCi/l may be used (NUREG 1301/1302) (b)

(c)

12.5.2 Land Use Census

•

_

12.5.2.A.	A Land Use Census shall be conducted and shall identify within a distance of 10 km (6.2 miles) the location in each of the 16 meteorological sectors* of the nearest milk animal, the nearest residence**, and an enumeration of livestock. For dose calculation, a garden will be assumed at the nearest residence.				
	Applicability: At all times.				
	Action:				
	1. With a Land Use Census identifying a location(s) that yields a calculated dose or dose commitment, via the same exposure pathway 20% greater than at a location from which samples are currently being obtained in accordance with Section 12.5.1, add the new location(s) within 30 days to the Radiological Environmental Monitoring Program given in Chapter 11. The sampling location(s), excluding the control location, having the lowest calculated dose or dose commitment(s), via the same exposure pathway, may be deleted from this monitoring program after October 31 of the year in which this Land Use Census was conducted. Submit in the next Annual Radiological Environmenta Operating Report documentation for a change in the ODCM including a revised figure(s) and table(s) for the ODCM reflecting the new location(s) with information supporting the change in sampling locations.				
	*This requirement may be reduced according to geographical limitations; e.g. at a lake site where some sector's will be over water.				
	**The nearest industrial facility shall also be documented if closer than the nearest residence.				
Surveillance Requirements					
12.5.2.B	The Land Use Census shall be conducted during the growing season, between June 1 and October 1, at least once per 12 months using that information that will provide the best results, such as by a door-to-door survey, aerial survey, or by consulting local agriculture authorities. The results of the Land Use Census shall be included in the Annual Radiological Environmental Operating Report.				
Bases	This specification is provided to ensure that changes in the use of greas at and				
12.3.2.0	beyond the SITE BOUNDARY are identified and that modifications to the Radiological Environmental Monitoring Program given in the ODCM are made if required by the results of this census. This census satisfies the requirements of Section IV.B.3 of Appendix I to 10 CFR Part 50. An annual garden census will not be required since the licensee will assume that there is a garden at the nearest residence in each sector for dose calculations.				

•

12.5.3 Interlaboratory Comparison Program

Operability Requirements

12.5.3.A Analyses shall be performed on radioactive materials supplied as part of an Interlaboratory Comparison Program that is traceable to NIST.

Applicability: At all times.

Action:

1. With analyses not being performed as required above, report the corrective actions taken to prevent a recurrence to the Commission in the Annual Radiological Environmental Operating Report.

Surveillance Requirements

12.5.3.8 A summary of the results obtained as part of the above required Interlaboratory Comparison Program shall be included in the Annual Radiological Environmental Operating Report.

		Bases				
	· · .	12.5.3.C	The requirement for participation in an Interlaboratory Comparison Program is			
at je j		?	provided to ensure that independent checks on the precision and accuracy of the			
•	· ··		measurements of radioactive material in environmental samples matrices are			
.•			performed as part of the quality assurance program for environmental monitoring in			
			order to demonstrate that the results are valid for the purposes of Section IV.B.2 of			
			Appendix I to 10 CFR Part 50.			

12.6 REPORTING REQUIREMENTS

12.6.1 Annual Radiological Environmental Operating Report*

Routine Annual Radiological Environmental Operating Report covering the operation of the Units during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and an analysis of trends of the results of the radiological environmental monitoring program for the report period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual, and in 10CFR50, Appendix I, Sections IV.B.2, IV.B.3, and IV.c. It should include, as found appropriate, a comparison of preoperational studies with operational controls or with previous environmental surveillance reports, and an assessment of the observed impacts of the plant operation on the environment.

The Annual Radiological Environmental Operating Report shall include the results of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to the locations specified in the tables and figures in Chapter 11 of the ODCM, as well as summarized and tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted as soon as possible in a supplementary report.

The reports shall also include the following: a summary description of the Radiological Environmental Monitoring Program; legible maps covering all sampling locations keyed to a table giving distances and directions from the midpoint between the two units; reasons for not conducting the Radiological Environmental Monitoring Program as required by Section 12.5.1, and discussion of all deviations from the sampling schedule of Table 12.5-1; a Table of Missed Samples and a Table of Sample Anomalies for all deviations from the sampling schedule of Table 12.5-2 but are not the result of plant effluents; discussion of all analyses in which the LLD required by Table 12.5-3 was not achievable; results of the Land Use Census required by Section 12.5.2; and the results of licensee participation in an Interlaboratory Comparison Program and the corrective actions being taken if the specified program is not being performed as required by Section 12.5.3.

The Annual Radiological Environmental Operating Report shall also include an annual summary of hourly meteorological data collected over the previous year. This annual summary may be either in the form of an hour-by-hour listing on magnetic tape of wind speed, wind direction, atmospheric stability, and precipitation (if measured), or in the form of joint frequency distributions of wind speed, wind direction, and atmospheric stability. In lieu of submission with the Annual Radiological Environmental Operating Report, the licensee has the option of retaining the summary of required meteorological data on site in a file that shall be provided to the NRC upon request.

*A single submittal may be made for a multiple unit station. The submittal should combine sections common to all units at the station.

je v

• .:-

çp -

ſ

:.:

. : : :

12.6.1 <u>Annual Radiological Environmental Operating Report (Continued)</u>

The Annual Radiological Environmental Operating Report shall also include an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the unit or station during the previous calendar year. This report shall also include an assessment of radiation doses to the most likely exposed MEMBER OF THE PUBLIC from reactor releases and other nearby uranium fuel cycle sources, including doses from primary effluent pathways and direct radiation, for the previous calendar year. The assessment of radiation doses shall be performed in accordance with the methodology and parameters in the ODCM and in compliance with 10CFR20 and 40 CFR 190, "Environmental Radiation Protection Standards for Nuclear Power Operation."

12.6.2 Radioactive Effluent Release Report⁴

- a. The radioactive effluent release reports covering the operation of the unit during the previous calendar year of operation shall be submitted in accordance with 10CFR50.36a prior to May 1 of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluent and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and the PROCESS CONTROL PROGRAM and in conformance with 10CFR50.36a and 10CFR50, Appendix I, Section IV.B.1.
- b. The radioactive effluent release reports shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit as outlined in Regulatory Guide 1.21, "Measuring, Evaluating and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," Revision 1, June 1974, with data summarized on a quarterly basis following the format of Appendix B thereof.
- c. The radioactive effluent release report shall include the following information for each type of solid waste shipped offsite during the report period:
 - 1. Container volume,
 - 2. Total curie quantity (specify whether determined by measurement or estimate),
 - 3. Principal radionuclides (specify whether determined by measurement or estimate),
 - 4. Type of waste (e.g., spent resin, compacted dry waste, evaporator bottoms),
 - 5. Type of container (e.g., LSA, Type A, Type B, Large Quantity), and
 - 6. Solidification agent (e.g., cement, urea formaldehyde).

The radioactive effluent release reports shall include unplanned releases from the site to unrestricted areas of radioactive materials in gaseous and liquid effluents on a quarterly basis.

The radioactive effluent release reports shall include any changes to the PROCESS CONTROL PROGRAM (PCP) made during the reporting period.

The radioactive effluent release reports shall include a description of licensee initiated major changes to the radioactive waste treatment systems (liquid, gaseous and solid), as described in Section 12.6.3.)

: · :

⁴A single submittal may be made for a multiple unit station. The submittal should combine those sections that are common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.

12.6 <u>REPORTING REQUIREMENTS</u> (Continued)

12.6.3 Offsite Dose Calculation Manual (ODCM)*

- 12.6.3.1 The ODCM shall contain the methodology and parameters used in the calculation of offsite doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring alarm and trip setpoints, and in the conduct of the radiological environmental monitoring program; and
- 12.6.3.2 The ODCM shall also contain the radioactive effluent controls and radiological environmental monitoring activities, and descriptions of the information that should be included in the Annual Radiological Environmental Operating, and Radioactive Effluent Release Reports required by Technical Specifications 5.6.2 and 5.6.3.
- 12.6.3.3 Licensee-initiated changes to the ODCM:
 - a. Shall be documented and records of reviews performed shall be retained as required by the Quality Assurance (QA) Manual. This documentation shall contain:
 - 1. Sufficient information to support the change(s) together with the appropriate analyses or evaluations justifying the change(s); and

. .

- 2. A determination that the change(s) maintain the level of radioactive effluent control required by 10 CFR 20.1302, 40 CFR Part 190, 10 CFR 50.36a, and 10 CFR Part 50, Appendix I, and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations.
 - a. Shall become effective after approval of the Plant Manager.
 - b. Shall be submitted to the NRC in the form of a complete, legible copy of the entire ODCM as a part of or concurrent with the Radioactive Effluent Release Report for the period of the report in which any change to the ODCM was made. Each change shall be identified by markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (i.e., month and year) the change was implemented.

*The OFFSITE DOSE CALCULATION MANUAL (ODCM) is common to LaSalle Unit 1 and LaSalle Unit 2.

p:\procupgd\approved\odcm\LS12R7.0

÷

217

12.6 <u>REPORTING REQUIREMENTS</u> (Continued)

12.6.4 Major Changes to Radioactive Waste Treatment Systems

- 12.6.4.1 License initiated major changes to the radioactive waste treatment systems (liquid and gaseous):
 - a. Shall be reported to the Commission in the Radioactive Effluent Release Report for the period in which the evaluation was reviewed by the Onsite Review and Investigative Function. The discussion of each change shall contain:
 - 1. A summary of the evaluation that led to the determination that the change could be made in accordance with 10 CFR 50.59;
 - 2. Sufficient detailed information to totally support the reason for the change without benefit or additional or supplemental information;
 - 3. A detailed description of the equipment, components and processes involved and the interfaces with other plant systems;
 - 4. An evaluation of the change which shows the predicted releases of radioactive materials in liquid and gaseous effluents waste that differ from those previously predicted in the license application and
 - amendments thereto;
 - An evaluation of the change which shows the expected maximum exposures to individual in the unrestricted area and to the general population that differ from those previously estimated in the license application and amendments thereto;
 - 6. A comparison of the predicted releases of radioactive materials, in liquid and gaseous effluents, to the actual releases for the period to when the changes are to be made;
 - 7. An estimate of the exposure to plant operating personnel as a result of the change; and
 - 8. Documentation of the fact that the change was reviewed and found acceptable by the Onsite Review and Investigative Function.
 - b. Shall become effective upon review and acceptance by the Onsite Review and Investigative Function.

p:\procupgd\approved\odcm\LS12R7.0

T

12-60