

# **BWR OWNERS' GROUP ALTERNATIVE SOURCE TERMS**

**PRESENTATION FOR  
NRC MEETING**

**April 28, 2004**

**GREG BROADBENT  
(ENERGY-Grand Gulf)**

**Committee Chairman**

BWROG ALTERNATIVE SOURCE TERMS  
**MEETING PURPOSE**

- **Background on BWROG AST Committee.**
- **BWROG plans for BWROG Fuel Gap Fraction Licensing Topical Report (LTR) submittal.**
- **Preliminary review of LTR submittal.**
- **Collect NRC observations.**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST COMMITTEE**

- **Committee Formed: 1995**
- **Committee Membership: 14 (of 20) BWR Utilities**
- **Committee Objective:**  
**Support generic aspects of BWR plant AST NRC application submittals and develop specific generic products necessary for future BWR AST applications.**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST COMMITTEE**

▪ **Past Committee Products:**

- **“Prediction of the Onset of Fission Gas Release from Fuel in Generic BWR”, NEDC-32963, July 1996**
  - Submitted as part of Entergy Grand Gulf-Unit 1 AST Submittal (May 1997)
  - NRC issued acceptance SER, September 9, 1999.
- **“BWROG Generic Source Terms”, NEDC-33043P. June 2001**
  - Defined isotopic inventories for bounding BWR fuel design for radio-nuclide groups in NUREG-1465.
  - Designed to assist BWR plants with NRC AST applications.

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST COMMITTEE**

■ **Current Committee Focus:**

- **Current NRC-approved fuel gap fractions for non-LOCA events [RG 1.183] are contingent on a maximum linear heat generation rate (LHGR) of 6.3kW/ft peak rod average power for rod burnups exceeding 54 GWd/MTU.**
- **Many BWRs are projecting rod power levels exceeding this currently-approved requirement.**
- **The BWROG has recently performed fuel gap fraction analyses based on BWR peak rod power histories that bound anticipated rod powers throughout BWR plant life.**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST COMMITTEE**

■ **Current Committee Focus (Continued):**

- A final LTR is planned for NRC submittal following BWROG approval (~End of May).
- NRC approval will allow BWR licensees to reference the approved LTR/SER and methodology for future AST applications.
- A Review Fee Waiver request is planned on the basis that NRC LTR approval should assist the Staff with a RG 1.183 revision to address high burnup fuel.

*future AST app in event  
licensees expect  
footnote.*

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

- **BWROG Contractors:** NISYS Corporation and KW Consulting were contracted to perform high burnup fuel gap fraction analysis for the BWROG.
- **Analysis Approach:** Identical to the gap fraction approach used to develop the current RG 1.183 values except:

# More Fuel Types


- **BWR Fuel Designs That Span BWR Industry Experience**
  - GE 8x8
  - GE 11/13 (9x9)
  - GE 12/14 (10x10)
  - Framatome ATRIUM-9 (9x9)
  - Framatome ATRIUM-10 (10x10)
  - ABB SVEA-96/96+
  - ABB SVEA-96 Optima2



# Higher Exposure

- **Higher Exposure:**
  - **Current RG 1.183 Gap Fractions  
Applicable up to 62 GWd/MTU**
  - **New Analysis Applicable to:**
    - **65 GWd/MTU for full-length rods**
    - **68 GWd/MTU for partial-length rods**

# More Aggressive Power History



BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Technical Presentation**

- **Objective**
- **Gap Release Fraction Analysis Methodology**
- **Gap Release Fraction Analysis Inputs**
- **Typical Results**
- **Conservatisms**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

**Objective**

- **To extend the gap release fraction analyses described in the NRC High Burnup Environmental Impact Statement (EIS) (NUREG/CR-6703), using the methodology described in the High Burnup EIS, to:**
  - **Higher rod burnups**
  - **Higher rod powers at high burnups**
  - **Complete spectrum of current BWR fuel designs**

BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **High Burnup EIS Methodology**

- **FRAPCON-3 fuel rod performance code**
- **Best estimate fuel rod performance models and nominal fuel rod fabrication parameters**
- **Normalization of the FRAPCON-3 gap release fraction results**
- **Gap release fractions for long-lived isotopes (Kr-85, Cs-134 and Cs-137) given by stable fission gas release fractions**

## **BWROG AST PLANNED LTR SUBMITTAL**

### **Normalization of Gap Release Fraction Results**

- **FRAPCON-3 has two gas release models:**
  - **“Massih” model**
    - **Predicts only stable fission gas release**
    - **Validated against high burnup stable fission gas release data**
  - **ANS-5.4 model**
    - **ANS standard for radioactive isotope gap release fractions**
    - **Predicts stable fission gas release and radioactive isotope gap release fractions**

## **BWROG AST PLANNED LTR SUBMITTAL**

### **Normalization of Gap Release Fraction Results (cont'd)**

- **ANS-5.4 model developed in late 70's, early 80's**
  - **Not validated against high burnup stable fission gas release data**
  - **Over-predicts high burnup stable fission gas release**
- **Compensate for over-prediction by multiplying the gap release fractions by the ratio of the Massih to the ANS-5.4 stable gas release predictions**

BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Additional Code Modifications**

- **At start of project, PNNL personnel responsible for FRAPCON-3 expressed concerns about the FRAPCON-3 implementation of the ANS-5.4 model**
- **KW Consulting review found coding errors dating back to the initial ANS-5.4 model implementation for FRAPCON-2**
  - **Used only the beginning-of-life axial power distribution**
  - **Did not use fuel pellet radial burnup distribution when calculating the gas diffusion coefficients**



BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Additional Code Modifications (cont'd)**

- **Gap release fractions calculated using a FRAPCON-3 code version that corrects these errors**
  - **Code modifications discussed with and evaluated by PNNL personnel**
- **Also modified gap release fraction output to give results in a more easily used format**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

**Gap Release Fraction Analysis Inputs**


- **Fuel rod geometry**
  - **Provided by the fuel vendors**
- **Nominal plant operating conditions (coolant temperature, flow rate, reactor coolant system pressure)**
- **Fuel rod power histories**
  - **Bounding power histories for both rod average and local powers needed to obtain bounding results for the gap release fractions**
  - **Bounding rod average power histories provided by the BWROG**
  - **Bounding local power histories based on the Technical Specification LHGR limits for each fuel design**

BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL

## Bounding Rod Average Power Histories

### Full Length Rods




BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL

## Bounding Rod Average Power Histories


### Part Length Rods



BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL

## Bounding Local Power Histories



BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **FRAPCON Axial Power Shape Inputs**

- **Generated from bounding rod average and local power histories**
- **Cycle from bottom-peaked to mid-peaked to top-peaked through each operating cycle**
- **Eighteen month cycles assumed**
- **Assure that rod powers used in the gap release fraction analysis are bounded by both the bounding rod average and local power limits**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

**Gamma Heating**

- **Bounding power history limits are based on the total heat generation rates**
  - **Include both energy deposited in the fuel and heat generated by gamma heating of the coolant and core structural components**
- **FRAPCON power history inputs are the energy deposited in the fuel**
- **FRAPCON gap release fraction analysis power history inputs adjusted to compensate for gamma heating of the coolant and core structural components**

BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Gadolinia Fuel Rods**

- **Operate at lower power and attain lower burnups than non-gadolinia fuel rods**
- **Recent field observations show that gap release fractions of gadolinia rods are less than half those of near-by non-gadolinia rods**
- **Very little qualification of FRAPCON-3 for gadolinia fuel**
- **Conservatively assumed that the gadolinia fuel rod gap release fractions are the same as the non-gadolinia fuel rod gap release fractions**



BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**


## **Gap Release Fraction Results**

- **Bundle average gap release fractions calculated from Beginning-of-Life to End-of-Life**
  - **Bundle average conservatively assumes all rods in the bundle are at the lead rod burnup**
  - **Contribution of part-length rods are weighted by their relative fuel mass**

BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL


## Gap Release Fraction Results for 10x10 Fuel



BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL


## Gap Release Fraction Results for 10x10 Fuel



BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL


## Gap Release Fraction Results for 10x10 Fuel



BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL


## Gap Release Fraction Results for 10x10 Fuel



BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL

## Gap Release Fraction Results for 10x10 Fuel



BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Gap Release Fraction Results**

- Typical behavior as a function of burnup consistent with the gas diffusion constant used in the gas release models

$$D \propto 100^{Bu_{local}/Bu_{const}} e^{-Q/RT}$$

**D: diffusion constant**

**Bu<sub>local</sub>: local burnup**

**Bu<sub>const</sub>: model constant**

**Q: activation energy**

**R: gas constant**

**T: absolute temperature**

BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Gap Release Fraction Results (cont'd)**

- **Low burnup: rod powers and fuel temperatures approximately constant, gap release fractions increase with increasing burnup**
- **Moderate burnups: rod powers and fuel temperatures decrease, compensating for increasing burnup, and gap release fractions plateau and then decrease**
- **High burnups: peak local burnups exceed the maximum value for the LHGR limits, local powers and fuel temperatures are approximately constant, and gap release fractions plateau or increase**



BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

**Peak Gap Release Fractions, All Rod Designs**

Fuel Design	Gap Release Fractions				
	I-131	Kr-85	Other Nobles	Other Halogens	Alkali Metals
GE 8x8	0.100	0.173	0.097	0.051	0.217
GE11 9x9	0.092	0.167	0.081	0.043	0.217
GE13 9x9	0.093	0.167	0.081	0.043	0.218
ATRIUM-9	0.106	0.146	0.076	0.040	0.220
GE12 10x10	0.062	0.090	0.042	0.022	0.152
GE14 10x10	0.062	0.090	0.042	0.022	0.151
ATRIUM-10	0.083	0.121	0.055	0.029	0.201
SVEA-96/96+	0.080	0.103	0.054	0.029	0.183
SVEA-96 Optima 2	0.086	0.117	0.058	0.031	0.187
<b>RG 1.183, Table 3</b>	<b>0.08</b>	<b>0.10</b>	<b>0.05</b>	<b>0.05</b>	<b>0.12</b>

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

**Changes from Reg. Guide 1.183**

- **Inclusion of precursor effects effectively doubles the Other Noble Gases gap release fractions**
  - **After accounting for precursor effects, gap release fractions for the short-lived isotopes (I-131, Other Noble Gases and Other Halogens) are comparable**
- **Increased gap release fractions for the long-lived isotopes (Kr-85 and Alkali Metals) reflect the use of more aggressive power histories**
- **Comparable gap release fractions for the short-lived isotopes reflect the corrections to the FRAPCON-3 implementation of the ANS-5.4 model**

BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Shutdown Pressures**

- **Calculated at a coolant temperature of 200 °F, reactor coolant pressure of 35 psia and decay heat after 24 hours of cooldown = 0.6% of rod power at operating conditions**
- **End-of-Life rod pressures at shutdown conditions are less than 905 psig**
- **Bounding value for all earlier times in life**

BWROG ALTERNATIVE SOURCE TERMS


# **BWROG AST PLANNED LTR SUBMITTAL**

## **Conservatism in This Analysis**

- **Primary conservatism is the assumption that the lead fuel operates at the bounding rod average and local powers throughout life**
  - **Gap release fraction results are very sensitive to fuel temperatures**
  - **Typically, cores are designed with ~10% margin to the LHGR limits to preclude Licensee Event Reports due to small power transients or small differences between predicted and actual core performance**
- **10% reduction in local power limits gives a 40-50% reduction in the peak gap release fractions**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**


## Conservatism in This Analysis



BWROG ALTERNATIVE SOURCE TERMS

# BWROG AST PLANNED LTR SUBMITTAL

## Conservatism in This Analysis



BWROG ALTERNATIVE SOURCE TERMS

# **BWROG AST PLANNED LTR SUBMITTAL**

## **Additional Conservatism**

- **All rods in the bundle are assumed to operate at the bounding rod average and local power limits**
  - **Typically, peak rod-to-bundle peaking factors are more than 10% at the peak gap fraction burnup**
- **No credit is taken for the reduced gap release fractions of the gadolinia rods**
- **Recent evaluations indicate that the ANS-5.4 model over-predicts I-131 gap release fractions by as much as a factor of 10**
  - **Scaling by the ratio of the Massih to ANS-5.4 stable gas release values only partially compensates for this conservatism of the ANS-5.4 model**

## **BWROG AST PLANNED LTR SUBMITTAL**

### **Additional Conservatism**

- **10x10 analyses use a conservative application of the bounding rod average and local power limit curves**
  - **Due to the axial burnup distribution in the rod, at high burnups the bounding rod average power is greater than that allowed by the local power limit**
  - **At these burnups, the gap release fraction analysis used the rod average power and an unrealistic, but conservative, flat axial power shape**



BWROG ALTERNATIVE SOURCE TERMS

## **BWROG AST PLANNED LTR SUBMITTAL**

- **BWROG intends to request:**
  - **Extension of current RG 1.183 gap fractions to higher BWR burnups and more aggressive power histories**
  - **Approval of this methodology for use with new fuel designs and/or revised design inputs**
- **Benefits:**
  - **Validation of existing RG 1.183 gap fractions**
  - **No requirements for re-analysis**
  - **No increased consequences under 50.59**
    - **No new submittals**

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

- **Current bounding analyses predict slightly higher gap fractions than RG 1.183 Table 3**
- **However, conservatisms in the calculations (previously described) more than bound these small increases based:**

## **BWROG AST PLANNED LTR SUBMITTAL**

- **Iodine-131**
  - 8% per Table 3 of RG 1.183
  - 6.2-10% per BWROG analysis
- **Disposition**
  - 8x8 and ATRIUM-9 fuel are no longer being reloaded and are well past the exposure of peak gap fraction
  - Remaining 9x9 and 10x10 designs are no more than 1% greater than the 8% RG value
    - More than bounded by the conservatisms in the analysis
      - ~40 – 50% margin with 10% lower peak LHGR
      - Another ~40% margin considering rod-to-bundle peaking of 10% or more

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

- **Other Halogens**
  - **5% per Table 3 of RG 1.183**
  - **2.2-5.1% per BWROG analysis**
- **Disposition**
  - **BWROG analysis calculates the same 5% fraction or less**

BWROG ALTERNATIVE SOURCE TERMS

## **BWROG AST PLANNED LTR SUBMITTAL**

- **Kr-85**
  - 10% per RG 1.183
  - 9-17% per BWROG analysis
- **Disposition**
  - **FHA analysis is insensitive to this isotope**
    - Kr-85 contrib. to GGNS FHA Control Dose =  $5E-4\%$
  - **Larger BWROG results are offset by the conservatisms in the analysis**
    - ~40 – 50% margin with 10% lower peak LHGR
    - Another ~40% margin considering rod-to-bundle peaking of 10% or more

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

- **Other Noble Gases**
  - 5% per RG 1.183
  - 4.2-9.7% per BWROG analysis
- **Disposition**
  - **FHA analysis is insensitive to these isotopes**
    - noble gas contrib. to GGNS FHA Control Dose = <2%
  - **Larger BWROG results are offset by the conservatisms in the analysis**
    - ~40 – 50% margin with 10% lower peak LHGR
    - Another ~40% margin considering rod-to-bundle peaking of 10% or more

BWROG ALTERNATIVE SOURCE TERMS  
**BWROG AST PLANNED LTR SUBMITTAL**

- **Alkali Metals**
  - 12% per RG 1.183
  - 15.1-21.7% per BWROG analysis
- **Disposition**
  - **FHA analysis is completely insensitive to particulate isotopes since they are completely scrubbed by the fuel pool water**
    - infinite decontamination factor per RG 1.183, App. B, Section 3

## BWROG ALTERNATIVE SOURCE TERMS

# SUMMARY

- **The BWROG has/is assisting BWR licensees with AST applications.**
- **RG 1.183 is currently limiting for high burnup fuel.**
- **Currently-planned LTR will request NRC review and approval (SER) for extension of current values in Table 3 of RG 1.183 to more aggressive power histories and burnups**
- **To address future fuel types, LTR will request NRC approval of defined methodology for developing non-LOCA fuel isotopic inventories.**