# VIRGINIA ELECTRIC AND POWER COMPANY RICHMOND, VIRGINIA 23261

April 13, 2004

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555-0001 Serial No. 04-207 SPS Lic/JSA R0 Docket Nos. 50-280

50-281

License Nos. DPR-32

**DPR-37** 

#### Gentlemen:

# VIRGINIA ELECTRIC AND POWER COMPANY SURRY POWER STATION UNITS 1 AND 2 MONTHLY OPERATING REPORT

The Monthly Operating Report for Surry Power Station Units 1 and 2 for the month of March 2004 is provided in the attachment.

If you have any questions or require additional information, please contact us.

Very truly yours,

Richard H. Blount, Site Vice President Surry Power Station

Attachment

Commitments made by this letter: None

cc: United States Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center 61 Forsyth Street, SW, Suite 23 T85 Atlanta, Georgia 30303-8931

> Mr. G. J. McCoy NRC Senior Resident Inspector Surry Power Station

IE24

# VIRGINIA ELECTRIC AND POWER COMPANY SURRY POWER STATION MONTHLY OPERATING REPORT REPORT No. 04-03

Approved:

1 Site Vice President Date 4/13/0

# TABLE OF CONTENTS

Section	Page
Operating Data Report - Unit No. 1	3
Operating Data Report - Unit No. 2	4
Unit Shutdowns and Power Reductions - Unit No. 1	5
Unit Shutdowns and Power Reductions - Unit No. 2	6
Average Daily Unit Power Level - Unit No. 1	7
Average Daily Unit Power Level - Unit No. 2	8
Summary of Operating Experience - Unit Nos. 1 and 2	9
Facility Changes That Did Not Require NRC Approval	11
Procedure or Method of Operation Changes That Did Not Require NRC Approval	12
Tests and Experiments That Did Not Require NRC Approval	13
Chemistry Report	14
Fuel Handling - Unit Nos. 1 and 2	15
Description of Periodic Test(s) Which Were Not Completed Within the Time Limits Specified in Technical Specifications	17

# **OPERATING DATA REPORT**

nit 1 :004 6 7.5 8 2 0 ough 7) Since		
6 7.5 8 2 0		
7.5 8 2 0		
8 2 0		
2 0		
0		
ough 7) Since		
	Last Report, Give	Reasons:
his Month	Year-To-Date	Cumulative
		274152.00
		203587.48
	0.00	3774.50
		200788.77
		3736.20
		479908172.70
		157986491.00
		150945901.00
		73.24%
		74.60%
		70.26%
		69.87%
0.00%	0.00%	11.93%
d Duration of	Each):	
	744.00 744.00 0.00 744.00 0.00 851536.70 616715.00 595370.00 100.00% 100.00% 98.79% 101.55% 0.00%	744.00 2184.00 744.00 2184.00 0.00 0.00 744.00 2184.00 0.00 0.00 851536.70 5516249.10 616715.00 1847226.00 595370.00 1783801.00 100.00% 100.00% 100.00% 100.00% 98.79% 100.83% 101.55% 103.65%

# **OPERATING DATA REPORT**

	Complet	et No.: 50-281 Date: 04/01/04 ed By: R. Stief phone: (757) 365-	2486
Unit Name:			
Nameplate Rating (Gross MWe):	847.5	·	
Design Electrical Rating (Net MWe):	788		
Maximum Dependable Capacity (Gross MWe):	847		
Maximum Dependable Capacity (Net MWe):	815		
If Changes Occur in Capacity Ratings (Items Num	ber 3 Through 7) Since	Last Report, Give Re	easons:
Power Level To Which Restricted, If Any (Net MW	e):		
Reasons For Restrictions, If Any:			
	This Month	Year-To-Date	Cumulativ
Hours in Reporting Period	744.00	2184.00	271033.0
Hours Reactor Was Critical	744.00	2184.00	201146.3
Reactor Reserve Shutdown Hours	0.00	0.00	328.1
Hours Generator On-Line	744.00	2184.00	198630.4
Unit Reserve Shutdown Hours	0.00	0.00	0.0
Gross Thermal Energy Generated (MWH)	1890032.30	5554072.60	476200416.4
Gross Electrical Energy Generated (MWH)	633894.00	1858914.00	156837228.0
Net Electrical Energy Generated (MWH)	612584.00	1795672.00	149888508.0
Unit Service Factor	100.00%	100.00%	73.29
Unit Availability Factor	100.00%	100.00%	73.29
Unit Capacity Factor (Using MDC Net)	101.03%	100.88%	70.26
Unit Capacity Factor (Using DER Net)	104.49%	104.34%	70.18
Unit Forced Outage Rate	0.0%	0.00%	9.46
Shutdowns Scheduled Over Next 6 Months (Type,	Date, and Duration of E	ach):	
Type and duration of schedu	led shutdowns are no lo	nger provided.	
[Reference: Letter S/N	00-069, dated February	7, 2000]	
If Shut Down at End of Report Period, Estimated [	provid	ated start-up dates a led. [Reference: Lett lated February 7, 20	er S/N 00-
Unit In Test Status (Prior to Commercial Operation	n):	•	-
·	FORECAST	ACHIEV	ED
		AOTILEV	<u></u>
INITIAL CRITICAL		<b>,</b>	<del></del>
INITIAL ELECTRIC			
COMMERCIAL OPERATI	ION		

## **UNIT SHUTDOWN AND POWER REDUCTION** (EQUAL TO OR GREATER THAN 20%)

REPORT MONTH: March 2004

Docket No.: 50-280 Unit Name: Surry Unit 1 Date: 04/01/04

Completed by: R. Stief

Telephone: (757) 365-2486

Date	(1) Type	Duration Hours	(2) Reason	(3) Method of Shutting Down Rx	LER No.	(4) System Code	(5) Component Code	Cause & Corrective Action to Prevent Recurrence
03/01/04	N/A	0	Α	4	N/A	JA	LIC	Unit 1 experienced a loss of Secondary Drain Level Control resulting in loss of secondary efficiencies and causing unit load reduction to 65.3%

(1) F: Forced S: Scheduled (2) REASON:

Equipment Failure (Explain) Maintenance or Test

1 - Manual

(3) METHOD:

Manual Scram

3 - Automatic Scram 4 - Other (Explain)

Refueling

Regulatory Restriction

Operator Training & Licensing Examination Ε

F -Administrative

G-Operational Error (Explain)

Н

Other (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG 0161)

(5) Exhibit 1 - Same Source

#### **UNIT SHUTDOWN AND POWER REDUCTION** (EQUAL TO OR GREATER THAN 20%)

REPORT MONTH: March 2004

Docket No.: 50-281 Unit Name: Surry Unit 2

Date: 04/01/04 Completed by: R. Stief

Telephone: (757) 365-2486

None during the Reporting Period

(1) F: Forced

REASON:

METHOD:

S: Scheduled

Manual

Equipment Failure (Explain)

2 - Manual Scram

B - Maintenance or TestC - Refueling Refueling

3 - Automatic Scram

Ď-

4 - Other (Explain)

Regulatory Restriction
Operator Training & Licensing Examination
Administrative

G-

Operational Error (Explain)

Other (Explain) Н

(5) Exhibit 1 - Same Source

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG 0161)

#### **AVERAGE DAILY UNIT POWER LEVEL**

Docket No.: 50-280
Unit Name: Surry Unit 1
Date: 04/01/04
Completed by: R. Stief
Telephone: (757) 365-2486

Month: March 2004

Day	Average Daily Power Level (MWe - Net)	Day	Average Daily Power Level (MWe - Net)
1	804	17	826
2	750	18	826
3	590	19	827
4	506	20	827
5	756	21	827
6	807	22	825
7	817	23	825
8	819	24	826
9	818	25	826
10	818	26	825
11	820	27	826
12	809	28	826
13	824	29	826
14	826	30	826
15	826	31	827
16	826		1

## **INSTRUCTIONS**

On this format, list the average daily unit power level in MWe - Net for each day in the reporting month. Compute to the nearest whole megawatt.

#### **AVERAGE DAILY UNIT POWER LEVEL**

Docket No.: 50-281

Unit Name: Surry Unit 2

Date: 04/01/04 Completed by: R. Stief Telephone: (757) 365-2486

March 2004 Монтн:

Day	Average Daily Power Level (MWe - Net)	Day	Average Daily Power Level (MWe - Net)
1	823	17	822
2	823	18	822
3	823	19	822
4	822	20	822
5	820	21	822
6	825	22	822
7	825	23	821
8	825	24	821
9	824	25	821
10	825	26	824
11	823	27	826
12	823	28	828
13	822	29	827
14	822	30	827
15	822	31	827
16	822		

#### **INSTRUCTIONS**

On this format, list the average daily unit power level in MWe - Net for each day in the reporting month. Compute to the nearest whole megawatt.

#### **SUMMARY OF OPERATING EXPERIENCE**

Month/Year: March 2004

The following chronological sequence by unit is a summary of operating experiences for this month that required load reductions or resulted in significant non-load related incidents.

UNIT ONE:		
03/01/04	0000	Unit started the month at 100% / 856 MWe.
03/01/04	1744	Unit power being reduced due to failure of the 1 <sup>st</sup> Point FW Heater High Divert
		Valves. Unit at 100% / 825 MWe.
03/01/04	1812	Stopped ramp at 94% / 770 MWe.
03/02/04	0047	Commenced ramping unit IAW 1-OP-TM-005 to allow removal of condensate
		polisher demineralizer 1-CP-DM-1A. Unit at 94% / 770 MWe.
03/02/04	0102	Stopped ramp at 92% / 750 MWe.
03/03/04	0606	While troubleshooting Network 90 problems, unit experienced a loss of HP/LP
		Heater Drain Pumps (1-SD-P-1A/2A & 2B), automatic bypass of the polisher
		and auto start of the 3 <sup>rd</sup> Condensate Pump. Initiated AP-23.00 for ramp to 75%
		to allow restoration of the Condensate Polishing Building. Unit at 92% / 750 MWe.
03/03/04	0646	Stopped ramp at 72.2% / 559 MWe.
03/03/04	2210	Entered AP-14.01 Rapid Main Condenser Waterbox removal, due to 1A waterbox
		tube rupture.
03/04/04	0018	Commenced ramping unit IAW 1-OP-TM-005 to maintain condenser vacuum.
		Unit at 73% / 505 MWe.
03/04/04	0100	Stopped ramp at 67% / 455 MWe.
03/04/04	1451	Per logs Reactor Power was increased from 67% / 455 MWe to 72% / 560
		MWe to control Tave.
03/05/04	0200	Ramped from 65.3% to 66.1% for temperature control.
03/05/04	0514	Commenced ramp IAW 1-OP-TM-005. Unit at 73% / 590 MWe.
03/05/04	0645	Secured ramp @ 90%.
03/05/04	0745	Commenced ramp to 100%.
03/05/04	0900	Unit at 100% / 850 MWe.
03/06/04	1126	Commenced ramp from 99% in prep for removing moisture separater reheater
		1-MS-E-1A/B from service due to suspected flow blockage.
03/06/04	1147	Stopped ramp at 94.5% / 813 MWe.
03/06/04	1341	Commenced ramp to 100%. Unit at 92.1% / 790 MWe.
03/06/04	1400	Ramp stopped at 96.5% / 821 MWe due to deviation between delta T and impulse pressure.
		Engineering evaluating.
03/06/04	2342	Commenced ramp to 100%. Unit at 97% / 822 MWe.
03/07/04	0110	Stopped ramp at 99.3% to adjust NI's.

03/07/04	0145	Recommenced ramp.
03/07/04	0230	Unit at 100% / 849 MWe.
03/12/04	1400	Commenced rampdown in preparation for returning 1-MS-E-1A & 1B to service.
		Unit at 100% / 847 MWe.
03/12/04	1440	Stopped ramp at 96% / 815 MWe.
03/13/04	0000	Unit at 98% / 835 MWe, 1-MS-E-1A & 1B are being returned to service.
03/13/04	0146	1-MS-MOV's 100A & 100B full open. Unit at 98% / 839 MWe.
03/13/04	0255	Commenced ramp from 98% to 100% IAW 1-OP-TM-005. Unit at 98% / 839 MWe.
03/13/04	0430	Stopped ramp at 100% / 855 MWe.
03/31/04	2400	Unit finished the month at 100% / 854 MWe.
UNIT TWO:		
03/01/04	0000	Unit started the month at 100% / 852 MWe.

Unit finished the month at 100% / 856 MWe.

03/31/04

2400

# FACILITY CHANGES THAT DID NOT REQUIRE NRC APPROVAL

Month/Year: March 2004

None during the Reporting Period.

Surry Monthly Operating Report No. 04-03 Page 12 of 17

# PROCEDURE OR METHOD OF OPERATION CHANGES THAT DID NOT REQUIRE NRC APPROVAL

Month/Year: March 2004

None during the Reporting Period

# TESTS AND EXPERIMENTS THAT DID NOT REQUIRE NRC APPROVAL

MONTH/YEAR: March 2004

None during the Reporting Period

# **CHEMISTRY REPORT**

Month/Year: March 2004

		Unit No. 1	····	Unit No. 2			
Primary Coolant Analysis	Max.	Min.	Avg.	Max.	Min.	Avg.	
Gross Radioactivity, μCi/ml	3.86E-1	1.56E-1	2.71E-1	3.56E-1	1.72E-1	2.48E-1	
Suspended Solids, ppm	≤ 0.010	≤ 0.010	≤ 0.010	≤ 0.010	≤ 0.010	≤ 0.010	
Gross Tritium, μCi/ml	1.03E+0	8.30E-1	9.06E-1	1.14E+0	9.35E-1	1.03E+0	
ι <sup>131</sup> , μCi/ml	2.59E-4	8.24E-5	1.54E-4	1.05E-4	6.16E-5	8.42E-5	
1131/1133	0.11	0.04	0.07	0.37	0.21	0.27	
Hydrogen, cc/kg	35	30	31.8	38.7	34.8	37.2	
Lithium, ppm	2.32	2.07	2.2	2.34	2.12	2.24	
Boron - 10, ppm*	170	137	152	254	242	249	
Oxygen, (DO), ppm	≤ 0.005	≤ 0.005	≤ 0.005	≤ 0.005	≤ 0.005	≤ 0.005	
Chloride, ppm	0.004	0.003	0.004	0.008	0.007	0.007	
pH @ 25 degree Celsius	6.9	6.68	6.79	6.56	6.29	6.44	

Boron -  $10 = \text{Total Boron } \times 0.196$ 

Comments:

•

Unit 1: 100% power Unit 2: 100% power

# FUEL HANDLING UNITS 1 & 2

MONTH/YEAR: March 2004

New Fuel Shipment or Cask No.	Date Stored or Received	Number of Assemblies per Shipment	Assembly Number	ANSI Number	Initial Enrichment	New or Spent Fuel Shipping Cask Activity
Spent Fuel						
Cask TN-32-39	03/24/04	32	0.J2	LM0UY8	3.8072	N/A
			0.15	LMOUYB	3.8068	
			oK1	LM0YK9	3.8179	
			0K2	LMOYKA	3.8144	
			0K3 <sup>-</sup>	LMOYKB	3.8189	
			oK4	LMOYKC	3.8182	
			0K5	LMOYKD	3.8190	
			0K6	LMOYKE	3.8208	
			0K7	LMOYKF	3.8184	
			<b>1J4</b>	LMOUYL	3.8081	
			1K0	LMÒYKJ	3.8188	
			1Ŵ0	LM0X2P	3.8073	
			1W4	LM0X2T	3.8064	
			1W5	LM0X2U	3.8090	
			1W7	LM0X2W	3.8036	
			1W8	LM0X2X	3.8004	
			2E4	LMODFP	3.5974	
			2E5	LMODEN	3.6034	

### FUEL HANDLING UNITS 1 & 2

MONTH/YEAR: March 2004

New Fuel Shipment or Cask No.	Date Stored or Received	Number of Assemblies per Shipment	Assembly Number	ANSI Number	Initial Enrichment	New or Spent Fuel Shipping Cask Activity
			<b>2J4</b>	LMOUYW	3.8069	
			2J6	LMOUYY	3.8058	
			. 2J7	LMOUYZ	3.8066	
			<b>2</b> J8	LM0UZ0	3.8144	
			2W2	LM0X31	3.8069	
			3E0	LMODEX	3.5972	
			3E4	LMODFF	3.6051	·
			4E7	LM0DE9	3.6073	
			4E8	LMODEV	3.6002	
			<b>4E</b> 9	LMODES	3.6028	
			<b>4J0</b>	LMOUZC	4.0092	
			5E0	LMODEB	3.5999	
			5R7	LM0C21	3.5902	
			6R0	LM0C2Q	3.5911	

# DESCRIPTION OF PERIODIC TEST(S) WHICH WERE NOT COMPLETED WITHIN THE TIME LIMITS SPECIFIED IN TECHNICAL SPECIFICATIONS

MONTH/YEAR: March 2004

None during the Reporting Period