## OFFICE OF ENFORCEMENT NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: PSEG Nuclear, LLC (EA-04-086)

Hope Creek Nuclear Generating Station

Docket Nos 50-354

Subject: ISSUANCE OF FINAL SIGNIFICANCE DETERMINATION AND NOTICE OF

VIOLATION

This is to inform the Commission that a White Significance Determination Process (SDP) finding and associated Notice of Violation will be issued on or around May 10, 2004, to PSEG Nuclear, LLC, as a result of inspections at the Hope Creek Nuclear Generating Station. This White finding, an issue with low to moderate importance to safety that may require additional NRC inspections, involved an inadequacy in a portion of a station maintenance procedure, as well as the failure to adhere to another procedure, which contributed to the A station service water system traveling screen failure that occurred on July 1, 2003. The failure to provide appropriate quantitative acceptance criteria to install the traveling screen head-shaft key and the failure to properly tension the traveling screen carrier basket chains were identified as examples of a violation of 10 CFR 50, Appendix B, Criterion V.

It should be noted that the licensee has not been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Final Significance Determination May 10, 2004
Telephone Notification of Licensee May 10, 2004

The State of New Jersey will be notified.

Contacts: Jennifer Dixon-Herrity, 415-1080 Chris Nolan, 415-3360

## Distribution

OWFN	OWFN	TWFN	Regional Offices
Chairman	EDO	OCFO	RI RIV
Comm	DEDR	OP CTR	RII
Comm	DEDMRS	NMSS	RIII
Comm	OE	OCIO	
Comm	OGC	OIG	MAIL
SECY	NRR	RES	PUBLIC
OCA	NSIR	ACRS	
PA	OI		
IP	STP		

G:\OECASES\ENs 2004\EN-04-029.HopeCreek.04086.jld.wpd

OE:ES OE:SC JDixon-Herrity CNolan 05/05/04 05/05/04

ML041260463

PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL VERIFICATION THAT LICENSEE HAS RECEIVED ACTION