

*Annual
Environmental
and
Effluent Release
Report*



*Perry Nuclear Power Plant
2003*

2003

**ANNUAL ENVIRONMENTAL
AND
EFFLUENT RELEASE
REPORT**

**for the
Perry Nuclear Power Plant**

**PREPARED BY:
RADWASTE, ENVIRONMENTAL, AND CHEMISTRY SECTION
PERRY NUCLEAR POWER PLANT
FIRSTENERGY NUCLEAR OPERATING COMPANY
PERRY, OHIO
MARCH, 2004**

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

TABLE OF CONTENTS

EXECUTIVE SUMMARY	1
Radioactive Effluent Releases	1
Radiological Environmental Monitoring.....	2
Land Use Census	3
Clam/Mussel Monitoring.....	3
Herbicide Use	3
Special Reports.....	3
Ohio Department of Natural Resources Survey	4
INTRODUCTION.....	4
Radiation Fundamentals	4
Radiation and Radioactivity	5
Units of Measure	5
Lower Limit of Detection	6
Background Radiation	7
RADIOACTIVE EFFLUENT RELEASES	8
Introduction	8
Regulatory Limits	8
Release Summary	10
Meteorological Data	16
Dose Assessment.....	16
Abnormal Releases	18
Non-Compliances	19
Offsite Dose Calculation Manual Changes	19
Process Control Program Changes	20
RADIOLOGICAL ENVIRONMENTAL MONITORING.....	21
Introduction	21
Sampling Locations.....	21
Sample Analysis	26
2003 Sampling Program.....	27
Inter-Laboratory Cross-Check Comparison Program.....	35
Land Use Census	36
CLAM/MUSSEL MONITORING	39
Introduction	39
Corbicula Program	39
Dreissena Program	40
Conclusions	41
HERBICIDE APPLICATIONS	42
SPECIAL REPORTS	44
Non-Compliances	44
Unreviewed Environmental Questions.....	44
Non-Routine Reports.....	44
Ohio Department of Natural Resources Survey	45
Appendix A, 2003 Inter-Laboratory Cross Check Comparison Program Results.....	46
Appendix B, 2003 REMP Data Summary Reports	47
Appendix C, 2003 REMP Detailed Data Reports.....	48
Appendix D, 2003 Abnormal Gaseous Release Meteorological Data	49

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Appendix E, 2002 Corrections to AEERR.....	50
--	----

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

EXECUTIVE SUMMARY

The Annual Environmental and Effluent Release Report (AEERR) details the results of environmental and effluent monitoring programs conducted at the Perry Nuclear Power Plant (PNPP) from January 01 through December 31, 2003. This report meets all of the requirements in PNPP Technical Specifications, the Environmental Protection Plan (EPP), and Regulatory Guide 1.21. It incorporates the requirements of the Annual Radioactive Effluent Release Report (ARERR), the Annual Radiological Environmental Operating Report (AREOR) and the Annual Environmental Operating Report (AEOR). Report topics include radioactive effluent releases, radiological environmental monitoring, land use census, clam/mussel monitoring, herbicide use, and special reports. The results of the environmental and effluent programs, for 2003, indicate that the operations of the Perry Nuclear Power Plant did not result in any significant environmental impact.

RADIOACTIVE EFFLUENT RELEASES

During the normal operation of a nuclear power plant, small quantities of radioactivity may be released to the environment in liquid and gaseous effluents. Radioactive material may also be released as solid waste. PNPP maintains a comprehensive program to control and monitor the release of radioactive materials from the site in accordance with Nuclear Regulatory Commission (NRC) release regulations.

The dose to the general public from the plant's liquid and gaseous effluents was below the applicable regulatory limits. The calculated hypothetical maximum individual whole body dose potentially received by an individual resulting from PNPP liquid effluents was $1.68\text{E-}03$ mrem (0.056 % of the applicable limit). The calculated hypothetical maximum individual whole body dose potentially received by an individual resulting from PNPP gaseous effluents was $7.46\text{E-}03$ mrem (0.15% of the applicable limit). The summation of the hypothetical maximum individual dose from effluents in 2003 is equivalent to < 0.1 % of the total dose an individual living in the PNPP area receives from all sources of radiation.

Shipments of solid waste consisted of waste generated during water treatment, radioactive material generated during normal daily operations and maintenance, and irradiated components. PNPP complied with applicable regulations governing radioactive shipments in 2003, making shipments of solid radioactive waste to a licensed burial site.

During 2003, there were two (2) Offsite Dose Calculation Manual (ODCM) non-compliance conditions and one (1) abnormal release:

- ◆ The Radwaste High-Flow Discharge Header Flow Monitor, 0G50-N445, was declared inoperable on 12/2/02. On 1/2/03 the monitor was inoperable in excess of 30 days. The monitor was inoperable due to a broken tooth on the tractor gear for the recorder and other parts issues. The monitor then remained inoperable until the correct parts could be obtained. During the period of inoperable status, the ODCM requirements specified for an inoperable Radwaste High-Flow Discharge Header Flow Monitor (Table 3.3.7.9-1, Action 112) were performed. An Engineering Change Request was submitted to resolve the monitor's obsolete parts issues. Work was completed on 3/14/03, and 0G50-N445 was declared operable on 3/14/03 at 0930.
- ◆ The Radwaste High-Flow Discharge Header Flow Monitor, 0G50-N445, was declared inoperable on 06/04/03. On 7/5/04, the monitor was inoperable in excess of 30 days. The monitor was inoperable due to erratic readings. The monitor repairs were delayed due to inability to find parts for an obsolete monitor. Therefore, Engineering had to locate a recorder with similar functionality for installation. Once the correct type of recorder was located, the new recorder was delivered to the plant and installed in the system. During the period of inoperable status, the ODCM requirements specified for an inoperable Radwaste High-Flow Discharge

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Header Flow Monitor (Table 3.3.7.9-1; Action 112) were performed. Work was completed on 07/26/03, and 0G50-N445 was declared operable on 07/26/03 at 1055.

- ◆ During testing of a Feedwater valve (N27-F599A) on 4/28/03 at 1030, an abnormal release to the environment occurred. Testing resulted in a Feedwater line becoming pressurized with air and subsequently being discharged into the Auxiliary Steam Tunnel. The Auxiliary Steam Tunnel doors were open at the time of the system depressurization allowing airborne contamination to escape to the outside environment. Since the Turbine Building and Heater Bay ventilation systems were secured for outage work, there was not a negative pressure in the Steam Tunnel. The dose contributions from this event (refer to Table 13) demonstrated minimal dose consequence to the general public. Refer to Appendix D for meteorological data.

RADIOLOGICAL ENVIRONMENTAL MONITORING

The Radiological Environmental Monitoring Program (REMP) was established in 1981 to monitor the radiological conditions in the environment around PNPP. The REMP is conducted in accordance with PNPP Technical Specifications and the Offsite Dose Calculation Manual (ODCM). This program includes the collection and analysis of environmental samples and evaluation of results.

The REMP was established at PNPP six (6) years before the plant became operational. This pre-operational program was designed to provide data on background radiation and radioactivity normally present in the area. PNPP has continued to monitor the environment during plant operation by collecting and analyzing samples of air, precipitation, milk, fish, produce, water and sediment, as well as by measuring radiation directly.

There were over 3000 radioactivity analyses performed on the 1263 radiological environmental samples collected in 2003. The results of the REMP indicate the adequacy of the control of the release of radioactivity in the effluents from PNPP. These results also demonstrate that PNPP complies with applicable federal regulations. The REMP results are divided into four sections: atmospheric monitoring, terrestrial monitoring, aquatic monitoring, and direct radiation monitoring.

Samples of air were collected to monitor the radioactivity in the atmosphere. The 2003 results were similar to those observed for the pre-operational and operational programs from prior years. Only natural background environmental radioactivity was detected.

Terrestrial monitoring included the analysis of milk, produce, and vegetation. The PNPP ODCM does not require vegetation or soil samples to be included in the monitoring program. The results of the sample analyses in 2003 indicated concentrations of radioactivity similar to that found in previous years. Analyses of other terrestrial samples also detected concentrations of natural radioactivity similar to those observed in previous years, and indicated no build-up of radioactivity attributable to the operation of PNPP.

Aquatic monitoring included the collection and analyses of water, fish, and shoreline sediments. The 2003 analytical results for water and fish samples showed normal background radionuclide concentrations. The results of sediment sample analyses indicated that the annual average cesium radioactivity was similar to previous years for the control location. Cesium-137 activity was detected in six (6) of the fourteen (14) samples collected. The average cesium-137 radioactivity for all locations was 565.90 pCi/kg and was within the maximum value of 864 pCi/kg established in 1981.

In 1999, a sediment sample of the northwest drain impoundment (sampling location #64) was analyzed to contain 62 pCi/kg of cobalt-60. During 2003, enhanced monitoring activities continued within the boundaries of the impoundment. The cobalt-60 remained centered within the organic material located at the top of the spillway, with little or no activity found farther upstream. Sample

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

analyses continue to identify cobalt-60 levels similar to those found in previous years. Refer to Tables 17 and 18 for detailed sample results.

Direct radiation measurements showed no change from previous years. The indicator locations averaged 67.88 mrem/year and control locations averaged 73.59 mrem/year. In 2003, radiation dose in the area of PNPP was similar to the radiation dose measured at locations greater than ten (10) miles away from the Plant.

Based on these results, during 2003, the operation of the PNPP resulted in no significant increase in the radionuclide concentrations observed in the environment.

LAND USE CENSUS

In order to estimate radiation dose attributable to the operation of PNPP, the potential pathways through which public exposure can occur must be known. To identify these exposure pathways, an Annual Land Use Census is performed as part of the REMP. During the census, PNPP personnel travel every public road within a five (5) mile radius of the plant to locate key radiological exposure pathways. These key pathways include the nearest resident, garden, and milk animal in each of the sixteen meteorological sectors. The information obtained from the census is entered into a computer program, which is used to assess the hypothetical dose to members of the public. In recent years, however, it has been noted that tracts of land once used for farming are now being developed as mini industrial parks and residential housing tracts. This is reflected in the loss of available milking animals within a five mile radius of PNPP to support the Radiological Environmental Monitoring Program (REMP). For 2003, the predominant land use within the census area continues to be rural/agricultural.

CLAM/MUSSEL MONITORING

Clam and mussel shells can clog plant piping and components that use water from Lake Erie. For this reason, sampling for clams and mussels has been conducted in Lake Erie in the vicinity of PNPP since 1971. The monitoring is specifically for *Corbicula* (Asiatic clams), since their introduction into the Great Lakes, in 1981, and for *Dreissena* (zebra mussels), since their discovery in Lake Erie, in 1989. Since no *Corbicula* have ever been found at PNPP, routine *Corbicula* monitoring will provide early detection capability, when this pest species arrives at PNPP. The *Dreissena* program includes both monitoring and control and is directed at minimizing the mussel's impact on plant operation. As in past years, this program has successfully prevented *Dreissena* from causing any operational problems at PNPP.

HERBICIDE USE

The use of herbicides on the PNPP site is monitored to ensure compliance with Ohio Environmental Protection Agency (OEPA) requirements and to protect the site's natural areas. Based on the results of on-site herbicide applications, and weekly general site inspections, herbicide use has not had a negative impact on the environment around the plant.

SPECIAL REPORTS

Significant environmental events (for example, spills, releases), noncompliance with environmental regulations [e.g., Ohio Environmental Protection Agency (OEPA) discharge limits], and changes in plant design or operation that affect the environment are reported to regulatory agencies as they occur. These special reports are also summarized in this report.

On January 29, 2003, the OEPA was notified that construction was completed on the dechlorination system upgrade and the system would now be using sodium bisulfate as the dechlorination chemical. This notification was made in accordance with the National Pollutant Discharge Elimination System (NPDES) Permit.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

On June 30, 2003, the OEPA was notified that the Preliminary Effluent Limit (PEL) for copper was exceeded during the month of June 2003. The increase in copper at the plant effluent coincided with a large increase of copper levels entering the plant from Lake Erie. This notification was made in accordance with the National Pollutant Discharge Elimination System (NPDES) Permit.

On September 30, 2003, the OEPA was notified of maintenance that would be performed on the neutralization basins. This notification was made in accordance with the National Pollutant Discharge Elimination System (NPDES) Permit.

OHIO DEPARTMENT OF NATURAL RESOURCES SURVEY

On February 21, 2003, the Ohio Department of Natural Resources (ODNR), Division of Wildlife contacted Perry requesting permission to access areas where spotted turtles had been previously documented. Perry granted the ODNR representative access, and the environmental staff participated in the surveys of the area. Although no spotted turtles were found in the previously recorded area, this was attributed to the area having been overrun by the *Phragmites* sp. The ODNR representative did state that the extensive wooded wetlands on the property offer excellent habitat as demonstrated by the observations of other turtles, salamanders and frogs. Later in the season, the ODNR representative discovered an open canopy of fens further south on the property. This area has yet to be impacted by *Phragmites* sp. and is considered a prime habitat for Spotted Turtles. Due to discovering this area late in the season, the ODNR representative hopes to return in 2004 to survey this area.

INTRODUCTION

Nuclear energy provides an alternative energy source, which is readily available and has very limited impact upon the environment. To more fully understand nuclear energy as a source of generating electricity, one must understand basic radiation concepts and its occurrence in nature.

RADIATION FUNDAMENTALS

Atoms are the basic building blocks of all matter. Simply described, atoms are made up of positively and negatively charged particles, and particles which are neutral. These particles are called protons, electrons, and neutrons, respectively. The relatively large protons and neutrons are packed together in the center of the atom called the nucleus. Orbiting around the nucleus are one or more smaller electrons. In an electrically neutral atom, the positively charged protons in the nucleus balance the negatively charged electrons. Due to their dissimilar charges, the protons and electrons have a strong attraction for each other, which helps hold the atom together. Other attractive forces between the protons and neutrons keep the densely packed protons from repelling each other, and preventing the nucleus from breaking apart.

Atoms with the same number of protons in their nuclei make up an element. The number of neutrons in the nuclei of an element may vary. Atoms with the same number of protons but different numbers of neutrons are called isotopes. All isotopes of the same element have the same chemical properties and many are stable or non-radioactive. An unstable or radioactive isotope of an element is called a radioisotope, or radionuclide. Radionuclides contain an excess amount of energy in the nucleus, which is usually due to an excess number of neutrons.

Radioactive atoms attempt to reach a stable, non-radioactive state through a process known as radioactive decay. Radioactive decay is the release of energy from an atom's nucleus through the emission of radiation. Radionuclides vary greatly in the frequency with which their atoms release radiation. The length of time an atom remains radioactive is defined in terms of its half-life. Half-life is defined as the time required for a radioactive substance to lose half its activity through the process of radioactive decay. Half-lives vary from millionths of a second to millions of years.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

RADIATION AND RADIOACTIVITY

Radioactive decay is a process in which the nucleus of an unstable atom becomes more stable by spontaneously emitting energy. Radiation refers to the energy that is released when radioactive decay occurs within the nucleus. This section includes a discussion on the three (3) primary forms of radiation produced by radioactive decay.

Alpha Particles

Alpha particles consist of two protons and two neutrons and have a positive charge. Because of their charge and large size, alpha particles do not travel very far when released (less than 4 inches, in air). They are unable to penetrate any solid material, such as paper or skin, to any significant depth. However, if alpha particles are released inside the body, they can damage the soft internal tissues because they deposit all their energy in a small area.

Beta Particles

Beta particles are essentially free electrons, which usually carry a negative electrical charge. They are much smaller than alpha particles and travel at nearly the speed of light. Thus they can travel for longer distances than alpha particles. External beta radiation primarily affects the skin. Because of their electrical charge, paper, plastic or thin metals can stop beta particles.

Gamma Rays

Gamma rays are bundles of electromagnetic energy, called photons, which behave as though they were particles. They are similar to visible light, but of a much higher energy. Gamma rays can travel long distances in air and are often released during radioactive decay, along with alpha and beta particles. Potassium-40 is an example of a naturally occurring radionuclide found in all humans that decays by emitting a gamma ray.

Interaction with Matter

When radiation interacts with other materials, it affects the atoms of those materials principally by knocking the negatively charged electrons out of orbit. This causes an atom to lose its electrical neutrality and become positively charged. An atom that is charged, either positively or negatively, is called an ion and the radiation is called ionizing radiation.

UNITS OF MEASURE

Some of the units of measure used in this report require explanation.

Activity

Activity is the number of atoms in a material that decay per unit of time. Each time an atom decays, radiation is emitted. The curie (Ci) is the unit used to describe the activity of a material and indicates the rate at which the atoms are decaying. One curie of activity indicates the decay of 37 billion atoms per second. Smaller units of the curie are often used in this report. Two common units are the microcurie (μCi), one millionth of a curie, and the picocurie (pCi), one trillionth of a curie. The mass, or weight, of radioactive material, which would result in one (1) curie of activity, depends on the disintegration rate. For example, one gram of radium-226 is equivalent to one (1) curie of activity. It would require about 1.5 million grams of natural uranium, however, to equal one (1) curie.

Dose

Biological damage due to alpha, beta, and gamma radiation may result from the ionization caused by these types of radiation. Some types of radiation, especially alpha particles, which causes dense local ionization, can result in much more biological damage for the same energy imparted than does

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

gamma or beta radiation. Therefore, a quality factor must be applied to account for the different ionizing capabilities of various types of ionizing radiation. When the quality factor is multiplied by the absorbed dose (as measured in rads), the result is the dose equivalent, which is an estimate of the possible biological damage resulting from exposure to any type of ionizing radiation. The dose equivalent is measured in terms of the Roentgen Equivalent Man (rem). When discussing environmental radiation effects, the rem is a large unit. Therefore, a smaller unit, the millirem (mrem) is often used. One mrem is equivalent to 1/1000 of a rem.

LOWER LIMIT OF DETECTION

Sample results are often reported as below the Lower Limit of Detection (LLD). The LLD for an analysis is the smallest amount of radioactive material that will show a positive result for which there can be a 95% confidence that radioactivity is present. This statistical parameter is used as a measure of the sensitivity of a sample analysis. When a measurement is reported as less than the LLD (<LLD), it means that no radioactivity was detected. Had radioactivity been present at (or above) the stated LLD value, it statistically would have been detected. The NRC has established LLD values for environmental and effluent sample analyses.


This Space Intentionally Left Blank

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

BACKGROUND RADIATION

Background radiation is a natural part of nature. Natural background radioactive decay occurs in the soil, water, air, and space. Common sources of radiation that contribute to the natural background radiation includes: the decay of radioactive elements in the earth's crust, a steady stream of high-energy particles from space (called cosmic radiation), naturally-occurring radioactive isotopes in the human body like potassium-40, the decay of radioisotopes used in medical procedures, man-made phosphate fertilizers (phosphates and uranium are often found together in nature), fallout from nuclear weapons testing, and even household items like smoke detectors. In the United States, a person's average annual exposure from background radiation is 360 mrem, and is due to the sources shown in Figure 1 [Source: National Council on Radiation Protection and Measurements].

Figure 1: Sources of Background Radiation



Many radionuclides are present in the environment due to sources such as cosmic radiation and fallout from nuclear weapons testing. These radionuclides are expected to be present in many of the environmental samples collected in the vicinity of PNPP. Some of the radionuclides normally present include:

- ◆ Beryllium-7, present as a result of the interaction of cosmic radiation with the upper atmosphere,
- ◆ Potassium-40, a naturally occurring radionuclide normally found in humans and throughout the environment, and
- ◆ Radionuclides from nuclear weapons testing fallout, including tritium and cesium-137. These radionuclides may also be released in minute amounts from nuclear facilities.

Beryllium-7 and potassium-40 are especially common in REMP samples. Since they are naturally occurring and are expected to be present, positive results for these radionuclides are not discussed in the section for the 2003 Sampling Program results. These radionuclides are included; however, in Appendix A, 2003 Inter-Laboratory Cross Check Comparison Program Results.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

RADIOACTIVE EFFLUENT RELEASES

INTRODUCTION

The source of radioactive material in a nuclear power plant is the generation of fission products (e.g., noble gas, iodine, and particulate) or neutron activation of water and corrosion products (e.g., tritium and cobalt). The majority of the fission products generated remain within the nuclear fuel pellet and fuel cladding. Most fission products that escape from the fuel cladding, as well as the majority of the activated corrosion products, are removed by plant processing equipment.

During the normal operation of a nuclear power plant, small amounts of radioactive material are released in the form of solids, liquids, and gases. PNPP was designed, and is operated in such a manner as to control and monitor these effluent releases. Effluents are controlled to ensure any radioactivity released to the environment is minimal and within regulatory limits. Effluent release programs include the operation of monitoring systems, in-plant sampling and analysis, quality assurance, and detailed procedures covering all aspects of effluent monitoring.

The liquid and gaseous radioactive waste treatment systems at PNPP are designed to collect and process these wastes in order to remove most of the radioactivity. Effluent monitoring systems are used to provide continuous indication of the radioactivity present and are sensitive enough to measure several orders of magnitude lower than the applicable release limits. This monitoring equipment is equipped with alarms and indicators in the plant control room. The alarms are set to provide warnings to alert plant operators when radioactivity levels reach a small fraction of actual limits. The waste streams are sampled and analyzed to identify and quantify the radionuclides being released to the environment.

Gaseous effluent release data is coupled with on-site meteorological data in order to calculate the dose to the general public. Devices are maintained at various locations around PNPP to constantly sample the air in the surrounding environment. Frequent samples of other environmental media are also taken to determine if any radioactive material deposition has occurred. The Radiological Environmental Monitoring Program (REMP) is described in detail in the next section.

Generation of solid waste is carefully monitored to identify opportunities for minimization. Limiting the amount of material taken into the plant, sorting material as radioactive or non-radioactive, shredding and compacting, or incinerating waste once it is identified help to lower the volume of radioactive solid waste generated. Solid waste is shipped to a licensed burial site.

REGULATORY LIMITS

The Nuclear Regulatory Commission has established limits for liquid and gaseous effluents that comply with:

- Title 10 of the Code of Federal Regulations, Part 20 (Standards for Protection Against Radiation) [10CFR20], Appendix B;
- Title 10 of the Code of Federal Regulations, Part 50 (Domestic Licensing of Production and Utilization Facilities) [10CFR50], Appendix I; and
- Title 40 of the Code of Federal Regulations, Part 190 (Environmental Radiation Protection Standards for Nuclear Power Plants) [40CFR190].

These limits were incorporated into the PNPP Technical Specifications, and subsequently into the PNPP Offsite Dose Calculation Manual (ODCM). The ODCM prescribes the maximum doses and dose rates due to radioactive effluents resulting from the operation of PNPP. These limits are defined in several ways to limit the over-all impact on persons living near the plant. Since there are

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

no other fuel sources near the PNPP, the 40CFR190 limits, which are described below, were not exceeded in 2003.

The 40CFR190 limit for total direct-radiation dose is 25 mrem. For 2003, the total whole body dose to a member of the general public, considering all sectors, was 5.4E-01 mrem. This value was determined by summing the annual whole body doses from liquid and gaseous radioactive effluents, the annual gaseous and liquid organ dose (refer to Table 8) and the maximum, direct-radiation dose. Since the direct radiation dose, as determined by TLD, was indistinguishable from natural background (refer to Figure 8), a value of zero was used for the calculation.

Liquid Effluents

The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the concentrations specified in 10CFR20, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases, as required by the ODCM. For dissolved or entrained noble gases, the concentration shall be limited to 2.0E-04 $\mu\text{Ci/mL}$ of total activity. These values are the maximum effluent concentrations.

The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released to unrestricted areas shall be limited to the following:

During any calendar quarter:

- Less than or equal to 1.5 mrem to the whole body, and
- Less than or equal to 5 mrem to any organ.

During any calendar year:

- Less than or equal to 3 mrem to the whole body, and
- Less than or equal to 10 mrem to any organ.

Gaseous Effluents

Dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the site boundary shall be limited to the following:

Noble gases:

- Less than or equal to 500 mrem per year to the whole body, and
- Less than or equal to 3000 mrem per year to the skin.

Iodine-131, Iodine-133, Tritium, and all radionuclides in particulate form with half lives greater than eight days:

- Less than or equal to 1500 mrem per year to any organ

Air dose due to noble gases to areas at, and beyond the site boundary, shall be limited to the following:

During any calendar quarter:

- Less than or equal to 5 mrad for gamma radiation, and
- Less than or equal to 10 mrad for beta radiation.

During any calendar year:

- Less than or equal to 10 mrad for gamma radiation, and
- Less than or equal to 20 mrad for beta radiation.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Dose to a member of the public from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives greater than eight days in gaseous effluents released to areas at and beyond the site boundary shall be limited to the following:

Less than or equal to 7.5 mrem to any organ per any calendar quarter, and

Less than or equal to 15 mrem to any organ per any calendar year.

The PNPP ODCM does not contain a concentration reference for gaseous effluents. For this reason, effluent concentrations are not used to calculate maximum release rates for gaseous effluents.

RELEASE SUMMARY

Effluents are sampled and analyzed to identify both the type and quantity of radionuclides present. This information is combined with effluent path flow measurements to determine the composition, concentration, and dose contribution of the radioactive effluents.

Liquid Effluents

The PNPP liquid radioactive waste system is designed to collect and treat all radioactive liquid waste produced in the plant. The treatment process used for radioactive liquid waste depends on its physical and chemical properties. It is designed to reduce the concentration of radioactive material in the liquid by filtration to remove suspended solids and demineralization to remove dissolved solids. Normally, the effluent from the liquid radioactive waste system is returned to plant systems. To reduce the volume of water stored in plant systems; however, the processed liquid effluent may be discharge from the plant via a controlled release. In this case, effluent activity and dose calculations are performed prior to, and after discharging this processed water to Lake Erie to ensure regulatory compliance and dose minimization principals are maintained.

Liquid radioactive waste system effluents may be intermittently released, which are considered to be "batch" releases. Table 1 provides information on the number and duration of these releases for 2003.

Table 1: Liquid Batch Releases

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	TOTAL
Number of batch releases	21	39	18	0	78
Total time period for batch releases, min	1.77E+04	1.13E+04	3.89E+03	0	3.29E+04
Maximum time for a batch release, min	1.09E+03	3.91E+02	2.50E+02	0	1.09E+03
Average time period for a batch release, min	8.45E+02	2.91E+02	2.16E+02	0	4.22E+02
Minimum time for a batch release, min	7.00E+00	2.21E+02	1.50E+01	0	7.00E+00
Average stream flow during periods of effluent release into a flowing stream, L/min	1.02E+05	1.83E+05	2.23E+05	0	1.44E+05

In addition to batch releases a continuous release may occur with the release of the Turbine Building Supply Plenum Drains. The moisture from the outside air is condensed and flows into a drain pan. During hot, humid months with low wind speed, the potential exists for some of the gaseous effluent exhaust from the plant to be recycled back into the plant through the Turbine Building Supply Plenums. Since the air from the plant gaseous effluents can contain tritium, then the water in the exhaust plenums can also contain tritium. One such continuous release did occur during the year with a duration of 163356 minutes and a discharge volume of 6.13E6 liters. Tritium concentration for this release was 8.35E-07 $\mu\text{Ci/ml}$.

Also, in April 2003, there was detectable tritium in the Emergency Service Water (ESW) composite sample. The source of the tritium was investigated and the most likely source was determined to be recycled flow through the ESW sluice gates during Liquid Batch Releases. Other potential sources that were investigated and subsequently dismissed as potential sources included Residual Heat

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Removal heat exchanger tube leaks, Emergency Closed Cooling and Fuel Pool Cooling leaks into the Nuclear Closed Cooling System with subsequent leakage into the ESW system, backflow into the idle ESW loop during Liquid Batch Releases, and sample contamination. Although the ultimate source was concluded to be recycling through the ESW sluice gates, the composite sample for this period was included in the dose calculations for liquid releases. The duration of the release was 30180 minutes with a discharge volume 6.09E+08 liters. Tritium concentration for this release was 2.66E-06 uCi/ml.

Table 2 provides information on the nuclide composition for the liquid radioactive waste system effluent releases. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" ($<$ LLD). In each case, LLDs were met, or were below the levels required by the ODCM.

Table 2: Summation of All Liquid Effluent Releases

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. TOTAL ERROR, %
A. Fission and Activation Products					
1. Total Released, Ci (excluding tritium, gases, alpha)	3.35E-03	2.80E-02	5.05E-03	0	1.00E+01
2. Average Diluted Concentration, μ Ci/mL *	2.33E-10	1.15E-09	1.69E-10	0	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	0	
B. Tritium					
1. Total Released, Ci	5.12E+01	4.48E+01	1.64E+01	0	1.00E+01
2. Average Diluted Concentration, μ Ci/mL	3.56E-06	1.84E-06	5.48E-07	0	
3. Percent of Applicable Limit, %	3.56E-01	1.84E-01	5.48E-02	0	
C. Dissolved and Entrained Gases					
1. Total Released, Ci	1.89E-04	1.06E-04	9.36E-04	0	1.00E+01
2. Average Diluted Concentration, μ Ci/mL	1.31E-11	4.36E-12	3.13E-11	0	
3. Percent of Applicable Limit, %	6.55E-06	2.18E-06	1.57E-05	0	
D. Alpha Activity, Ci	1.77E-06	1.17E-05	7.88E-06	0	1.00E+01
E. Waste Volume Released, Liters (prior to dilution)	2.55E+06	5.07E+06	2.23E+06	0	1.00E+00
F. Dilution Water Volume Used, Liters **	1.44E+10	2.43E+10	2.99E+10	2.50E+10	2.8E+01

<LLD - Less than the lower limit of detection

N/A - Not Applicable, the ODCM does not have a limit for fission and activation products.

** Average diluted concentrations are based on total volume of water released during quarter.*

*** Dilution Water Volume indicates total dilution volume for the period of the report.*

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 3 lists the total number of curies (Ci) of each radionuclide present in liquid effluent releases for each quarter. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" (<LLD). In each case, the LLDs were either met, or were below the levels required by the ODCM.

Table 3: Radioactive Liquid Effluent Nuclide Composition

	UNIT	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	ANNUAL TOTAL
Tritium	Ci	5.13E+01	4.48E+01	1.64E+01	0	1.13E+02
Chromium-51	Ci	<LLD	3.83E-03	5.09E-05	0	3.88E-03
Manganese-54	Ci	2.58E-04	4.00E-03	5.34E-4	0	4.79E-03
Iron-55	Ci	<LLD	4.40E-03	<LLD	0	4.40E-03
Iron-59	Ci	<LLD	3.60E-04	<LLD	0	3.60E-04
Cobalt-58	Ci	1.48E-04	1.12E-03	2.11E-04	0	1.48E-03
Cobalt-60	Ci	2.15E-03	1.17E-02	2.17E-03	0	1.60E-02
Zinc-65	Ci	8.09E-05	8.62E-04	1.59E-04	0	1.10E-03
Strontium-92	Ci	<LLD	2.01E-05	3.65E-04	0	3.85E-04
Zirconium-95	Ci	<LLD	2.44E-05	<LLD	0	2.44E-05
Niobium-95	Ci	<LLD	2.40E-05	<LLD	0	2.40E-05
Technetium-99M	Ci	1.03E-04	<LLD	<LLD	0	1.03E-04
Rhuthenium-105	Ci	<LLD	<LLD	<LLD	0	<LLD
Silver-110m	Ci	9.39E-05	1.01E-03	1.26E-03	0	2.36E-03
Antimony-124	Ci	<LLD	<LLD	<LLD	0	<LLD
Antimony-125	Ci	<LLD	<LLD	<LLD	0	<LLD
Iodine-131	Ci	<LLD	<LLD	<LLD	0	<LLD
Xenon-133	Ci	<LLD	<LLD	<LLD	0	<LLD
Cesium-134	Ci	4.94E-05	2.48E-04	1.18E-04	0	4.15E-04
Cesium-137	Ci	1.31E-04	3.26E-04	1.75E-04	0	6.32E-04
Cesium-138	Ci	<LLD	<LLD	<LLD	0	<LLD
Lanthanum-140	Ci	3.31E-04	1.03E-04	<LLD	0	4.34E-04
Gold-199	Ci	<LLD	<LLD	6.96E-06	0	6.96E-06
Total for Period	Ci	5.13E+01	4.48E+01	1.64E+01	0	1.13E+02

<LLD - Less than the lower limit of detection

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Gaseous Effluents

Gaseous effluents are made up of fission and activation gases, iodine and particulate releases. The fission and activation gas releases are primarily a result of containment purge operations, small steam leaks, and offgas system operation during plant start up and shut down operations. The iodine and particulate releases are primarily a result of small steam leaks. Gaseous effluents from PNPP exit the plant via one of four effluent vents. Each of these four effluent vents contains radiation detectors that continuously monitor the air to ensure that the levels of radioactivity released are well below regulatory limits. Samples are also collected and analyzed on a routine basis to ensure regulatory compliance and dose minimization principals are maintained. The majority of gaseous effluents released from PNPP are considered continuous and at ground level.

A summation of all gaseous radioactive effluent releases is given in Table 4. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" ($<$ LLD). In each case, the measured LLDs either met or were below the levels required by the PNPP ODCM.

Table 4: Summation of All Gaseous Effluents

	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	EST. TOTAL ERROR, %
A. Fission and Activation Products					
1. Total Released, Ci	9.05E-02	3.90E+01	3.06E+00	8.17E-02	1.00E+01
2. Average Release Rate, μ Ci/sec	1.16E-02	4.96E+00	3.85E-01	1.03E-02	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
B. Iodine					
1. Total Iodine-131 Released, Ci	9.91E-04	3.29E-03	2.47E-04	1.54E-04	1.00E+01
2. Average Release Rate, μ Ci/sec	1.27E-04	4.19E-04	3.11E-05	1.93E-05	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
C. Particulates with Half-Lives > 8 days					
1. Total Released, Ci	<LLD	4.87E-05	1.97E-06	<LLD	1.00E+01
2. Average Release Rate, μ Ci/sec	<LLD	6.19E-06	2.48E-07	<LLD	
3. Percent of Applicable Limit, %	N/A	N/A	N/A	N/A	
D. Alpha Activity, Ci	5.40E-06	5.19E-06	<LLD	5.28E-07	
E. Tritium					
1. Total Released, Ci	1.49E+01	3.66E+00	8.57E+00	8.26E-01	1.00E+01
2. Average Release Rate, μ Ci/sec	1.92E+00	4.65E-01	1.08E+00	1.04E-01	
3. Percent of ODCM Limit, %	N/A	N/A	N/A	N/A	

<LLD - Less than the lower limit of detection

N/A - Not Applicable, the ODCM does not have a limit for fission and activation products.

The radionuclide composition of all gaseous radioactive effluents for a continuous-mode, ground-level release is given in Table 5. If a radionuclide was not present at a level "greater than or equal to the LLD" (\geq LLD), then the value is expressed as "less than the LLD" ($<$ LLD). In each case, LLDs were met or were below the levels required by the ODCM.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 5: Radioactive Gaseous Effluent Nuclide Composition

	UNIT	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4	ANNUAL TOTAL
A. FISSION AND ACTIVATION GASES						
Tritium	Ci	1.49E+01	3.66E+00	8.57E+00	8.26E-01	2.80E+01
Argon-41	Ci	<LLD	8.02E-02	<LLD	<LLD	8.02E-02
Krypton-85m	Ci	<LLD	1.19E-01	<LLD	<LLD	1.19E-01
Krypton-85	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Krypton-87	Ci	<LLD	1.05E-01	2.51E-02	<LLD	1.30E-01
Krypton-88	Ci	<LLD	1.24E-01	<LLD	<LLD	1.24E-01
Xenon-131m	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Xenon-133m	Ci	<LLD	3.87E-01	3.58E-02	<LLD	4.23E-01
Xenon-133	Ci	1.27E-02	3.28E+01	2.24E+00	<LLD	3.51E+01
Xenon-135m	Ci	2.10E-03	1.64E-01	1.63E-02	<LLD	1.82E-01
Xenon-135	Ci	7.57E-02	4.41E+00	3.81E-01	8.17E-02	4.95E+00
Xenon-137	Ci	<LLD	1.55E-01	1.42E-01	<LLD	2.97E-01
Xenon-138	Ci	<LLD	6.87E-01	2.24E-01	<LLD	9.11E-01
Total for Period	Ci	1.50E+01	4.27E+01	1.16E+01	9.08E-01	7.02E+01
B. IODINE						
Iodine-131	Ci	9.91E-04	3.29E-03	2.47E-04	1.54E-04	4.68E-03
Iodine-132	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Iodine-133	Ci	3.58E-03	1.20E-04	2.73E-04	3.00E-04	4.27E-03
Iodine-134	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Iodine-135	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	4.57E-03	3.41E-03	5.21E-04	4.53E-04	8.96E-03
B. PARTICULATE						
Chromium-51	Ci	<LLD	2.27E-06	<LLD	<LLD	2.27E-06
Manganese-54	Ci	<LLD	8.41E-07	1.97E-06	<LLD	2.81E-06
Iron-59	Ci	<LLD	4.33E-07	<LLD	<LLD	4.33E-07
Cobalt-58	Ci	<LLD	3.50E-07	<LLD	<LLD	3.50E-07
Cobalt-60	Ci	<LLD	6.81E-06	<LLD	<LLD	6.81E-06
Zinc-65	Ci	<LLD	2.64E-07	<LLD	<LLD	2.64E-07
Rubidium-88	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Rubidium-89	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-89	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-90	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-91	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Yttrium-91m	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Strontium-92	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Zirconium-95	Ci	<LLD	1.38E-08	<LLD	<LLD	1.38E-08
Molybdenum-99	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Cesium-138	Ci	<LLD	2.92E-05	<LLD	<LLD	2.92E-05
Barium-139	Ci	<LLD	8.54E-06	<LLD	<LLD	8.54E-06
Barium-140	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Lanthanum-140	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Lanthanum-142	Ci	<LLD	<LLD	<LLD	<LLD	<LLD
Total for Period	Ci	0.00	4.87E-05	1.97E-06	0.00	5.07E-05

<LLD - Less than the lower limit of detection

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Solid Waste

There were no shipments of PNPP solid radioactive waste transported, by truck, directly to the Barnwell, South Carolina, disposal facility for burial. Solid radioactive waste from PNPP was processed and combined with waste from several other utilities by intermediate vendors (Duratek in Oak Ridge, TN and Studsvik in Erwin, TN). This waste was ultimately sent to the Barnwell, South Carolina, or Clive, Utah, disposal facilities for burial. Additionally, radioactive waste was shipped from ATG Richland, WA to Clive, UT for final disposal. No irradiated fuel or components were transported from PNPP in 2003. The solid radioactive waste summary in Table 6 includes all PNPP shipments.

Table 6: Solid Waste Shipped Offsite for Burial or Disposal

A. Type of Solid Waste Shipped	VOLUME m ³	ACTIVITY Ci	PERIOD	EST. TOTAL ERROR %
Spent resin, filter sludge, evaporator bottoms, etc.	25.3	333.0	1/1/2003- 12/31/2003	+/- 25
Dry compressible waste, contaminated equipment, etc.	25.7	8.3	1/1/2003- 12/31/2003	+/- 25
Irradiated components, control rods, etc.	0	0	1/1/2003- 12/31/2003	+/- 25
Other (describe)	0	0	1/1/2003- 12/31/2003	+/- 25

B. Estimate of Major ⁽¹⁾ Nuclide Composition (by type of waste)	RADIONUCLIDE	ABUNDANCE %	EST. TOTAL ERROR, %
Spent Resin, Filter Sludge, Evaporator Bottoms, etc.	Mn-54 Fe-55 Co-58 Co-60 Zn-65	6.0 40.2 1.0 47.0 2.7	± 25
Dry Compressible Waste, Contaminated Equipment, etc.	Mn-54 Fe-55 Co-60 Ni-63 Zn-65	3.0 48.9 43.8 1.2 1.1	± 25
Irradiated Components, Control Rods, etc.	None	N/A	N/A
Other (describe)	None	N/A	N/A

C. Disposition	Number of Shipments	Mode of Transportation	Destination
Solid Waste ⁽²⁾	0	N/A	N/A
Irradiated Fuel Shipments	0	N/A	N/A

N/A – Not Applicable

(1) – "Major" is defined as any individual radionuclide identified as >1% of the waste type abundance.

(2) – Additional shipments were made to Studsvik, in Erwin, TN; Duratek, Oak Ridge, TN. This waste was combined with waste from other utilities disposed of at Barnwell, SC or Envirocare of Utah.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

METEOROLOGICAL DATA

The Meteorological Monitoring System at PNPP consists of a 60-meter tower equipped with two independent systems for measuring wind speed, wind direction, and temperature at both 10-meter and 60-meter heights. The tower also has instrumentation to measure dew point and barometric pressure. Data is logged from the tower through separate data loggers, and transmitted to a common plant computer. This system compiles the data and calculates a variety of atmospheric parameters, communicates with the Meteorological Information Dose Assessment System (MIDAS), and sends data over communication links to the plant Control Room.

DOSE ASSESSMENT

The maximum concentration for any radioactive release is controlled by the limits set forth in Title 10 of the Code of Federal Regulations, Part 20 (10CFR20). Sampling, analyzing, processing, and monitoring the effluent stream ensures compliance with these concentration limits. Dose limit compliance is verified through periodic dose assessment calculations. Some dose calculations are conservatively performed for a hypothetical individual who is assumed to reside on the site boundary at the highest potential dose location all year. This person, called the "maximum individual", would incur the maximum potential dose from direct exposure (air plus ground plus water), inhalation, and ingestion of water, milk, vegetation, and fish. Because no one actually meets these criteria, the actual dose received by a real member of the public is significantly less than what is calculated for this hypothetical individual.

Dose calculations for this maximum individual at the site boundary are performed for two cases. First, they are performed using data for a 360° radius around the plant site (land and water based meteorological sectors), even though some of these sectors are over Lake Erie, which has no permanent residents. The second calculation is performed considering only those sectors around the plant in which people reside (land-based meteorological sectors).

The calculated hypothetical, maximum individual dose values at the site boundary are provided in Table 7. This table considers all meteorological sectors around PNPP and provides either the whole body or worst-case, organ dose values. If any radionuclide was not present at a level greater than the LLD, it was not used in the dose calculations.

Table 7: Maximum Individual Site Boundary Dose, Considering All Sectors

TYPE OF DOSE	ORGAN	ESTIMATED DOSE, mrem	LIMIT	% OF LIMIT
Liquid Effluent	Whole body	9.50E-03	3.0E+00	3.2E-01
	Liver	1.23E-02	1.0E+01	1.2E-01
Noble Gas Gamma air Beta air	N/A	1.63E-03	1.0E+01	1.6E-02
	N/A	2.81E-03	2.0E+01	1.4E-02
Noble Gas	Whole body	1.95E-03	5.0E+00	3.9E-02
	Skin	5.37E-03	1.5E+01	3.6E-02
Particulate & Iodine	Thyroid	2.52E-02	1.5E+01	1.7E-01

N/A -- Not Applicable

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

The calculated hypothetical, maximum population dose values at the site boundary are provided in Table 8. This table considers all meteorological sectors around PNPP and provides either the whole body or worst-case, organ dose values.

Table 8: Population Dose, Considering All Sectors

	ORGAN	ESTIMATED DOSE person-rem
Liquid Effluent	Whole body	1.8E+00
	Thyroid	9.4E-01
Gaseous Effluent	Whole body	4.3E-03
	Thyroid	1.2E-02

Table 9 provides the calculated hypothetical maximum site boundary dose values considering only the land-based sectors. If any radionuclide was not present at a level greater than the LLD, it was not used in the dose calculations.

Table 9: Maximum Individual Site Boundary Dose, Considering Sectors on Land

TYPE OF DOSE	ORGAN	ESTIMATED DOSE, mrem	LIMIT	% OF LIMIT
Liquid Effluent	Whole body	9.50E-03	3.0E+00	3.2E-01
	Liver	1.23E-02	1.0E+01	1.2E-01
Noble Gas Gamma Air Beta Air	N/A	1.33E-03	1.0E+01	1.3E-02
	N/A	2.43E-03	2.0E+01	1.2E-02
Noble Gas	Whole body	6.21E-04	5.0E+00	1.2E-02
	Skin	1.64E-03	1.5E+01	1.1E-02
Particulate & Iodine	Thyroid	7.03E-03	1.5E+01	4.7E-02

N/A – Not Applicable

Other dose calculations are performed for a hypothetical individual who is assumed to be inside the site boundary for some specified amount of time. This person would receive the maximum dose during the time spent inside site boundary. Because no one actually meets the criteria established for these conservative calculations, the actual dose received by a real member of the public is significantly less than what is calculated for this hypothetical individual. This dose is assessed relative to the offsite dose, and considers dilution, dispersion, and occupancy factors.

The highest hypothetical dose from liquid effluents to a member of the public inside the site boundary is to a person who is fishing on Lake Erie from the shore on PNPP property. The calculations assume that this person will spend 60 hours per year fishing, with a liquid dilution factor of 10. The ratio of the exposure pathway to the doses calculated for offsite locations yields the dose values shown in Table 10.

Table 10: Maximum Site Dose from Liquid Effluents

	WHOLE BODY DOSE mrem	ORGAN DOSE mrem
First Quarter	2.3E-04	2.8E-04
Second Quarter	6.8E-04	8.1E-04
Third Quarter	1.1E-04	1.3E-04
Fourth Quarter ⁽¹⁾	0.0E+00	0.0E+00
Annual	1.0E-03	1.2E-03

(1) – No liquid radioactive effluent releases during this period

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Although several cases were evaluated to determine the highest hypothetical dose from gaseous effluents to members of the public inside site boundary, the activity inside the site boundary with the highest dose potential is also shoreline fishing. The cases evaluated included traversing a public road within the site boundary, shoreline fishing (assuming fishing 60 hours per year), non-plant related training, car-pooling, and job interviews. The maximum on-site gaseous doses generated are shown in Table 11.

Table 11: Maximum Site Dose from Gaseous Effluents

	WHOLE BODY DOSE mrem	ORGAN DOSE mrem
First Quarter	6.5E-04	1.4E-03
Second Quarter	2.5E-04	9.6E-04
Third Quarter	3.8E-04	1.4E-03
Fourth Quarter	5.3E-05	1.9E-04
Annual	1.3E-03	3.3E-03

An average whole body dose to individual members of the public at or beyond the site boundary is then determined by combining the dose from gaseous and liquid radiological effluents. The dose from gaseous radiological effluents is based upon the population that lives within 50 miles of PNPP (2,420,000 people). The dose from liquid radiological effluents is determined for the population that receives drinking water from intakes within 50 miles of PNPP (1,820,000 people). The results of this calculation are provided in Table 12.

Table 12: Average Individual Whole Body Dose

	Liquid Effluents (mrem)	Gaseous Effluents (mrem)
First Quarter	2.9E-07	6.6E-10
Second Quarter	2.9E-07	5.8E-10
Third Quarter	1.4E-07	5.8E-10
Fourth Quarter (1)	0.0E+00	3.2E-11
Annual	7.4E-07	1.8E-9

(1)– No liquid radioactive effluent releases during this period

ABNORMAL RELEASES

There was one abnormal radioactive release event during 2003.

Abnormal Release During Feedwater Valve Testing in Steam Tunnel

During testing of a Feedwater valve (N27-F599A), an abnormal release to the environment occurred. Testing resulted in a Feedwater line becoming pressurized with air and subsequently being discharged into the Auxiliary Steam Tunnel. The Auxiliary Steam Tunnel doors were open at the time of the system depressurization allowing airborne contamination to escape to the outside environment. Since the Turbine Building and Heater Bay ventilation systems were secured for outage work, there was not a negative pressure in the Steam Tunnel. The dose contributions from this event (refer to Table 13) demonstrated minimal dose consequence to the general public. Refer to Appendix D for meteorological data.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 13: Abnormal Release During Feedwater Valve Testing in Steam Tunnel

	ORGAN	ESTIMATED DOSE, mrem	ANNUAL LIMIT	% OF LIMIT
Noble Gas -air gamma -air beta	NA	0	1.0E+01	0
	NA	0	2.0E+01	0
Noble Gas	Whole body	0	5.0E+00	0
	Skin	0	1.5E+01	0
Particulate & Iodine	Thyroid	1.05E-04	1.5E+01	7.00E-04

NON-COMPLIANCES

There were two (2) non-compliance to the ODCM Controls requirements in 2003:

The Radwaste High-Flow Discharge Header Flow Monitor was inoperable greater than 30 days

The Radwaste High-Flow Discharge Header Flow Monitor, 0G50-N445, was declared inoperable on 12/2/02 due to a tractor gear on the recorder having a broken tooth. This repair was made within two days; however, the surveillance for the turbine flow meter (which provides the signal for the high flow monitor) became overdue and the parts necessary to perform that surveillance were not available. The monitor then remained inoperable until the correct parts could be obtained. An Engineering Change Request was submitted to resolve the obsolete parts issues associated with this monitor. Work was completed on 3/14/03, and 0G50-N445 was declared operable on 3/14/03 at 0930.

The Radwaste High-Flow Discharge Header Flow Monitor was inoperable greater than 30 days

The Radwaste High-Flow Discharge Header Flow Monitor, 0G50-N445, was declared inoperable at 0340 on 06/04/03 due to erratic readings. ODCM controls were entered. The monitor was not repaired and returned to service within 30 days. The cause in the delay is that the installed recorder was obsolete and replacement parts could not be located. Therefore, Engineering had to locate a recorder with similar functionality for installation. Once the correct type of recorder was located, the new recorder was delivered to the plant and installed in the system. Work was completed on 07/26/03, and 0G50-N445 was declared operable on 07/26/03 at 1055.

OFFSITE DOSE CALCULATION MANUAL CHANGES

During this reporting period, there were two (2) revisions to the Offsite Dose Calculation Manual:

Revision 8

- ♦ Revised to clarify that the wording in 4.0.2 of Appendix C so you can apply 1.25 times to actions in addition to surveillance items.
- ♦ Corrected the frequency note for release path B on page 138 to (b) instead of (c), which was in error.
- ♦ Added ingestion and external dose factors for Cu-67 and Sr-87m.
- ♦ Added reference to Federal Guidance Report 13 CD Supplement since this was the source for the dose factors for Cu-67 and Sr-87m.
- ♦ Clarified that a batch release requires a review under 10CFR50.59.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Revision 9

- ◆ Added reference to Commitment L01117.
- ◆ Removed reference to the low discharge volume throttle valves in Section 2.1.1.3.
- ◆ Removed reference to an interlaboratory program approved by the commission from Control 3.12.3.
- ◆ Updated the definition of MEMBER OF THE PUBLIC to reference the new 10CFR20 definition. Added the 10CFR20 definition of OCCUPATIONAL EXPOSURE.

PROCESS CONTROL PROGRAM CHANGES

During 2003, there was one (1) change to the Process Control Program:

- ◆ Corrected numerous administrative deficiencies throughout including renumbering of steps, corrections of typos and removal of the requirement for Plant Oversight Review Committee (PORC) review.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

RADIOLOGICAL ENVIRONMENTAL MONITORING

INTRODUCTION

The Radiological Environmental Monitoring Program (REMP) was established at PNPP for several reasons. First, it verifies the adequacy of plant design and operation to control radioactive materials and limit effluent releases. Second, it assesses the radiological impact, if any, that the plant has had on the surrounding environment. Third, it ensures compliance with regulatory guidelines. The REMP is conducted in accordance with the PNPP Operating License, Appendix B, Technical Specifications and the ODCM. The Nuclear Regulatory Commission (NRC) established the REMP requirements.

A wide variety of samples are collected as part of the PNPP REMP. The selection of sample types, sampling locations, and sample collection frequency are based on many things. Potential pathways for the transfer of radionuclides through the environment to humans, sample availability, local meteorology, population characteristics, land use and NRC requirements are all considered.

To ensure that the REMP data are meaningful and useful, detailed sampling methods and procedures are followed. This ensures that samples are collected in the same manner and from the same locations each time. All samples are packaged on site, then shipped to an independent vendor laboratory for analysis. The vendor laboratory analyzes the samples and reports results to the PNPP Chemistry Unit staff, the Lake County General Health District, and the State of Ohio Department of Health.

The REMP began in 1981 with 24 direct radiation monitoring locations, four sediment locations, and two fish sampling locations. In 1982, collections of air, water, milk, food products, and feed/silage were added. Vegetation, precipitation and soil were added in 1985. Although the NRC did not require these last three media, they were incorporated into the program to establish baseline data. In 1993, feed/silage sampling was dropped from the program, based on ten years worth of data. For the same reason, Strontium analyses were deleted from the program in 1994, gross beta and tritium were deleted from precipitation analyses in 1995, and precipitation sampling was deleted entirely in 1996. In 1999, grass and soil sampling were dropped from the program.

SAMPLING LOCATIONS

REMP samples are collected at numerous locations, both on site and up to 22 miles away from the plant. Sampling locations are divided into two general categories: indicator and control. Indicator locations are those which would be most likely to display effects caused by plant operation. They are relatively close to the plant. Control locations are those which are considered to be unaffected by plant operation. Typically, they are a greater distance from the plant, in the least prevalent wind directions. Data obtained from the indicator locations are compared with data from the control locations. This comparison allows naturally occurring background radiation to be taken into account when evaluating any radiological impact PNPP may have had on the environment. Table 14, Figure 2, Figure 3 and Figure 4 identify the PNPP REMP sampling locations.

Many REMP samples are collected in addition to those required by the PNPP ODCM. The ODCM requirements for each sample type are discussed in more detail below. Sample types and locations required by the ODCM are shown in **Bold** in Table 14.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 14: REMP Sampling Locations ⁽¹⁾


Location #	Description	Miles	Direction	Media ⁽²⁾
1	Chapel Road	3.4	ENE	TLD, AIP
2	Kanda Garden	1.9	ENE	Food Products
3	Meteorological Tower	1.0	SE	TLD, AIP
4	Site Boundary	0.7	S	TLD, AIP
5	Quincy Substation	0.6	SW	TLD, Air
6	Concord Service Center	11.0	SSW	TLD, AIP
7	Site Boundary	0.6	NE	TLD, AIP
8	Site Boundary	0.8	E	TLD
9	Site Boundary	0.7	ESE	TLD
10	Site Boundary	0.8	SSE	TLD
11	Parmly Rd.	0.6	SSW	TLD
12	Site Boundary	0.6	WSW	TLD
13	Madison-on-the-Lake	4.7	ENE	TLD
14	Hubbard Rd.	4.9	E	TLD
15	Eagle St. Substation	5.1	ESE	TLD
16	Eubank Garden.	0.8	S	Food Products
20	Rainbow Farms	1.9	E	Food Products
21	Hardy Rd.	5.1	WSW	TLD
23	High St. Substation	7.9	WSW	TLD
24	St. Clair Ave.	15.1	SW	TLD
25	Offshore - PNPP discharge	0.6	NNW	Sediment, Fish
26	Offshore - Redbird	4.2	ENE	Sediment
27	Offshore - Fairport Harbor	7.9	WSW	Sediment
28	CEI Ashtabula Plant Intake	22.0	ENE	Water
29	River Rd.	4.3	SSE	TLD
30	Lane Rd.	4.8	SSW	TLD
31	Wood and River Rd.	4.8	SE	TLD
32	Offshore - Mentor	15.8	WSW	Sediment, Fish
33	River Rd.	4.5	S	TLD
34	PNPP Intake	0.7	NW	Water
35	Site Boundary	0.6	E	TLD, AIP
36	Lake County Water Plant	3.9	WSW	TLD, Water
37	Gerlica Farm	1.5	ENE	Food Products
51	Rettger Milk Farm	9.6	S	Milk
53	Neff Perkins	0.5	WSW	TLD
54	Hale Rd. School	4.6	SW	TLD
55	Center Rd.	2.5	S	TLD
56	Madison High School	4.0	ESE	TLD
58	Antioch Rd.	0.8	ENE	TLD
59	Lake Shoreline at Green Rd.	4.0	ENE	Water
60	Lake Shoreline at Perry Park	1.0	WSW	Water
61	Keller Milk Farm	7.4	SE	Milk
63	Minor Stream Mouth	0.08	NNE	Sediment
64	Northwest Drain Mouth	0.09	NW	Sediment
65	Major Stream Mouth	0.18	W	Sediment
70	H&H Farm Stand	16.2	SSW	Food Products
71	Mosley Farm	7.9	SE	Milk

(1) chronologically missing location numbers denote deleted or retired sampling locations.

(2) AIP = Air, Iodine and Particulate
Veg = Vegetation
TLD = Thermoluminescent Dosimeter


ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 2: REMP Sampling Locations Within Two Miles of Plant Site



ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 3: REMP Sampling Locations Between Two and Eight Miles of Plant Site





ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SAMPLE ANALYSIS

When environmental samples are analyzed for radioactivity, several types of measurements are performed to provide information about the types of radiation and radionuclides present. The major analyses that are performed are discussed below.

Gross beta activity measures the total amount of beta-emitting radioactivity present in a sample, and acts as a tool to identify samples that may require further analysis. Beta radiation may be released by many different radionuclides. Since beta decay results in a continuous energy spectrum rather than the discrete energy levels, or "peaks", associated with gamma radiation, identification of specific beta-emitting nuclides is much more difficult. Therefore, gross beta activity only indicates whether the sample contains normal, or abnormal amounts of beta-emitting radioactivity; it does not specifically identify the radionuclides present.

Gamma spectral analysis provides more specific information than does the analysis for gross beta activity. Gamma spectral analysis identifies each radionuclide, and the amount of radioactivity, present in the sample emitting gamma radiation. Each radionuclide has a very specific "fingerprint" that allows for accurate identification and quantification.

Iodine activity analysis measures the amount of radioactive Iodine present in a sample. Some media (for example, air sample charcoal cartridges) are analyzed directly by gamma spectral analysis. With other media (for example, milk), the radioiodines are extracted by chemical separation before being analyzed by gamma spectral analysis.

Tritium activity analysis measures the amount of the radionuclide tritium (H-3) present in a sample. Tritium is an isotope of hydrogen that emits low-energy beta particles. Tritium occurs naturally and is also man-made.

Gamma doses received by Thermoluminescent Dosimeters (TLD) while in the field are determined by a special laboratory procedure. Thermoluminescence is a process by which ionizing radiation interacts with the sensitive phosphor material in the TLD. Energy is trapped in the TLD material and can be stored for months or years. This capability provides an excellent method to measure the dose received over long periods of time. The amount of energy that was stored in the TLD as a result of interaction with radiation is released by a controlled heating process and measured in a calibrated reading system. As the TLD is heated, the phosphor releases the stored energy as light. The amount of light is directly proportional to the amount of radiation to which the TLD was exposed. The reading process also zeroes the TLD and prepares it for reuse. Table 15 provides a list of the analyses performed on environmental samples collected for the PNPP REMP in 2003.

Sample results are often reported as less than the lower limit of detection ($< \text{LLD}$), which is defined as the smallest amount of radioactive material that will show a positive result for which there can be confidence that radioactivity is present. This statistical parameter is used as a measure of the sensitivity of a sample analysis. When a measurement is reported as $< \text{LLD}$, it means that no radioactivity was detected at a value above, or equal to the appropriate ODCM table value. The NRC has established LLD values for REMP sample analyses. The vendor laboratory for REMP sample analyses complied with those values in 2003.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 15: REMP Sample Analyses

TYPE	SAMPLE	FREQUENCY	ANALYSIS
Atmospheric Monitoring	Airborne Particulates	Weekly Quarterly	Gross Beta Activity Gamma Spectral Analysis
	Airborne Radioiodine	Weekly	Iodine-131
Terrestrial Monitoring	Milk	Bi-Monthly	Gamma Spectral Analysis Iodine-131
	Food Products	Monthly	Gamma Spectral Analysis
	Vegetation	As Required	Gamma Spectral Analysis
Aquatic Monitoring	Water	Monthly	Gross Beta Activity, Gamma Spectral Analysis
		Quarterly	Tritium Activity
	Fish	Annually	Gamma Spectral Analysis
	Sediment	Biannually	Gamma Spectral Analysis
Direct Radiation Monitoring	TLD	Quarterly	Gamma Dose
		Annually	Gamma Dose

2003 SAMPLING PROGRAM

The contribution of radionuclides to the environment resulting from PNPP operation is assessed by comparing results from the 2003 program with pre-operational data (i.e., data from before 1986), operational data from previous years, and control location data. The results for each sample type are discussed below and compared to historical data to determine if there are any observable trends. All results are expressed as concentrations. Refer to Appendix B, 2003 REMP Data Summary Reports for a detailed listing of these results. The NRC requires special reporting whenever sample analysis results exceed set limits. No values exceeded these reporting levels in 2003.

Program Changes

There were no changes in 2003.

Missed Samples

On occasion, samples cannot be collected. This can be due to a variety of events, including equipment malfunction, animal husbandry practices, or lost shipments. Events may also occur which prevent a sample from being collected in the normal way, or prevent a complete sample from being collected. The drying period for goats is an annual occurrence, since unlike cows, goats cannot produce milk year-round. Missing TLDs may be the result of vandalism. When vandalism has been identified as a recurring problem, the TLD is relocated. If the loss of a TLD is determined to be a single or unusual event, it is not normally relocated. Table 16 provides information on samples missed during 2003.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 16: Missed REMP Samples in 2003

MEDIA	LOCATION	DATE	REASON
Food Products	All	April, May, June 2003	Vegetables not ready for harvest
Food Products	2	July 2003	Vegetables not ready for harvest
Lake Water	59	January, February 2003	Sample unavailable due to frozen shoreline
Lake Water	60	January, February 2003	Sample unavailable due to frozen shoreline
Milk	61	January, February, March, October, November, December	Drying period for goats
Milk	71	June – December	Owner retires from farming
TLD (Quarterly)	15	2 nd Quarter	TLD found to be missing at collection time.
TLD (Annual)	15, 23, 24	Annual	TLD found to be missing at collection time.

Atmospheric Monitoring

Air

Air sampling is conducted to detect any increase in the concentration of airborne radionuclides. The PNPP ODCM requires five locations (four indicator and one control). Air sampling pumps are used to draw continuous samples at a rate of approximately two cubic feet per minute. The air is drawn through glass fiber filters (to collect particulate material) and a charcoal cartridge (to adsorb Iodine). The samples are collected on a weekly basis, 52 weeks a year, from each of seven air sampling stations. Six (6) of these locations are within four miles of the plant site; the seventh is used as a control location and is eleven miles from PNPP.

On occasion, air sample locations can experience power losses associated with storms and/or malfunctioning equipment. No power losses or malfunctioning equipment were experienced during 2003.


Air samples are analyzed weekly for gross beta activity and radioiodine activity. The air samples are also analyzed by gamma spectral analysis quarterly. A total of 364 for air particulate and 364 air radioiodine samples were collected and analyzed in 2003.

Gross beta activity was detected in all air samples and ranged up to 0.04 pCi/m³. The annual average gross beta activity at both indicator and control locations was 0.02 pCi/m³. Historically, the concentration of gross beta in air has been essentially identical at indicator and control locations. Figure 5 reflects the average gross beta activity for 2003 and the previous years.

Except for naturally occurring beryllium-7, no radionuclides were identified in the gamma spectral analysis above the LLD values. Iodine-131 was not detected in any sample above the LLD of 0.05 pCi/m³.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 5: Annual Average Gross Beta Activity, in Air



Terrestrial Monitoring

Collecting and analyzing samples of milk, food products and vegetation provides data to assess the build-up of radionuclides that may be ingested by humans. The historical data from soil and vegetation samples provides information on the atmospheric radionuclide deposition. The PNPP ODCM requires neither vegetation nor soil samples.

Milk

Samples of milk are collected once each month from November through March, and twice each month from April through October. Sampling is increased during the summer because animals usually feed outside on pasture and not on stored feed. Through April 2003 the PNPP REMP included three (3) milk locations that are located between 7.4 and 9.6 miles away from the plant. In early May, milk location #71 retired from farming and withdrew from the program. Since the milk sampling locations did not meet the requirements of the ODCM (no milk-producing animals located within the required areas), food product sampling (discussed below) was performed. Milk was collected from the available locations, even though they did not meet the ODCM requirements. If new locations that meet the ODCM requirements are identified in the future, they will be added to the program.

Milk samples are analyzed by gamma spectral analysis for radioiodines and other radionuclides. A total of 37 milk samples were collected in 2003. Iodine was not detected above the LLD of 0.75 pCi/L in any of the samples. The concentrations of all radionuclides, except naturally occurring potassium-40, were below LLDs in all samples collected.

Food Products

Food products can provide a direct pathway to humans by ingestion. They can absorb radionuclides from atmospheric deposition on soil or from irrigation water drawn from a lake or pond receiving airborne or liquid effluents. Also, radionuclides in the soil may be absorbed by the roots of the plants and become incorporated into the edible portions. Because there is not a sufficient number of milk sampling locations, the PNPP REMP is required to include two food product indicator locations and one control location. Food products are collected monthly during the growing season from five farms in the vicinity of PNPP. The control location for food products is 16.2 miles from PNPP.

A total of sixty five (65) food product samples were collected and analyzed by gamma spectral analysis in 2003. Four (4) food products were collected which included: collard greens, turnip

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

greens, chinese cabbage and swiss chard. Beryllium-7 and potassium-40, naturally-occurring radionuclides, were found in several samples, as expected. No other radionuclides were detected above the required LLDs.

Aquatic Monitoring

Radionuclides may be present in Lake Erie from many sources other than the PNPP. These sources include atmospheric deposition, run-off/soil erosion, and releases of radioactivity in liquid effluents from hospitals, universities or other industrial facilities. These sources provide two forms of potential radiation exposure, external and internal. External exposure can occur from contact with water or shoreline sediments, while internal exposure can occur from either direct ingestion of radionuclides or the transfer of radionuclides through the aquatic food chain. Direct ingestion can occur from drinking the water, while the transfer via the aquatic food chain occurs from the eventual consumption of aquatic organisms, such as fish. To monitor these pathways, PNPP samples water, shoreline sediments, and fish.


Water

Water is sampled from five locations along Lake Erie in the vicinity of the PNPP as required by the PNPP ODCM. Samples from three locations are collected using composite sample pumps. The pumps are designed to collect water at regular intervals and composite it in a sample container. The containers are emptied monthly and the samples shipped to the laboratory for analysis. Samples from two locations are collected weekly and combined. Each month the combined sample is shipped for analysis.

Fifty-six (56) water samples were collected and analyzed for gross beta activity and gamma spectral analysis in 2003. From these monthly samples, a quarterly composite sample was obtained and analyzed for tritium activity. Refer to Table 16 for an explanation of missed samples.

Gross beta activity was detected in four (4) of the fifty-six (56) samples collected. The detectable (i.e., above the lab LLD value) gross beta activity ranged from 3.02 pCi/L to 3.81 pCi/L. Referring to Figure 6, the annual average gross beta activity was 3.30 pCi/L at the indicator locations and 3.81 pCi/L at the control location, using the mean of values >LLD. The significant difference between the pre-1988 data and post-1988 data has been attributed to a change in vendor laboratories in 1987/1988. A comprehensive explanation for the observed difference is provided in the 1988 Annual Environmental Operating Report.

Figure 6: Annual Average Gross Beta Activity, in Water



ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

There were no radionuclides detected by gamma spectral analysis above the LLD. Tritium was not detected above the LLD value in any of the twenty (20) samples analyzed. These results are well within the range of those measured in previous years, which have ranged from below the LLD to 2,200 pCi/L.

Sediment

Sampling lake bottom sediments can provide an indication of the accumulation of particulate radionuclides which may lead to internal exposure to humans through the ingestion of fish, the re-suspension into drinking water, or as an external radiation source to fishermen and swimmers from shoreline exposure. Although the PNPP ODCM requires only one location, sediment is sampled twice each year from seven (7) locations. Two (2) of the sampling locations are also fish sampling locations. Sediment samples from offshore are collected using a hand dredge. Shoreline samples are collected using a scoop. Fourteen (14) sediment samples were collected in 2003 and analyzed by gamma spectrometry.


The predominant radionuclide detected by gamma spectral analysis was naturally-occurring potassium-40. Potassium-40 has been detected in all samples, since the program began in 1981.

Cesium-137 activity was detected in six (6) of the fourteen (14) samples collected and ranged from 142.95 pCi/kg to 1134.90 pCi/kg. The annual average cesium-137 activity was 334.56 pCi/kg at the indicator locations and 1028.57 pCi/kg at the control location. The average cesium-137 radioactivity for all locations was 565.90 pCi/kg and was within the maximum value of 864 pCi/kg established in 1981. Year-to-year variations in the lake bottom sediment sample activities is expected and beyond the control of PNPP. For example, cesium-137 activity variations (refer to figure 7) in the control locations from year-to-year may be contributed to:

1. The movement of sediment on the lake bottom due to wave action and currents, and
2. Sampling in nearly the same location approximately 4½ miles off-shore, even with GPS, is extremely difficult.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Figure 7: Annual Average Cesium-137 Concentration in Sediment



In 1999, a sediment sample from location #64 (shoreline discharge point of the northwest drain impoundment) was found to contain trace levels of cobalt-60. Ten (10) additional sample locations were established upstream from location #64 and within the impoundment to identify the boundary of the cobalt-60 activity and to support supplemental monitoring activities. For 2003, sample results for cobalt-60 confirm that no activity was identified at the discharge point (Location #64), and continues to remain within the northwest drain impoundment with activity ranging from <14.4 pCi/kg to 193 +/- 32 pCi/kg (Refer to Table 17). Also for comparison, cesium-137 activity within the impoundment is reflected in Table 18.

Table 17: Northwest Drain Impoundment Cobalt-60 Activity, pCi/kg (dry)

Location	05/27/03	5/28/03	10/08/03	10/20/03
64	<14.6		<14.4	
64-1		<17.1		<37.9
64-2		<25.7		<38.3
64-3		<28.5		<33.6
64-4		87 ± 24		*
64-5		*		<19.4
64-6		75 ± 31		145 ± 57
64-7		129 ± 27		139 ± 31
64-8		71 ± 31		70 ± 23
64-9		157 ± 27		132 ± 30
64-10		193 ± 32		124 ± 36

* No sample available or insufficient sample for analysis

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Table 18: Northwest Drain Impoundment Cesium-137 Activity, pCi/kg (dry)

Location	05/27/03	05/28/03	10/08/03	10/20/03
64	<17.8		<13.7	
64-1		116 ± 29		839 ± 38
64-2		359 ± 39		1138 ± 88
64-3		238 ± 41		859 ± 63
64-4		631 ± 57		*
64-5		*		135 ± 33
64-6		1218 ± 76		1080 ± 85
64-7		1621 ± 75		783 ± 79
64-8		612 ± 47		910 ± 56
64-9		1801 ± 79		1119 ± 71
64-10		1099 ± 69		968 ± 76

* No sample available or insufficient sample for analysis

Fish

Fish are analyzed primarily to quantify the dietary radionuclide intake by humans, and secondarily to serve as indicators of radioactivity in the aquatic ecosystem. Fish are collected from two locations, annually during the fishing season as required by the ODCM. An important sport or commercial species is targeted, and only the fillets are sent to the laboratory for analysis. In 2003, fish sampling was performed for PNPP by a local licensed sport fisherman.

Two (2) fish samples representing yellow perch were collected and analyzed by gamma spectral analysis in 2003. As expected, naturally occurring potassium-40 was found in all samples. No other radionuclides were detected above the LLD.

Direct Radiation Monitoring

Thermoluminescent Dosimeter (TLD)


Environmental radiation is measured directly at twenty-eight locations around the PNPP site, two of which are control locations. The locations are positioned in two rings around the plant as well as at the site boundary. The inner ring is within a one-mile radius of the plant site; the outer ring is four to five miles from the plant. The control locations are over ten miles from the plant in the two least prevalent wind directions. Each location is equipped with three TLDs, two of which are changed quarterly and one is changed annually.

A total of 248 TLDs were collected and analyzed in 2003. This includes 223 of 224 collected on a quarterly basis and twenty-five (25) of twenty-eight (28) collected annually. During the 2nd quarter collection of TLDs on 07/01/03, one (1) quarterly TLD at location 15 was found to be missing. Three annual TLDs were found to be missing during the fourth quarter collection performed on 01/06/04. Annual TLDs are not required per the ODCM and are used for supplemental data only.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

In 2003, the annual average dose for all indicator locations was 67.88 mrem, and 73.59 mrem for all control locations. Referring to Figure 8, the average quarterly dose for all indicator locations was 15.84 mrem, and 15.71 mrem for all control locations. Prior to 1988, the TLD results were higher due to a change in the vendor laboratory services. A comprehensive explanation of this difference was provided in the 1988 Annual Environmental Operating Report.

Figure 8: Average Quarterly TLD Dose



Conclusion

Sediment samples continue to confirm cobalt-60 in the northwest drain impoundment. The activity level was just above the detection limits. Additional monitoring is being performed to monitor this location. An environmental evaluation determined that there would be less impact upon the environment by leaving this material in place. Atmospheric monitoring results were consistent with past results. The prevalent radionuclide in air was beryllium-7, which is naturally occurring. Naturally occurring potassium-40 was detected in all terrestrial samples, as expected. The annual concentrations excluding this sample were similar to those measured in previous years.

Finally, direct radiation measurements are consistent with past data.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

INTER-LABORATORY CROSS-CHECK COMPARISON PROGRAM

Introduction

The purpose of the Inter-laboratory Cross-Check Comparison Program (ICCCP) is to provide an independent check on the vendor laboratory's analytical procedures. Samples with a known concentration of specific radionuclides are provided to the vendor laboratory. The vendor laboratory measures and reports the concentration of specified radionuclides. The known values are then compared to the vendor results. Results consistently outside established acceptance criteria indicate a need to check instruments or procedures. Regulatory Guide 4.15 specifically required that contractor laboratories that performed environmental measurement participate in the EPA's Environmental Radioactivity Laboratory Inter-Comparison Studies Program, or an equivalent program.

The EPA's program is not longer funded and no longer offered. The reason that the EPA program was referenced in the regulatory guide is that the EPA standards were traceable to National Bureau of Standards (now known as National Institute Standard Technology). In response to this problem, Teledyne (our vendor lab) incorporated a program offered by Environmental Resource Associates (ERA Company), which covered the same analyses in the same matrix at the same frequency as the EPA program. The ERA Company has received NIST accreditation for its program, as an equivalent program. In addition to comparison cross checks performed with the ERA Company, the vendor laboratory routinely monitors the quality of their analyses by:

- ♦ Analyzing "spiked" samples (samples with a specific quantity of radioactive material present in them),
- ♦ Participating in the Department of Energy's Mixed Analyte Performance Program (MAPEP), and
- ♦ Participating in the Environmental Measurements Laboratory Quality Assessment Program (EML).

Conclusion

Appendix A, 2003 Inter-Laboratory Cross Check Comparison Program Results, includes results from both the above referenced programs and the ERA Company cross-check program. In Table A-1, three (3) samples were determined to be outside the ERA program control limits: Sample STW-975 for gross alpha was analyzed twice and still failed, falling outside the control limits on the low side. No cause could be determined, however, subsequent analyses for gross alpha of various media within the Inter-Laboratory Cross-Check Comparison Program were found to be within their control limits. Sample STW-986 for Cs-134 analysis initially failed outside the control limits. Re-analysis results were within the control limits. Sample STW-990 for gross beta analysis initially exceeded the ERA control limits. Re-analysis was within the control limits.

The Vendor Laboratory's cross-check testing of Thermoluminescent Dosimetry, Table A-2 and Table A-3, the In-House "Spike" Samples were all within their control limits.

In Table A-4, In-House "Blank" Samples, two (2) milk samples (SPMI-2056, 4018) analyzed for Sr-90 were found to be outside the program acceptance criteria. Low levels of Sr-90 remain in the environment and concentrations of (1-5 pCi/l) found in milk is not unusual.

For Table A-5, In-House "Duplicate" Samples, two samples (SL-2910, 4399) for gross beta and 1 sample (CF-1049) for K-40 experienced longer count times resulting in lower errors.

For the MAPEP Program Table A-6, all analyses were within the expected control limits.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

In Table A-7 the Environmental Measurements Laboratory Quality Assessment Program (EML), one sample result was found to be outside the expected control limits and the second was an error in preliminary reporting. Sample STW-978 for cesium-134 was analyzed and reported as lower than the EML result. The Vendor Lab found no errors with its equipment or efficiencies. This low bias of Cs-134 activity has been observed by the Vendor Lab in the past and will be corrected through additional spike analyses and calculation corrections. Sample STW-978 for tritium (H-3) was identified as a reporting error. During the conversion of pC to Bq, the incorrect result of 297.3 Bq/L was reported to EML. The value of 341.9 Bq/L referenced in Table A-7 is correct. All other analysis results performed under these programs were within the control limits established.

LAND USE CENSUS

Introduction

Each year a land use census, which is required by Section 3/4.12.2 of the PNPP ODCM, is conducted to identify the locations of the nearest milk animal, garden (of greater than 500 square feet), and residence in each of the meteorological sectors that is over land. Information gathered during the Land Use Census is used for off-site dose assessment and to update sampling locations for the Radiological Environmental Monitoring Program. The census is conducted by traveling all roads within a five-mile radius of the plant site, and recording and mapping the location of the nearest resident, milk animal, and vegetable garden. The 2003 Land Use Census, which was conducted July 9th and 10th provided the garden, residence and milk animal locations tabulated in Tables 19, 20 and 21 and depicted in Figure 9. Note that the W, WNW, NNW, NW, N, and NNE sectors extend over Lake Erie, and therefore, are not included in the survey.

Discussions and Results

In general, the predominant land use within the census area continues to be rural/agricultural. In recent years however, it has been noted that tracts of land once used for farming are now being developed as mini industrial parks and residential housing tracts. This is reflected in the loss of available milking animals within a five mile radius of PNPP to support the Radiological Environmental Monitoring Program (REMP). The 2003 Land Use Survey used the 1999 survey map produced by the Commercial Survey Co. of Cleveland. GPS units are used for more accurate location identification.

Table 19 identifies the nearest residences, by sector, to the PNPP. The table is updated annually to reflect any changes identified during the annual Land Use Census. For 2003, there is one (1) change noted for the "nearest residence" in the SSE sector. A name change occurred for the extension of Parmly Road. It is now known as Redmill Valley Road.

Table 19: Nearest Residence, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	X/Q VALUE, sec/m ³	MAP LOCATOR NUMBER
NE	4384 Lockwood	0.7	2.66E-06	1
ENE	4460 Lockwood	0.8	1.59E-06	2
E	2626 Antioch	1.1	6.77E-07	3
ESE	2750 Antioch	1.0	8.57E-07	4
SE	4537 North Ridge	1.3	3.44E-07	5
SSE	4247 Redmill Valley Rd.	1.1	5.52E-06	6
S	3119 Parmly	0.9	2.25E-06	7
SSW	3121 Center	0.9	1.11E-06	8
SW	3440 Clark	1.3	4.42E-07	9
WSW	3462 Parmly	1.1	8.67E-07	10




Figure 9: Land Use Census Map

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

During the 2003 Land Use Census, no changes were identified regarding the nearest milk animal. These locations are reflected in Table 20.

Table 20: Nearest Milk Animal, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	MAP LOCATOR NUMBER
ESE	3485 Dayton	4.0	21
S	3588 River	4.8	22

There were three (3) changes in the nearest gardens recorded during this year's census. These changes reflect either the loss of the previous year's garden or the addition of a new garden identified in this year's census. These changes are identified in Table 21, which lists nearest gardens occupying at least 500 square feet.

Table 21: Nearest Garden, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	D/Q VALUE, m ²	MAP LOCATOR NUMBER
NE	2330 Lakehurst	0.9	8.91E-09	11
ENE	4630 Lockwood	1.1	4.77E-09	12
E	2601 Antioch	1.1	5.29E-09	13
ESE	2864 Antioch	1.1	3.96E-09	14
SE	5021 Middle Ridge	2.2	1.01E-09	15
SSE	3289 Call Rd.	1.5	2.04E-09	16
S	3964 North Ridge	1.4	2.73E-09	17
SSW	3121 Center	0.9	5.58E-09	8
SW	3455 Clark	1.2	2.24E-09	19
WSW	2975 Perry Park	1.3	2.01E-09	20

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

CLAM/MUSSEL MONITORING

INTRODUCTION

Sampling for benthic macro-invertebrates (clams and mussels) has been conducted in Lake Erie in the vicinity of PNPP, since 1971. The clam/mussel program currently focuses on two species: *Corbicula fluminea* (Asiatic clam) and *Dreissena polymorpha* (zebra mussel).

CORBICULA PROGRAM

Monitoring specifically for *Corbicula* was initiated in response to a NRC bulletin and concerns of the Atomic Safety and Licensing Board. The 2003 monitoring was done as part of the Environmental Protection Plan (Operating License, Appendix B). The program consists of visually inspecting the raw water systems, whenever they are opened for maintenance. The purpose of this program is to detect *Corbicula*, should it appear at PNPP.

No *Corbicula* have ever been found in any sample collected from PNPP or from Lake Erie in the vicinity of PNPP. Two *Corbicula* were found in a sample collected from the Eastlake plant in June, 1987. No *Corbicula* have been found in any other sample collected since that time. A more detailed program history can be found in the 1986 and 1987 PNPP Annual Environmental Operating Reports.

Monitoring

In 2003, samples were collected from the Service Water (SW), Emergency Service Water (ESW), Fire Water, and Circulating Water (CW) systems at PNPP. All samples were collected by Ponar hand dredge, hand scoop, or scraper. They were examined for asiatic clam shells and fragments. In addition to sample collections, plant components that use raw water are inspected whenever opened for maintenance or repair. Sample collection/inspection dates are listed in Table 22.

Table 22: 2003 *Corbicula* Monitoring

DATE	SAMPLE LOCATION	DATE	SAMPLE LOCATION
02/10/03	Emergency Service Water Valve 1P45-F0520	09/17/03	Fire Protection Underground Piping at 0P54-F0502, 503, 504, 505
04/08/03	Condenser & Auxiliary Water Boxes 1N61-B0001A	09/23/03	Fire Protection Piping at 0P54-F3552, 0625, 0631
04/11/03	Bearing Cooling Lines 1P45-C0001B	09/25/03	Fire Protection Piping at 1P54-F0642, 0643
04/13/03	Emergency Service Water Valve 1P45-F0130B	09/25/03	Fire Protection Piping at 1P54-F1379
04/27/03	Circulating Water Basin	09/30/03	Fire Protection Valve 0P54-F0506
05/12/03	Condenser & Auxiliary Water Boxes 1N61-B0001B	10/02/03	Fire Protection Piping at 0P54-F3554, 3555
05/15/03	Emergency Service Water Spool Piece	10/15/03	Fire Protection Piping at PY-1P54-F0959
06/11/03	Fire Protection Water Strainer 1P54-D0920	10/15/03	Fire Protection Water Strainer 1P54-D0706
06/12/03	Fire Protection Water Strainer 1P54-D1240	10/16/03	Fire Protection Valve P54-F0960
07/18/03	Fire Protection Water Strainer 0P54-D0705	10/17/03	Fire Protection Piping at PY-1P54-F0686
07/31/03	Fire Protection Water Strainer 0P54-D0906	10/29/03	Fire Protection Deluge Piping Interbus Transformer 'B'
08/06/03	Fire Protection Water Strainer PY-1P54-D0840	10/30/03	Fire Protection Water Strainer 0P54-D0742
08/29/03	Fuel Handling Building Deluge Header Strainer P54-D0767	12/09/03	Nuclear Closed Cooling Heat Exchanger oP43B0001B

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Conclusions

The sample collected in June, 1987, was the only indication of *Corbicula* in the vicinity of PNPP. Although the presence of *Corbicula* was detected at the Eastlake Power Plant, it has not been demonstrated that their presence has created any operational problems there, or at PNPP. As in the past, the 2003 monitoring program did not identify *Corbicula* in any sample collected.

DREISSENA PROGRAM

Dreissena, or Zebra mussels were first discovered at PNPP in September, 1988. The initial collection of 19 mussels was made as part of the *Corbicula* monitoring program. The *Dreissena* monitoring program began in 1989, with monitoring and testing. The current control program was designed and implemented in 1990.

Monitoring

In addition to visually inspecting the plant's raw water systems when they are opened for maintenance or repair, monitoring methods include the use of commercial divers, side-stream monitors, and plankton nets. Commercial divers monitor mussel infestation during the inspection of forebays, basins, and the intake and discharge structures. Divers have also been used to take underwater videotapes of the water basins and intake tunnel. Side-stream monitors are flow-through containers that receive water diverted from plant systems, and are normally used in three in-plant locations during the mussel season. The side-stream monitors are fitted with slides and inspected for veliger settlement. In 2003, a plankton net was used on a limited basis to help trend veligers during the spawning season and samples from the side-stream monitors were filtered and evaluated.

Treatment

Chemicals used for mussel control in 2003 included chlorine and a commercial molluscicide. The chlorine is intermittently injected into the plant service water, emergency service water, and circulating water systems by metering sodium hypochlorite into each system's influent. Sodium sulfite or sodium bisulfite is added at the plant discharge structure for dechlorination prior to return into Lake Erie.

The use of a commercial molluscicide requires approval by the Ohio Environmental Protection Agency (OEPA). The chemical selected for use at the PNPP in 2003 was alkyl-dimethyl-benzyl-ammonium chloride. One treatment was applied in September, 2003. The active ingredients were detoxified by adsorption onto bentonite clay, prior to discharge into Lake Erie.

Results

The effectiveness of the intermittent chlorination treatment has been determined in several ways. First, visual inspections of raw water system components are conducted when systems are open during maintenance or repair. In addition, settlement monitors were inspected for new settlement. No live settlement has been found in any plant component to date.

The effectiveness of the application of the commercial molluscicide was measured by observing mortality of mussels placed in a flow-through container placed in plant service water and subjected to the chemical treatment. The observed mortality rate in the flow-through container was 99%. To date, PNPP has had no problems related to zebra mussels.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

CONCLUSIONS

Perry Nuclear Power Plant has taken the approach that the best method for avoiding problems with zebra mussels is preventive treatment of plant water systems. The current program of monitoring and chemical treatment will be continued to minimize the possibility that PNPP will experience future problems due to zebra mussels.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

HERBICIDE APPLICATIONS

Herbicides are used sparingly on the PNPP site. A request must be made to, and approved by the PNPP Chemistry Unit prior to spraying to ensure that only approved chemicals are used, and only in approved areas.

In 2003, three (3) general and one (1) specific herbicide requests were initiated for chemical applications. Each application was in compliance with the Ohio Environmental Protection Agency's rules and regulations. There were no adverse environmental impacts observed during weekly site environmental inspections as a result of these applications. The herbicides approved for use in the Owner-Controlled Area are Round-Up, Riverdale, Karmex, Peptoil and Glypro Plus. For each application, the type of weed to be treated dictated the herbicide and concentration to be used. Table 23 provides detailed documentation for each application in 2003. The quantity represents the amount of herbicide applied, after any dilution.

Table 23: 2003 Herbicide Applications

Application Date	Location	Area sq ft	Quantity gal or lbs	Chemical Conc.	Chemical Name
05/19/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	10,000	5	1.6%	Roundup
05/19/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	175,000	75	1.6%	Roundup
05/27/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	130,000	33	1.6%	Roundup
05/27/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	100,000	30	1.6%	Roundup
06/02/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	175,000	25	2.3%	Roundup
06/09/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	130,000	10	2.3%	Roundup
06/10/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	65,000	3	2.3%	Roundup
06/23/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	250,000	50	2.3%	Roundup
06/24/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	307,000	67	2.3%	Roundup
07/08/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	180,000	50	2.3%	Roundup
07/08/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	220,000	50	2.3%	Roundup
07/09/03	Environmental Inspection Paths, Fire Training Grounds, Waste Storage Areas	109,000	200	3.5%	Roundup, Karmex
07/12/03	Transmission Yard	87,000	1200	0.5%	Glypro Plus, Riverdale, Peptoil
07/16/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	175,000	50	2.3%	Roundup
07/22/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	175,000	25	2.3%	Roundup
07/28/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	200,000	25	2.3%	Roundup
07/29/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	209,000	50	2.3%	Roundup
07/30/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	80,000	2	2.3%	Roundup
08/04/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	200,000	25	2.3%	Roundup
08/04/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	175,000	25	2.3%	Roundup
08/11/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	105,000	25	2.3%	Roundup

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

08/18/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	185,000	50	2.3%	Roundup
08/25/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	204,000	50	2.3%	Roundup
09/02/03	Graveled areas/landscape beds within the Owner Controlled Area (Unit #2)	240,000	50	2.3%	Roundup
10/20/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	195,000	25	2.3%	Roundup
11/03/03	Graveled areas/landscape beds within the Protected Area (Unit #1)	179,000	15	2.3%	Roundup

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SPECIAL REPORTS

NON-COMPLIANCES

NPDES Permit

The National Pollutant Discharge Elimination System (NPDES) permit is issued by the Ohio Environmental Protection Agency (OEPA). It establishes monitoring requirements and limits for discharges from the PNPP. It also specifies the locations from which the plant is allowed to discharge.

There was one NPDES non-compliance issue identified in 2003:

On June 30, 2003, the OEPA was notified that the Preliminary Effluent Limit (PEL) for copper was exceeded during the month of June 2003. The increase in copper at the plant effluent coincided with a large increase of copper levels entering the plant from Lake Erie. This notification was made in accordance with the National Pollutant Discharge Elimination System (NPDES) Permit.

Environmental Protection Plan

The Environmental Protection Plan (EPP), which is a part of the PNPP Operating License, requires a non-radiological environmental monitoring and reporting program be established at the PNPP. There were no instances of an EPP non-compliance identified in 2003.

UNREVIEWED ENVIRONMENTAL QUESTIONS

All proposed changes to the PNPP design or operation, as well as tests or experiments, must be evaluated for potential environmental impacts in accordance with the EPP and administrative quality assurance procedures. In 2003, these reviews ensured that no changes to the facility or programs were performed, which could have resulted in an adverse environmental impact. Therefore, there were no potentially significant unreviewed environmental questions identified.

NON-ROUTINE REPORTS

There were three (3) non-routine reports submitted in 2003.

On January 29, 2003, the OEPA was notified that construction was completed on the dechlorination system upgrade and the system would now be using sodium bisulfate as the dechlorination chemical. This notification was made in accordance with the National Pollutant Discharge Elimination System (NPDES) Permit.

On June 30, 2003, the OEPA was notified that the Preliminary Effluent Limit (PEL) for copper was exceeded during the month of June 2003. The increase in copper at the plant effluent coincided with a large increase of copper levels entering the plant from Lake Erie. This notification was made in accordance with the National Pollutant Discharge Elimination System (NPDES) Permit.

On September 30, 2003, the OEPA was notified of maintenance that would be performed on the neutralization basins. This notification was made in accordance with the National Pollutant Discharge Elimination System (NPDES) Permit.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

OHIO DEPARTMENT OF NATURAL RESOURCES SURVEY

On February 21, 2003, the Ohio Department of Natural Resources (ODNR), Division of Wildlife contacted Perry requesting permission to access areas where spotted turtles had been previously documented. Perry granted the ODNR representative access, and the environmental staff participated in the surveys of the area. Although no spotted turtles were found in the previously recorded area, this was attributed to the area having been overrun by the *Phragmites sp.*

At the time of this report, the ODNR did not have their final report complete. Below is an excerpt from the draft summary of the report:

“Records indicate that the Spotted Turtle was at one time fairly common in the powerline right-of-way east of the Perry Nuclear Power Plant. In 1986, the NUS Corporation estimated a population size of 148 in a 22 acre area, based on a five year mark-recapture survey. A total of 66 Spotted Turtles were captured during this period.


The 2003 survey did not result in the capture of any Spotted Turtles on the Perry Nuclear Power Plant property. The wet prairies and meadows along the powerline right-of-way have been overrun by *Phragmites sp.* reducing their suitability as Spotted Turtle habitat. (It is believed that this native plant has been hybridized with European *Phragmites sp.*, causing it to become more aggressive in many areas.) The discovery of an open canopy fen late in 2003, however, has renewed hopes that the Spotted Turtle may still be found on the property. This fen has yet to be substantially impacted by *Phragmites sp.*

One other reptile species, the Common Snapping Turtle (*Chelydra serpentina serpentina*) was observed during the 2003 surveys. Amphibians observed on the property include the Spotted Salamander (*Ambystoma maculatum*), Red-backed Salamander (*Plethodon cinereus*), and Western Chorus Frog (*Pseudacris triseriata triseriata*). The extensive wooded wetlands on the property offer excellent habitat for these species.”

The ODNR representative has also stated verbally to the environmental staff, that the plant’s protection of these areas has maintained excellent habitat for various species. It was also stated that one of the species of salamanders observed is not commonly found in Ohio. Perry will continue to cooperate with the ODNR on any further request to access the property for surveys.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

APPENDIX A, 2003 INTER-LABORATORY CROSS CHECK COMPARISON PROGRAM RESULTS



Environmental, Inc.
Midwest Laboratory
an Allegheny Technologies Co.

700 Landwehr Road • Northbrook, IL 60062-2
(847) 564-0700 Fax (847) 564-4517

APPENDIX A

INTERLABORATORY COMPARISON PROGRAM RESULTS

NOTE: Environmental Inc., Midwest Laboratory participates in intercomparison studies administered by Environmental Resources Associates, and serves as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada. Results are reported in Appendix A. TLD Intercomparison results, in-house spikes, blanks, duplicates and mixed analyte performance evaluation program results are also reported. Appendix A is updated four times a year; the complete Appendix is included in March, June, September and December monthly progress reports only.

January, 2003 through December, 2003

Appendix A

Interlaboratory Comparison Program Results

Environmental, Inc., Midwest Laboratory, formerly Teledyne Brown Engineering Environmental Services. Midwest Laboratory has participated in interlaboratory comparison (crosscheck) programs since the formulation of its quality control program in December 1971. These programs are operated by agencies which supply environmental type samples containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on a laboratory's analytical procedures and to alert it of any possible problems.

Participant laboratories measure the concentration of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

Results in Table A-1 were obtained through participation in the environmental sample crosscheck program administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada.

The results in Table A-2 were obtained for Thermoluminescent Dosimeters (TLDs), via International Intercomparison of Environmental Dosimeters under the sponsorships listed in Table A-2. Results of internal laboratory testing is also listed.

Table A-3 lists results of the analyses on in-house "spiked" samples for the past twelve months. All samples are prepared using NIST traceable sources. Data for previous years available upon request.

Table A-4 lists results of the analyses on in-house "blank" samples for the past twelve months. Data for previous years available upon request.

Table A-5 list results of the in-house "duplicate" program for the past twelve months. Acceptance is based on the difference of the results being less than the sum of the errors. Data for previous years available upon request.

The results in Table A-6 were obtained through participation in the Mixed Analyte Performance Evaluation Program.

The results in Table A-7 were obtained through participation in the Environmental Measurement Laboratory Quality Assessment Program.

Attachment A lists acceptance criteria for "spiked" samples.

Out-of-limit results are explained directly below the result.

TABLE A-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

Lab Code	Date	Analysis	Concentration (pCi/L)		Control Limits
			Laboratory Result ^b	ERA Result ^c	
STW-973	02/17/03	Sr-89	17.0 ± 0.5	15.9 ± 5.0	7.2 - 24.6
STW-973	02/17/03	Sr-90	8.9 ± 0.3	9.0 ± 5.0	0.4 - 17.7
STW-974	02/17/03	Ba-133	14.5 ± 0.9	19.5 ± 5.0	10.8 - 28.2
STW-974	02/17/03	Co-60	37.5 ± 0.9	37.4 ± 5.0	28.7 - 46.1
STW-974	02/17/03	Cs-134	18.2 ± 0.6	17.8 ± 5.0	9.1 - 26.5
STW-974	02/17/03	Cs-137	42.7 ± 1.0	44.2 ± 5.0	35.5 - 52.9
STW-974	02/17/03	Zn-65	56.8 ± 2.2	60.3 ± 6.0	49.9 - 70.7
STW-975 ^d	02/17/03	Gr. Alpha	18.4 ± 0.3	37.6 ± 9.4	21.3 - 53.9
STW-975	02/17/03	Gr. Beta	11.7 ± 0.5	8.6 ± 5.0	0.0 - 17.2
STW-976	02/17/03	Ra-226	4.1 ± 0.1	4.7 ± 0.7	3.5 - 6.0
STW-976	02/17/03	Ra-228	7.6 ± 0.5	6.5 ± 1.6	3.7 - 9.3
STW-976	02/17/03	Uranium	52.9 ± 1.9	53.7 ± 5.4	44.4 - 63.0
STW-983	05/19/03	H-3	1290.0 ± 25.0	1250.0 ± 331.0	678.0 - 1820.0
STW-984	05/19/03	I-131	19.7 ± 1.3	20.8 ± 3.0	15.6 - 26.0
STW-985	05/19/03	Gr. Alpha	54.4 ± 3.0	70.3 ± 17.6	39.9 - 101.0
STW-985	05/19/03	Ra-226	14.9 ± 0.2	16.5 ± 2.5	12.2 - 20.8
STW-985	05/19/03	Ra-228	13.1 ± 0.6	10.3 ± 2.6	5.8 - 14.8
STW-985	05/19/03	Uranium	14.5 ± 0.4	15.1 ± 3.0	9.9 - 20.3
STW-986	05/19/03	Co-60	56.9 ± 8.6	63.8 ± 5.0	55.1 - 72.5
STW-986 ^e	05/19/03	Cs-134	61.6 ± 6.6	75.7 ± 5.0	67.0 - 84.4
STW-986	05/19/03	Cs-137	143.0 ± 1.2	150.0 ± 7.5	137.0 - 163.0
STW-986	05/19/03	Gr. Beta	309.0 ± 2.7	363.0 ± 54.5	269.0 - 457.0
STW-986	05/19/03	Sr-89	33.1 ± 0.2	31.3 ± 5.0	22.6 - 40.0
STW-986	05/19/03	Sr-90	28.8 ± 1.3	27.4 ± 5.0	18.7 - 36.1
STW-988	08/18/03	Ra-226	13.3 ± 1.1	13.4 ± 2.0	9.9 - 16.9
STW-988	08/18/03	Ra-228	11.5 ± 1.0	12.5 ± 3.1	7.1 - 17.9
STW-988	08/18/03	Uranium	12.3 ± 0.4	11.4 ± 3.0	6.2 - 16.6
STW-989	08/18/03	Ba-133	18.1 ± 1.9	20.7 ± 5.0	12.0 - 29.4
STW-989	08/18/03	Co-60	35.9 ± 1.3	37.4 ± 5.0	28.7 - 46.1
STW-989	08/18/03	Cs-134	32.6 ± 1.8	32.6 ± 5.0	23.9 - 41.3
STW-989	08/18/03	Cs-137	48.3 ± 0.6	44.3 ± 5.0	35.6 - 53.0
STW-989	08/18/03	Zn-65	58.9 ± 2.1	60.2 ± 6.0	49.8 - 70.6
STW-990	08/18/03	Gr. Alpha	41.8 ± 3.4	56.2 ± 16.3	36.9 - 93.3
STW-990 ^f	08/18/03	Gr. Beta	51.3 ± 3.0	31.6 ± 5.0	22.9 - 40.3
STW-991	08/18/03	Sr-89	57.2 ± 4.3	58.8 ± 5.0	50.1 - 67.5
STW-991	08/18/03	Sr-90	21.2 ± 0.9	20.6 ± 5.0	11.9 - 29.3

TABLE A-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)^a.

Lab Code	Date	Analysis	Concentration (pCi/L)		Control Limits
			Laboratory Result ^b	ERA Result ^c	
STW-997	11/18/03	Gr. Alpha	37.0 ± 2.0	29.5 ± 7.4	16.7 - 42.3
STW-997	11/18/03	Gr. Beta	26.5 ± 0.8	26.3 ± 5.0	17.6 - 35.0
STW-998	11/18/03	I-131	14.8 ± 0.3	16.5 ± 3.0	11.3 - 21.7
STW-999	11/18/03	Ra-226	17.2 ± 1.1	17.8 ± 2.7	13.2 - 22.4
STW-999	11/18/03	Ra-228	6.6 ± 0.3	6.8 ± 1.7	3.8 - 9.7
STW-999	11/18/03	Uranium	11.7 ± 0.3	11.7 ± 3.0	6.5 - 16.9
STW-1000	11/18/03	H-3	15900.0 ± 174.0	14300.0 ± 1430.0	11800.0 - 16800.0
STW-1001	11/18/03	Gr. Alpha	32.9 ± 0.3	54.2 ± 3.0	30.7 - 77.7
STW-1001	11/18/03	Ra-226	16.5 ± 0.9	16.1 ± 2.4	11.9 - 20.3
STW-1001	11/18/03	Ra-228	6.2 ± 0.5	5.5 ± 1.4	3.1 - 7.9
STW-1001	11/18/03	Uranium	9.7 ± 1.5	9.3 ± 13.6	4.1 - 14.5
STW-1002	11/18/03	Co-60	27.7 ± 1.9	27.7 ± 5.0	19.0 - 36.4
STW-1002	11/18/03	Cs-134	21.5 ± 1.1	23.4 ± 5.0	17.6 - 29.2
STW-1002	11/18/03	Cs-137	66.3 ± 2.8	64.2 ± 5.0	55.5 - 72.9
STW-1002	11/18/03	Gr. Beta	159.0 ± 2.5	168.0 ± 5.0	124.0 - 212.0
STW-1002	11/18/03	Sr-89	48.5 ± 0.4	50.4 ± 5.0	41.7 - 59.1
STW-1002	11/18/03	Sr-90	10.1 ± 3.0	10.2 ± 25.2	1.5 - 18.9

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the environmental samples crosscheck program operated by Environmental Resources Associates (ERA).

^b Unless otherwise indicated, the laboratory result is given as the mean ± standard deviation for three determinations.

^c Results are presented as the known values, expected laboratory precision (1 sigma, 1 determination) and control limits as provided by ERA.

^d Recount of the original sample still low. The ERA blank was spiked in the lab;

known value of 20.1 pCi/L, measured 21.5 ± 1.1 pCi/L. No explanation for ERA test failure.

^e Lower bias observed for gamma spectroscopic analysis. The undiluted sample was reanalyzed;

Results of reanalysis, Co-60: 62.3 pCi/L., Cs-134: 69.2 pCi/L., Cs-137: 152.3 pCi/L.

^f Reason for deviation unknown. A recount of the original planchets averaged 43.4 pCi/L.

Cs-137 activity by gamma spectroscopy; 28.3 pCi/L. Result of reanalysis; 29.3 pCi/L.

Attachment A

ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES^a

Analysis	Level	One standard deviation for single determination
Gamma Emitters	5 to 100 pCi/liter or kg > 100 pCi/liter or kg	5.0 pCi/liter 5% of known value
Strontium-89 ^b	5 to 50 pCi/liter or kg > 50 pCi/liter or kg	5.0 pCi/liter 10% of known value
Strontium-90 ^b	2 to 30 pCi/liter or kg > 30 pCi/liter or kg	5.0 pCi/liter 10% of known value
Potassium-40	> 0.1 g/liter or kg	5% of known value
Gross alpha	20 pCi/liter > 20 pCi/liter	5.0 pCi/liter 25% of known value
Gross beta	100 pCi/liter > 100 pCi/liter	5.0 pCi/liter 5% of known value
Tritium	4,000 pCi/liter > 4,000 pCi/liter	1s = (pCi/liter) = 169.85 x (known) ^{0.0933} 10% of known value
Radium-226,-228	0.1 pCi/liter	15% of known value
Plutonium	0.1 pCi/liter, gram, or sample	10% of known value
Iodine-131, Iodine-129 ^b	55 pCi/liter > 55 pCi/liter	6.0 pCi/liter 10% of known value
Uranium-238, Nickel-63 ^b Technetium-99 ^b	35 pCi/liter > 35 pCi/liter	6.0 pCi/liter 15% of known value
Iron-55 ^b	50 to 100 pCi/liter > 100 pCi/liter	10 pCi/liter 10% of known value
Others ^b	—	20% of known value

^a From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year, 1981-1982, EPA-600/4-81-004.

^b Laboratory limit.

TABLE A-2. Crosscheck program results; Thermoluminescent Dosimetry, (TLDs).

Lab Code	TLD Type	Date	Description	Known Value	mR	
					Lab Result ± 2 sigma	Control Limits
<u>Environmental, Inc.</u>						
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 120	4.69	4.74 ± 0.54	3.28 - 6.10
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 150	3.00	3.02 ± 0.20	2.10 - 3.90
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 180	2.08	1.89 ± 0.45	1.46 - 2.70
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 180	2.08	2.11 ± 0.22	1.46 - 2.70
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 30	75.00	84.40 ± 4.87	52.50 - 97.50
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 60	18.75	19.11 ± 1.86	13.13 - 24.38
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 60	18.75	22.82 ± 5.41	13.13 - 24.38
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 90	8.33	9.05 ± 1.17	5.83 - 10.83
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 90	8.33	7.60 ± 1.08	5.83 - 10.83
<u>Environmental, Inc.</u>						
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 30	61.96	73.50 ± 2.58	43.37 - 80.55
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 60	15.49	19.70 ± 0.51	10.84 - 20.14
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 60	15.49	16.93 ± 1.37	10.84 - 20.14
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 90	6.88	8.06 ± 0.60	4.82 - 8.94
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 90	6.88	6.64 ± 0.58	4.82 - 8.94
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 120	3.87	4.39 ± 0.17	2.71 - 5.03
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 150	2.48	2.34 ± 0.18	1.74 - 3.22
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 150	2.48	2.51 ± 0.16	1.74 - 3.22
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 180	1.72	2.01 ± 0.13	1.20 - 2.24

TABLE A-3. In-House "Spike" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L) ^a		
				Laboratory results 2s, n=1 ^b	Known Activity	Control Limits ^c
SPW-356	water	1/2/2003	Sr-90	34.04 ± 1.57	30.93	24.74 - 37.12
W-10303	water	1/3/2003	Gr. Beta	63.24 ± 1.20	63.90	53.90 - 73.90
W-11303	water	1/13/2003	Gr. Beta	59.75 ± 1.10	63.90	53.90 - 73.90
W-12103	water	1/21/2003	Gr. Beta	61.56 ± 1.59	63.99	53.99 - 73.99
SPAP-446	Air Filter	1/31/2003	Gr. Beta	1.49 ± 0.02	1.52	-8.48 - 11.52
SPW-468	water	1/31/2003	H-3	95982.00 ± 865.00	89607.00	71685.60 - 107528.40
W-20703	water	2/7/2003	Fe-55	9095.00 ± 114.00	10587.00	8469.60 - 12704.40
SPU-1347	Urine	3/1/2003	H-3	1724.00 ± 412.00	1784.33	1101.27 - 2467.39
DW-30303	water	3/3/2003	Gr. Beta	65.44 ± 0.59	63.90	53.90 - 73.90
SPCH-964	Charcoal	3/8/2003	I-131(G)	73.37 ± 0.28	69.45	59.45 - 79.45
SPMI-1086	Milk	3/13/2003	Cs-137	57.18 ± 8.03	49.50	39.50 - 59.50
SPMI-1086	Milk	3/13/2003	I-131	75.13 ± 12.01	67.60	54.08 - 81.12
SPMI-1086	Milk	3/13/2003	I-131(G)	65.81 ± 1.06	67.56	57.56 - 77.56
SPW-1088	water	3/13/2003	Co-60	27.16 ± 4.79	28.20	18.20 - 38.20
SPW-1088	water	3/13/2003	Cs-137	51.74 ± 9.15	49.50	39.50 - 59.50
SPW-1088	water	3/13/2003	I-131(G)	68.14 ± 12.92	67.60	57.60 - 77.60
SPW-1088	water	3/13/2003	I-131	76.94 ± 1.13	67.56	54.05 - 81.07
SPVE-1110	Vegetation	3/14/2003	I-131(G)	122.80 ± 16.80	124.00	111.60 - 136.40
SPW-1194	water	3/21/2003	Co-60	31.09 ± 6.28	28.15	18.15 - 38.15
SPW-1194	water	3/21/2003	Cs-137	55.11 ± 0.13	49.50	39.50 - 59.50
SPW-1194	water	3/21/2003	I-131(G)	66.17 ± 9.15	67.60	57.60 - 77.60
W-32103	water	3/21/2003	C-14	5201.00 ± 16.60	4966.00	2979.60 - 6952.40
SPCH-1429	Charcoal	4/1/2003	I-131(G)	8.83 ± 0.11	9.18	-0.82 - 19.18
W-40103	water	4/1/2003	Gr. Beta	67.74 ± 0.52	63.39	53.39 - 73.39
SPF-1407	Fish	4/2/2003	Cs-134	0.58 ± 0.03	0.59	0.35 - 0.83
SPF-1407	Fish	4/2/2003	Cs-137	1.29 ± 0.06	1.32	0.79 - 1.85
SPAP-1409	Air Filter	4/2/2003	Gr. Beta	1.44 ± 0.02	1.51	-8.49 - 11.51
SPU-41203	Urine	4/12/2003	H-3	1798.50 ± 409.30	1784.33	1101.27 - 2467.39
SPU-41703	Urine	4/17/2003	H-3	1625.10 ± 401.30	1784.33	1101.27 - 2467.39
SPW-2022	water	4/25/2003	H-3	89007.00 ± 798.00	88463.00	70770.40 - 106155.60
SPW-2053	water	4/28/2003	Cs-137	45.70 ± 9.44	49.35	39.35 - 59.35
SPW-2053	water	4/28/2003	Sr-90	47.51 ± 1.87	44.47	35.58 - 53.36
SPMI-2055	Milk	4/28/2003	Cs-137	61.65 ± 7.17	65.80	55.80 - 75.80
SPMI-2055	Milk	4/28/2003	Sr-90	38.45 ± 1.59	44.74	35.79 - 53.69
W-50603	water	5/6/2003	Gr. Beta	70.95 ± 0.53	63.39	53.39 - 73.39
W-60303	water	6/3/2003	Gr. Beta	63.00 ± 0.51	65.73	55.73 - 75.73
SPW-3960	water	7/15/2003	H-3	88700.00 ± 822.00	87369.00	69895.20 - 104842.80
SPMI-4019	Milk	7/18/2003	Cs-137	47.17 ± 7.22	49.11	39.11 - 59.11
SPMI-4019	Milk	7/18/2003	Sr-89	40.95 ± 4.88	49.49	39.49 - 59.49
SPMI-4019	Milk	7/18/2003	Sr-90	45.30 ± 1.73	44.24	35.39 - 53.09
SPW-4023	water	7/18/2003	Cs-137	51.92 ± 6.24	49.11	39.11 - 59.11
SPW-4023	water	7/18/2003	Sr-89	42.49 ± 10.23	49.49	39.49 - 59.49
SPW-4023	water	7/18/2003	Sr-90	49.69 ± 3.04	44.24	35.39 - 53.09
SPW-4518	water	8/8/2003	Fe-55	8176.00 ± 107.00	9330.00	7464.00 - 11196.00

TABLE A-3. In-House "Spike" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L)		
				Laboratory results 2s, n=1 ^b	Known Activity	Control Limits ^c
SPW-6197	water	10/16/2003	Tc-99	540.14 ± 54.00	539.73	377.81 - 701.65
SPAP-3958	Air Filter	10/28/2003	Gr. Beta	1.45 ± 0.02	1.50	-8.50 - 11.50
SPW-6401	water	10/28/2003	H-3	84867.00 ± 826.00	85984.00	68787.20 - 103180.80
SPAP-6403	Air Filter	10/28/2003	Gr. Beta	1.71 ± 0.02	1.49	-8.51 - 11.49
SPF-6418	Fish	10/28/2003	Cs-134	0.50 ± 0.02	0.49	0.29 - 0.69
SPF-6418	Fish	10/28/2003	Cs-137	1.37 ± 0.05	1.30	0.78 - 1.82
SPW-6421	water	10/28/2003	Fe-55	104.18 ± 1.26	88.18	68.18 - 108.18
SPMI-7459	Milk	12/12/2003	Cs-134	41.06 ± 2.45	41.88	31.88 - 51.88
SPMI-7459	Milk	12/12/2003	Cs-137	48.48 ± 4.99	48.64	38.64 - 58.64
SPMI-7459	Milk	12/12/2003	Sr-89	55.94 ± 4.12	65.80	52.64 - 78.96
SPMI-7459	Milk	12/12/2003	Sr-90	41.86 ± 1.57	43.80	35.04 - 52.56
SPW-7461	water	12/12/2003	Cs-134	44.07 ± 1.49	41.88	31.88 - 51.88
SPW-7461	water	12/12/2003	Cs-137	50.26 ± 2.67	48.64	38.64 - 58.64
SPW-7461	water	12/12/2003	Sr-89	56.41 ± 4.87	65.80	52.64 - 78.96
SPW-7461	water	12/12/2003	Sr-90	48.44 ± 1.84	43.80	35.04 - 52.56

^c Control limits are based on Attachment A, Page A2 of this report.

NOTE: For fish, Jello is used for the Spike matrix. For Vegetation, cabbage is used for the Spike matrix.

TABLE A-3. In-House "Spike" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L) ^a		
				Laboratory results 2s, n=1 ^b	Known Activity	Control Limits ^c
SPW-5824		10/1/2002	Ra-226	17.80 ± 0.58	17.22	12.05 - 22.39
SPW-5824		10/1/2002	Ra-228	12.38 ± 1.92	17.70	12.39 - 23.01
W-100302	water	10/7/2002	Gr. Alpha	17.81 ± 4.08	16.58	6.58 - 26.58
W-100302	water	10/7/2002	Gr. Beta	125.20 ± 7.48	127.80	115.02 - 140.58
W-100302	water	10/8/2002	Gr. Alpha	16.12 ± 1.28	16.58	6.58 - 26.58
W-100302	water	10/8/2002	Gr. Alpha	15.58 ± 0.37	16.58	6.58 - 26.58
W-100302	water	10/8/2002	Gr. Beta	129.14 ± 0.73	127.80	115.02 - 140.58
W-100302	water	10/8/2002	Gr. Beta	123.40 ± 2.50	127.80	115.02 - 140.58
W-100802	water	10/10/2002	Gr. Alpha	18.11 ± 0.53	16.58	6.58 - 26.58
W-100802	water	10/10/2002	Gr. Beta	62.18 ± 0.54	63.90	53.90 - 73.90
SPW-5824		10/11/2002	Ra-226	21.58 ± 0.83	17.22	12.05 - 22.39
SPW-6753		10/11/2002	Ra-226	20.88 ± 0.74	21.13	14.79 - 27.47
SPW-6753		10/11/2002	Ra-226	18.59 ± 0.66	21.13	14.79 - 27.47
SPW-6753		10/11/2002	Ra-226	22.44 ± 0.73	21.13	14.79 - 27.47
SPW-6753		10/11/2002	Ra-226	19.96 ± 0.65	21.13	14.79 - 27.47
SPW-6753		10/11/2002	Ra-228	26.01 ± 3.06	24.50	17.15 - 31.85
SPW-6753		10/11/2002	Ra-228	20.09 ± 1.85	24.50	17.15 - 31.85
SPW-6753		10/11/2002	Ra-228	22.32 ± 2.38	24.50	17.15 - 31.85
SPW-6753		10/11/2002	Ra-228	18.42 ± 2.30	24.50	17.15 - 31.85
SPW-6753		10/11/2002	Ra-228	4.89 ± 1.28	24.50	17.15 - 31.85
SPW-6753		10/11/2002	Ra-228	19.67 ± 2.69	24.50	17.15 - 31.85
W-100802	water	10/11/2002	Gr. Alpha	11.89 ± 0.34	16.58	6.58 - 26.58
W-100802	water	10/11/2002	Gr. Beta	65.49 ± 0.52	63.90	53.90 - 73.90
SPW-5824		10/14/2002	Ra-228	18.67 ± 2.57	17.70	12.39 - 23.01
SPW-6880	water	10/16/2002	U-238	39.79 ± 3.51	41.73	29.21 - 54.25
W-101202	water	10/16/2002	Gr. Alpha	15.53 ± 0.43	16.58	6.58 - 26.58
W-101202	water	10/16/2002	Gr. Beta	65.04 ± 0.54	63.90	53.90 - 73.90
W-100802	water	10/17/2002	Gr. Alpha	13.36 ± 0.87	16.58	6.58 - 26.58
W-100802	water	10/17/2002	Gr. Beta	64.58 ± 1.29	63.90	53.90 - 73.90
W-101202	water	10/17/2002	Gr. Alpha	17.21 ± 0.45	16.58	6.58 - 26.58
W-101202	water	10/17/2002	Gr. Beta	66.06 ± 0.55	63.90	53.90 - 73.90
W-102302	water	10/23/2002	Gr. Alpha	16.90 ± 0.39	16.58	6.58 - 26.58
W-102302	water	10/23/2002	Gr. Alpha	18.29 ± 0.42	16.58	6.58 - 26.58
W-102302	water	10/23/2002	Gr. Beta	113.59 ± 0.68	105.58	95.02 - 116.14
W-102302	water	10/23/2002	Gr. Beta	113.61 ± 0.72	105.58	95.02 - 116.14
W-102802	water	10/28/2002	Gr. Alpha	24.14 ± 0.52	16.58	6.58 - 26.58
W-102802	water	10/28/2002	Gr. Beta	66.76 ± 0.58	63.90	53.90 - 73.90
W-103102	water	10/31/2002	Gr. Alpha	21.12 ± 1.08	16.58	6.58 - 26.58
W-103102	water	10/31/2002	Gr. Beta	65.73 ± 1.30	63.90	53.90 - 73.90
W-110502	water	11/5/2002	Gr. Alpha	13.49 ± 0.66	16.58	6.58 - 26.58
W-110502	water	11/5/2002	Gr. Beta	68.62 ± 1.24	63.90	53.90 - 73.90
W-7603	water	11/8/2002	U-238	39.54 ± 2.18	41.73	29.21 - 54.25
W-110902	water	11/9/2002	Gr. Alpha	23.57 ± 1.16	16.58	6.58 - 26.58
W-110902	water	11/9/2002	Gr. Beta	58.60 ± 1.23	63.90	53.90 - 73.90

TABLE A-3. In-House "Spike" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L)		
				Laboratory results 2s, n=1 ^b	Known Activity	Control Limits ^c
W-110902	water	11/9/2002	Gr. Beta	58.60 ± 1.23	63.90	53.90 - 73.90
W-111202	water	11/12/2002	Gr. Alpha	22.12 ± 0.47	16.58	6.58 - 26.58
W-111202	water	11/12/2002	Gr. Beta	66.45 ± 0.52	63.90	53.90 - 73.90
SPW-6753		11/20/2002	Ra-226	19.44 ± 0.65	21.13	14.79 - 27.47
W-112102	water	11/21/2002	Gr. Alpha	21.67 ± 0.46	16.58	6.58 - 26.58
W-112102	water	11/21/2002	Gr. Beta	63.36 ± 0.51	63.90	53.90 - 73.90
W-112602	water	11/26/2002	Gr. Alpha	16.50 ± 0.44	16.58	6.58 - 26.58
W-112602	water	11/26/2002	Gr. Beta	63.27 ± 0.58	63.90	53.90 - 73.90
W-113002	water	11/30/2002	Gr. Alpha	12.03 ± 0.82	16.58	6.58 - 26.58
W-113002	water	11/30/2002	Gr. Beta	60.65 ± 1.25	63.90	53.90 - 73.90
W-120302	water	12/3/2002	Gr. Alpha	19.97 ± 1.07	16.58	6.58 - 26.58
W-120302	water	12/3/2002	Gr. Beta	64.32 ± 1.29	63.90	53.90 - 73.90
SPW-8086	water	12/5/2002	U-238	38.61 ± 3.00	41.73	29.21 - 54.25
SPW-8138		12/7/2002	Ra-226	19.91 ± 0.60	21.13	14.79 - 27.47
SPW-8138		12/7/2002	Ra-226	20.19 ± 0.64	21.13	14.79 - 27.47
SPW-8138		12/7/2002	Ra-228	21.00 ± 2.30	24.04	16.83 - 31.25
SPW-8138		12/7/2002	Ra-228	19.07 ± 3.44	24.04	16.83 - 31.25
SPW-8499		12/7/2002	Ra-226	21.82 ± 0.62	21.13	14.79 - 27.47
SPW-8499		12/7/2002	Ra-226	22.11 ± 0.82	21.13	14.79 - 27.47
SPW-8499		12/7/2002	Ra-226	19.57 ± 0.79	21.13	14.79 - 27.47
SPW-8499		12/7/2002	Ra-226	21.36 ± 0.69	21.13	14.79 - 27.47
SPW-8499		12/7/2002	Ra-228	30.54 ± 3.37	39.93	27.95 - 51.91
SPW-8499		12/7/2002	Ra-228	38.66 ± 2.88	39.93	27.95 - 51.91
SPW-8499		12/7/2002	Ra-228	39.64 ± 3.24	39.93	27.95 - 51.91
SPW-8499		12/7/2002	Ra-228	41.93 ± 3.32	39.93	27.95 - 51.91
W-120702	water	12/7/2002	Gr. Alpha	17.82 ± 0.42	16.58	6.58 - 26.58
W-120702	water	12/7/2002	Gr. Beta	67.90 ± 0.53	63.90	53.90 - 73.90
W-121002	water	12/10/2002	Gr. Alpha	19.05 ± 0.50	16.58	6.58 - 26.58
W-121002	water	12/10/2002	Gr. Beta	62.38 ± 0.56	63.90	53.90 - 73.90
W-121402	water	12/14/2002	Gr. Alpha	12.79 ± 0.79	16.58	6.58 - 26.58
W-121402	water	12/14/2002	Gr. Beta	66.46 ± 1.31	63.90	53.90 - 73.90
W-122102	water	12/21/2002	Gr. Alpha	16.77 ± 0.39	16.58	6.58 - 26.58
W-122102	water	12/21/2002	Gr. Beta	60.13 ± 0.49	63.90	53.90 - 73.90
SPW-8636	water	12/23/2002	U-238	35.50 ± 1.96	41.60	29.12 - 54.08
W-123002	water	12/30/2002	Gr. Alpha	19.65 ± 0.97	16.58	6.58 - 26.58
W-123002	water	12/30/2002	Gr. Beta	64.61 ± 1.13	63.90	53.90 - 73.90
W-10303	water	1/3/2003	Gr. Alpha	23.79 ± 1.07	16.58	6.58 - 26.58
W-10303	water	1/3/2003	Gr. Beta	63.24 ± 1.20	63.90	53.90 - 73.90
W-10803	water	1/8/2003	Gr. Alpha	21.45 ± 1.01	16.58	6.58 - 26.58
W-10803	water	1/8/2003	Gr. Beta	58.74 ± 1.16	63.90	53.90 - 73.90

Concentration (pCi/L)

TABLE A-4. In-House "Blank" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L) ^a		
				Laboratory results (4.66σ)		Acceptance Criteria (4.66 σ)
				LLD	Activity ^b	
SPW-357	water	1/2/2003	Sr-90	0.50	0.12 ± 0.25	1
W-10303	water	1/3/2003	Gr. Beta	0.12	0.022 ± 0.10	3.2
W-11303	water	1/13/2003	Gr. Beta	0.14	0.035 ± 0.10	3.2
W-12103	water	1/21/2003	Gr. Beta	0.12	0.029 ± 0.09	3.2
SPAP-447	Air Filter	1/31/2003	Gr. Beta	0.00	-0.0034 ± 0.00	3.2
SPW-469	water	1/31/2003	H-3	160.20	19.3 ± 80.30	200
W-20103	water	2/1/2003	Gr. Beta	0.17	0.0 ± 0.12	3.2
W-20703	water	2/7/2003	Fe-55	802.00	149 ± 498.00	1000
DW-30303		3/3/2003	Gr. Beta	0.15	0.007 ± 0.11	3.2
SPCH-965	Charcoal Cani:	3/8/2003	I-131(G)	0.01		9.6
SPMI-1087	Milk	3/13/2003	Cs-134	7.49		10
SPMI-1087	Milk	3/13/2003	Cs-137	7.90		10
SPMI-1087	Milk	3/13/2003	I-131	0.33	-0.013 ± 0.18	0.5
SPMI-1087	Milk	3/13/2003	I-131(G)	7.76		20
SPW-1089	water	3/13/2003	Co-60	4.48		10
SPW-1089	water	3/13/2003	Cs-134	5.60		10
SPW-1089	water	3/13/2003	Cs-137	4.32		10
SPW-1089	water	3/13/2003	I-131	0.29	-0.050 ± 0.16	0.5
SPVE-1111	Vegetation	3/14/2003	I-131(G)	7.53		20
W-32103	water	3/21/2003	C-14	17.50	-0.4 ± 9.200	200
SPCH-1430	Charcoal Cani:	4/1/2003	I-131(G)	0.01		9.6
W-40103	water	4/1/2003	Gr. Beta	0.14	-0.11 ± 0.100	3.2
SPF-1408	Fish	4/2/2003	Cs-134	0.01		100
SPF-1408	Fish	4/2/2003	Cs-137	0.01		100
SPAP-1410	Air Filter	4/2/2003	Gr. Beta	0.00	-0.0029 ± 0.002	3.2
SPU-41203	Urine	4/12/2003	H-3	653.99	542.28 ± 364.780	200
SPU-41703	Urine	4/17/2003	H-3	648.35	100.1 ± 344.800	200
SPW-2054	water	4/28/2003	Cs-137	3.16		10
SPW-2054	water	4/28/2003	Sr-89	0.55	0.45 ± 0.50	5
SPW-2054	water	4/28/2003	Sr-90	0.55	0.072 ± 0.260	1
SPMI-2056 ^c	Milk	4/28/2003	Sr-90	0.77	0.66 ± 0.430	1
SPMI-2056	Milk	4/28/2003	Cs-137	2.74		10
SPMI-2056	Milk	4/28/2003	I-131(G)	3.54		20
W-50603	water	5/6/2003	Gr. Beta	0.12	0 ± 0.090	3.2
W-60303	water	6/3/2003	Gr. Beta	0.14	-0.035 ± 0.095	3.2
SPW-3960	water	7/15/2003	H-3	156.60	53.4 ± 80.200	200
SPMI-4018	Milk	7/18/2003	Cs-137	4.10		10
SPMI-4018	Milk	7/18/2003	Sr-89	0.73	0.39 ± 0.880	5
SPMI-4018 ^c	Milk	7/18/2003	Sr-90	0.51	0.93 ± 0.340	1
SPW-4024	water	7/18/2003	Sr-89	0.83	0.21 ± 0.730	5
SPW-4024	water	7/18/2003	Sr-90	0.62	0.09 ± 0.300	1
SPW-4519	water	8/8/2003	Fe-55	527.00	87 ± 369.000	1000
SPW-6401	water	10/28/2003	H-3	163.80	-23.8 ± 85.000	200

TABLE A-4. In-House "Blank" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L) ^a		
				Laboratory results (4.66σ)		Acceptance Criteria (4.66 σ)
				LLD	Activity ^b	
SPAP-6404	Air Filter	10/28/2003	Gr. Beta	0.87	-0.99 ± 0.440	3.2
SPF-6419	Fish	10/28/2003	Cs-134	0.01		100
SPF-6419	Fish	10/28/2003	Cs-137	0.01		100
SPMI-7460	Milk	12/12/2003	Cs-134	4.52		10
SPMI-7460	Milk	12/12/2003	Cs-137	5.77		10
SPMI-7460 ^c	Milk	12/12/2003	Sr-90	0.50	1.26 ± 0.370	1

^a Liquid sample results are reported in pCi/Liter, air filters(pCi/filter), charcoal (pCi/charcoal canister), and solid samples (pCi/kg).

^b The activity reported is the net activity result.

^c Low levels of Sr-90 are still detected in the environment. A concentration of (1-5 pCi/L) in milk is not unusual.

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a		Averaged Result
			First Result	Second Result	
MI-24, 25	1/2/2003	K-40	1362.00 ± 117.00	1377.00 ± 188.00	1369.50 ± 110.72
MI-24, 25	1/2/2003	Sr-90	1.45 ± 0.40	2.21 ± 0.50	1.83 ± 0.32
CF-47, 48	1/2/2003	Gr. Beta	2.72 ± 0.10	2.84 ± 0.10	2.78 ± 0.07
CF-47, 48	1/2/2003	K-40	2.61 ± 0.31	2.32 ± 0.12	2.47 ± 0.17
AP-8827, 8828	1/2/2003	Be-7	0.06 ± 0.01	0.05 ± 0.02	0.05 ± 0.01
AP-8869, 8870	1/2/2003	Be-7	0.04 ± 0.02	0.05 ± 0.02	0.05 ± 0.01
MI-119, 120	1/8/2003	K-40	1351.90 ± 116.10	1234.70 ± 108.70	1293.30 ± 79.52
MI-119, 120	1/8/2003	Sr-90	2.22 ± 0.43	1.88 ± 0.40	2.05 ± 0.30
MI-213, 214	1/14/2003	K-40	1372.30 ± 104.80	1303.80 ± 109.10	1338.05 ± 75.64
MI-213, 214	1/14/2003	Sr-90	1.81 ± 0.41	2.29 ± 0.45	2.05 ± 0.31
MI-262, 263	1/15/2003	K-40	1399.20 ± 200.70	1347.70 ± 126.40	1373.45 ± 118.59
S-696, 697	1/29/2003	Gr. Alpha	24.70 ± 4.89	23.23 ± 4.64	23.97 ± 3.37
S-696, 697	1/29/2003	Gr. Beta	22.89 ± 2.67	22.71 ± 2.73	22.80 ± 1.91
MI-448, 449	2/3/2003	K-40	1159.70 ± 157.90	1396.40 ± 106.20	1278.05 ± 95.15
SW-470, 471	2/3/2003	Gr. Beta	13.62 ± 1.23	15.21 ± 1.21	14.42 ± 0.86
SW-470, 471	2/3/2003	K-40 (ICP)	5.10 ± 0.51	5.20 ± 0.52	5.15 ± 0.36
SW-470, 471	2/3/2003	K-40	5.80 ± 0.51	5.90 ± 0.52	5.85 ± 0.36
MI-517, 518	2/4/2003	K-40	1437.70 ± 125.50	1357.70 ± 188.00	1397.70 ± 113.02
MI-541, 542	2/5/2003	K-40	1443.00 ± 194.80	1385.20 ± 190.10	1414.10 ± 136.09
MI-620, 621	2/11/2003	K-40	1294.70 ± 115.10	1234.10 ± 165.10	1264.40 ± 100.63
DW-922, 923	3/4/2003	I-131	0.67 ± 0.16	0.79 ± 0.16	0.73 ± 0.11
CF-1048, 1049 ^b	3/10/2003	K-40	3.09 ± 0.12	2.67 ± 0.07	2.88 ± 0.07
LW-1152, 1153	3/13/2003	H-3	1147.26 ± 122.56	1094.42 ± 120.92	1120.84 ± 86.09
F-1120, 1121	3/14/2003	Cs-137	0.04 ± 0.02	0.05 ± 0.01	0.05 ± 0.01
F-1120, 1121	3/14/2003	Gr. Beta	2.04 ± 0.06	2.11 ± 0.06	2.08 ± 0.04
F-1120, 1121	3/14/2003	K-40	1.93 ± 0.38	1.89 ± 0.25	1.91 ± 0.23
DW-1278, 1279	3/25/2003	I-131	0.37 ± 0.22	0.34 ± 0.29	0.36 ± 0.18
SO-1380, 1381	3/25/2003	Gr. Beta	18.60 ± 2.68	20.53 ± 2.83	19.57 ± 1.95
LW-1299, 1300	3/27/2003	Gr. Beta	2.35 ± 0.55	2.48 ± 0.56	2.42 ± 0.39
LW-1320, 1321	3/27/2003	H-3	487.12 ± 104.43	422.00 ± 102.00	454.56 ± 72.99
W-1403, 1404	3/31/2003	Sr-90	0.96 ± 0.32	1.10 ± 0.42	1.03 ± 0.26
AP-2019, 2020	3/31/2003	Be-7	0.07 ± 0.01	0.08 ± 0.01	0.07 ± 0.01
MI-1422, 1423	4/1/2003	K-40	1410.00 ± 176.00	1340.00 ± 114.00	1375.00 ± 104.85
MI-2170, 2171	4/1/2003	K-40	1452.30 ± 129.10	1472.50 ± 191.00	1462.40 ± 115.27
MI-1422, 1423	4/2/2003	Sr-90	1.84 ± 0.42	1.15 ± 0.39	1.50 ± 0.29
AP-1633, 1634	4/2/2003	Be-7	0.05 ± 0.01	0.06 ± 0.01	0.06 ± 0.01
AP-1871, 1872	4/2/2003	Be-7	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
AP-1974, 1975	4/2/2003	Be-7	0.08 ± 0.02	0.07 ± 0.02	0.08 ± 0.01
LW-1828, 1829	4/11/2003	Gr. Beta	2.49 ± 0.58	3.42 ± 0.63	2.96 ± 0.43
S-1544, 1545	4/15/2003	K-40	15.84 ± 2.36	15.41 ± 2.02	15.63 ± 1.55
DW-1913, 1914	4/15/2003	I-131	0.29 ± 0.21	0.42 ± 0.19	0.36 ± 0.14
MI-1996, 1997	4/21/2003	Sr-90	2.05 ± 0.74	3.25 ± 0.91	2.65 ± 0.58
MI-1996, 1997	4/22/2003	K-40	1580.20 ± 118.90	1602.10 ± 120.40	1591.15 ± 84.61

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a		Averaged Result
			First Result	Second Result	
LW-2063, 2064	4/28/2003	Gr. Beta	2.33 ± 0.66	2.68 ± 0.60	2.51 ± 0.45
SWU-2275, 2276	4/28/2003	Gr. Beta	3.62 ± 0.67	4.60 ± 0.71	4.11 ± 0.49
G-2149, 2150	4/30/2003	Be-7	0.71 ± 0.19	0.69 ± 0.20	0.70 ± 0.14
TD-2339, 2340	5/1/2003	H-3	221.00 ± 91.00	161.00 ± 88.00	191.00 ± 63.29
SO-2381, 2382	5/1/2003	Cs-137	0.11 ± 0.03	0.10 ± 0.02	0.10 ± 0.02
SO-2381, 2382	5/1/2003	Gr. Alpha	11.14 ± 5.15	10.39 ± 5.60	10.77 ± 3.80
SO-2381, 2382	5/1/2003	Gr. Beta	35.18 ± 4.69	39.66 ± 5.24	37.42 ± 3.52
SO-2381, 2382	5/1/2003	K-40	18.29 ± 0.84	17.83 ± 0.84	18.06 ± 0.59
SO-2381, 2382	5/1/2003	Sr-90	0.06 ± 0.02	0.10 ± 0.02	0.08 ± 0.01
DW-2317, 2318	5/6/2003	I-131	1.77 ± 0.27	1.47 ± 0.26	1.62 ± 0.19
BS-2595, 2596	5/6/2003	Cs-137	0.06 ± 0.02	0.06 ± 0.02	0.06 ± 0.02
BS-2595, 2596	5/6/2003	K-40	13.74 ± 0.62	14.10 ± 0.73	13.92 ± 0.48
U-2484, 2485	5/9/2003	H-3	512.00 ± 100.00	370.00 ± 95.00	441.00 ± 68.97
SO-2645, 2646	5/14/2003	Be-7	1.18 ± 0.42	1.21 ± 0.35	1.19 ± 0.27
SO-2645, 2646	5/14/2003	Cs-137	0.11 ± 0.04	0.09 ± 0.05	0.10 ± 0.03
SO-2645, 2646	5/14/2003	K-40	16.50 ± 1.13	15.33 ± 1.09	15.91 ± 0.79
MI-2696, 2697	5/19/2003	K-40	1320.40 ± 124.50	1394.10 ± 113.00	1357.25 ± 84.07
MI-2696, 2697	5/19/2003	Sr-90	1.49 ± 0.47	2.01 ± 0.45	1.75 ± 0.32
SO-2787, 2788	5/28/2003	Cs-137	0.27 ± 0.04	0.23 ± 0.04	0.25 ± 0.03
SO-2787, 2788	5/28/2003	Gr. Beta	19.62 ± 1.73	20.81 ± 1.72	20.21 ± 1.22
SO-2787, 2788	5/28/2003	K-40	14.77 ± 1.02	14.41 ± 1.00	14.59 ± 0.71
MI-2840, 2841	5/28/2003	K-40	1179.50 ± 167.80	1401.70 ± 120.20	1290.60 ± 103.20
SWU-2864, 2865	5/28/2003	Gr. Beta	3.39 ± 0.59	3.41 ± 0.64	3.40 ± 0.43
BS-2888, 2889	5/29/2003	Cs-137	0.05 ± 0.02	0.07 ± 0.04	0.06 ± 0.02
BS-2888, 2889	5/29/2003	K-40	9.70 ± 0.83	10.17 ± 0.87	9.93 ± 0.60
W-3230, 3231	5/30/2003	Gr. Beta	4.33 ± 1.00	3.28 ± 1.22	3.81 ± 0.79
TD-3036, 3037	6/2/2003	H-3	529.50 ± 100.00	585.50 ± 102.00	557.50 ± 71.42
SL-2909, 2910 ^b	6/3/2003	Gr. Beta	7.10 ± 0.15	7.60 ± 0.16	7.35 ± 0.11
SL-2909, 2910	6/3/2003	K-40	3.90 ± 0.67	3.49 ± 0.52	3.70 ± 0.42
SW-3080, 3081	6/10/2003	Gr. Alpha	4.63 ± 1.90	4.47 ± 1.71	4.55 ± 1.28
SW-3080, 3081	6/10/2003	Gr. Beta	9.07 ± 1.29	8.98 ± 1.28	9.02 ± 0.91
VE-3172, 3173	6/11/2003	K-40	2.62 ± 0.35	3.17 ± 0.58	2.90 ± 0.34
F-3742, 3743	6/11/2003	Gr. Beta	3.47 ± 0.13	3.71 ± 0.14	3.59 ± 0.10
F-3742, 3743	6/11/2003	K-40	2.94 ± 0.39	2.70 ± 0.40	2.82 ± 0.28
SO-3325, 3326	6/13/2003	Gr. Beta	20.95 ± 1.88	19.97 ± 2.01	20.46 ± 1.38
MI-3253, 3254	6/17/2003	K-40	1329.40 ± 121.80	1417.60 ± 130.90	1373.50 ± 89.40
MI-3297, 3298	6/17/2003	Sr-90	2.14 ± 0.57	2.27 ± 0.50	2.21 ± 0.38
WW-3380, 3381	6/23/2003	Gr. Beta	5.58 ± 0.69	5.03 ± 0.69	5.31 ± 0.49
SWT-3403, 3404	6/24/2003	Gr. Beta	2.80 ± 0.56	2.63 ± 0.55	2.72 ± 0.39
MI-3424, 3425	6/24/2003	K-40	1422.80 ± 185.40	1216.20 ± 170.10	1319.50 ± 125.80
SW-3862, 3863	6/24/2003	Gr. Beta	3.66 ± 1.18	3.70 ± 1.22	3.68 ± 0.85
G-3479, 3480	6/25/2003	Be-7	1.52 ± 0.25	1.43 ± 0.28	1.47 ± 0.19
G-3479, 3480	6/25/2003	K-40	5.02 ± 0.45	5.10 ± 0.48	5.06 ± 0.33
LW-3809, 3810	6/30/2003	Gr. Beta	2.12 ± 0.76	2.39 ± 0.72	2.25 ± 0.52

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a		Averaged Result
			First Result	Second Result	
LW-3809, 3810	6/30/2003	H-3	2814.09 ± 167.99	2812.17 ± 167.94	2813.13 ± 118.77
AP-4105, 4106	6/30/2003	Be-7	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
G-3572, 3573	7/1/2003	Be-7	0.91 ± 0.24	0.81 ± 0.28	0.86 ± 0.18
G-3572, 3573	7/1/2003	Gr. Beta	6.35 ± 0.15	6.35 ± 0.15	6.35 ± 0.11
G-3572, 3573	7/1/2003	K-40	5.44 ± 0.55	5.68 ± 0.28	5.56 ± 0.31
G-3572, 3573	7/1/2003	Sr-90	0.01 ± 0.00	0.02 ± 0.00	0.01 ± 0.00
MI-3601, 3602	7/1/2003	K-40	1318.60 ± 117.40	1435.10 ± 117.80	1376.85 ± 83.16
MI-3601, 3602	7/1/2003	Sr-90	0.86 ± 0.51	1.74 ± 0.60	1.30 ± 0.39
AP-3933, 3934	7/1/2003	Be-7	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
AP-4061, 4062	7/2/2003	Be-7	0.07 ± 0.01	0.08 ± 0.01	0.08 ± 0.01
AP-4147, 4148	7/2/2003	Be-7	0.08 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
AP-4084, 4085	7/3/2003	Be-7	0.09 ± 0.02	0.08 ± 0.02	0.08 ± 0.01
LW-3786, 3787	7/9/2003	Gr. Beta	2.13 ± 0.56	2.93 ± 0.62	2.53 ± 0.42
WW-4168, 4169	7/11/2003	Gr. Beta	3.79 ± 1.87	4.48 ± 1.98	4.14 ± 1.36
CF-3975, 3976	7/14/2003	Be-7	1.64 ± 0.81	1.66 ± 0.57	1.65 ± 0.50
CF-3975, 3976	7/14/2003	K-40	6.54 ± 0.75	6.19 ± 0.50	6.36 ± 0.45
MI-4020, 4021	7/16/2003	K-40	1350.90 ± 174.90	1199.80 ± 153.20	1275.35 ± 116.25
DW-4272, 4273	7/29/2003	Gr. Beta	2.35 ± 0.92	2.29 ± 0.89	2.32 ± 0.64
SWU-4461, 4462	7/30/2003	Gr. Beta	2.28 ± 0.44	1.93 ± 0.43	2.10 ± 0.31
SL-4398, 4399	8/4/2003	Be-7	4.55 ± 1.05	4.50 ± 1.10	4.53 ± 0.76
SL-4398, 4399 b	8/4/2003	Gr. Beta	3.41 ± 0.12	3.12 ± 0.11	3.27 ± 0.08
SL-4398, 4399	8/4/2003	K-40	2.47 ± 0.67	2.44 ± 0.87	2.46 ± 0.55
G-4419, 4420	8/4/2003	Be-7	3.98 ± 0.63	3.93 ± 0.57	3.96 ± 0.42
G-4419, 4420	8/4/2003	Gr. Beta	5.38 ± 0.14	5.35 ± 0.16	5.37 ± 0.11
G-4419, 4420	8/4/2003	K-40	4.42 ± 0.66	4.32 ± 0.74	4.37 ± 0.50
TD-4550, 4551	8/4/2003	H-3	327.30 ± 95.10	390.20 ± 92.10	358.75 ± 66.19
MI-4482, 4483	8/6/2003	K-40	1301.40 ± 115.20	1370.30 ± 116.80	1335.85 ± 82.03
MI-4482, 4483	8/6/2003	Sr-90	0.81 ± 0.30	0.85 ± 0.31	0.83 ± 0.21
G-4526, 4527	8/6/2003	Be-7	1.47 ± 0.29	1.42 ± 0.28	1.45 ± 0.20
G-4526, 4527	8/6/2003	K-40	5.42 ± 0.56	5.21 ± 0.63	5.31 ± 0.42
SWU-4609, 4610	8/6/2003	Gr. Beta	3.22 ± 0.63	2.67 ± 0.64	2.95 ± 0.45
CW-4694, 4695	8/6/2003	Gr. Beta	1.48 ± 0.34	1.09 ± 0.34	1.29 ± 0.24
CW-4694, 4695	8/6/2003	H-3	22776.41 ± 428.73	21831.75 ± 420.10	22304.08 ± 300.12
LW-4673, 4674	8/13/2003	Gr. Beta	2.86 ± 0.65	3.75 ± 0.71	3.30 ± 0.48
MI-4735, 4736	8/19/2003	K-40	1396.30 ± 127.90	1410.10 ± 120.20	1403.20 ± 87.76
MI-4756, 4757	8/19/2003	Sr-90	1.66 ± 0.47	1.53 ± 0.44	1.60 ± 0.32
VE-4832, 4833	8/20/2003	K-40	1.96 ± 0.50	1.43 ± 0.47	1.70 ± 0.34
MI-4860, 4861	8/26/2003	K-40	1312.10 ± 191.80	1307.80 ± 109.30	1309.95 ± 110.38
SO-5082, 5083	8/28/2003	Cs-137	0.01 ± 0.00	0.01 ± 0.00	0.01 ± 0.00
SO-5082, 5083	8/28/2003	Gr. Beta	20.02 ± 1.84	20.92 ± 2.03	20.47 ± 1.37
CW-5349, 5350	8/31/2003	Gr. Beta	1.45 ± 0.39	1.55 ± 0.45	1.50 ± 0.30
CW-5349, 5350	8/31/2003	H-3	24429.50 ± 444.42	24744.25 ± 447.18	24586.88 ± 315.23
ME-4968, 4969	9/2/2003	Gr. Beta	4.90 ± 0.23	5.18 ± 0.24	5.04 ± 0.17
ME-4968, 4969	9/2/2003	K-40	2.46 ± 0.41	2.68 ± 0.37	2.57 ± 0.28

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a		Averaged Result
			First Result	Second Result	
DW-4989, 4990	9/2/2003	Gr. Beta	2.20 ± 1.04	3.19 ± 1.14	2.70 ± 0.77
MI-5154, 5155	9/8/2003	K-40	1365.50 ± 116.70	1456.70 ± 119.10	1411.10 ± 83.37
MI-5154, 5155	9/8/2003	Sr-90	1.19 ± 0.39	1.39 ± 0.39	1.29 ± 0.28
AP-6177, 6178	9/29/2003	Be-7	0.07 ± 0.01	0.06 ± 0.01	0.06 ± 0.01
SWU-5773, 5774	9/30/2003	Gr. Beta	2.55 ± 0.63	2.83 ± 0.60	2.69 ± 0.44
AP-6102, 6103	9/30/2003	Be-7	0.07 ± 0.01	0.05 ± 0.01	0.06 ± 0.01
G-5631, 5632	10/1/2003	Be-7	1.88 ± 0.48	2.21 ± 0.40	2.05 ± 0.31
G-5631, 5632	10/1/2003	Gr. Beta	5.87 ± 0.09	5.85 ± 0.08	5.86 ± 0.06
G-5631, 5632	10/1/2003	K-40	5.24 ± 0.77	5.26 ± 0.58	5.25 ± 0.48
SO-5660, 5661	10/1/2003	Cs-137	0.15 ± 0.04	0.16 ± 0.05	0.16 ± 0.03
SO-5660, 5661	10/1/2003	Gr. Alpha	12.72 ± 3.72	14.86 ± 3.88	13.79 ± 2.69
SO-5660, 5661	10/1/2003	Gr. Beta	32.42 ± 3.09	33.60 ± 3.04	33.01 ± 2.17
SO-5660, 5661	10/1/2003	K-40	18.93 ± 0.87	18.25 ± 1.19	18.59 ± 0.74
SO-5660, 5661	10/1/2003	Sr-90	0.03 ± 0.01	0.03 ± 0.01	0.03 ± 0.01
AP-6334, 6335	10/1/2003	Be-7	0.06 ± 0.01	0.06 ± 0.01	0.06 ± 0.01
AP-6363, 6364	10/2/2003	Be-7	0.07 ± 0.02	0.07 ± 0.02	0.07 ± 0.01
MI-5794, 5795	10/6/2003	Sr-90	1.37 ± 0.37	1.02 ± 0.37	1.19 ± 0.26
MI-5838, 5839	10/8/2003	K-40	1364.30 ± 124.10	1414.40 ± 110.40	1389.35 ± 83.05
MI-5838, 5839	10/8/2003	Sr-90	0.76 ± 0.30	1.00 ± 0.34	0.88 ± 0.23
BS-5938, 5939	10/8/2003	Cs-137	0.18 ± 0.03	0.20 ± 0.05	0.19 ± 0.03
BS-5938, 5939	10/8/2003	K-40	15.59 ± 0.70	16.69 ± 0.80	16.14 ± 0.53
SS-5959, 5960	10/13/2003	K-40	7.49 ± 0.42	7.29 ± 0.63	7.39 ± 0.38
MI-6011, 6012	10/13/2003	K-40	1165.20 ± 118.70	1191.20 ± 99.50	1178.20 ± 77.44
MI-6034, 6035	10/14/2003	Sr-90	0.86 ± 0.33	0.90 ± 0.34	0.88 ± 0.24
VE-6055, 6056	10/15/2003	Gr. Beta	5.18 ± 0.18	5.33 ± 0.18	5.25 ± 0.13
VE-6055, 6056	10/15/2003	K-40	5.31 ± 0.57	4.52 ± 0.51	4.92 ± 0.38
MI-6291, 6292	10/21/2003	K-40	1935.60 ± 147.70	1936.10 ± 116.50	1935.85 ± 94.06
MI-6291, 6292	10/21/2003	Sr-90	1.22 ± 0.39	1.41 ± 0.37	1.31 ± 0.27
SS-6435, 6436	10/21/2003	Cs-137	0.05 ± 0.02	0.05 ± 0.03	0.05 ± 0.02
SS-6435, 6436	10/21/2003	K-40	14.08 ± 0.54	14.28 ± 0.80	14.18 ± 0.48
CF-6313, 6314	10/22/2003	K-40	14.56 ± 0.45	14.70 ± 0.95	14.63 ± 0.53
SO-6528, 6529	10/22/2003	Cs-137	0.15 ± 0.03	0.16 ± 0.05	0.16 ± 0.03
SO-6528, 6529	10/22/2003	K-40	17.46 ± 0.69	17.90 ± 1.05	17.68 ± 0.63
SO-6393, 6394	10/25/2003	Cs-137	0.09 ± 0.03	0.10 ± 0.04	0.10 ± 0.03
SO-6393, 6394	10/25/2003	Gr. Beta	23.21 ± 1.98	21.76 ± 1.91	22.48 ± 1.38
SO-6393, 6394	10/25/2003	K-40	13.98 ± 0.80	14.57 ± 0.86	14.27 ± 0.59
SWT-6507, 6508	10/28/2003	Gr. Beta	2.64 ± 0.52	2.63 ± 0.53	2.63 ± 0.37
DW-6647, 6648	10/31/2003	I-131	0.46 ± 0.27	0.61 ± 0.31	0.53 ± 0.21
BS-6603, 6604	11/3/2003	Cs-137	9.03 ± 0.82	8.60 ± 1.13	8.82 ± 0.70
BS-6603, 6604	11/3/2003	Gr. Beta	26.83 ± 1.94	27.18 ± 1.95	27.01 ± 1.38
SO-6670, 6671	11/5/2003	Cs-137	0.15 ± 0.04	0.13 ± 0.04	0.14 ± 0.03
SO-6670, 6671	11/5/2003	K-40	12.96 ± 0.66	12.95 ± 0.72	12.96 ± 0.49
S-7067, 7068	11/10/2003	Cs-137	0.21 ± 0.05	0.19 ± 0.08	0.20 ± 0.05
MI-6818, 6819	11/11/2003	K-40	1695.50 ± 129.80	1709.40 ± 143.00	1702.45 ± 96.56

TABLE A-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) ^a		Averaged Result
			First Result	Second Result	
MI-6818, 6819	11/11/2003	Sr-90	2.01 ± 0.41	1.59 ± 0.39	1.80 ± 0.28
WL-6987, 6988	11/17/2003	Fe-55	603.49 ± 53.32	619.65 ± 53.97	611.57 ± 37.93
SO-7156, 7157	11/21/2003	Cs-137	0.74 ± 0.08	0.77 ± 0.07	0.76 ± 0.06
SO-7156, 7157	11/21/2003	Gr. Alpha	14.90 ± 4.24	19.25 ± 4.45	17.07 ± 3.07
SO-7156, 7157	11/21/2003	Gr. Beta	22.97 ± 3.12	25.51 ± 2.98	24.24 ± 2.16
SO-7156, 7157	11/21/2003	K-40	12.51 ± 1.06	12.94 ± 1.07	12.73 ± 0.75
S-7281, 7282	11/24/2003	Cs-137	0.82 ± 0.15	1.16 ± 0.20	0.99 ± 0.12
SWU-7198, 7199	11/25/2003	Gr. Beta	2.60 ± 0.53	2.54 ± 0.55	2.57 ± 0.38
DW-7221, 7222	11/25/2003	Gr. Beta	12.32 ± 1.40	12.38 ± 1.43	12.35 ± 1.00
SW-7133, 7134	12/1/2003	Gr. Beta	2.10 ± 0.23	2.46 ± 0.23	2.28 ± 0.16
SW-7133, 7134	12/1/2003	K-40	1.50 ± 0.15	1.40 ± 0.14	1.45 ± 0.10
W-7519, 7520	12/1/2003	Fe-55	3.03 ± 0.65	3.12 ± 0.64	3.08 ± 0.46
SW-7805, 7806	12/1/2003	Sr-90	0.59 ± 0.32	0.56 ± 0.33	0.58 ± 0.23
VE-7399, 7400	12/9/2003	Gr. Beta	4.99 ± 0.15	5.24 ± 0.15	5.11 ± 0.11
VE-7399, 7400	12/9/2003	K-40	5.04 ± 0.46	5.34 ± 0.74	5.19 ± 0.43
SW-7540, 7541	12/9/2003	Gr. Alpha	2.64 ± 1.36	2.10 ± 1.19	2.37 ± 0.91
SW-7540, 7541	12/9/2003	Gr. Beta	6.62 ± 1.22	5.89 ± 1.35	6.25 ± 0.91
LW-7736, 7737	12/26/2003	Gr. Beta	2.62 ± 0.54	2.83 ± 0.56	2.73 ± 0.39
AP-7868, 7869	12/30/2003	Be-7	0.05 ± 0.01	0.04 ± 0.01	0.04 ± 0.01
AP-7952, 7953	12/30/2003	Be-7	0.04 ± 0.01	0.04 ± 0.01	0.04 ± 0.01
AP-7994, 7995	12/31/2003	Be-7	0.05 ± 0.02	0.05 ± 0.01	0.05 ± 0.01

Note: Duplicate analyses are performed on every twentieth sample received in-house. Results are not listed for those analyses with activities that measure below the LLD.

^a Results are reported in units of pCi/L, except for air filters (pCi/Filter), food products, vegetation, soil, sediment (pCi/g).

^b 200 minute count time or longer, resulting in lower error.

TABLE A-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)^a.

Lab Code	Type	Date	Analysis	Concentration ^b		Control Limits ^c
				Laboratory result	Known Activity	
STW-972	water	12/01/02	Am-241	0.56 ± 0.06	0.58 ± 0.09	0.40 - 0.75
STW-972	water	12/01/02	Co-57	57.10 ± 1.90	57.00 ± 5.70	39.90 - 74.10
STW-972	water	12/01/02	Co-60	38.30 ± 0.60	38.20 ± 3.82	26.74 - 49.66
STW-972	water	12/01/02	Cs-134	395.30 ± 10.10	421.00 ± 42.10	294.70 - 547.30
STW-972	water	12/01/02	Cs-137	316.40 ± 5.30	329.00 ± 32.90	230.30 - 427.70
STW-972	water	12/01/02	Fe-55	94.90 ± 24.50	96.00 ± 9.60	67.20 - 124.80
STW-972	water	12/01/02	Mn-54	33.40 ± 0.10	32.90 ± 3.29	23.03 - 42.77
STW-972	water	12/01/02	Ni-63	123.80 ± 5.50	136.50 ± 13.70	95.55 - 177.45
STW-972	water	12/01/02	Pu-238	0.66 ± 0.06	0.83 ± 0.08	0.58 - 1.08
STW-972	water	12/01/02	Pu-239/40	0.001 ± 0.001	0.000 ± 0.000	0.000 - 0.005
STW-972	water	12/01/02	Sr-90	13.80 ± 1.00	12.31 ± 1.23	8.62 - 16.00
STW-972	water	12/01/02	Tc-99	128.10 ± 3.80	132.00 ± 13.20	92.40 - 171.60
STW-972	water	12/01/02	U-233/4	1.60 ± 0.09	1.54 ± 0.15	1.08 - 2.00
STW-972	water	12/01/02	U-238	1.64 ± 0.09	1.60 ± 0.16	1.12 - 2.08
STW-972	water	12/01/02	Zn-65	540.40 ± 9.90	516.00 ± 51.60	361.20 - 670.80
STSO-987	soil	01/01/03	Co-57	534.36 ± 2.61	530.00 ± 53.00	371.00 - 689.00
STSO-987	soil	01/01/03	Co-60	442.16 ± 2.31	420.00 ± 42.00	294.00 - 546.00
STSO-987	soil	01/01/03	Cs-134	211.00 ± 2.30	238.00 ± 23.80	166.60 - 309.40
STSO-987	soil	01/01/03	Cs-137	849.50 ± 3.30	832.00 ± 83.20	582.40 - 1081.60
STSO-987	soil	01/01/03	K-40	716.50 ± 12.80	652.00 ± 65.20	456.40 - 847.60
STSO-987	soil	01/01/03	Mn-54	148.76 ± 2.84	137.00 ± 13.70	95.90 - 178.10
STSO-987	soil	01/01/03	Ni-63	597.10 ± 23.50	770.00 ± 77.00	539.00 - 1001.00
STSO-987	soil	01/01/03	Pu-238	67.05 ± 3.10	66.90 ± 6.70	46.83 - 86.97
STSO-987	soil	01/01/03	Pu-239/40	52.80 ± 3.60	52.70 ± 5.30	36.90 - 68.50
STSO-987	soil	01/01/03	Sr-90	609.50 ± 9.80	714.00 ± 71.40	499.80 - 928.20
STSO-987	soil	01/01/03	U-233/4	99.50 ± 7.60	89.00 ± 8.90	62.30 - 115.70
STSO-987	soil	01/01/03	U-238	508.60 ± 42.20	421.00 ± 42.10	294.70 - 547.30
STSO-987	soil	01/01/03	Zn-65	492.70 ± 28.10	490.00 ± 49.00	343.00 - 637.00

^a Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the Department of Energy's Mixed Analyte Performance Evaluation Program, Idaho Operations office, Idaho Falls, Idaho

^b All results are in Bq/kg or Bq/L as requested by the Department of Energy.

^c MAPEP results are presented as the known values and expected laboratory precision (1 sigma, 1 determination) and control limits as defined by the MAPEP.

TABLE A-7. Environmental Measurements Laboratory Quality Assessment Program (EML)

Lab Code	Type	Date	Analysis	Concentration ^a		
				Laboratory results	EML Result ^b	Control Limits ^c
STW-977	water	03/01/03	Gr. Alpha	304.30 ± 53.10	377.50	0.58 - 1.29
STW-977	water	03/01/03	Gr. Beta	615.80 ± 14.70	627.50	0.61 - 1.43
STW-978	water	03/01/03	Am-241	2.00 ± 0.10	2.13	0.79 - 1.41
STW-978	water	03/01/03	Co-60	221.30 ± 1.20	234.00	0.80 - 1.20
STW-978 ^d	water	03/01/03	Cs-134	23.30 ± 1.10	30.50	0.80 - 1.30
STW-978	water	03/01/03	Cs-137	61.40 ± 0.60	63.80	0.80 - 1.22
STW-978 ^e	water	03/01/03	H-3	341.90 ± 22.70	390.00	0.78 - 2.45
STW-978	water	03/01/03	Pu-238	3.70 ± 0.20	3.33	0.74 - 1.20
STW-978	water	03/01/03	Pu-239/40	4.40 ± 0.10	3.92	0.79 - 1.20
STW-978	water	03/01/03	Sr-90	4.60 ± 0.30	4.34	0.69 - 1.34
STW-978	water	03/01/03	Uranium	5.10 ± 0.60	4.29	0.75 - 1.33
STSO-979	soil	03/01/03	Ac-228	55.60 ± 2.50	57.60	0.80 - 1.38
STSO-979	soil	03/01/03	Am-241	12.42 ± 0.90	15.60	0.65 - 2.28
STSO-979	soil	03/01/03	Bi-212	57.70 ± 3.20	60.60	0.50 - 1.34
STSO-979	soil	03/01/03	Bi-214	60.40 ± 3.20	67.00	0.78 - 1.42
STSO-979	soil	03/01/03	Cs-137	1416.80 ± 70.00	1450.00	0.80 - 1.25
STSO-979	soil	03/01/03	K-40	653.80 ± 11.90	636.00	0.80 - 1.32
STSO-979	soil	03/01/03	Pb-212	51.10 ± 5.20	57.90	0.78 - 1.32
STSO-979	soil	03/01/03	Pb-214	64.70 ± 5.10	71.10	0.76 - 1.46
STSO-979	soil	03/01/03	Pu-239/40	24.40 ± 0.30	23.40	0.71 - 1.30
STSO-979	soil	03/01/03	Sr-90	54.50 ± 2.60	64.40	0.67 - 2.90
STSO-979	soil	03/01/03	Uranium	245.00 ± 1.50	249.00	0.71 - 1.32
STVE-980	Vegetation	03/01/03	Am-241	3.10 ± 0.20	3.51	0.73 - 2.02
STVE-980	Vegetation	03/01/03	Cm-244	1.40 ± 0.50	2.01	0.61 - 1.59
STVE-980	Vegetation	03/01/03	Co-60	12.60 ± 0.40	12.10	0.80 - 1.44
STVE-980	Vegetation	03/01/03	Cs-137	449.70 ± 6.20	444.00	0.80 - 1.31
STVE-980	Vegetation	03/01/03	K-40	1159.00 ± 38.60	1120.00	0.79 - 1.39
STVE-980	Vegetation	03/01/03	Pu-239/40	4.80 ± 0.40	5.17	0.69 - 1.31
STVE-980	Vegetation	03/01/03	Sr-90	659.70 ± 50.40	650.00	0.55 - 1.21
STAP-981	Air Filter	03/01/03	Am-241	0.27 ± 0.10	0.34	0.70 - 2.34
STAP-981	Air Filter	03/01/03	Co-60	30.20 ± 0.30	33.50	0.80 - 1.26
STAP-981	Air Filter	03/01/03	Cs-137	90.30 ± 1.30	99.70	0.80 - 1.32
STAP-981	Air Filter	03/01/03	Mn-54	41.80 ± 0.60	43.80	0.80 - 1.35
STAP-981	Air Filter	03/01/03	Pu-238	0.52 ± 0.10	0.52	0.67 - 1.33
STAP-981	Air Filter	03/01/03	Pu-239/40	0.35 ± 0.10	0.33	0.73 - 1.26
STAP-981	Air Filter	03/01/03	Sr-90	2.50 ± 0.10	2.80	0.53 - 1.84
STAP-981	Air Filter	03/01/03	Uranium	0.51 ± 0.10	0.50	0.79 - 2.10
STAP-982	Air Filter	03/01/03	Gr. Alpha	0.90 ± 0.10	1.17	0.73 - 1.43
STAP-982	Air Filter	03/01/03	Gr. Beta	1.50 ± 0.10	1.50	0.76 - 1.36

TABLE A-7. Environmental Measurements Laboratory Quality Assessment Program (EML)

Lab Code	Type	Date	Analysis	Concentration ^a		
				Laboratory results	EML Result ^b	Control Limits ^c
STW-992	water	09/02/03	Am-241	9.78 ± 0.32	8.76	0.79 - 1.41
The September, 2003 results are preliminary. Control limits used were taken from the March, 2003 data.						
Control limits may vary slightly when the final study is published.						
STW-992	water	09/02/03	Co-60	468.30 ± 4.10	513.00	0.80 - 1.20
STW-992	water	09/02/03	Cs-134	53.90 ± 0.80	63.00	0.80 - 1.30
STW-992	water	09/02/03	Cs-137	76.10 ± 1.40	80.30	0.80 - 1.22
STW-992	water	09/02/03	H-3	355.20 ± 12.80	446.30	0.78 - 2.45
STW-992	water	09/02/03	Pu-238	1.71 ± 0.07	2.07	0.74 - 1.20
STW-992	water	09/02/03	Pu-239/40	4.24 ± 0.01	4.99	0.79 - 1.20
STW-992	water	09/02/03	Sr-90	6.70 ± 0.50	7.04	0.69 - 1.34
STW-992	water	09/02/03	Uranium	6.03 ± 0.14	5.69	0.75 - 1.33
STW-993	water	09/02/03	Gr. Alpha	688.00 ± 7.60	622.00	0.58 - 1.29
STW-993	water	09/02/03	Gr. Beta	1985.00 ± 111.00	1948.00	0.61 - 1.43
STSO-994	soil	09/02/03	Am-241	19.70 ± 1.50	18.40	0.65 - 2.28
STSO-994	soil	09/02/03	Cs-137	1928.00 ± 19.00	1973.00	0.80 - 1.25
STSO-994	soil	09/02/03	K-40	533.00 ± 79.00	488.00	0.80 - 1.32
STSO-994	soil	09/02/03	Pu-238	15.30 ± 0.80	14.60	0.59 - 2.88
STSO-994	soil	09/02/03	Pu-239/40	32.50 ± 2.30	30.40	0.71 - 1.30
STSO-994	soil	09/02/03	Sr-90	69.80 ± 2.30	80.30	0.67 - 2.90
STSO-994	soil	09/02/03	Uranium	228.30 ± 17.10	259.30	0.71 - 1.32
STAP-995	Air Filter	09/02/03	Am-241	0.64 ± 0.05	0.44	0.70 - 2.34
STAP-995	Air Filter	09/02/03	Co-60	48.50 ± 0.40	55.10	0.80 - 1.26
STAP-995	Air Filter	09/02/03	Cs-137	51.20 ± 1.10	54.80	0.80 - 1.32
STAP-995	Air Filter	09/02/03	Mn-54	53.70 ± 1.10	58.00	0.80 - 1.35
STAP-995	Air Filter	09/02/03	Pu-238	0.24 ± 0.05	0.23	0.67 - 1.33
STAP-995	Air Filter	09/02/03	Pu-239/40	0.41 ± 0.10	0.40	0.73 - 1.26
STAP-995	Air Filter	09/02/03	Sr-90	1.90 ± 0.10	2.06	0.53 - 1.84
STAP-995	Air Filter	09/02/03	Uranium	0.80 ± 0.06	0.82	0.79 - 2.10
STAP-996	Air Filter	09/02/03	Gr. Alpha	3.23 ± 0.07	3.11	0.73 - 1.43
STAP-996	Air Filter	09/02/03	Gr. Beta	4.18 ± 0.03	3.89	0.76 - 1.36

^a Results are reported in Bq/L with the following exceptions: Air Filters (Bq/Filter), Soil and Vegetation (Bq/kg).

^b The EML result listed is the mean of replicate determinations for each nuclide ± the standard error of the mean.

^c Control limits are reported by EML as the ratio of Reported Value / EML value.

^d A low bias for Cs-134 activity has been observed in the past. No errors have been found in the library or efficiency.

Additional spike analyses will be performed and a correction factored into the calculation.

^e Reporting error.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

APPENDIX B, 2003 REMP DATA SUMMARY REPORTS

Air Gamma Spectral Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Air pCi/m3	Be-7 28	N/A	0.05 28 / 28 0.04 - 0.06	0.05 24 / 24 0.04 - 0.06	1 3.40 ENE	0.05 4 / 20 0.04 - 0.05	0.05 4 / 4 0.04 - 0.06
Air pCi/m3	Co-58 28	N/A	LLD	-	-	-	-
Air pCi/m3	Co-60 28	N/A	LLD	-	-	-	-
Air pCi/m3	Cs-134 28	0.04	LLD	-	-	-	-
Air pCi/m3	Cs-137 28	0.05	LLD	-	-	-	-

Air Gross Beta Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (L.L.D)	Mean of Results from	Mean of Results from	Location with Highest Annual Mean:		Mean of Results from
			All Locations and Number Detected/Number Collected and Range	All Indicator Locations and Number Detected/Number Collected and Range	Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	All Control Locations and Number Detected/Number Collected and Range
Air pCi/m3	Gross Beta 364	0.01	0.02 364 / 364 0.01 - 0.04	0.02 312 / 312 0.01 - 0.04	5 0.60 SW	0.02 52 / 52 0.01 - 0.04	0.02 52 / 52 0.01 - 0.04

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Air pCi/m3	I-131 364	0.05	LLD	-	-	-	-

Fish Gamma Spectral Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean: Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Fish pCi/kg wet	Co-58 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Co-60 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Cs-134 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Cs-137 2	112.00	LLD	-	-	-	-
Fish pCi/kg wet	Fe-59 2	195.00	LLD	-	-	-	-
Fish pCi/kg wet	K-40 2	N/A	1,546.73 2 / 2 1,402.10 - 1,691.35	1,402.10 1 / 1 1,402.10 - 1,402.10	32 15.80 WSW	1,691.35 1 / 8 1,691.35 - 1,691.35	1,691.35 1 / 1 1,691.35 - 1,691.35
Fish pCi/kg wet	Mn-54 2	97.00	LLD	-	-	-	-
Fish pCi/kg wet	Zn-65 2	195.00	LLD	-	-	-	-

Food Products Gamma Spectral Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Food Products pCi/kg wet	Be-7 65	N/A	497.66 13 / 65 241.94 - 1,195.50	510.40 10 / 49 241.94 - 1,195.50	20 1.90 E	715.41 5 / 56 287.30 - 1,195.50	455.22 3 / 16 331.62 - 685.28
Food Products pCi/kg wet	Co-58 65	N/A	LLD	-	-	-	-
Food Products pCi/kg wet	Co-60 65	N/A	LLD	-	-	-	-
Food Products pCi/kg wet	Cs-134 65	45.00	LLD	-	-	-	-
Food Products pCi/kg wet	Cs-137 65	60.00	LLD	-	-	-	-
Food Products pCi/kg wet	I-131 65	45.00	LLD	-	-	-	-
Food Products pCi/kg wet	K-40 65	N/A	4,494.92 65 / 65 2,352.30 - 6,851.20	4,502.38 49 / 49 2,714.70 - 6,851.20	20 1.90 E	5,067.91 8 / 56 3,924.50 - 6,294.00	4,472.06 16 / 16 2,352.30 - 6,005.10

Milk Gamma Spectral Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and Distance and Direction	Location with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Milk pCi/L	Ba-140 37	45.00	LLD	-	-	-	-
Milk pCi/L	Cs-134 37	11.00	LLD	-	-	-	-
Milk pCi/L	Cs-137 37	13.00	LLD	-	-	-	-
Milk pCi/L	K-40 37	N/A	1,409.20 37 / 37 842.81 - 2,053.70	1,562.35 18 / 18 1,198.00 - 2,053.70	61 7.40 SE	1,722.51 12 / 60 1,415.50 - 2,053.70	1,264.11 19 / 19 842.81 - 1,616.70
Milk pCi/L	La-140 37	11.00	LLD	-	-	-	-

Milk Iodine Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location # and Distance and Direction	Location with Highest Annual Mean: Mean and Number Detected/Number Collected and Range	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Milk pCi/L	I-131 37	0.75	LLD	-	-	-	-

Sediment Gamma Spectral Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean: Location # and Distance and Direction	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Sediment pCi/kg dry	Co-58 14	50.00	LLD	-	-	-
Sediment pCi/kg dry	Co-60 14	40.00	LLD	-	-	-
Sediment pCi/kg dry	Cs-134 14	112.00	LLD	-	-	-
Sediment pCi/kg dry	Cs-137 14	135.00	565.90 6 / 14 142.95 - 1,134.90	334.56 4 / 12 142.95 - 590.71	32 15.80 WSW	1,028.57 2 / 10 922.24 - 1,134.90
Sediment pCi/kg dry	K-40 14	N/A	12,671.30 14 / 14 5,721.90 - 26,949.00	10,651.43 12 / 12 5,721.90 - 16,136.00	32 15.80 WSW	24,790.50 2 / 10 22,632.00 - 26,949.00

[illegible]

Water Gamma Spectral Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range		Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range		Location with Highest Annual Mean: Location # and Distance and Direction Mean and Number Detected/Number Collected and Range		Mean of Results from All Control Locations and Number Detected/Number Collected and Range	
Water pCi/L	Ba-140 56	45.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Co-58 56	11.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Co-60 56	11.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Cs-134 56	11.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Cs-137 56	13.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Fe-59 56	22.00	LLD	-	-	-	-	-	-	-
Water pCi/L	La-140 56	11.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Mn-54 56	11.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Nb-95 56	11.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Zn-65 56	22.00	LLD	-	-	-	-	-	-	-
Water pCi/L	Zr-95 56	22.00	LLD	-	-	-	-	-	-	-

Water Gross Beta Summary Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean:		Mean of Results from All Control Locations and Number Detected/Number Collected and Range
					Location # and Distance and Direction	Mean and Number Detected/Number Collected and Range	
Water pCi/L	Gross Beta 56	3.00	3.42 4 / 56 3.02 - 3.81	3.30 3 / 44 3.02 - 3.73	28 22.00 ENE	3.81 1 / 12 3.81 - 3.81	3.81 1 / 12 3.81 - 3.81

Sample Type and Units	Type and Number of Analyses Performed	Lower Limit (LLD)	Mean of Results from All Locations and Number Detected/Number Collected and Range	Mean of Results from All Indicator Locations and Number Detected/Number Collected and Range	Location with Highest Annual Mean: Location # and Distance and Direction	Mean of Results from All Control Locations and Number Detected/Number Collected and Range
Water pCi/L	H-3 20	1,500.00	LLD	-	-	-

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

APPENDIX C, 2003 REMP DETAILED DATA REPORTS

Air Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7	Co-58	Co-60	Cs-134	Cs-137
1	Air	4/2/03	0.053 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
1	Air	7/2/03	0.053 +/- 0.009	< 0.000	< 0.001	< 0.000	< 0.000
1	Air	10/1/03	0.055 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
1	Air	12/31/03	0.044 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
3	Air	4/2/03	0.050 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
3	Air	7/2/03	0.044 +/- 0.008	< 0.000	< 0.001	< 0.000	< 0.000
3	Air	10/1/03	0.049 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
3	Air	12/31/03	0.039 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
4	Air	4/2/03	0.042 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
4	Air	7/2/03	0.043 +/- 0.007	< 0.000	< 0.001	< 0.000	< 0.000
4	Air	10/1/03	0.045 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000

Air Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7	Co-58	Co-60	Cs-134	Cs-137
4	Air	12/31/03	0.045 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
5	Air	4/2/03	0.051 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
5	Air	7/2/03	0.055 +/- 0.008	< 0.000	< 0.001	< 0.000	< 0.000
5	Air	10/1/03	0.054 +/- 0.011	< 0.000	< 0.000	< 0.001	< 0.000
5	Air	12/31/03	0.043 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
6	Air	4/2/03	0.056 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000
6	Air	7/2/03	0.046 +/- 0.009	< 0.000	< 0.001	< 0.000	< 0.000
6	Air	10/1/03	0.055 +/- 0.011	< 0.000	< 0.000	< 0.000	< 0.000
6	Air	12/31/03	0.041 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
7	Air	4/2/03	0.055 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000
7	Air	7/2/03	0.049 +/- 0.008	< 0.000	< 0.000	< 0.000	< 0.000

Air Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Date	Bc-7	Co-58	Co-60	Cs-134	Cs-137
7	Air	10/1/03	0.049 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
7	Air	12/31/03	0.037 +/- 0.006	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	4/2/03	0.048 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	7/2/03	0.055 +/- 0.010	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	10/1/03	0.049 +/- 0.007	< 0.000	< 0.000	< 0.000	< 0.000
35	Air	12/31/03	0.037 +/- 0.009	< 0.000	< 0.000	< 0.000	< 0.000

Air Gross Beta Detail Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
1/8/03	Air	0.025 +/- 0.003 0.024 +/- 0.003	0.025 +/- 0.003 0.023 +/- 0.003	0.023 +/- 0.003	0.027 +/- 0.003	0.024 +/- 0.003
1/15/03	Air	0.019 +/- 0.003 0.023 +/- 0.003	0.025 +/- 0.003 0.021 +/- 0.003	0.020 +/- 0.003	0.023 +/- 0.003	0.025 +/- 0.003
1/22/03	Air	0.026 +/- 0.003 0.028 +/- 0.003	0.029 +/- 0.003 0.027 +/- 0.003	0.026 +/- 0.002	0.031 +/- 0.003	0.031 +/- 0.003
1/29/03	Air	0.026 +/- 0.003 0.025 +/- 0.003	0.026 +/- 0.003 0.022 +/- 0.003	0.022 +/- 0.003	0.023 +/- 0.003	0.024 +/- 0.003
2/5/03	Air	0.032 +/- 0.003 0.033 +/- 0.003	0.030 +/- 0.003 0.032 +/- 0.003	0.031 +/- 0.003	0.032 +/- 0.003	0.031 +/- 0.003
2/12/03	Air	0.028 +/- 0.003 0.027 +/- 0.003	0.023 +/- 0.003 0.024 +/- 0.003	0.023 +/- 0.003	0.025 +/- 0.003	0.021 +/- 0.003
2/19/03	Air	0.030 +/- 0.002 0.025 +/- 0.002	0.029 +/- 0.002 0.030 +/- 0.002	0.026 +/- 0.002	0.028 +/- 0.002	0.028 +/- 0.002
2/26/03	Air	0.031 +/- 0.003 0.030 +/- 0.003	0.032 +/- 0.003 0.031 +/- 0.003	0.028 +/- 0.003	0.030 +/- 0.003	0.032 +/- 0.003
3/5/03	Air	0.030 +/- 0.003 0.029 +/- 0.003	0.031 +/- 0.003 0.032 +/- 0.003	0.029 +/- 0.003	0.030 +/- 0.003	0.032 +/- 0.003
3/12/03	Air	0.037 +/- 0.003 0.031 +/- 0.003	0.035 +/- 0.003 0.032 +/- 0.003	0.029 +/- 0.003	0.035 +/- 0.003	0.033 +/- 0.003
3/19/03	Air	0.030 +/- 0.003 0.028 +/- 0.003	0.030 +/- 0.003 0.028 +/- 0.003	0.025 +/- 0.002	0.030 +/- 0.003	0.030 +/- 0.003
3/26/03	Air	0.020 +/- 0.003 0.020 +/- 0.003	0.017 +/- 0.003 0.020 +/- 0.003	0.017 +/- 0.002	0.019 +/- 0.003	0.017 +/- 0.003
4/2/03	Air	0.020 +/- 0.003 0.022 +/- 0.003	0.020 +/- 0.003 0.020 +/- 0.003	0.018 +/- 0.003	0.021 +/- 0.003	0.017 +/- 0.003
4/9/03	Air	0.020 +/- 0.003 0.018 +/- 0.003	0.015 +/- 0.003 0.015 +/- 0.003	0.016 +/- 0.003	0.014 +/- 0.002	0.015 +/- 0.003
4/16/03	Air	0.025 +/- 0.003 0.023 +/- 0.003	0.025 +/- 0.002 0.021 +/- 0.002	0.017 +/- 0.002	0.023 +/- 0.003	0.023 +/- 0.003
4/23/03	Air	0.016 +/- 0.003 0.016 +/- 0.003	0.016 +/- 0.003 0.017 +/- 0.003	0.014 +/- 0.003	0.015 +/- 0.003	0.017 +/- 0.003

Air Gross Beta Detail Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
4/30/03	Air	0.021 +/- 0.003 0.020 +/- 0.003	0.019 +/- 0.003 0.022 +/- 0.003	0.012 +/- 0.003	0.018 +/- 0.003	0.019 +/- 0.003
5/7/03	Air	0.014 +/- 0.003 0.015 +/- 0.003	0.015 +/- 0.003 0.015 +/- 0.003	0.013 +/- 0.003	0.015 +/- 0.003	0.016 +/- 0.003
5/14/03	Air	0.014 +/- 0.003 0.011 +/- 0.002	0.013 +/- 0.003 0.013 +/- 0.003	0.012 +/- 0.003	0.013 +/- 0.003	0.015 +/- 0.003
5/21/03	Air	0.011 +/- 0.003 0.011 +/- 0.002	0.011 +/- 0.002 0.010 +/- 0.002	0.012 +/- 0.003	0.012 +/- 0.003	0.012 +/- 0.003
5/28/03	Air	0.015 +/- 0.003 0.013 +/- 0.003	0.014 +/- 0.003 0.016 +/- 0.003	0.014 +/- 0.003	0.014 +/- 0.003	0.016 +/- 0.003
6/4/03	Air	0.016 +/- 0.003 0.017 +/- 0.003	0.015 +/- 0.002 0.016 +/- 0.003	0.013 +/- 0.002	0.017 +/- 0.003	0.016 +/- 0.003
6/11/03	Air	0.017 +/- 0.002 0.018 +/- 0.002	0.017 +/- 0.002 0.018 +/- 0.002	0.017 +/- 0.002	0.018 +/- 0.002	0.018 +/- 0.002
6/18/03	Air	0.018 +/- 0.002 0.015 +/- 0.002	0.013 +/- 0.002 0.017 +/- 0.002	0.015 +/- 0.002	0.016 +/- 0.002	0.014 +/- 0.002
6/25/03	Air	0.019 +/- 0.002 0.021 +/- 0.002	0.021 +/- 0.002 0.019 +/- 0.002	0.019 +/- 0.002	0.018 +/- 0.002	0.020 +/- 0.002
7/2/03	Air	0.024 +/- 0.003 0.022 +/- 0.003	0.021 +/- 0.003 0.024 +/- 0.003	0.023 +/- 0.003	0.025 +/- 0.003	0.022 +/- 0.003
7/9/03	Air	0.027 +/- 0.003 0.028 +/- 0.003	0.024 +/- 0.003 0.027 +/- 0.003	0.028 +/- 0.003	0.028 +/- 0.003	0.027 +/- 0.003
7/16/03	Air	0.017 +/- 0.003 0.019 +/- 0.003	0.018 +/- 0.003 0.017 +/- 0.003	0.019 +/- 0.003	0.021 +/- 0.003	0.018 +/- 0.003
7/23/03	Air	0.018 +/- 0.003 0.017 +/- 0.003	0.018 +/- 0.003 0.019 +/- 0.003	0.017 +/- 0.003	0.020 +/- 0.003	0.019 +/- 0.003
7/30/03	Air	0.018 +/- 0.003 0.019 +/- 0.003	0.018 +/- 0.003 0.021 +/- 0.003	0.020 +/- 0.003	0.020 +/- 0.003	0.020 +/- 0.003
8/6/03	Air	0.030 +/- 0.003 0.026 +/- 0.003	0.027 +/- 0.003 0.024 +/- 0.003	0.025 +/- 0.003	0.026 +/- 0.003	0.025 +/- 0.003

Air Gross Beta Detail Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
8/13/03	Air	0.019 +/- 0.003 0.020 +/- 0.002	0.018 +/- 0.002 0.018 +/- 0.002	0.020 +/- 0.003	0.022 +/- 0.003	0.020 +/- 0.003
8/20/03	Air	0.026 +/- 0.003 0.026 +/- 0.003	0.026 +/- 0.003 0.023 +/- 0.003	0.026 +/- 0.003	0.027 +/- 0.003	0.027 +/- 0.003
8/27/03	Air	0.033 +/- 0.003 0.032 +/- 0.003	0.028 +/- 0.003 0.030 +/- 0.003	0.031 +/- 0.003	0.030 +/- 0.003	0.030 +/- 0.003
9/3/03	Air	0.023 +/- 0.003 0.019 +/- 0.003	0.016 +/- 0.002 0.018 +/- 0.002	0.019 +/- 0.003	0.019 +/- 0.003	0.020 +/- 0.003
9/10/03	Air	0.022 +/- 0.003 0.021 +/- 0.002	0.022 +/- 0.002 0.021 +/- 0.002	0.025 +/- 0.003	0.022 +/- 0.003	0.024 +/- 0.003
9/17/03	Air	0.028 +/- 0.003 0.027 +/- 0.003	0.024 +/- 0.003 0.028 +/- 0.003	0.029 +/- 0.003	0.029 +/- 0.003	0.027 +/- 0.003
9/24/03	Air	0.027 +/- 0.003 0.026 +/- 0.003	0.023 +/- 0.003 0.025 +/- 0.003	0.026 +/- 0.003	0.025 +/- 0.003	0.025 +/- 0.003
10/1/03	Air	0.019 +/- 0.003 0.018 +/- 0.003	0.019 +/- 0.003 0.017 +/- 0.003	0.019 +/- 0.003	0.019 +/- 0.003	0.018 +/- 0.003
10/8/03	Air	0.014 +/- 0.002 0.014 +/- 0.002	0.013 +/- 0.002 0.013 +/- 0.002	0.014 +/- 0.002	0.014 +/- 0.002	0.015 +/- 0.002
10/15/03	Air	0.038 +/- 0.003 0.037 +/- 0.003	0.037 +/- 0.003 0.038 +/- 0.003	0.043 +/- 0.004	0.042 +/- 0.003	0.038 +/- 0.003
10/22/03	Air	0.022 +/- 0.003 0.021 +/- 0.003	0.021 +/- 0.003 0.022 +/- 0.003	0.024 +/- 0.003	0.022 +/- 0.003	0.024 +/- 0.003
10/29/03	Air	0.021 +/- 0.003 0.019 +/- 0.002	0.021 +/- 0.003 0.019 +/- 0.002	0.023 +/- 0.003	0.019 +/- 0.003	0.021 +/- 0.003
11/5/03	Air	0.029 +/- 0.003 0.027 +/- 0.003	0.027 +/- 0.003 0.028 +/- 0.003	0.029 +/- 0.003	0.030 +/- 0.003	0.036 +/- 0.003
11/12/03	Air	0.023 +/- 0.003 0.024 +/- 0.003	0.023 +/- 0.003 0.025 +/- 0.003	0.023 +/- 0.003	0.024 +/- 0.003	0.025 +/- 0.003
11/19/03	Air	0.021 +/- 0.003 0.022 +/- 0.003	0.021 +/- 0.003 0.021 +/- 0.003	0.021 +/- 0.003	0.022 +/- 0.003	0.021 +/- 0.003
11/26/03	Air	0.025 +/- 0.003 0.027 +/- 0.003	0.026 +/- 0.003 0.026 +/- 0.003	0.025 +/- 0.003	0.027 +/- 0.003	0.026 +/- 0.003

Air Gross Beta Detail Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Collection Date	Sample Type	Location				
		1 7	3 35	4	5	6
12/3/03	Air	0.023 +/- 0.003 0.023 +/- 0.003	0.026 +/- 0.003 0.025 +/- 0.003	0.024 +/- 0.002	0.024 +/- 0.002	0.025 +/- 0.003
12/10/03	Air	0.020 +/- 0.002 0.020 +/- 0.002	0.020 +/- 0.002 0.019 +/- 0.002	0.023 +/- 0.003	0.019 +/- 0.002	0.018 +/- 0.002
12/17/03	Air	0.018 +/- 0.003 0.022 +/- 0.003	0.023 +/- 0.003 0.022 +/- 0.003	0.025 +/- 0.003	0.023 +/- 0.003	0.022 +/- 0.003
12/23/03	Air	0.022 +/- 0.003 0.023 +/- 0.003	0.022 +/- 0.003 0.025 +/- 0.003	0.023 +/- 0.003	0.022 +/- 0.003	0.022 +/- 0.003
12/31/03	Air	0.025 +/- 0.002 0.028 +/- 0.002	0.027 +/- 0.002 0.025 +/- 0.002	0.027 +/- 0.002	0.028 +/- 0.002	0.026 +/- 0.002

Air Iodine Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
1	Air	1/8/03	< 0.003
1	Air	1/15/03	< 0.004
1	Air	1/22/03	< 0.004
1	Air	1/29/03	< 0.003
1	Air	2/5/03	< 0.005
1	Air	2/12/03	< 0.005
1	Air	2/19/03	< 0.003
1	Air	2/26/03	< 0.005
1	Air	3/5/03	< 0.004
1	Air	3/12/03	< 0.004
1	Air	3/19/03	< 0.003
1	Air	3/26/03	< 0.004
1	Air	4/2/03	< 0.003
1	Air	4/9/03	< 0.004
1	Air	4/16/03	< 0.005
1	Air	4/23/03	< 0.004
1	Air	4/30/03	< 0.005
1	Air	5/7/03	< 0.003
1	Air	5/14/03	< 0.002
1	Air	5/21/03	< 0.002
1	Air	5/28/03	< 0.003
1	Air	6/4/03	< 0.003
1	Air	6/11/03	< 0.003
1	Air	6/18/03	< 0.005
1	Air	6/25/03	< 0.006
1	Air	7/2/03	< 0.006
1	Air	7/9/03	< 0.005
1	Air	7/16/03	< 0.008
1	Air	7/23/03	< 0.005
1	Air	7/30/03	< 0.005
1	Air	8/6/03	< 0.007
1	Air	8/13/03	< 0.008
1	Air	8/20/03	< 0.007
1	Air	8/27/03	< 0.008
1	Air	9/3/03	< 0.008
1	Air	9/10/03	< 0.004
1	Air	9/17/03	< 0.007
1	Air	9/24/03	< 0.004
1	Air	10/1/03	< 0.005
1	Air	10/8/03	< 0.006
1	Air	10/15/03	< 0.006
1	Air	10/22/03	< 0.009

Air Iodine Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
1	Air	10/29/03	< 0.004
1	Air	11/5/03	< 0.007
1	Air	11/12/03	< 0.005
1	Air	11/19/03	< 0.005
1	Air	11/26/03	< 0.006
1	Air	12/3/03	< 0.008
1	Air	12/10/03	< 0.005
1	Air	12/17/03	< 0.005
1	Air	12/23/03	< 0.005
1	Air	12/31/03	< 0.006
3	Air	1/8/03	< 0.003
3	Air	1/15/03	< 0.003
3	Air	1/22/03	< 0.004
3	Air	1/29/03	< 0.003
3	Air	2/5/03	< 0.005
3	Air	2/12/03	< 0.005
3	Air	2/19/03	< 0.003
3	Air	2/26/03	< 0.005
3	Air	3/5/03	< 0.004
3	Air	3/12/03	< 0.004
3	Air	3/19/03	< 0.003
3	Air	3/26/03	< 0.004
3	Air	4/2/03	< 0.003
3	Air	4/9/03	< 0.004
3	Air	4/16/03	< 0.004
3	Air	4/23/03	< 0.004
3	Air	4/30/03	< 0.004
3	Air	5/7/03	< 0.003
3	Air	5/14/03	< 0.002
3	Air	5/21/03	< 0.002
3	Air	5/28/03	< 0.003
3	Air	6/4/03	< 0.002
3	Air	6/11/03	< 0.003
3	Air	6/18/03	< 0.005
3	Air	6/25/03	< 0.006
3	Air	7/2/03	< 0.006
3	Air	7/9/03	< 0.005
3	Air	7/16/03	< 0.007
3	Air	7/23/03	< 0.005
3	Air	7/30/03	< 0.005
3	Air	8/6/03	< 0.007
3	Air	8/13/03	< 0.007

All ne D Rep 103
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
3	Air	8/20/03	< 0.006
3	Air	8/27/03	< 0.008
3	Air	9/3/03	< 0.007
3	Air	9/10/03	< 0.004
3	Air	9/17/03	< 0.007
3	Air	9/24/03	< 0.004
3	Air	10/1/03	< 0.004
3	Air	10/8/03	< 0.005
3	Air	10/15/03	< 0.006
3	Air	10/22/03	< 0.008
3	Air	10/29/03	< 0.004
3	Air	11/5/03	< 0.007
3	Air	11/12/03	< 0.005
3	Air	11/19/03	< 0.004
3	Air	11/26/03	< 0.006
3	Air	12/3/03	< 0.008
3	Air	12/10/03	< 0.005
3	Air	12/17/03	< 0.005
3	Air	12/23/03	< 0.005
3	Air	12/31/03	< 0.006
4	Air	1/8/03	< 0.003
4	Air	1/15/03	< 0.003
4	Air	1/22/03	< 0.003
4	Air	1/29/03	< 0.003
4	Air	2/5/03	< 0.005
4	Air	2/12/03	< 0.005
4	Air	2/19/03	< 0.003
4	Air	2/26/03	< 0.005
4	Air	3/5/03	< 0.004
4	Air	3/12/03	< 0.004
4	Air	3/19/03	< 0.003
4	Air	3/26/03	< 0.003
4	Air	4/2/03	< 0.002
4	Air	4/9/03	< 0.004
4	Air	4/16/03	< 0.005
4	Air	4/23/03	< 0.004
4	Air	4/30/03	< 0.005
4	Air	5/7/03	< 0.003
4	Air	5/14/03	< 0.002
4	Air	5/21/03	< 0.002
4	Air	5/28/03	< 0.003
4	Air	6/4/03	< 0.002

Air Iodine Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
4	Air	6/11/03	< 0.003
4	Air	6/18/03	< 0.005
4	Air	6/25/03	< 0.006
4	Air	7/2/03	< 0.006
4	Air	7/9/03	< 0.005
4	Air	7/16/03	< 0.007
4	Air	7/23/03	< 0.005
4	Air	7/30/03	< 0.005
4	Air	8/6/03	< 0.007
4	Air	8/13/03	< 0.008
4	Air	8/20/03	< 0.006
4	Air	8/27/03	< 0.008
4	Air	9/3/03	< 0.008
4	Air	9/10/03	< 0.004
4	Air	9/17/03	< 0.007
4	Air	9/24/03	< 0.004
4	Air	10/1/03	< 0.004
4	Air	10/8/03	< 0.006
4	Air	10/15/03	< 0.006
4	Air	10/22/03	< 0.009
4	Air	10/29/03	< 0.004
4	Air	11/5/03	< 0.007
4	Air	11/12/03	< 0.005
4	Air	11/19/03	< 0.004
4	Air	11/26/03	< 0.006
4	Air	12/3/03	< 0.008
4	Air	12/10/03	< 0.005
4	Air	12/17/03	< 0.005
4	Air	12/23/03	< 0.005
4	Air	12/31/03	< 0.006
5	Air	1/8/03	< 0.003
5	Air	1/15/03	< 0.003
5	Air	1/22/03	< 0.004
5	Air	1/29/03	< 0.003
5	Air	2/5/03	< 0.005
5	Air	2/12/03	< 0.005
5	Air	2/19/03	< 0.003
5	Air	2/26/03	< 0.005
5	Air	3/5/03	< 0.004
5	Air	3/12/03	< 0.004
5	Air	3/19/03	< 0.003
5	Air	3/26/03	< 0.004

Air 1e D1 Rep 03
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
5	Air	4/2/03	< 0.003
5	Air	4/9/03	< 0.004
5	Air	4/16/03	< 0.004
5	Air	4/23/03	< 0.004
5	Air	4/30/03	< 0.004
5	Air	5/7/03	< 0.003
5	Air	5/14/03	< 0.002
5	Air	5/21/03	< 0.002
5	Air	5/28/03	< 0.003
5	Air	6/4/03	< 0.002
5	Air	6/11/03	< 0.003
5	Air	6/18/03	< 0.005
5	Air	6/25/03	< 0.006
5	Air	7/2/03	< 0.006
5	Air	7/9/03	< 0.005
5	Air	7/16/03	< 0.008
5	Air	7/23/03	< 0.005
5	Air	7/30/03	< 0.005
5	Air	8/6/03	< 0.007
5	Air	8/13/03	< 0.008
5	Air	8/20/03	< 0.006
5	Air	8/27/03	< 0.008
5	Air	9/3/03	< 0.008
5	Air	9/10/03	< 0.004
5	Air	9/17/03	< 0.007
5	Air	9/24/03	< 0.004
5	Air	10/1/03	< 0.004
5	Air	10/8/03	< 0.006
5	Air	10/15/03	< 0.006
5	Air	10/22/03	< 0.009
5	Air	10/29/03	< 0.004
5	Air	11/5/03	< 0.007
5	Air	11/12/03	< 0.005
5	Air	11/19/03	< 0.004
5	Air	11/26/03	< 0.006
5	Air	12/3/03	< 0.008
5	Air	12/10/03	< 0.005
5	Air	12/17/03	< 0.005
5	Air	12/23/03	< 0.005
5	Air	12/31/03	< 0.006
6	Air	1/8/03	< 0.003
6	Air	1/15/03	< 0.004

Air Iodine Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
6	Air	1/22/03	< 0.004
6	Air	1/29/03	< 0.003
6	Air	2/5/03	< 0.005
6	Air	2/12/03	< 0.006
6	Air	2/19/03	< 0.003
6	Air	2/26/03	< 0.006
6	Air	3/5/03	< 0.004
6	Air	3/12/03	< 0.004
6	Air	3/19/03	< 0.003
6	Air	3/26/03	< 0.004
6	Air	4/2/03	< 0.003
6	Air	4/9/03	< 0.004
6	Air	4/16/03	< 0.005
6	Air	4/23/03	< 0.004
6	Air	4/30/03	< 0.004
6	Air	5/7/03	< 0.003
6	Air	5/14/03	< 0.002
6	Air	5/21/03	< 0.002
6	Air	5/28/03	< 0.003
6	Air	6/4/03	< 0.002
6	Air	6/11/03	< 0.003
6	Air	6/18/03	< 0.005
6	Air	6/25/03	< 0.006
6	Air	7/2/03	< 0.006
6	Air	7/9/03	< 0.005
6	Air	7/16/03	< 0.008
6	Air	7/23/03	< 0.005
6	Air	7/30/03	< 0.005
6	Air	8/6/03	< 0.007
6	Air	8/13/03	< 0.008
6	Air	8/20/03	< 0.006
6	Air	8/27/03	< 0.008
6	Air	9/3/03	< 0.008
6	Air	9/10/03	< 0.004
6	Air	9/17/03	< 0.007
6	Air	9/24/03	< 0.004
6	Air	10/1/03	< 0.004
6	Air	10/8/03	< 0.006
6	Air	10/15/03	< 0.006
6	Air	10/22/03	< 0.009
6	Air	10/29/03	< 0.004
6	Air	11/5/03	< 0.007
6	Air	11/12/03	< 0.005
6	Air	11/19/03	< 0.005

Annual Report 103
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
6	Air	11/26/03	< 0.006
6	Air	12/3/03	< 0.008
6	Air	12/10/03	< 0.005
6	Air	12/17/03	< 0.005
6	Air	12/23/03	< 0.005
6	Air	12/31/03	< 0.006
7	Air	1/8/03	< 0.003
7	Air	1/15/03	< 0.004
7	Air	1/22/03	< 0.004
7	Air	1/29/03	< 0.003
7	Air	2/5/03	< 0.005
7	Air	2/12/03	< 0.005
7	Air	2/19/03	< 0.003
7	Air	2/26/03	< 0.005
7	Air	3/5/03	< 0.004
7	Air	3/12/03	< 0.004
7	Air	3/19/03	< 0.003
7	Air	3/26/03	< 0.004
7	Air	4/2/03	< 0.003
7	Air	4/9/03	< 0.004
7	Air	4/16/03	< 0.005
7	Air	4/23/03	< 0.004
7	Air	4/30/03	< 0.004
7	Air	5/7/03	< 0.003
7	Air	5/14/03	< 0.002
7	Air	5/21/03	< 0.002
7	Air	5/28/03	< 0.003
7	Air	6/4/03	< 0.002
7	Air	6/11/03	< 0.003
7	Air	6/18/03	< 0.005
7	Air	6/25/03	< 0.006
7	Air	7/2/03	< 0.006
7	Air	7/9/03	< 0.005
7	Air	7/16/03	< 0.007
7	Air	7/23/03	< 0.005
7	Air	7/30/03	< 0.005
7	Air	8/6/03	< 0.007
7	Air	8/13/03	< 0.007
7	Air	8/20/03	< 0.006
7	Air	8/27/03	< 0.008
7	Air	9/3/03	< 0.007
7	Air	9/10/03	< 0.004

Air Iodine Detail Report 2003
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
7	Air	9/17/03	< 0.007
7	Air	9/24/03	< 0.003
7	Air	10/1/03	< 0.004
7	Air	10/8/03	< 0.006
7	Air	10/15/03	< 0.006
7	Air	10/22/03	< 0.009
7	Air	10/29/03	< 0.004
7	Air	11/5/03	< 0.007
7	Air	11/12/03	< 0.005
7	Air	11/19/03	< 0.005
7	Air	11/26/03	< 0.006
7	Air	12/3/03	< 0.008
7	Air	12/10/03	< 0.005
7	Air	12/17/03	< 0.005
7	Air	12/23/03	< 0.005
7	Air	12/31/03	< 0.006
35	Air	1/8/03	< 0.004
35	Air	1/15/03	< 0.005
35	Air	1/22/03	< 0.007
35	Air	1/29/03	< 0.002
35	Air	2/5/03	< 0.004
35	Air	2/12/03	< 0.003
35	Air	2/19/03	< 0.007
35	Air	2/26/03	< 0.006
35	Air	3/5/03	< 0.005
35	Air	3/12/03	< 0.006
35	Air	3/19/03	< 0.006
35	Air	3/26/03	< 0.003
35	Air	4/2/03	< 0.006
35	Air	4/9/03	< 0.005
35	Air	4/16/03	< 0.006
35	Air	4/23/03	< 0.007
35	Air	4/30/03	< 0.012
35	Air	5/7/03	< 0.004
35	Air	5/14/03	< 0.012
35	Air	5/21/03	< 0.005
35	Air	5/28/03	< 0.007
35	Air	6/4/03	< 0.005
35	Air	6/11/03	< 0.006
35	Air	6/18/03	< 0.005
35	Air	6/25/03	< 0.006
35	Air	7/2/03	< 0.010

Air Monitoring Report 2003
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Weekly Results in pCi/m3 +/- 2 Sigma

Location	Sample Type	Collection Dat	I-131
35	Air	7/9/03	< 0.007
35	Air	7/16/03	< 0.008
35	Air	7/23/03	< 0.004
35	Air	7/30/03	< 0.006
35	Air	8/6/03	< 0.003
35	Air	8/13/03	< 0.004
35	Air	8/20/03	< 0.004
35	Air	8/27/03	< 0.005
35	Air	9/3/03	< 0.006
35	Air	9/10/03	< 0.008
35	Air	9/17/03	< 0.008
35	Air	9/24/03	< 0.010
35	Air	10/1/03	< 0.006
35	Air	10/8/03	< 0.007
35	Air	10/15/03	< 0.005
35	Air	10/22/03	< 0.004
35	Air	10/29/03	< 0.009
35	Air	11/5/03	< 0.004
35	Air	11/12/03	< 0.007
35	Air	11/19/03	< 0.008
35	Air	11/26/03	< 0.014
35	Air	12/3/03	< 0.004
35	Air	12/10/03	< 0.008
35	Air	12/17/03	< 0.007
35	Air	12/23/03	< 0.007
35	Air	12/31/03	< 0.008

Food Products Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Bc-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
2	chinese cabbage	8/12/03	< 155.91 < 33.37	< 13.63 5,014.40 +/- 548.30	< 10.80	< 20.49	< 20.56
2	collard greens	8/12/03	< 141.68 < 24.29	< 12.34 4,571.90 +/- 416.50	< 11.14	< 11.15	< 12.94
2	swiss chard	8/12/03	< 117.74 < 13.37	< 13.92 5,489.90 +/- 426.20	< 13.23	< 10.09	< 13.20
2	turnip greens	8/12/03	< 110.41 < 16.65	< 7.62 5,942.40 +/- 414.20	< 8.18	< 14.71	< 12.70
2	chinese cabbage	9/8/03	< 104.57 < 16.71	< 8.31 3,082.40 +/- 332.03	< 10.99	< 11.30	< 15.04
2	collard greens	9/8/03	< 136.80 < 16.61	< 7.61 3,617.10 +/- 399.70	< 11.20	< 13.22	< 9.64
2	swiss chard	9/8/03	< 194.40 < 18.88	< 12.76 4,790.30 +/- 604.50	< 8.90	< 14.88	< 22.01
2	turnip greens	9/8/03	< 162.20 < 16.39	< 17.61 5,122.30 +/- 639.80	< 17.18	< 21.10	< 19.78
2	chinese cabbage	10/16/03	< 199.78 < 21.98	< 16.34 2,797.10 +/- 433.40	< 16.52	< 15.95	< 16.70
2	collard greens	10/16/03	< 148.37 < 29.09	< 17.13 3,468.00 +/- 462.80	< 11.11	< 16.80	< 14.97
2	swiss chard	10/16/03	241.94 +/- 135.80 < 28.81	< 10.16 5,123.80 +/- 579.50	< 20.49	< 24.57	< 21.35
2	turnip greens	10/16/03	< 169.18 < 22.84	< 9.22 3,971.90 +/- 507.60	< 12.83	< 9.82	< 15.01

Food Products Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
16	chinese cabbage	7/15/03	< 200.86 < 27.46	< 20.29 5,226.80 +/- 615.60	< 17.71	< 23.62	< 13.09
16	collard greens	7/15/03	< 145.25 < 17.69	< 14.95 4,390.40 +/- 509.40	< 9.10	< 13.57	< 9.50
16	swiss chard	7/15/03	< 141.54 < 22.14	< 12.10 5,371.90 +/- 466.50	< 11.53	< 12.92	< 12.64
16	turnip greens	7/15/03	< 115.94 < 16.31	< 11.06 4,805.20 +/- 500.20	< 7.56	< 10.09	< 12.73
16	chinese cabbage	8/12/03	< 208.97 < 27.45	< 19.44 4,136.20 +/- 507.90	< 18.23	< 12.13	< 12.71
16	collard greens	8/12/03	< 126.67 < 24.90	< 12.95 5,105.30 +/- 507.90	< 9.99	< 9.29	< 13.72
16	swiss chard	8/12/03	< 94.87 < 15.63	< 11.55 4,789.60 +/- 273.55	< 8.91	< 9.31	< 5.85
16	turnip greens	8/12/03	270.16 +/- 136.50 < 14.02	< 15.36 6,851.20 +/- 677.80	< 22.45	< 19.99	< 12.89
16	chinese cabbage	9/8/03	< 81.97 < 10.99	< 5.59 2,714.70 +/- 290.40	< 6.92	< 7.25	< 6.35
16	collard greens	9/8/03	< 131.83 < 25.83	< 12.38 4,560.40 +/- 448.00	< 8.45	< 6.94	< 16.06
16	swiss chard	9/8/03	< 189.51 < 20.38	< 18.82 5,010.40 +/- 649.50	< 13.70	< 27.35	< 13.33
16	turnip greens	9/8/03	< 174.55 < 21.61	< 5.50 5,405.00 +/- 587.60	< 15.29	< 9.85	< 20.66

Food Products Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
16	collard greens	10/16/03	< 113.02 < 11.68	< 9.03 3,912.40 +/- 257.03	< 4.56	< 9.61	< 9.88
16	turnip greens	10/16/03	357.83 +/- 158.80 < 13.96	< 8.67 4,784.10 +/- 450.10	< 5.47	< 6.95	< 12.44
20	chinese cabbage	8/12/03	< 183.09 < 23.75	< 8.40 3,924.50 +/- 404.50	< 9.94	< 10.87	< 15.15
20	collard greens	8/12/03	< 200.52 < 33.76	< 12.26 5,825.00 +/- 687.60	< 16.60	< 19.93	< 19.74
20	chinese cabbage	9/8/03	287.30 +/- 123.70 < 18.65	< 10.83 4,069.50 +/- 406.10	< 8.31	< 12.30	< 11.11
20	collard greens	9/8/03	< 147.92 < 22.43	< 13.16 5,844.70 +/- 515.20	< 14.83	< 12.24	< 12.66
20	turnip greens	9/8/03	758.66 +/- 281.20 < 27.88	< 20.37 6,294.00 +/- 716.00	< 14.89	< 20.00	< 23.08
20	chinese cabbage	10/16/03	1,195.50 +/- 283.80 < 23.26	< 21.78 5,347.80 +/- 719.30	< 15.84	< 16.39	< 26.97
20	collard greens	10/16/03	362.56 +/- 111.20 < 12.37	< 6.97 3,984.20 +/- 342.60	< 7.77	< 10.61	< 7.89
20	turnip greens	10/16/03	973.04 +/- 254.10 < 28.13	< 17.41 5,253.60 +/- 503.10	< 17.18	< 16.48	< 15.83
37	chinese cabbage	7/15/03	< 116.40 < 11.17	< 12.89 3,338.80 +/- 348.40	< 11.30	< 15.18	< 10.29

Food Products Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
37	collard greens	7/15/03	< 141.66 < 18.72	< 9.38 3,696.00 +/- 436.80	< 8.85	< 20.39	< 12.15
37	swiss chard	7/15/03	< 168.48 < 23.96	< 10.06 4,150.00 +/- 526.70	< 12.09	< 14.28	< 11.37
37	turnip greens	7/15/03	< 131.34 < 12.09	< 9.15 3,844.10 +/- 371.40	< 7.96	< 12.48	< 12.15
37	chinese cabbage	8/12/03	339.85 +/- 137.90 < 18.97	< 6.82 3,231.90 +/- 433.80	< 12.01	< 12.35	< 15.64
37	collard greens	8/12/03	< 173.72 < 20.39	< 15.84 4,127.40 +/- 532.10	< 11.36	< 11.76	< 14.84
37	swiss chard	8/12/03	< 155.12 < 22.12	< 13.90 3,760.90 +/- 489.60	< 7.67	< 12.30	< 14.63
37	turnip greens	8/12/03	317.11 +/- 129.00 < 20.55	< 15.06 4,301.50 +/- 444.70	< 8.28	< 11.13	< 12.61
37	chinese cabbage	9/8/03	< 96.05 < 9.67	< 5.92 5,015.40 +/- 387.10	< 6.41	< 9.82	< 9.79
37	collard greens	9/8/03	< 103.45 < 15.54	< 7.88 3,908.20 +/- 388.60	< 10.96	< 11.11	< 16.00
37	swiss chard	9/8/03	< 184.98 < 36.74	< 16.25 4,184.30 +/- 550.00	< 17.43	< 23.83	< 12.61
37	turnip greens	9/8/03	< 80.89 < 12.03	< 8.01 3,951.80 +/- 319.10	< 6.66	< 7.17	< 7.54
37	chinese cabbage	10/16/03	< 134.14 < 19.54	< 9.16 3,970.50 +/- 403.80	< 11.71	< 15.56	< 16.28

Food Products Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Bc-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
37	collard greens	10/16/03	< 166.64 < 21.24	< 12.37 3,674.90 +/- 447.20	< 15.30	< 17.59	< 16.36
37	swiss chard	10/16/03	< 177.77 < 15.75	< 14.66 4,862.70 +/- 520.50	< 10.80	< 11.49	< 15.14
70	chinese cabbage	7/15/03	< 97.71 < 13.36	< 5.97 3,213.65 +/- 264.51	< 4.65	< 10.06	< 10.04
70	collard greens	7/15/03	< 151.44 < 23.92	< 18.13 5,388.00 +/- 604.10	< 15.79	< 16.13	< 19.69
70	swiss chard	7/15/03	< 162.05 < 20.22	< 15.03 5,452.50 +/- 636.00	< 19.50	< 21.87	< 11.80
70	turnip greens	7/15/03	< 195.01 < 17.36	< 7.41 4,903.90 +/- 622.00	< 16.45	< 17.30	< 12.42
70	chinese cabbage	8/12/03	< 126.41 < 16.73	< 10.90 2,352.30 +/- 325.00	< 10.24	< 12.96	< 7.24
70	collard greens	8/12/03	< 208.06 < 28.03	< 18.43 4,891.10 +/- 569.50	< 10.03	< 12.66	< 18.58
70	swiss chard	8/12/03	< 142.36 < 17.96	< 10.15 4,631.70 +/- 500.30	< 19.80	< 9.07	< 9.63
70	turnip greens	8/12/03	331.62 +/- 165.30 < 25.73	< 15.58 5,130.00 +/- 528.20	< 10.79	< 11.88	< 14.94
70	chinese cabbage	9/8/03	< 178.61 < 34.63	< 8.51 3,285.90 +/- 490.30	< 14.44	< 21.91	< 19.44
70	collard greens	9/8/03	< 192.88 < 22.32	< 23.27 3,971.70 +/- 605.60	< 22.10	< 18.78	< 19.83

Food Products Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Be-7 I-131	Co-58 K-40	Co-60	Cs-134	Cs-137
70	swiss chard	9/8/03	< 190.44 < 42.85	< 21.08 5,910.00 +/- 674.90	< 10.99	< 15.73	< 18.13
70	turnip greens	9/8/03	348.76 +/- 160.50 < 29.44	< 17.60 5,357.40 +/- 600.00	< 23.89	< 14.11	< 12.85
70	chinese cabbage	10/16/03	< 159.12 < 24.68	< 16.70 2,548.50 +/- 432.70	< 13.11	< 14.69	< 16.18
70	collard greens	10/16/03	< 175.91 < 20.59	< 12.57 3,046.00 +/- 462.40	< 10.98	< 16.98	< 12.33
70	swiss chard	10/16/03	< 192.55 < 20.11	< 12.27 6,005.10 +/- 565.10	< 12.43	< 19.04	< 12.38
70	turnip greens	10/16/03	685.28 +/- 202.00 < 21.33	< 15.90 5,465.20 +/- 613.50	< 15.19	< 13.35	< 16.86

Fish Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Annually Results in pCi/kg wet +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58 K-40	Co-60 Mn-54	Cs-134 Zn-65	Cs-137	Fe-59
25	yellow perch	8/28/03	< 12.88 1,402.10 +/- 388.10	< 7.51 < 20.72	< 13.62 < 27.43	< 13.11	< 52.32
32	yellow perch	8/20/03	< 16.18 1,691.35 +/- 341.24	< 11.86 < 19.07	< 16.27 < 25.21	< 18.94	< 41.20

Milk Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
51	Milk	1/6/03	< 23	< 2	< 3	1,360 +/- 125	< 4
51	Milk	2/3/03	< 8	< 2	< 4	1,278 +/- 95	< 2
51	Milk	3/3/03	< 13	< 5	< 4	1,617 +/- 125	< 3
51	Milk	4/7/03	< 20	< 6	< 6	1,284 +/- 195	< 5
51	Milk	4/21/03	< 22	< 9	< 5	1,335 +/- 163	< 4
51	Milk	5/5/03	< 33	< 3	< 4	1,373 +/- 115	< 3
51	Milk	5/19/03	< 11	< 2	< 4	1,295 +/- 119	< 2
51	Milk	6/2/03	< 12	< 5	< 3	1,260 +/- 123	< 2
51	Milk	6/17/03	< 12	< 4	< 3	1,298 +/- 117	< 3
51	Milk	7/7/03	< 42	< 5	< 4	1,123 +/- 160	< 6
51	Milk	7/22/03	< 17	< 4	< 4	843 +/- 96	< 2
51	Milk	8/4/03	< 21	< 5	< 3	1,316 +/- 126	< 4

Milk Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
51	Milk	8/18/03	< 17	< 4	< 3	982 +/- 100	< 2
51	Milk	9/3/03	< 18	< 3	< 5	1,240 +/- 162	< 3
51	Milk	9/22/03	< 20	< 5	< 5	1,194 +/- 171	< 7
51	Milk	10/6/03	< 12	< 4	< 3	1,275 +/- 128	< 2
51	Milk	10/20/03	< 23	< 8	< 6	1,450 +/- 176	< 4
51	Milk	11/3/03	< 12	< 4	< 4	1,076 +/- 112	< 2
51	Milk	12/1/03	< 23	< 4	< 4	1,423 +/- 118	< 4
61	Milk	4/7/03	< 22	< 4	< 6	1,416 +/- 173	< 4
61	Milk	4/21/03	< 17	< 6	< 7	1,590 +/- 183	< 4
61	Milk	5/5/03	< 33	< 3	< 5	1,877 +/- 127	< 3
61	Milk	5/19/03	< 15	< 3	< 4	1,663 +/- 148	< 4
61	Milk	6/2/03	< 15	< 4	< 4	1,762 +/- 134	< 2

Milk Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
61	Milk	6/16/03	< 28	< 8	< 6	1,730 +/- 200	< 4
61	Milk	7/7/03	< 37	< 6	< 6	1,687 +/- 184	< 8
61	Milk	7/21/03	< 19	< 2	< 5	1,739 +/- 131	< 3
61	Milk	8/4/03	< 21	< 5	< 6	1,686 +/- 199	< 4
61	Milk	8/18/03	< 16	< 3	< 4	1,862 +/- 126	< 1
61	Milk	9/2/03	< 8	< 3	< 6	2,054 +/- 155	< 2
61	Milk	9/22/03	< 18	< 5	< 5	1,607 +/- 187	< 3
71	Milk	1/6/03	< 19	< 3	< 4	1,240 +/- 124	< 4
71	Milk	2/3/03	< 27	< 4	< 5	1,236 +/- 186	< 5
71	Milk	3/3/03	< 10	< 4	< 4	1,198 +/- 112	< 3
71	Milk	4/7/03	< 12	< 4	< 3	1,323 +/- 121	< 4
71	Milk	4/21/03	< 13	< 4	< 3	1,244 +/- 128	< 3

Milk Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	Ba-140	Cs-134	Cs-137	K-40	La-140
71	Milk	5/5/03	< 28	< 3	< 4	1,213 +/- 121	< 7

Sediment Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Annually Results in pCi/kg dry +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58	Co-60	Cs-134	Cs-137	K-40
25	Sediment	5/27/03	< 15.02	< 21.84	< 31.53	590.71 +/- 48.21	13,423.00 +/- 753.50
25	Sediment	10/8/03	< 26.05	< 10.34	< 19.70	413.19 +/- 34.68	14,063.00 +/- 666.90
26	Sediment	5/27/03	< 14.66	< 15.96	< 26.37	LLD	14,956.00 +/- 771.40
26	Sediment	10/8/03	< 23.14	< 19.34	< 25.99	191.40 +/- 29.41	16,136.00 +/- 530.43
27	Sediment	5/27/03	< 10.99	< 10.61	< 6.23	LLD	9,951.75 +/- 370.31
27	Sediment	10/8/03	< 28.49	< 11.39	< 28.09	142.95 +/- 59.03	13,046.00 +/- 516.30
32	Sediment	5/27/03	< 38.66	< 32.33	< 60.16	922.24 +/- 85.26	22,632.00 +/- 1,205.00
32	Sediment	10/8/03	< 44.00	< 35.29	< 51.25	1,134.90 +/- 74.68	26,949.00 +/- 1,020.00
63	Sediment	5/27/03	< 13.36	< 9.47	< 9.97	< 12.29	8,335.00 +/- 477.70
63	Sediment	10/9/03	< 23.54	< 11.47	< 24.04	< 11.74	7,445.30 +/- 519.70

Sediment Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Bi-Annually Results in pCi/kg dry +/- 2 Sigma

Location	Sample Type	Collection Date	Co-58	Co-60	Cs-134	Cs-137	K-40
64	Sediment	5/27/03	< 19.48	< 14.59	< 24.15	< 17.80	7,138.70 +/- 624.10
64	Sediment	10/9/03	< 11.90	< 14.44	< 24.07	< 13.68	5,721.90 +/- 430.00
65	Sediment	5/27/03	< 13.70	< 14.59	< 12.90	< 13.38	9,444.00 +/- 503.50
65	Sediment	10/9/03	< 12.38	< 12.80	< 16.62	< 12.40	8,156.50 +/- 397.40

TLD Gamma Dose Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly

Location	Sample Type	Collection Period	Exposure
1	TLD	1/9/03 to 4/5/03	14.42 +/- 0.91
1	TLD	4/5/03 to 7/1/03	14.68 +/- 0.66
1	TLD	7/1/03 to 10/9/03	14.76 +/- 0.47
1	TLD	10/9/03 to 1/6/04	15.68 +/- 0.65
3	TLD	1/9/03 to 4/5/03	14.90 +/- 0.76
3	TLD	4/5/03 to 7/1/03	14.93 +/- 0.59
3	TLD	7/1/03 to 10/9/03	14.55 +/- 0.78
3	TLD	10/9/03 to 1/6/04	16.55 +/- 0.68
4	TLD	1/9/03 to 4/5/03	15.04 +/- 0.88
4	TLD	4/5/03 to 7/1/03	14.72 +/- 0.39
4	TLD	7/1/03 to 10/9/03	15.06 +/- 0.45
4	TLD	10/9/03 to 1/6/04	16.35 +/- 0.95
5	TLD	1/9/03 to 4/5/03	13.52 +/- 0.66
5	TLD	4/5/03 to 7/1/03	14.07 +/- 0.47
5	TLD	7/1/03 to 10/9/03	13.43 +/- 0.29
5	TLD	10/9/03 to 1/6/04	16.21 +/- 0.46
6	TLD	1/9/03 to 4/5/03	15.09 +/- 0.83
6	TLD	4/5/03 to 7/1/03	16.80 +/- 0.42
6	TLD	7/1/03 to 10/9/03	15.69 +/- 0.61
6	TLD	10/9/03 to 1/6/04	18.30 +/- 0.62
7	TLD	1/9/03 to 4/5/03	12.43 +/- 0.81
7	TLD	4/5/03 to 7/1/03	15.19 +/- 0.36
7	TLD	7/1/03 to 10/9/03	13.92 +/- 0.58
7	TLD	10/9/03 to 1/6/04	16.55 +/- 0.63
8	TLD	1/9/03 to 4/5/03	11.66 +/- 0.73
8	TLD	4/5/03 to 7/1/03	13.76 +/- 0.43
8	TLD	7/1/03 to 10/9/03	12.73 +/- 0.38
8	TLD	10/9/03 to 1/6/04	14.99 +/- 0.52
9	TLD	1/9/03 to 4/5/03	11.38 +/- 0.77
9	TLD	4/5/03 to 7/1/03	14.20 +/- 0.47
9	TLD	7/1/03 to 10/9/03	12.56 +/- 0.49
9	TLD	10/9/03 to 1/6/04	15.67 +/- 0.64
10	TLD	1/9/03 to 4/5/03	15.58 +/- 0.89
10	TLD	4/5/03 to 7/1/03	17.72 +/- 0.74
10	TLD	7/1/03 to 10/9/03	16.94 +/- 0.55

TLD Gamma Dose Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly

Location	Sample Type	Collection Period			Exposure		
10	TLD	10/9/03	to	1/6/04	19.85	+/-	1.27
11	TLD	1/9/03	to	4/5/03	15.54	+/-	0.82
11	TLD	4/5/03	to	7/1/03	14.67	+/-	0.45
11	TLD	7/1/03	to	10/9/03	15.84	+/-	1.20
11	TLD	10/9/03	to	1/6/04	16.19	+/-	0.56
12	TLD	1/9/03	to	4/5/03	15.16	+/-	0.81
12	TLD	4/5/03	to	7/1/03	15.53	+/-	0.56
12	TLD	7/1/03	to	10/9/03	15.64	+/-	0.58
12	TLD	10/9/03	to	1/6/04	17.13	+/-	0.70
13	TLD	1/9/03	to	4/5/03	15.89	+/-	0.68
13	TLD	4/5/03	to	7/1/03	16.23	+/-	0.74
13	TLD	7/1/03	to	10/9/03	15.54	+/-	0.32
13	TLD	10/9/03	to	1/6/04	16.92	+/-	0.74
14	TLD	1/9/03	to	4/5/03	14.34	+/-	0.82
14	TLD	4/5/03	to	7/1/03	15.41	+/-	0.49
14	TLD	7/1/03	to	10/9/03	14.38	+/-	0.48
14	TLD	10/9/03	to	1/6/04	16.60	+/-	0.63
15	TLD	1/9/03	to	4/5/03	13.85	+/-	0.90
15	TLD	4/5/03	to	7/1/03			
15	TLD	7/1/03	to	10/9/03	14.09	+/-	0.60
15	TLD	10/9/03	to	1/6/04	11.57	+/-	0.63
21	TLD	1/9/03	to	4/5/03	17.55	+/-	0.79
21	TLD	4/5/03	to	7/1/03	18.01	+/-	0.50
21	TLD	7/1/03	to	10/9/03	17.42	+/-	0.58
21	TLD	10/9/03	to	1/6/04	19.60	+/-	0.73
23	TLD	1/9/03	to	4/5/03	17.71	+/-	0.69
23	TLD	4/5/03	to	7/1/03	18.14	+/-	0.39
23	TLD	7/1/03	to	10/9/03	17.60	+/-	0.32
23	TLD	10/9/03	to	1/6/04	19.45	+/-	0.41
24	TLD	1/9/03	to	4/5/03	15.28	+/-	0.69
24	TLD	4/5/03	to	7/1/03	15.82	+/-	0.55
24	TLD	7/1/03	to	10/9/03	14.80	+/-	0.33
24	TLD	10/9/03	to	1/6/04	17.38	+/-	0.56
29	TLD	1/9/03	to	4/5/03	19.03	+/-	0.81
29	TLD	4/5/03	to	7/1/03	20.67	+/-	0.70

TLI nma Del epon 3
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Quarterly

Location	Sample Type	Collection Period	Exposure
29	TLD	7/1/03 to 10/9/03	18.92 +/- 0.79
29	TLD	10/9/03 to 1/6/04	22.63 +/- 0.72
30	TLD	1/9/03 to 4/5/03	17.94 +/- 1.01
30	TLD	4/5/03 to 7/1/03	18.37 +/- 0.61
30	TLD	7/1/03 to 10/9/03	16.95 +/- 0.60
30	TLD	10/9/03 to 1/6/04	20.06 +/- 0.91
31	TLD	1/9/03 to 4/5/03	17.57 +/- 1.16
31	TLD	4/5/03 to 7/1/03	19.73 +/- 0.51
31	TLD	7/1/03 to 10/9/03	17.47 +/- 0.43
31	TLD	10/9/03 to 1/6/04	22.42 +/- 1.80
33	TLD	1/9/03 to 4/5/03	17.08 +/- 0.94
33	TLD	4/5/03 to 7/1/03	20.31 +/- 0.67
33	TLD	7/1/03 to 10/9/03	17.99 +/- 0.57
33	TLD	10/9/03 to 1/6/04	22.10 +/- 0.82
35	TLD	1/9/03 to 4/5/03	12.46 +/- 0.78
35	TLD	4/5/03 to 7/1/03	14.88 +/- 0.36
35	TLD	7/1/03 to 10/9/03	13.43 +/- 0.49
35	TLD	10/9/03 to 1/6/04	16.11 +/- 0.66
36	TLD	1/9/03 to 4/5/03	16.40 +/- 0.82
36	TLD	4/5/03 to 7/1/03	18.47 +/- 0.68
36	TLD	7/1/03 to 10/9/03	17.28 +/- 0.72
36	TLD	10/9/03 to 1/6/04	19.24 +/- 1.85
53	TLD	1/9/03 to 4/5/03	13.68 +/- 0.79
53	TLD	4/5/03 to 7/1/03	15.99 +/- 0.40
53	TLD	7/1/03 to 10/9/03	15.20 +/- 0.35
53	TLD	10/9/03 to 1/6/04	17.87 +/- 0.55
54	TLD	1/9/03 to 4/5/03	13.67 +/- 1.48
54	TLD	4/5/03 to 7/1/03	15.75 +/- 0.41
54	TLD	7/1/03 to 10/9/03	14.37 +/- 0.81
54	TLD	10/9/03 to 1/6/04	17.18 +/- 0.40
55	TLD	1/9/03 to 4/5/03	14.81 +/- 1.20
55	TLD	4/5/03 to 7/1/03	17.03 +/- 0.41
55	TLD	7/1/03 to 10/9/03	16.14 +/- 0.67
55	TLD	10/9/03 to 1/6/04	18.57 +/- 0.52
56	TLD	1/9/03 to 4/5/03	13.63 +/- 0.85

TLD Gamma Dose Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly

Location	Sample Type	Collection Period	Exposure
56	TLD	4/5/03 to 7/1/03	15.49 +/- 0.79
56	TLD	7/1/03 to 10/9/03	14.18 +/- 0.51
56	TLD	10/9/03 to 1/6/04	16.42 +/- 0.61
58	TLD	1/9/03 to 4/5/03	13.66 +/- 0.83
58	TLD	4/5/03 to 7/1/03	15.24 +/- 0.49
58	TLD	7/1/03 to 10/9/03	14.03 +/- 0.38
58	TLD	10/9/03 to 1/6/04	16.75 +/- 0.57

TLB Gamma 2003 Data Report 2003
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Quarterly

Location	Sample Type	Collection Period		Exposure		
1	TLB	1/9/03	to 4/5/03	13.97	+/-	1.54
1	TLB	4/5/03	to 7/1/03	14.45	+/-	0.83
1	TLB	7/1/03	to 10/9/03	12.72	+/-	0.84
1	TLB	10/9/03	to 1/6/04	14.67	+/-	0.88
3	TLB	1/9/03	to 4/5/03	14.26	+/-	0.49
3	TLB	4/5/03	to 7/1/03	10.85	+/-	0.65
3	TLB	7/1/03	to 10/9/03	13.22	+/-	0.53
3	TLB	10/9/03	to 1/6/04	11.39	+/-	0.58
4	TLB	1/9/03	to 4/5/03	15.72	+/-	1.71
4	TLB	4/5/03	to 7/1/03	14.98	+/-	0.72
4	TLB	7/1/03	to 10/9/03	13.50	+/-	0.31
4	TLB	10/9/03	to 1/6/04	16.08	+/-	0.71
5	TLB	1/9/03	to 4/5/03	14.70	+/-	0.43
5	TLB	4/5/03	to 7/1/03	14.35	+/-	0.65
5	TLB	7/1/03	to 10/9/03	13.38	+/-	0.36
5	TLB	10/9/03	to 1/6/04	15.44	+/-	0.64
6	TLB	1/9/03	to 4/5/03	16.14	+/-	0.30
6	TLB	4/5/03	to 7/1/03	16.34	+/-	0.70
6	TLB	7/1/03	to 10/9/03	14.89	+/-	0.32
6	TLB	10/9/03	to 1/6/04	17.02	+/-	0.61
7	TLB	1/9/03	to 4/5/03	14.99	+/-	0.32
7	TLB	4/5/03	to 7/1/03	15.57	+/-	1.00
7	TLB	7/1/03	to 10/9/03	12.85	+/-	0.23
7	TLB	10/9/03	to 1/6/04	15.97	+/-	0.89
8	TLB	1/9/03	to 4/5/03	14.07	+/-	0.33
8	TLB	4/5/03	to 7/1/03	14.10	+/-	0.64
8	TLB	7/1/03	to 10/9/03	12.85	+/-	0.23
8	TLB	10/9/03	to 1/6/04	14.76	+/-	0.68
9	TLB	1/9/03	to 4/5/03	13.95	+/-	0.31
9	TLB	4/5/03	to 7/1/03	13.63	+/-	0.76
9	TLB	7/1/03	to 10/9/03	13.06	+/-	0.31
9	TLB	10/9/03	to 1/6/04	14.64	+/-	0.82
10	TLB	1/9/03	to 4/5/03	16.54	+/-	0.47
10	TLB	4/5/03	to 7/1/03	17.65	+/-	0.69
10	TLB	7/1/03	to 10/9/03	15.76	+/-	0.46
10	TLB	10/9/03	to 1/6/04	19.14	+/-	0.45

TLD Gamma Dose Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly

Location	Sample Type	Collection Period		Exposure		
11	TLB	1/9/03	to 4/5/03	12.70	+/-	0.49
11	TLB	4/5/03	to 7/1/03	15.50	+/-	0.93
11	TLB	7/1/03	to 10/9/03	12.85	+/-	0.37
11	TLB	10/9/03	to 1/6/04	16.08	+/-	0.53
12	TLB	1/9/03	to 4/5/03	15.42	+/-	0.38
12	TLB	4/5/03	to 7/1/03	15.49	+/-	0.56
12	TLB	7/1/03	to 10/9/03	14.38	+/-	0.26
12	TLB	10/9/03	to 1/6/04	16.89	+/-	0.82
13	TLB	1/9/03	to 4/5/03	13.68	+/-	0.55
13	TLB	4/5/03	to 7/1/03	14.94	+/-	0.79
13	TLB	7/1/03	to 10/9/03	13.61	+/-	0.32
13	TLB	10/9/03	to 1/6/04	15.78	+/-	0.88
14	TLB	1/9/03	to 4/5/03	12.63	+/-	0.46
14	TLB	4/5/03	to 7/1/03	14.76	+/-	0.57
14	TLB	7/1/03	to 10/9/03	12.11	+/-	0.36
14	TLB	10/9/03	to 1/6/04	15.36	+/-	0.80
15	TLB	1/9/03	to 4/5/03	10.67	+/-	0.45
15	TLB	4/5/03	to 7/1/03	13.29	+/-	0.75
15	TLB	7/1/03	to 10/9/03	11.53	+/-	0.92
15	TLB	10/9/03	to 1/6/04	14.49	+/-	0.90
21	TLB	1/9/03	to 4/5/03	15.58	+/-	0.50
21	TLB	4/5/03	to 7/1/03	16.85	+/-	1.04
21	TLB	7/1/03	to 10/9/03	15.27	+/-	0.40
21	TLB	10/9/03	to 1/6/04	17.65	+/-	0.93
23	TLB	1/9/03	to 4/5/03	13.13	+/-	0.79
23	TLB	4/5/03	to 7/1/03	16.01	+/-	0.96
23	TLB	7/1/03	to 10/9/03	13.97	+/-	0.78
23	TLB	10/9/03	to 1/6/04	16.84	+/-	0.72
24	TLB	1/9/03	to 4/5/03	14.56	+/-	0.99
24	TLB	4/5/03	to 7/1/03	14.39	+/-	0.74
24	TLB	7/1/03	to 10/9/03	13.78	+/-	0.76
24	TLB	10/9/03	to 1/6/04	15.15	+/-	0.77
29	TLB	1/9/03	to 4/5/03	18.17	+/-	0.59
29	TLB	4/5/03	to 7/1/03	20.53	+/-	0.85
29	TLB	7/1/03	to 10/9/03	17.81	+/-	0.54

TLE ...ama ... Def ...spor ...3
 Radiological Environmental Monitoring Program Detail Data
 Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
 Sample Frequency is: Quarterly

Location	Sample Type	Collection Period		Exposure		
29	TLB	10/9/03	to 1/6/04	20.56	+/-	1.06
30	TLB	1/9/03	to 4/5/03	16.53	+/-	0.75
30	TLB	4/5/03	to 7/1/03	17.75	+/-	0.78
30	TLB	7/1/03	to 10/9/03	16.28	+/-	0.51
30	TLB	10/9/03	to 1/6/04	18.02	+/-	0.68
31	TLB	1/9/03	to 4/5/03	17.78	+/-	0.61
31	TLB	4/5/03	to 7/1/03	19.02	+/-	0.66
31	TLB	7/1/03	to 10/9/03	17.50	+/-	0.54
31	TLB	10/9/03	to 1/6/04	19.62	+/-	0.48
33	TLB	1/9/03	to 4/5/03	19.11	+/-	0.44
33	TLB	4/5/03	to 7/1/03	20.36	+/-	0.70
33	TLB	7/1/03	to 10/9/03	18.63	+/-	0.48
33	TLB	10/9/03	to 1/6/04	21.46	+/-	0.58
35	TLB	1/9/03	to 4/5/03	14.26	+/-	0.48
35	TLB	4/5/03	to 7/1/03	15.11	+/-	0.55
35	TLB	7/1/03	to 10/9/03	13.67	+/-	0.44
35	TLB	10/9/03	to 1/6/04	15.89	+/-	0.53
36	TLB	1/9/03	to 4/5/03	18.54	+/-	0.46
36	TLB	4/5/03	to 7/1/03	18.83	+/-	0.78
36	TLB	7/1/03	to 10/9/03	17.98	+/-	0.39
36	TLB	10/9/03	to 1/6/04	20.30	+/-	0.60
53	TLB	1/9/03	to 4/5/03	15.71	+/-	0.46
53	TLB	4/5/03	to 7/1/03	16.21	+/-	0.80
53	TLB	7/1/03	to 10/9/03	15.45	+/-	0.41
53	TLB	10/9/03	to 1/6/04	18.87	+/-	0.87
54	TLB	1/9/03	to 4/5/03	15.87	+/-	0.77
54	TLB	4/5/03	to 7/1/03	16.29	+/-	0.74
54	TLB	7/1/03	to 10/9/03	15.11	+/-	0.57
54	TLB	10/9/03	to 1/6/04	19.09	+/-	0.88
55	TLB	1/9/03	to 4/5/03	16.24	+/-	0.61
55	TLB	4/5/03	to 7/1/03	16.53	+/-	0.67
55	TLB	7/1/03	to 10/9/03	15.58	+/-	0.28
55	TLB	10/9/03	to 1/6/04	18.89	+/-	0.70
56	TLB	1/9/03	to 4/5/03	14.45	+/-	0.60
56	TLB	4/5/03	to 7/1/03	13.92	+/-	0.80

TLD Gamma Dose Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly

Location	Sample Type	Collection Period	Exposure
56	TLB	7/1/03 to 10/9/03	13.68 +/- 0.35
56	TLB	10/9/03 to 1/6/04	16.12 +/- 0.96
58	TLB	1/9/03 to 4/5/03	14.40 +/- 0.72
58	TLB	4/5/03 to 7/1/03	14.50 +/- 0.73
58	TLB	7/1/03 to 10/9/03	13.73 +/- 0.58
58	TLB	10/9/03 to 1/6/04	16.23 +/- 1.07

TLE Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Annual

Location	Sample Type	Collection Period	Exposure
1	TLA	1/9/03 to 1/6/04	58.19 +/- 2.57
3	TLA	1/9/03 to 1/6/04	56.91 +/- 1.23
4	TLA	1/9/03 to 1/6/04	65.41 +/- 2.26
5	TLA	1/9/03 to 1/6/04	55.90 +/- 1.44
6	TLA	1/9/03 to 1/6/04	73.59 +/- 1.65
7	TLA	1/9/03 to 1/6/04	62.74 +/- 1.28
8	TLA	1/9/03 to 1/6/04	61.00 +/- 2.02
9	TLA	1/9/03 to 1/6/04	57.88 +/- 2.99
10	TLA	1/9/03 to 1/6/04	81.86 +/- 2.86
11	TLA	1/9/03 to 1/6/04	60.10 +/- 3.33
12	TLA	1/9/03 to 1/6/04	66.37 +/- 1.76
13	TLA	1/9/03 to 1/6/04	64.05 +/- 3.38
14	TLA	1/9/03 to 1/6/04	54.81 +/- 3.41
15	TLA	1/9/03 to 1/6/04	
21	TLA	1/9/03 to 1/6/04	75.57 +/- 5.06
23	TLA	1/9/03 to 1/6/04	
24	TLA	1/9/03 to 1/6/04	
29	TLA	1/9/03 to 1/6/04	75.77 +/- 1.99
30	TLA	1/9/03 to 1/6/04	72.66 +/- 2.14
31	TLA	1/9/03 to 1/6/04	82.42 +/- 2.65
33	TLA	1/9/03 to 1/6/04	87.25 +/- 3.97
35	TLA	1/9/03 to 1/6/04	66.90 +/- 2.29

TLD Gamma Dose Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Annual

Location	Sample Type	Collection Period	Exposure
36	TLA	1/9/03 to 1/6/04	88.76 +/- 1.77
53	TLA	1/9/03 to 1/6/04	70.57 +/- 3.06
54	TLA	1/9/03 to 1/6/04	68.15 +/- 4.99
55	TLA	1/9/03 to 1/6/04	71.75 +/- 5.64
56	TLA	1/9/03 to 1/6/04	64.65 +/- 4.42
58	TLA	1/9/03 to 1/6/04	59.45 +/- 1.61

Water Gamma Spectral Detail Report 2003

Radiological Environmental Monitoring Program Detail Data

Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
28	Water	12/26/02 to 1/30/03	< 20.27 < 3.92 < 10.91	< 3.22 < 4.74	< 4.45 < 3.19	< 5.82 < 3.60	< 3.48 < 4.40
28	Water	1/30/03 to 2/27/03	< 29.95 < 6.36 < 11.46	< 4.73 < 6.42	< 3.89 < 4.08	< 6.82 < 5.14	< 5.18 < 4.81
28	Water	2/27/03 to 3/27/03	< 9.85 < 3.09 < 3.18	< 1.96 < 2.96	< 1.91 < 1.30	< 1.31 < 2.75	< 1.67 < 4.34
28	Water	3/27/03 to 4/28/03	< 14.00 < 4.83 < 6.56	< 2.47 < 2.23	< 2.21 < 1.65	< 2.49 < 4.51	< 3.47 < 4.40
28	Water	4/28/03 to 5/29/03	< 20.82 < 4.52 < 2.77	< 1.71 < 2.69	< 1.91 < 2.70	< 2.79 < 2.41	< 2.16 < 1.57
28	Water	5/29/03 to 6/26/03	< 36.53 < 12.27 < 13.05	< 2.71 < 6.21	< 2.87 < 4.27	< 4.23 < 6.30	< 4.40 < 6.56
28	Water	6/26/03 to 7/31/03	< 15.70 < 5.94 < 4.11	< 2.45 < 1.42	< 1.75 < 2.60	< 2.29 < 3.42	< 3.32 < 2.85
28	Water	7/31/03 to 8/26/03	< 4.49 < 3.09 < 3.40	< 1.78 < 2.08	< 1.94 < 2.05	< 2.28 < 1.53	< 2.54 < 3.14
28	Water	8/26/03 to 9/25/03	< 28.40 < 5.29 < 3.38	< 2.25 < 6.44	< 2.34 < 4.37	< 1.75 < 3.88	< 4.57 < 4.01
28	Water	9/25/03 to 10/28/03	< 10.47 < 3.62 < 6.56	< 2.37 < 1.63	< 1.63 < 2.11	< 2.58 < 2.07	< 1.91 < 3.31
28	Water	10/28/03 to 11/25/03	< 18.51 < 3.53 < 4.14	< 3.46 < 2.26	< 1.16 < 2.37	< 2.69 < 3.48	< 2.69 < 2.05
28	Water	11/25/03 to 12/26/03	< 26.74 < 3.96 < 5.19	< 2.10 < 2.22	< 2.15 < 2.82	< 2.26 < 3.76	< 4.51 < 3.91

Water Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
34	Water	12/26/02 to 1/30/03	< 18.02 < 4.17 < 7.15	< 4.00 < 3.64	< 1.86 < 4.11	< 3.39 < 4.18	< 5.64 < 7.06
34	Water	1/30/03 to 2/27/03	< 19.21 < 6.78 < 9.85	< 4.14 < 4.69	< 4.17 < 3.65	< 4.79 < 6.10	< 3.14 < 12.55
34	Water	2/27/03 to 3/27/03	< 17.77 < 5.78 < 6.87	< 3.50 < 4.76	< 4.13 < 1.87	< 4.28 < 4.24	< 5.23 < 3.94
34	Water	3/27/03 to 4/28/03	< 9.69 < 3.93 < 4.88	< 1.55 < 1.25	< 2.18 < 1.66	< 2.21 < 1.53	< 2.87 < 4.04
34	Water	4/28/03 to 5/29/03	< 13.00 < 4.21 < 5.34	< 2.66 < 1.79	< 3.06 < 2.55	< 3.78 < 1.62	< 2.56 < 4.52
34	Water	5/29/03 to 6/26/03	< 24.27 < 7.03 < 7.13	< 2.10 < 6.41	< 2.35 < 3.29	< 2.46 < 3.51	< 3.62 < 6.43
34	Water	7/31/03 to 7/31/03	< 19.55 < 7.10 < 11.14	< 2.48 < 5.08	< 5.94 < 2.95	< 4.57 < 2.06	< 5.54 < 3.81
34	Water	7/31/03 to 8/26/03	< 11.37 < 2.88 < 5.01	< 1.59 < 2.37	< 1.73 < 1.88	< 2.63 < 1.91	< 1.65 < 4.11
34	Water	8/26/03 to 9/25/03	< 13.36 < 4.23 < 4.42	< 3.29 < 2.89	< 1.18 < 1.92	< 3.17 < 4.18	< 2.79 < 3.36
34	Water	9/25/03 to 10/28/03	< 15.57 < 2.27 < 7.03	< 4.87 < 2.04	< 3.66 < 3.49	< 4.97 < 2.74	< 6.14 < 8.12
34	Water	10/28/03 to 11/25/03	< 22.86 < 8.79 < 10.36	< 5.00 < 3.50	< 4.39 < 3.14	< 4.74 < 3.78	< 5.70 < 8.65
34	Water	11/25/03 to 12/26/03	< 16.54 < 4.60 < 5.08	< 3.25 < 2.26	< 2.21 < 2.74	< 2.83 < 3.66	< 3.58 < 2.89

Water Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
36	Water	12/26/02 to 1/30/03	< 18.31 < 7.84 < 9.52	< 2.01 < 3.21	< 5.10 < 2.21	< 5.45 < 2.96	< 6.19 < 3.58
36	Water	1/30/03 to 2/27/03	< 15.73 < 7.21 < 8.35	< 2.56 < 4.65	< 5.95 < 2.28	< 5.16 < 2.60	< 4.37 < 5.01
36	Water	2/27/03 to 3/27/03	< 24.11 < 4.11 < 8.89	< 3.54 < 7.47	< 3.93 < 5.45	< 3.85 < 3.74	< 3.67 < 9.42
36	Water	3/27/03 to 4/28/03	< 18.50 < 6.49 < 12.99	< 1.68 < 3.31	< 4.53 < 3.36	< 6.93 < 2.34	< 4.92 < 9.44
36	Water	4/28/03 to 5/29/03	< 20.14 < 8.91 < 9.84	< 3.97 < 3.89	< 4.66 < 3.65	< 5.61 < 4.73	< 7.91 < 6.97
36	Water	5/29/03 to 6/26/03	< 14.26 < 7.09 < 5.19	< 1.36 < 2.98	< 2.00 < 3.02	< 1.80 < 2.59	< 2.90 < 3.32
36	Water	6/26/03 to 7/31/03	< 10.60 < 3.36 < 4.07	< 1.71 < 1.46	< 2.41 < 2.22	< 2.80 < 2.53	< 2.89 < 5.25
36	Water	7/31/03 to 8/26/03	< 8.13 < 3.58 < 3.18	< 1.97 < 1.25	< 1.79 < 2.28	< 1.04 < 2.31	< 2.36 < 1.72
36	Water	8/26/03 to 9/25/03	< 15.12 < 3.39 < 5.25	< 2.51 < 1.97	< 1.18 < 2.25	< 2.45 < 4.05	< 2.14 < 2.90
36	Water	9/25/03 to 10/28/03	< 19.96 < 3.25 < 8.20	< 3.79 < 5.51	< 2.91 < 4.17	< 2.78 < 3.97	< 3.00 < 4.35
36	Water	10/28/03 to 11/25/03	< 17.11 < 9.74 < 12.40	< 3.31 < 8.11	< 3.51 < 4.51	< 4.20 < 3.44	< 5.04 < 9.81
36	Water	11/25/03 to 12/26/03	< 17.14 < 4.77 < 6.02	< 2.21 < 5.30	< 2.28 < 1.73	< 3.10 < 2.86	< 2.91 < 4.62

Water Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
59	Water	3/27/03 to 3/27/03	< 14.15 < 3.38 < 4.48	< 1.53 < 1.69	< 2.73 < 1.82	< 3.55 < 3.61	< 3.70 < 3.78
59	Water	3/27/03 to 4/28/03	< 21.02 < 10.77 < 7.02	< 2.57 < 3.44	< 4.07 < 3.78	< 5.59 < 4.12	< 3.49 < 4.05
59	Water	4/28/03 to 5/29/03	< 13.51 < 5.83 < 3.17	< 2.47 < 2.45	< 1.46 < 2.20	< 2.48 < 2.84	< 3.64 < 1.84
59	Water	5/29/03 to 6/26/03	< 20.81 < 3.80 < 5.98	< 1.69 < 2.27	< 2.24 < 2.28	< 2.99 < 3.31	< 2.63 < 3.30
59	Water	6/26/03 to 7/31/03	< 13.87 < 6.95 < 9.25	< 4.73 < 3.06	< 4.61 < 4.97	< 3.27 < 4.80	< 2.54 < 8.55
59	Water	7/31/03 to 8/26/03	< 17.13 < 3.07 < 9.29	< 2.66 < 5.10	< 3.48 < 2.93	< 3.12 < 3.54	< 3.79 < 2.82
59	Water	8/26/03 to 9/25/03	< 9.39 < 3.78 < 4.80	< 2.19 < 2.13	< 2.36 < 2.29	< 2.64 < 1.86	< 1.65 < 4.57
59	Water	9/25/03 to 10/28/03	< 14.57 < 4.76 < 4.17	< 2.47 < 2.31	< 2.50 < 3.25	< 2.33 < 1.13	< 4.13 < 7.17
59	Water	10/28/03 to 11/25/03	< 18.63 < 2.82 < 8.52	< 2.43 < 2.63	< 2.91 < 3.18	< 4.04 < 4.00	< 3.76 < 3.47
59	Water	11/25/03 to 12/26/03	< 13.18 < 5.92 < 5.57	< 2.75 < 3.28	< 3.36 < 1.70	< 3.35 < 3.49	< 3.07 < 4.57
60	Water	3/27/03 to 3/27/03	< 8.80 < 3.79 < 5.08	< 1.88 < 4.66	< 2.67 < 3.50	< 4.44 < 4.13	< 3.03 < 1.84
60	Water	3/27/03 to 4/28/03	< 13.99 < 3.95 < 2.68	< 2.03 < 1.45	< 2.21 < 1.98	< 3.05 < 2.78	< 1.55 < 4.02

Water Gamma Spectral Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Period	Ba-140 Fe-59 Zr-95	Co-58 La-140	Co-60 Mn-54	Cs-134 Nb-95	Cs-137 Zn-65
60	Water	4/28/03 to 5/29/03	< 16.64 < 6.28 < 7.96	< 2.50 < 4.49	< 2.27 < 1.64	< 1.69 < 2.15	< 3.14 < 4.12
60	Water	5/29/03 to 6/26/03	< 23.16 < 4.83 < 4.55	< 2.53 < 5.02	< 2.90 < 3.75	< 3.33 < 2.60	< 3.34 < 4.65
60	Water	6/26/03 to 7/31/03	< 12.80 < 4.08 < 4.80	< 2.14 < 3.26	< 2.24 < 2.84	< 2.76 < 2.53	< 2.95 < 3.38
60	Water	7/31/03 to 8/26/03	< 12.95 < 4.59 < 7.39	< 2.93 < 4.68	< 2.43 < 3.78	< 3.30 < 2.86	< 3.50 < 4.81
60	Water	8/26/03 to 9/25/03	< 24.74 < 11.08 < 6.68	< 4.28 < 4.59	< 3.14 < 3.47	< 2.94 < 3.04	< 5.75 < 4.00
60	Water	9/25/03 to 10/28/03	< 13.78 < 5.81 < 5.82	< 2.63 < 3.73	< 2.20 < 2.73	< 2.64 < 2.07	< 3.56 < 3.67
60	Water	10/28/03 to 11/25/03	< 9.63 < 4.73 < 4.78	< 1.48 < 1.89	< 1.72 < 1.83	< 2.68 < 3.22	< 1.70 < 3.13
60	Water	11/25/03 to 12/26/03	< 23.13 < 5.77 < 6.17	< 2.72 < 6.09	< 2.07 < 2.97	< 3.17 < 3.02	< 3.83 < 4.77

Water Gross Beta Detail Report 2003
Radiological Environmental Monitoring Program Data Summary
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Collection Period	Sample Type	Location				
		28	34	36	59	60
12/26/02 to 1/30/03	Water	3.81 +/- 0.75	LLD	LLD		
1/30/03 to 2/27/03	Water	LLD	LLD	LLD		
2/27/03 to 3/27/03	Water	LLD	LLD	LLD		
3/27/03 to 3/27/03	Water				LLD	3.73 +/- 0.61
3/27/03 to 4/28/03	Water	LLD	LLD	LLD	LLD	LLD
4/28/03 to 5/29/03	Water	LLD	LLD	LLD	LLD	3.14 +/- 0.69
5/29/03 to 6/26/03	Water	LLD	LLD	LLD	LLD	LLD
6/26/03 to 7/31/03	Water	LLD		LLD	LLD	LLD
7/31/03 to 7/31/03	Water		LLD			
7/31/03 to 8/26/03	Water	LLD	LLD	LLD	LLD	LLD
8/26/03 to 9/25/03	Water	LLD	LLD	LLD	LLD	LLD
9/25/03 to 10/28/03	Water	LLD	LLD	LLD	LLD	LLD

Sample Frequency is: Monthly Results in pCi/L +/- 2 Sigma

Collection Period	Sample Type	Location				
		28	34	36	59	60
10/28/03 to 11/25/03	Water	LLD	LLD	3.02 +/- 0.56	LLD	LLD
11/25/03 to 12/26/03	Water	LLD	LLD	LLD	LLD	LLD

Water Tritium Detail Report 2003
Radiological Environmental Monitoring Program Detail Data
Perry Nuclear Power Plant, Lake County Ohio Docket no. : 50-440/50-441
Sample Frequency is: Quarterly Results in pCi/L +/- 2 Sigma

Location	Sample Type	Collection Date	H-3
28	Water	3/27/03	< 161.17
28	Water	6/26/03	< 161.47
28	Water	9/25/03	< 167.00
28	Water	12/26/03	< 160.80
34	Water	3/27/03	LLD
34	Water	6/26/03	LLD
34	Water	9/25/03	< 167.00
34	Water	12/26/03	< 160.80
36	Water	3/27/03	< 161.17
36	Water	6/26/03	< 161.47
36	Water	9/25/03	< 167.00
36	Water	12/26/03	< 160.80
59	Water	3/27/03	< 161.17
59	Water	6/26/03	< 161.47
59	Water	9/25/03	< 167.00
59	Water	12/26/03	< 160.80
60	Water	3/27/03	< 161.17
60	Water	6/26/03	< 161.47
60	Water	9/25/03	< 167.00
60	Water	12/26/03	< 160.80

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

APPENDIX D, 2003 ABNORMAL GASEOUS RELEASE METEOROLOGICAL DATA

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS A DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND	WIND SPEED(MPH)						
DIRECTION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	1	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	1	0	0	0	1

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS B DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND DIRECTION	WIND SPEED(MPH)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS C DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND	WIND SPEED(MPH)						
DIRECTION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	1	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	1	0	0	0	1

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS D DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND DIRECTION	WIND SPEED(MPH)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS E DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND	WIND SPEED(MPH)						
DIRECTION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS F DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND	WIND SPEED(MPH)						
DIRECTION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS G DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND	WIND SPEED(MPH)						
DIRECTION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

SITE: PERRY

UNIT: UNIT 1

3/05/04 10:35

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD = 03042810-03042811

STABILITY CLASS ALL DT/DZ

ELEVATION: SPEED: SPD10P DIRECTION: DIR10P LAPSE: DT50M

WIND DIRECTION	WIND SPEED(MPH)						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	2	0	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS): 0

VARIABLE DIRECTION 0

HOURS OF MISSING DATA: 0

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

APPENDIX E, 2002 CORRECTIONS TO AEERR

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Corrections for Table 6: Solid Waste Shipped Offsite for Burial or Disposal (Not Irradiated Fuel) are reflected below. This revised table is the result of late reporting by one of Perry Power Plant's contracted waste processors, creating inaccuracies in previously reported volumes and activity.

A: Solid Waste Shipped Offsite for Burial or Disposal (Not irradiated fuel)

A. Type of Waste	VOLUME m ³	ACTIVITY Ci	PERIOD	EST. TOTAL ERROR %
Spent resin, filter sludge, evaporator bottoms, etc.	14.5	900.1	1/1/2003- 12/31/2003	+/- 25
Dry compressible waste, contaminated equipment, etc.	47.47	13.6	1/1/2003- 12/31/2003	+/- 25
Irradiated components, control rods, etc.	0	0	1/1/2003- 12/31/2003	+/- 25
Other (describe)	0	0	1/1/2003- 12/31/2003	+/- 25

B. Estimate of Major ⁽¹⁾ Nuclide Composition (by type of waste)	RADIONUCLIDE	ABUNDANCE %	EST. TOTAL ERROR, %
Spent Resin, Filter Sludge, Evaporator Bottoms, etc.	Mn-54	10.2	± 25
	Fe-55	26.9	
	Co-60	52.5	
	Zn-65	3.5	
	Ag-110m	1.4	
	Cs-137	1.2	
	Ce-144	1.1	
Dry Compressible Waste, Contaminated Equipment, etc.	Mn-54	4.1	± 25
	Fe-55	48.4	
	Co-60	36.5	
	Zn-65	2.7	
	Ce-144	5.7	
Irradiated Components, Control Rods, etc.	None	0	N/A
Other (describe)	None	N/A	N/A

C. Disposition	Number of Shipments	Mode of Transportation	Destination
Solid Waste ⁽²⁾	2	Truck	Barnwell, SC
Irradiated Fuel Shipments	0	N/A	N/A

N/A – Not Applicable

(1) – "Major" is defined as any individual radionuclide identified as >1% of the waste type abundance.

(2) – Additional shipments were made to Studsvik, in Erwin, TN; Duratek, Oak Ridge, TN. This waste was combined with waste from other utilities disposed of at Barnwell, SC or Envirocare of Utah.

ANNUAL ENVIRONMENTAL AND EFFLUENT RELEASE REPORT

Corrections for Tables 19 and 21: Revisions to X/Q and D/Q values for Nearest Residence and Nearest Garden were not performed for the 2002 AEERR. The updated tables are as follows:


Table 19: Nearest Residence, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	X/Q VALUE, sec/m^3	MAP LOCATOR NUMBER
NE	4384 Lockwood	0.7	2.66E-06	1
ENE	4460 Lockwood	0.8	1.59E-06	2
E	2626 Antioch	1.1	6.77E-07	3
ESE	2750 Antioch	1.0	8.57E-07	4
SE	4537 North Ridge	1.3	3.44E-07	5
SSE	4247 Parmly	1.1	5.52E-07	6
S	3119 Parmly	0.9	2.25E-06	7
SSW	3121 Center	0.9	1.11E-06	8
SW	3440 Clark	1.3	4.42E-07	9
WSW	3462 Parmly	1.1	8.67E-07	10

Table 21: Nearest Garden, By Sector

SECTOR	LOCATION ADDRESS	MILES FROM PNPP	D/Q VALUE, m^{-2}	MAP LOCATOR NUMBER
NE	No gardens available	N/A	N/A	N/A
ENE	2382 Antioch	1.1	4.77E-09	12
E	2601 Antioch	1.1	5.29E-09	13
ESE	2864 Antioch	1.1	3.96E-09	20
SE	5021 Middle Ridge	2.2	1.01E-09	14
SSE	3323 Call	1.5	2.04E-09	15
S	4176 North Ridge	1.2	3.56E-09	21
SSW	3121 Center	0.9	5.58E-09	8
SW	3440 Clark	1.3	1.95E-09	9
WSW	2975 Perry Park	1.3	2.01E-09	17

PNPPD



Generating Success!

For more information, write :

Perry Nuclear Power Plant
10 Center Road
P.O. Box 97
Perry OH 44081-0097