

H. L. Sumner, Jr.
Vice President
Hatch Project

Southern Nuclear
Operating Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201
Tel 205.992.7279

May 3, 2004



Energy to Serve Your WorldSM
NL-04-0718

Docket Nos.: 50-321
50-366

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Edwin I. Hatch Nuclear Plant
Revisions to Emergency Response Data System

Ladies and Gentlemen:

Per the Requirements of 10 CFR 50, Appendix E, VI.3.a, Southern Nuclear Operating Company is submitting the following changes recently made to the Plant Hatch Emergency Response Data system (ERDS) database, documented in plant drawings A-44047 and A-51672 for Hatch Units 1 and 2, respectively:

The high reactor pressure alarm setpoint has been changed from 1054 psig to 1074 psig on Unit 1 and from 1085 to 1074 psig on Unit 2.

This letter contains no NRC commitments. If you have any questions, please advise.

Respectfully submitted,

SOUTHERN NUCLEAR OPERATING COMPANY

A handwritten signature in cursive script that reads "H. L. Sumner, Jr.".

H. L. Sumner, Jr.

HLS/OCV/daj

A026

cc: Southern Nuclear Operating Company
Mr. J. B. Beasley, Jr., Executive Vice President
Mr. G. R. Frederick, General Manager – Plant Hatch
RType: CHA02.004

U. S. Nuclear Regulatory Commission
Mr. L. A. Reyes, Regional Administrator
Mr. C. Gratton, NRR Project Manager – Hatch
Mr. D. S. Simpkins, Senior Resident Inspector – Hatch

State of Georgia
Mr. L. C. Barrett, Commissioner – Department of Natural Resources