

May 10, 2004

LICENSEE: Indiana Michigan Power Company

FACILITY: Donald C. Cook Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF MARCH 31, 2004, MEETING BETWEEN THE
U.S. NUCLEAR REGULATORY COMMISSION (NRC) AND INDIANA
MICHIGAN POWER COMPANY (I&M) CONCERNING SCOPING AND
SCREENING OF STRUCTURES AND COMPONENTS USED IN DEVELOPING
THE LICENSE RENEWAL APPLICATION FOR DONALD C. COOK
NUCLEAR PLANT, UNITS 1 AND 2

The U.S. Nuclear Regulatory Commission staff (the staff) and a representative of Indiana Michigan Power Company (the applicant) held a meeting at NRC headquarters on March 31, 2004, to discuss the scoping and screening methodology used in developing the Donald C. Cook Nuclear Plant (Cook) license renewal application (LRA). The meeting was used to clarify whether or not the Cook boundary drawings that had been submitted with the LRA to aid the staff in their review of the application identified components that are subject to an aging management review (AMR), which is a subset of components within the scope of license renewal. The staff questioned the applicant as to whether or not the submitted license renewal drawings depict the boundaries for components within the scope of license renewal in accordance with Title 10 of the *Code of Federal Regulation* Part 54.4 (10 CFR). The applicant demonstrated its electronic database of components within the scope of license renewal to aid in the clarification.

The staff informed the applicant that providing a description of system scoping evaluation boundaries in relation to passive mechanical components that are within the scope of license renewal for 10 CFR 54.4(a)(1) and (a)(3) but not subject to an AMR would facilitate the staff's review. Also, the staff informed the applicant that describing the methodology used to identify mechanical component types that are non-safety related but are within the scope of license renewal, the location and systems containing these mechanical component types would facilitate the staff's review. The applicant agreed to furnish the requested information to the staff.

This was a Category 1 public meeting. Enclosure 1 provides a list of the meeting's participants. The applicant has had an opportunity to review and comment on this summary.

/RA/

Jonathan Rowley, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-315 and 50-316

Enclosures: As stated

cc w/enclosures: See next page

May 10, 2004

LICENSEE: Indiana Michigan Power Company

FACILITY: Donald C. Cook Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF MARCH 31, 2004, MEETING BETWEEN THE
U.S. NUCLEAR REGULATORY COMMISSION (NRC) AND INDIANA
MICHIGAN POWER COMPANY (I&M) CONCERNING SCOPING AND
SCREENING OF STRUCTURES AND COMPONENTS USED IN DEVELOPING
THE LICENSE RENEWAL APPLICATION FOR DONALD C. COOK
NUCLEAR PLANT, UNITS 1 AND 2

The U.S. Nuclear Regulatory Commission staff (the staff) and a representative of Indiana Michigan Power Company (the applicant) held a meeting at NRC headquarters on March 31, 2004, to discuss the scoping and screening methodology used in developing the Donald C. Cook Nuclear Plant (Cook) license renewal application (LRA). The meeting was used to clarify whether or not the Cook boundary drawings that had been submitted with the LRA to aid the staff in their review of the application identified components that are subject to an aging management review (AMR), which is a subset of components within the scope of license renewal. The staff questioned the applicant as to whether or not the submitted license renewal drawings depict the boundaries for components within the scope of license renewal in accordance with Title 10 of the *Code of Federal Regulation* Part 54.4 (10 CFR). The applicant demonstrated it's electronic database of components within the scope of license renewal to aid in the clarification.

The staff informed the applicant that providing a description of system scoping evaluation boundaries in relation to passive mechanical components that are within the scope of license renewal for 10 CFR 54.4(a)(1) and (a)(3) but not subject to an AMR would facilitate the staff's review. Also, the staff informed the applicant that describing the methodology used to identify mechanical component types that are non-safety related but are within the scope of license renewal, the location and systems containing these mechanical component types would facilitate the staff's review. The applicant agreed to furnish the requested information to the staff.

This was a Category 1 public meeting. Enclosure 1 provides a list of the meeting's participants. The applicant has had an opportunity to review and comment on this summary.

/RA/

Jonathan Rowley, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-315 and 50-316

Enclosures: As stated

cc w/enclosures: See next page

Accession No: ML041310231

DISTRIBUTION:

Document Name: C:\ORPCheckout\FileNET\ML041310231.wpd

OFFICE	PM:RLEP	LA:RLEP	SC:RLEP
NAME	JRowley	MJenkins	SLee
DATE	5/10/04	5/10/04	5/10/04

OFFICIAL RECORD COPY

DISTRIBUTION: Dated: May 10,2004 Accession No: ML041310231

HARD COPY

RLEP RF

Jonathan Rowley (PM)

E-MAIL:

PUBLIC

D. Matthews

F. Gillespie

C. Grimes

RidsNrrDe

E. Imbro

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

R. Jenkins

P. Shemanski

J. Fair

S. Black

B. Boger

D. Thatcher

R. Pettis

G. Galletti

C. Li

M. Itzkowitz

R. Weisman

M. Mayfield

A. Murphy

S. Smith (srs3)

S. Duraiswamy

Y. L. (Renee) Li

RLEP Staff

K. Coyne

L. Lund

S. Coffin

T. Chan

R. Gramm

A. Howell

M. Shuaibi

J. Strasma, RIV

M. Kotzalas

OPA

NRR/ADPT secretary (RidsNrrAdpt)

**LIST OF PARTICIPANTS FOR MEETING WITH I&M ON
SCOPING AND SCREENING METHODOLOGY USED FOR COOK
LICENSE RENEWAL APPLICATION**

March 31, 2004

Participants

Jonathan Rowley
Johnny Eads (via phone)
Harry Wagage
Russell Arrighi
Cliff Marks
Bob Kalinowski

Affiliation

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
NRC
NRC
Indiana Michigan Power Company

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Mr. John A. Zwolinski
Director, Design Engineering and
Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Mr. Fred Emerson
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708

Michigan Department of Environmental
Quality
Waste and Hazardous Materials Div.
Hazardous Waste & Radiological
Protection Section
Nuclear Facilities Unit
Constitution Hall, Lower-Level North
525 West Allegan Street
P.O. Box 30241
Lansing, MI 48909-7741

David A. Lochbaum
Nuclear Safety Engineer
Union of Concern Scientists
1707 H Street NW, Suite 600
Washington, DC 20036

Michael J. Finissi, Plant Manager
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mr. Joseph N. Jensen, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Richard J. Grumbir
Project Manager, License Renewal
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

Mr. Mano K. Nazar
American Electric Power
Senior Vice President and Chief Nuclear
Officer
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107