

ĩ

Duke Power

526 South Church Street P.O. Box 1006 Charlotte, NC 28201-1006

May 13, 2004

Document Control Desk U. S. Nuclear Regulatory Commission Washington, DC 20555-0001

Subject:Duke Energy Corporation Catawba Nuclear Station Units 1 & 2, Docket
Nos. 50-413, 50-414 Proposed Amendments to the Facility Operating
License and Technical Specifications to Allow Insertion of Mixed Oxide
(MOX) Fuel Lead Assemblies (Correspondence Review)

- References: (1) Letter, April 16, 2004, H. B. Barron (Duke) to U. S. Nuclear Regulatory Commission, Proposed Amendments to the Facility Operating License and Technical Specifications to Allow Insertion of Mixed Oxide (MOX) Fuel Lead Assemblies (MOX in Catawba 1 Cycle 16)
 - (2) Letter, February 27, 2003, M. S. Tuckman (Duke) to U. S. Nuclear Regulatory Commission, Proposed Amendments to the Facility Operating License and Technical Specifications to Allow Insertion of Mixed Oxide (MOX) Fuel Lead Assemblies and Request for Exemption from Certain Regulations in 10 CFR Part 50

In Reference 1, Duke supplied additional information to the NRC in support of the license amendment application for receipt and use of four MOX fuel lead assemblies (Reference 2). The material in reference one identified Catawba 1 Cycle 16 (C1C16) as the first fuel cycle in which Duke intends to load the four MOX lead assemblies. The planned cycle design includes 181 Westinghouse Robust Fuel assemblies (RFAs) and also includes eight Westinghouse Next Generation Fuel (NGF) assemblies. The eight NGF assemblies were previously loaded in C1C15; hence those assemblies will be in their second cycle of operation in C1C16. The NGF LTA design is very similar to the Westinghouse Robust Fuel Assembly (RFA) design. Duke provided some basic design characteristics of the Next Generation Fuel in Reference 1 and subsequently met with the NRC staff to further describe the core design for Catawba 1 Cycle 16. In addition, Reference 1 indicated that Duke was undertaking a review of the license amendment application material and would provide the NRC staff with a written summary of that review. The review is documented in the Duke corrective action program as PIP G-04-157. Attachment 1 to this letter contains specific items that Duke has determined should be clarified. None of these clarifications is expected to have an impact on prior staff review. Please contact Mike Cash at (704) 382-5826 regarding this or any other matters related to the MOX fuel lead assemblies.

Sincerely,

3

NR Roum

H. B. Barron Executive Vice President – Nuclear Generation Duke Energy Corporation

Attachment 1- Summary of Items from Correspondence Review

Oath and Affirmation

I affirm that I, H.B. Barron, am the person who subscribed my name to the foregoing, and that all the matters and facts set forth herein are true and correct to the best of my knowledge.

NBRaum

H.B. Barron

٦,

.

Subscribed and sworn to before me on this	Altery	13rday of_	Μαγ	2004
	MR	-		

Mil F. Cad

Notary Public

My Commission expires:

MICHAEL T. CASH Notary Public Lincoln County, North Carolina Commission Expires January 22, 2008

January 22, 2008 Date



cc: w/attachments

٦.

L. A. Reyes U. S. Nuclear Regulatory Commission Regional Administrator, Region II Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, GA 30303

R. E. Martin (addressee only) NRC Project Manager U. S. Nuclear Regulatory Commission Mail Stop O-8G9 Washington, DC 20555-0001

E. F. Guthrie Senior Resident Inspector U. S. Nuclear Regulatory Commission Catawba Nuclear Station

J. B. Brady Senior Resident Inspector U. S. Nuclear Regulatory Commission McGuire Nuclear Station

Diane Curran Harmon, Curran, Spielberg & Eisenberg, LLP 1726 M Street, N.W. Suite 600 Washington, DC 20036

Mary Olson Director, Southeast Office Nuclear Information and Resource Service P.O. Box 7586 Asheville, NC 28802

H. J. Porter, Director Division of Radioactive Waste Management Bureau of Land and Waste Management Department of Health and Environmental Control Columbia, SC 29201 bcc: w/attachments

. 5

Richard Clark-DCS Martin Neudorf-DOE Guy Lunsford - DOE David Alberstein-DOE Don Spellman-ORNL NCMPA-1 NCEMC PMPA SRE

bcc: w/attachment (via email)

S. P. Nesbit M. T. Cash F. J. Verbos J. L. Eller S. P. Schultz L. F Vaughn M. W. Scott L. J. Rudy J. Hoerner – Framatome ANP G. A. Meyer – Framatome ANP

bcc: w/attachments (paper copy)

NRIA File/ELL - EC050 MOX File 1607.2304 Catawba Document Control File 801.01– CN04DM Catawba RGC Date File (J. M. Ferguson – CN01SA)

Attachment 1 Summary of Items from Correspondence Review

. . .

- -· ·

-

·

.

Item	Document/Section	Item Description	Clarification
NO	Description		
1	2/27/03 License Amendment Request (LAR), Att. 3, Section 3.2	Paragraph 2 identifies the "nominal average total plutonium concentration" of the MOX fuel lead assemblies and the nominal plutonium concentrations of each zone. These are nominal values and are subject to change during the core design process. In fact, the currently-planned values are slightly different (4.35% vs. 4.37%).	These values are representative and are not final design values. This should be clear from the totality of the application (e.g., Section 3.5.1, "maximum expected plutonium concentration is 4.94 weight percent") and the MOX Fuel Design Report (BAW-10238 (P), Rev. 1).
2	2/27/03 License Amendment Request (LAR), Att. 3, Appendix 3-1, A3.3	Reference values of MOX fuel assembly plutonium concentration and isotopics are provided.	These values are representative and are not final design values. See Item 1.
3	2/27/03 License Amendment Request (LAR), Att. 3, Appendix 3-1, A3.6, p. A3-12	Reference values of isotopics are provided.	These values are representative and are not final design values. See Item 1.
4	2/27/03 License Amendment Request (LAR), Att. 4, Section 4.2.1.1	The cited failure rate (less than one per 100,000 rods, from all manufacturing related causes) is subject to change.	This value was meant to be representative and subject to change with time. There are additional Mk-BW failures under review.
5	12/10/03 Request for Additional Information (RAI) Response Letter, Attachment 1	The response to #2 does not clearly state that the MOX fuel lead assembly burnup and peaking factor projections for three cycles are representative, not final values.	There was telephonic discussion with the NRC that made this point clear.
6	2/2/04 RAI Response Letter, Att. 1, Introductory Response	Paragraph 2 refers to a failure rate (less than one per 100,000 rods, from all manufacturing related causes) that is subject to change.	Same as Item 4.

Item	Document/Section	Item Description	Clarification
No	Description		
7	2/27/03 License Amendment	This section does not specifically mention COPERNIC.	COPERNIC is also used for fuel rod analyses, and was the subject
	Request (LAR),		of a stand alone topical report for
	Attach. 3, Technical		this purpose and was subject to
	Justification, Sec.		review at the time of the
	3.6.3		application.
8	11/03/03 RAI	Discusses RFA & Mark-	The Next Generation Fuel will
	Response Letter,	BW/MOX1, but not NGF (the	have specific MAP limits
	Question 31 (pg. 70)	question asks about maximum	developed or determined to be
		allowable peaking (MAP) limits,	bounding for DNBR analyses.
		not what CHF correlations are	The WRB-2M DNB correlation is
		used)	applied to the NGF assemblies.
			This application has been
			continued by westinghouse as the
0	11/03/03 P A I	Analysis of mixed core addresses	Duke has determined an exclusion
	Response Letter	RFA/MOX core but does not	zone of separation between MOX
	Question 29 (pg. 58)	discuss mixed core effects of NGF	and NGF fuel assemblies to
	Duke Response to	assemblies.	prevent hydraulic interactions
	RAIs		between the two fuel assembly
			types.
10	2/27/03 License	The peak cladding temperature	Table 3-6 presents the results from
	Amendment	(PCT) identified in Table 3-6	an early MOX-low enriched
	Request (LAR),	(LAR) for the MOX analysis is	uranium (LEU) analysis. There
	Table 3-6 (page 3-	2018 F. A similar case presented	were minor adjustments made to
	44)	in the response to question 14	the model inputs between the time
	and 11/3/03 RAI	(RAI response, Table Q14-1)	of the Table 3-6 analysis and the
	response Table	shows a somewhat different PCT	performance of the analyses that
	Q14-1	of 1919.2 F. The difference in	provided the detailed MOX fuel
}		PCTS is somewhat allihoutable to	in Table O14.1. The minor
1		the axial near but this does not	adjustments do not affect the
		explain all of the difference	conclusions about relative
		explain an of the arrefelice.	differences between MOX and
			LEU based on Table 3-6 (Table 3-
			6 study remains valid for that
			purpose). The actual MOX lead
			assembly LOCA limits (Table
			Q14-1) are based on the most up-
			to-date model inputs.
1		`	

:

.

.