



MAY 03 2004

L-2004-084
10 CFR 50.55a

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Inservice Testing Program
Fourth 10 Year Interval Inservice Testing Program
Select Relief Requests Withdraw

By letter L-2003-316, dated January 6, 2004 Florida Power and Light Company submitted to NRC for review and approval the Turkey Point Fourth 10-year Interval Inservice Testing (IST) Relief Requests. These Relief Requests were discussed with the Staff on March 30, 2004.

The purpose of this letter is to withdraw the following Fourth 10-year Interval pump and valve IST Relief Requests:

Relief Request	Relief Request Title
PR-02	Gauge Lines: 0.25% Gauge Liquid
PR-05	No Comprehensive Test for Certain Group A Pumps
PR-06	Categorization of Residual Heat Removal Pumps as Group B
VR-01	Exercise Testing of Option B Check Valves with Only a Closed Safety Function
VR-02	Position Indication Verification Performed in Accordance with Appendix J Seat Leakage Testing Frequency for Solenoid Operated Valves
VR-03	Auxiliary Feedwater Pump Discharge Check Valve, 20-143, Exercise Frequency

If you have any questions please contact Walter Parker at (305) 246-6632.

Very truly yours,

Terry D. Jones
Vice President
Turkey Point Nuclear Plant

SM

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

A047