

May 21, 2004

MEMORANDUM TO: File

FROM: Girija S. Shukla, Project Manager, Section 2 /RA/
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: DIABLO CANYON POWER PLANT, UNIT NOS. 1 AND 2 - VERBAL
AUTHORIZATION OF THE INSERVICE INSPECTION RELIEF
REQUEST FOR ASME CODE N-579 (MC2092 AND MC2093)

In a telephone call on May 6, 2004, in accordance with 10 CFR 50.55a(3)(i), the NRC staff granted verbal authorization to Pacific Gas & Electric Company for its inservice inspection (ISI) Relief Request No. REP-1 regarding the inclusion into the Diablo Canyon ISI Program Plan the use of ASME Code Case N-579, "Use of Nonstandard Nuts, Class 1, 2, 3, MC, CS Components and Supports Construction Section III, Division 1," since the proposed alternative provides an acceptable level of quality and safety. Code Case N-579 was approved for use in Regulatory Guide 1.84, "Design, Fabrication, and Materials Code Case Acceptability, ASME Section III," Revision 32, dated June 2003.

The NRC staff that participated in the phone call were Terence Chan, Steve Dembek, and Girija Shukla. The NRC staff will issue the final written authorization within 30 days.

Docket Nos. 50-275 and 50-323

May 21, 2004

MEMORANDUM TO: File

FROM: Girija S. Shukla, Project Manager, Section 2 /RA/
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: DIABLO CANYON POWER PLANT, UNIT NOS. 1 AND 2 - VERBAL
AUTHORIZATION OF THE INSERVICE INSPECTION RELIEF
REQUEST FOR ASME CODE N-579 (MC2092 AND MC2093)

In a telephone call on May 6, 2004, in accordance with 10 CFR 50.55a(3)(i), the NRC staff granted verbal authorization to Pacific Gas & Electric Company for its inservice inspection (ISI) Relief Request No. REP-1 regarding the inclusion into the Diablo Canyon ISI Program Plan the use of ASME Code Case N-579, "Use of Nonstandard Nuts, Class 1, 2, 3, MC, CS Components and Supports Construction Section III, Division 1," since the proposed alternative provides an acceptable level of quality and safety. Code Case N-579 was approved for use in Regulatory Guide 1.84, "Design, Fabrication, and Materials Code Case Acceptability, ASME Section III," Revision 32, dated June 2003.

The NRC staff that participated in the phone call were Terence Chan, Steve Dembek, and Girija Shukla. The NRC staff will issue the final written authorization within 30 days.

Docket Nos. 50-275 and 50-323

DISTRIBUTION:

PUBLIC
PDIV-2 Reading
RidsNrrPMGShukla
RidsNrrLAEPeyton
TChan
GGeorgiev

ADAMS Accession No. ML041450007

| | | | |
|--------|------------|-----------|-----------|
| OFFICE | PDIV-2/PM | PDIV-2/LA | PDIV-2/SC |
| NAME | GShukla:mp | EPeyton | SDembek |
| DATE | 5/21/04 | 5/21/04 | 5/21/04 |

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML041450007.wpd

OFFICIAL RECORD COPY