

INDEX

LIMITING CONDITION FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1	TURBINE CYCLE
3/4.7.1.1	Main Steam Safety Valves (MSSVs) 3/4 7-1
3/4.7.1.2	Auxiliary Feedwater System..... 3/4 7-4
3/4.7.1.3	Primary Plant Demineralized Water (PPDW) 3/4 7-6
3/4.7.1.4	Activity..... 3/4 7-7
3/4.7.1.5	Main Steam Line Isolation Valves..... 3/4 7-9
3/4.7.3	PRIMARY COMPONENT COOLING WATER SYSTEM..... 3/4 7-11
3/4.7.4	SERVICE WATER SYSTEM (SWS) 3/4 7-12
3/4.7.5	ULTIMATE HEAT SINK - OHIO RIVER..... 3/4 7-13
3/4.7.7	CONTROL ROOM EMERGENCY AIR CLEANUP AND PRESSURIZATION SYSTEM..... 3/4 7-15
3/4.7.8	SUPPLEMENTAL LEAK COLLECTION AND RELEASE SYSTEM (SLCRS) 3/4 7-18

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

4.6.3.1.2 Each containment isolation valve shall be demonstrated OPERABLE* at least once per 18 months by:

- a. Verifying that on a Phase A containment isolation test signal each Phase A isolation valve actuates to its isolation position.
- b. Verifying that on a Phase B containment isolation test signal, each Phase B isolation valve actuates to its isolation position.
- c. Deleted.
- d. Cycling each power operated or automatic valve through at least one complete cycle of full travel and measuring the isolation time pursuant to Specification 4.0.5.
- e. Cycling each weight or spring loaded check valve not testable during plant operation, through one complete cycle of full travel and verifying that each check valve remains closed when the differential pressure in the direction of flow is < 1.2 psid and opens when the differential pressure in the direction of flow is ≥ 1.2 psid but less than 6.0 psid.
- f. Cycling each manual valve not locked, sealed or otherwise secured in the closed position through at least one complete cycle of full travel.

* Locked or sealed closed valves may be opened on an intermittent basis under administrative control.