

L. M. Stinson (Mike)
Vice President

Southern Nuclear
Operating Company, Inc.
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201

Tel 205.992.5181
Fax 205.992.0341



Energy to Serve Your WorldSM

NL-04-0908

May 20, 2004

Docket No.: 50-425

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Vogtle Electric Generating Plant
Technical Specification Report 2-2004-1
Number of Steam Generator Tubes Plugged During 2R10

Ladies and Gentlemen:

In accordance with the requirements of Vogtle Electric Generating Plant Technical Specification 5.6.10, Southern Nuclear Operating Company submits this report of the number of steam generator (SG) tubes plugged during the Unit 2 tenth maintenance/refueling outage (2R10).

As a result of the SG tube inservice inspections completed on May 8, 2004, a total of eleven (11) tubes were plugged. One tube was plugged in SG No. 1, five tubes were plugged in SG No. 2 of which two tubes were pulled for future evaluation with their SG openings plugged, three tubes were plugged in SG No. 3, and two tubes were plugged in SG No. 4.

This letter contains no NRC commitments. If you have any questions, please advise.

Sincerely,


L. M. Stinson

LMS/TDH/daj

cc: Southern Nuclear Operating Company
Mr. J. B. Beasley, Jr., Executive Vice President
Mr. J. T. Gasser, Vice President, Plant Vogtle
Mr. W. F. Kitchens, General Manager – Plant Vogtle
RType: CVC7000

U. S. Nuclear Regulatory Commission
Mr. L. A. Reyes, Regional Administrator
Mr. C. Gratton, NRR Project Manager – Vogtle
Mr. J. Zeiler, Senior Resident Inspector – Vogtle

~~A001~~
A047