

May 11, 2004

NRC 2004-0049
TS 5.6.3

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Point Beach Nuclear Plant, Units 1 and 2,
Dockets 50-266 and 50-301
License Nos. DPR-24 and DPR-27

Monthly Operating Report

In accordance with Technical Specification 5.6.3, Enclosure 1 contains the Monthly Operating Report for April 2004 for the Point Beach Nuclear Plant, Units 1 and 2.

This letter contains no new commitments and no revisions to existing commitments.



Gary D. Van Middlesworth
Site Vice-President, Point Beach Nuclear Plant
Nuclear Management Company, LLC

Enclosure

cc: Administrator, Region III, USNRC
Project Manager, Point Beach Nuclear Plant, USNRC
Resident Inspector, Point Beach Nuclear Plant, USNRC
PSCW
INPO Records Center

IE24

ENCLOSURE 1

MONTHLY OPERATING REPORT

4 pages follow

OPERATING DATA REPORT

DOCKET NO. 50-266
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1
DATE 05/04/04
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD April - 2004

- | | |
|--|-------|
| 1. DESIGN ELECTRICAL RATING (MWE-NET) | 522.0 |
| 2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) | 516.0 |

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	74.0	2,258.0	242,403.9
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	73.5	2,257.5	238,854.2
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	846.9
6. NET ELECTRICAL ENERGY (MWH)	20,584.5	1,130,453.0	111,024,765.0

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-266
 UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1
 DATE 05/04/2004
 COMPLETED BY Kim M. Locke
 TELEPHONE 920-755-6420

REPORTING PERIOD: April 2004
 (Month/Year)

NO.	DATE	TYPE		DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED	S: SCHEDULED				COMMENTS
01	04/03/04		S	645.0	C	1	U1R28

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1. Manual
- 2. Manual Trip/Scram
- 3. Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

SUMMARY:

While preparing to inspect the Unit 1 Steam Generator on Friday April 9, 2004, the scheduled sequence for Steam Generator nozzle dam installation was not followed.

There were no LERs for Unit 1 in the month of April.

OPERATING DATA REPORT

DOCKET NO. 50-301
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2
DATE 05/04/04
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD April - 2004

- 1. DESIGN ELECTRICAL RATING (MWE-NET) 522.0
- 2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) 518.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	719.0	2,903.0	236,250.7
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	719.0	2,903.0	233,139.8
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	302.2
6. NET ELECTRICAL ENERGY (MWH)	374,831.5	1,509,111.0	110,010,192.5

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-301
 UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2
 DATE 05/04/2004
 COMPLETED BY Kim M. Locke
 TELEPHONE 920-755-6420

REPORTING PERIOD: April 2004
 (Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1. Manual
- 2. Manual Trip/Scram
- 3. Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

SUMMARY:

Unit 2 average daily power for the month of April was 521.3 MWe.
 There were no significant operating events on Unit 2 during the month of April.
 There were no LERs for Unit 2 in the month of April.