

Exelon Generation Company, LLC  
Dresden Nuclear Power Station  
6500 North Dresden Road  
Morris, IL 60450-9765

www.exeloncorp.com

May 17, 2004

RHLTR: #04-0029

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001


Dresden Nuclear Power Station Units 1, 2, and 3  
Facility Operating Licenses DPR-2, DPR-19, and DPR-25  
NRC Docket Nos. 50-010, 50-237, and 50-249

Subject: Dresden Nuclear Power Station Annual Radiological Environmental Operating Report for 2003

The attached "Annual Radiological Environmental Operating Report," is submitted in accordance with Section 6.9.A.3 of the Unit 1 Dresden Nuclear Power Station Technical Specifications and Section 5.6.2, "Annual Radiological Environmental Operating Report," of the Units 2 and 3 Technical Specifications. This report provides the results of the radiological environmental and meteorological monitoring programs for the 2003 calendar year.

Should you have any questions concerning this letter, please contact Mr. Jeff Hansen, Regulatory Assurance Manager, at (815) 416-2800.

Respectfully,



Danny G. Bost  
Site Vice President  
Dresden Nuclear Power Station

Enclosure

cc: Regional Administrator - NRC Region III  
NRC Senior Resident - Dresden Nuclear Power Station

JE25

**DRESDEN STATION**

**ANNUAL RADIOLOGICAL  
ENVIRONMENTAL OPERATING  
REPORT**

**2003**

**MAY 2004**

## TABLE OF CONTENTS

	<u>Page</u>
INTRODUCTION.....	1
SUMMARY .....	2
1.0 EFFLUENTS	
1.1 Gaseous Effluents to the Atmosphere .....	3
1.2 Liquids Released to Illinois River .....	3
2.0 SOLID RADIOACTIVE WASTE.....	3
3.0 DOSE TO MAN	
3.1 Gaseous Effluent Pathways .....	3
3.1.1 Noble Gases .....	3
3.1.1.1 Gamma Air Dose Rates .....	4
3.1.1.2 Beta Air and Skin Dose Rates .....	4
3.1.2 Radioactive Iodine .....	4
3.1.2.1 Iodine Concentrations in Air .....	5
3.1.2.2 Dose to Thyroid .....	5
3.1.3 Concentrations of Particulates in Air.....	5
3.2 Liquid Effluent Pathways.....	5
3.3 Assessment of Dose to Member of Public.....	5
4.0 SITE METEOROLOGY.....	6
5.0 ENVIRONMENTAL MONITORING.....	6
5.1 Gamma Radiation .....	6
5.2 Airborne I-131 and Particulate Radioactivity .....	7
5.3 Terrestrial Activity.....	7
5.4 Aquatic Radioactivity .....	7
5.5 Milk.....	8
5.6 Listing of Missed Samples.....	8
5.7 Program Modifications .....	8
6.0 ANALYTICAL PROCEDURES.....	8
7.0 MILCH ANIMALS AND NEAREST CATTLE CENSUSES .....	8
8.0 NEAREST RESIDENCE CENSUS.....	9
9.0 DREDGE SPOILS RESULTS .....	9
10.0 INTERLABORATORY COMPARISON PROGRAM RESULTS.....	9
11.0 ERRATA DATA.....	9

TABLE OF CONTENTS (continued)

	<u>Page</u>
APPENDIX I - DATA TABLES AND FIGURES .....	I-1
Station Releases	
Table 1.1-1    Gaseous Effluents .....	I-2
Table 1.2-1    Liquid Effluents .....	I-3
Figure 3.0-1 - Figure 3.0-4 Isodose and Concentration Contours .....	I-4
Table 3.1-1    Maximum Doses Resulting from Airborne Releases Based on Average Meteorological Data .....	I-8
Table 3.2-1    Maximum Doses Resulting from Liquid Effluents Based on Average Meteorological Data .....	I-10
Table 3.3-1    10CFR20 Compliance Assessment.....	I-11
Table 3.4-1    Maximum Doses Resulting from Airborne Releases Based on Concurrent Meteorological Data.....	I-17
Environmental Monitoring	
Figure 5.0-1    Fixed Air Sampling and TLD Sites, Milk and Outer Ring TLD Locations .....	I-20
Figure 5.0-2    Inner Ring TLD Sites, Near Station Water, Sediment and Fish Sampling Locations.....	I-21
Table 5.0-1    Radiological Environmental Monitoring Locations .....	I-22
Table 5.0-2    Radiological Environmental Monitoring Program Sampling Locations and Sample Collection and Analyses .....	I-23
Table 5.0-3 - Table 5.0-6 Radiological Environmental Monitoring Program Quarterly Summary.....	I-29
APPENDIX II - METEOROLOGICAL DATA .....	II-1
APPENDIX III - 2003 REMP SAMPLE RESULTS.....	III-1
APPENDIX IV - INTERLABORATORY COMPARISON PROGRAM RESULTS .....	IV-1
APPENDIX V - ERRATA DATA (if applicable).....	V-1

## INTRODUCTION

The Dresden Station is located approximately twelve miles southwest of Joliet, Illinois at the confluence of the Des Plaines and Kankakee Rivers where they form the Illinois River. This station uses two boiling water reactors (G.E. design) to generate electricity. Unit 1, which began operating in 1960 and had a rated power output of 200 megawatts electrical (MWe), was shut down permanently on August 31, 1984 and is currently being decommissioned. Unit 2 net rated power output was increased to 912 MWe in 2001; Unit 3 net rated power output was increased to 912 MWe in 2002. Liquid radwaste from Unit 1 is transferred to Units 2 and 3 for collective processing and discharge.

Liquid effluents from Dresden are released to the Illinois River in controlled batches after radioassay of each batch. Gaseous effluents are released to the atmosphere after delay to permit decay of short-lived (noble) gases. Releases to the atmosphere are calculated on the basis of analyses of weekly grab samples of noble gases as well as continuously collected composite samples of iodine and particulate activity sampled during the course of the year. The results of effluent analyses are summarized on a monthly basis and reported to the Nuclear Regulatory Commission as required per Technical Specifications. Airborne concentrations of noble gases, I-131, and particulate radioactivity in offsite areas are calculated using isotopic composition of control effluent and meteorological data.

Environmental monitoring is conducted by sampling at indicator and control (background) locations in the vicinity of the Dresden Station to measure changes in radiation or radioactivity levels that may be attributable to station operation. If significant changes attributable to Dresden are measured, these changes are correlated with effluent releases. External gamma radiation exposure from turbine shine and released noble gases, and internal dose from I-131 in milk are the critical pathways at this site; however, a comprehensive environmental monitoring program is conducted which includes many other pathways which are less significant in terms of radiation protection.

## SUMMARY

Calculations based on gaseous and liquid effluents, Illinois River flow, meteorological data and hydrogen addition activities indicate that public dose due to radioactive material attributable to Dresden Station during the period does not exceed regulatory or Offsite Dose Calculation Manual (ODCM) limits.

The Total Effective Dose Equivalent (TEDE) for the period due to licensed activities at Dresden Station calculated for the maximally-exposed individual is 8.01 mrem. The annual limit on TEDE is 100 mrem. This value is largely dominated by the direct radiation constituent from the Unit 2 and Unit 3 turbines (7.99 mrem). The balance of the calculated maximum dose (0.02 mrem) is due to exposure from radionuclides released from the Station in liquid and gaseous effluents.

The assessment of radiation doses to the public is performed in accordance with the ODCM. The results of these analyses confirm that the Station is operating in compliance with 10CFR50 Appendix I, 10CFR20 and 40CFR190.

## 1.0 EFFLUENTS

### 1.1 Gaseous Effluents to the Atmosphere

Measured concentrations of noble gases, radioiodine, and particulate radioactivity released in gaseous effluents to the atmosphere during the year are listed in Table 1.1-1. A total of  $1.97\text{E}+02$  curies of noble gases with a maximum quarterly average release rate of  $8.38\text{E}+00$   $\mu\text{Ci}/\text{sec}$  were released from Dresden Units 1, 2 and 3.

A total of  $4.90\text{E}-03$  curies of I-131 were released during the year with a maximum quarterly average release rate of  $2.68\text{E}-04$   $\mu\text{Ci}/\text{sec}$ .

A total of  $7.79\text{E}-03$  curies of beta-gamma emitters were released as airborne particulate matter with a maximum quarterly average release rate of  $3.37\text{E}-04$   $\mu\text{Ci}/\text{sec}$ . Alpha emitting radionuclides totaled  $2.59\text{E}-05$  curies. Also,  $4.60\text{E}+01$  curies of tritium were released with a maximum quarterly average release rate of  $3.21\text{E}+00$   $\mu\text{Ci}/\text{sec}$ .

### 1.2 Liquids Released to Illinois River

Measured concentrations and isotopic composition of radioactivity released in liquid effluents during the year are listed in Table 1.2-1.

A total of  $2.31\text{E}+07$  liters of radioactive liquid wastes containing  $1.89\text{E}-03$  curies of fission and activation products (excluding tritium, noble gases and gross alpha) were discharged from the station. These wastes were released at a maximum quarterly average diluted concentration of  $1.16\text{E}-08$   $\mu\text{Ci}/\text{ml}$  from all units. During the same period,  $1.40\text{E}+01$  curies of tritium were released with a maximum quarterly average diluted concentration of  $1.91\text{E}-06$   $\mu\text{Ci}/\text{ml}$ . A total of  $1.82\text{E}-06$  curies of alpha-emitting radionuclides were released.

## 2.0 SOLID RADIOACTIVE WASTE

Solid radioactive wastes were shipped by truck to the Barnwell disposal facility, the Envirocare disposal facility or to waste processors. For more detail, refer to the Dresden Station 2003 Annual Radiological Effluent Release Report.

## 3.0 DOSE TO MAN

### 3.1 Gaseous Effluent Pathways

#### 3.1.1 Noble Gases

To demonstrate compliance with the applicable regulations regarding public radiation dose due to gaseous effluents from Dresden Station, two methods are reported in the following sections. Both methods employ measured isotopic composition and release rates from the station.

Assumed "average meteorological data" are used in ODCM-required calculations performed at least every 31 days. These data use a ten-year average (1/1/1978-12/31/1987) for Dresden Station. Actual "concurrent meteorological

data" is used to recalculate the quarterly release information using actual meteorological data for the period.

#### 3.1.1.1 Gamma Air Dose Rates

Offsite gamma air and total body doses are shown in Table 3.1-1 and were calculated based on measured release rates, isotopic composition of the noble gases, and average meteorological data for the period. Doses based on concurrent meteorological data are shown in Table 3.4-1. Isodose contours based on concurrent meteorological data for gamma air dose are shown in Figure 3.0-1.

Based on measured effluents and average meteorological data, the maximum total body dose (from all units) to an individual is calculated to be  $2.12\text{E-}03$  mrem (Table 3.1-1) for the year, with an occupancy or shielding factor of 0.7 included. The maximum total body dose from all units based on measured effluents and concurrent meteorological data would be  $3.83\text{E-}03$  mrem (Table 3.4-1). The maximum gamma air dose based on measured effluents and average meteorological data was  $2.81\text{E-}03$  mrad (Table 3.1-1) and  $4.15\text{E-}03$  mrad based on concurrent meteorological data (Table 3.4-1).

#### 3.1.1.2 Beta Air and Skin Dose Rates

The range of beta particles in air is relatively small (on the order of a few meters or less); consequently, plumes of gaseous effluents may be considered "infinite" for the purpose of calculating the dose from beta radiation incident on the skin. However, the actual dose to sensitive skin tissues is difficult to calculate due to the effect of the beta particle energies, thickness of inert skin, and clothing covering sensitive tissues. For purposes of this report the skin is assumed to have a thickness of 0.07 mm and an occupancy factor of 1.0 is used. The skin dose from beta and gamma radiation based on measured effluents and average meteorological data for the year was  $2.38\text{E-}03$  mrem (Table 3.1-1) and  $4.85\text{E-}03$  mrem based on concurrent meteorological data (Table 3.4-1).

The air concentrations of radioactive noble gases at the offsite receptor locations are given in Figure 3.0-2. The maximum offsite beta air dose based on measured effluents and average meteorological data for the year was  $2.58\text{E-}04$  mrad (Table 3.1-1) and  $8.10\text{E-}04$  mrad based on concurrent meteorological data (Table 3.4-1).

#### 3.1.2 Radioactive Iodine

The human thyroid exhibits a significant capacity to concentrate ingested or inhaled iodine. The radioiodine, I-131, released during routine operation of the station, may be made available to man resulting in a dose to the thyroid. The principal pathway of interest for this radionuclide is ingestion of radioiodine in milk. Calculations made in previous years indicate that contributions to doses



from inhalation of I-131 and I-133 and from ingestion of I-133 in milk are negligible.

#### 3.1.2.1 Iodine Concentrations in Air

The calculated concentration contours for iodine in air are shown in Figure 3.0-3. These calculations include an iodine cloud depletion factor which accounts for the phenomenon of elemental iodine deposition on the ground. The maximum iodine offsite average concentration is estimated to be  $8.85\text{E-}05$  pCi/m<sup>3</sup> for the year (Table 3.4-1).

#### 3.1.2.2 Dose to Thyroid

The hypothetical thyroid dose to a maximum exposed individual living near the station via ingestion of milk was calculated. The radionuclide considered was I-131 and the source of milk was taken to be the nearest dairy farm with the cows pastured from May through October. The maximum thyroid dose is calculated to be  $3.40\text{E-}02$  mrem during the year (Table 3.1-1 [child]).

#### 3.1.3 Concentrations of Particulates in Air

Concentration contours of radioactive airborne particulates are shown in Figure 3.0-4. The maximum offsite average concentration is estimated to be  $4.03\text{E-}01$  pCi/m<sup>3</sup> (Table 3.4-1).

### 3.2 Liquid Effluent Pathways

The three principal pathways for potential dose to man from liquid waste effluents are ingestion of potable water, ingesting aquatic foods, and exposure while on the shoreline. Not all of these pathways are applicable at a given time or station, but a reasonable approximation of the dose can be made by adjusting the dose formula for season of the year or type and degree of use of the aquatic environment. NRC-developed equations\* were used to calculate the doses to the whole body, lower GI tract, thyroid, bone and skin; specific parameters for use in the equations are given in the Dresden Station Offsite Dose Calculation Manual. The maximum total body dose and organ dose for the year was  $1.08\text{E-}04$  mrem (adult) and  $1.49\text{E-}04$  mrem (child), respectively (Table 3.2-1).

### 3.3 Assessment of Dose to Member of Public

During the period January to December, 2003, Dresden Station did not exceed the following limits as shown in Table 3.1-1 and Table 3.2-1 (based on average meteorological data) and as shown in Table 3.4-1 (based on concurrent meteorological data):

---

\* Nuclear Regulatory Commission, Regulatory Guide 1.109 (Rev. 1).

- The RETS limits on dose or dose commitment to a member of the public due to radioactive materials in liquid effluents from each reactor unit (1.5 mrem to the total body or 5 mrem to any organ during any calendar quarter; 3 mrem to the total body or 10 mrem to any organ during any calendar year).
- The RETS limits on air dose in noble gases released in gaseous effluents to a member of the public from each reactor unit (5 mrad for gamma radiation or 10 mrad for beta radiation during any calendar quarter; 10 mrad for gamma radiation or 20 mrad for beta radiation during any calendar year).
- The RETS limits on dose to a member of the public due to Iodine-131, Iodine-133, tritium, and radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released from each reactor unit (7.5 mrem to any organ during any calendar quarter; 15 mrem to any organ during any calendar year).
- The 10CFR20 limit on Total Effective Dose Equivalent to individual members of the public (100 mrem) from the site.

#### 4.0 SITE METEOROLOGY

A summary of the site meteorological measurements taken during each calendar quarter of the year is given in Appendix II. The data are presented as cumulative joint frequency distributions of the wind direction for the 35' and 300' levels and wind speed class by atmospheric stability class determined from the temperature difference between the 150' and 35' and between the 300' and 35' levels, respectively. Data recovery for all measurements on the tower was 99.9% during 2003 (Table 3.4-1).

#### 5.0 ENVIRONMENTAL MONITORING

Table 5.0-1 and Table 5.0-2 provide an outline of the Radiological Environmental Monitoring Program (REMP) as required in the ODCM. Tables 5.0-3 to 5.0-6 summarize data for the year by quarter. A detailed listing of all data is given in Appendix III.

Specific findings for various environmental media are discussed below.

##### 5.1 Gamma Radiation

External radiation dose from onsite sources and noble gases released to the atmosphere was measured using CaF<sub>2</sub> thermoluminescent dosimeters (TLDs). Each location consists of 2 TLD sets. Quarterly average external radiation dose for the year was 24.4 ± 3.2 mR at indicator locations and 21.9 ± 2.4 mR at control locations. TLD results are listed in Section 6.0 in Appendix III and locations are shown in Figures 5.0-1 and 5.0-2.

## 5.2 Airborne I-131 and Particulate Radioactivity

Locations of the samplers are shown in Figure 5.0-1. Airborne I-131 remained below the LLD of 0.07 pCi/m<sup>3</sup> throughout the year in all analyzed samples.

Gross beta concentrations ranged from 0.8E-02 to 5.0E-02 pCi/m<sup>3</sup> and averaged 2.5E-02 pCi/m<sup>3</sup>, and were similar to those measured in previous years (except for the period from May 17 through June 7, 1986 when it was influenced by the nuclear reactor accident at Chernobyl). The mean beta measurement value was below the control mean value for every quarter. Quarterly gamma isotopic results were below the LLD level of 0.01 pCi/m<sup>3</sup>.

No radioactivity attributable to station operation was detected in any sample.

## 5.3 Terrestrial Activity

Vegetables were collected in the third quarter and analyzed for I-131 and gamma-emitting nuclides. All nuclides were below the limits of detection, indicating that there was no measurable amount of radioactivity attributable to the station releases.

## 5.4 Aquatic Radioactivity

Surface water samples were collected weekly from three locations, shown in Figure 5.0-2, and composited monthly for gross beta and gamma-emitters. Quarterly composites were analyzed for tritium. Cs-134 and Cs-137 levels were below the detection limit of 15 and 18 pCi/L, respectively. All other gamma emitters were below their respective LLDs in all samples collected during the year.

Gross beta at D-51 (Dresden Lock & Dam) averaged 5.3 pCi/L with a range of 2.6 to 6.9 pCi/L; D-52 (DesPlaines River) gross beta averaged 7.1 pCi/L with a range of 3.3 to 13.6 pCi/L; D-54 (Kankakee River) gross beta averaged 3.5 pCi/L with a range of 2.0-5.5 pCi/L.

Tritium concentration was below the LLD of 200 pCi/L in all samples collected from D-54 (Kankakee River). D-51 (Dresden Lock & Dam) averaged 715 pCi/L with a range of 277 to 1,626 pCi/L; D-52 (DesPlaines River) had a first quarter high of 230 pCi/L; remaining quarters were below LLD.

Well water samples were collected quarterly and analyzed for tritium and gamma-emitting nuclides. Gamma-emitters were below LLD for all samples during the year; tritium activity at D-35 (Dresden Lock & Dam) was also below LLD. Tritium activity at D-23 (Thorsen Well) averaged 722 pCi/L with a third quarter high of 839 pCi/L.

Levels of gamma radioactivity in fish samples were measured and found in all cases to be below the lower limits of detection for the program. The results were similar to those obtained in 1983 through 2002.

Sediment samples were collected twice and analyzed by gamma spectroscopy. The May levels of Cs-134 and Cs-137 were below the LLD levels of 0.15 and 0.18 pCi/g

dry weight, respectively. Cs-134 was also below LLD in the October sample; Cs-137 showed an activity of 0.44 pCi/g dry weight. Other gamma emitters were below their respective LLDs for the program.

Fish, sediment and water locations are shown in Figure 5.0-2.

### 5.5 Milk

Milk sample locations are shown in Figure 5.0-1. Milk samples were collected biweekly during the grazing season (May through October) and monthly during the balance of the year from the Vince Biros Farm (D-25). I-131 was determined for each sample by chemical separation of I-131 and beta counting.

I-131 remained below the ODCM-required detection limits of 1.0 pCi/L. The results were similar to those obtained during the 1983 - 2002 period except for samples collected during the second and third quarters of 1986. I-131 detected in milk samples during this period is attributable to the nuclear accident at Chernobyl.

### 5.6 Listing of Missed Samples

All samples were collected as scheduled except for those listed in Listing of Missed Samples, Appendix III.

### 5.7 Program Modifications

New control surface water location, D-54 (Kankakee River), was added to the program in 2003.

## 6.0 ANALYTICAL PROCEDURES

Procedures used during the period covered in this report remained essentially unchanged. A summary of the procedures used for analyzing radioactivity in environmental samples is given in Appendix VI of the report for the period January - December 1993.

## 7.0 MILCH ANIMALS AND NEAREST CATTLE CENSUS

Census of milch animals and nearest cattle were conducted within a 6.2-mile radius of the station. The survey was conducted by "door-to-door" canvas by A. Lewis on August 27, 2003. Results of the milch animal and nearest cattle census are presented on pages 38 and 39, Section 5.0 of Appendix III.

There are no dairy farms within a 6.2-mile radius of the Dresden Nuclear Power Station.

## 8.0 NEAREST RESIDENCES CENSUS

The nearest resident census was conducted by A. Lewis on August 27, 2003. Results of the nearest resident census are presented page 40, Section 5.0 of Appendix III.

## 9.0 DREDGE SPOILS RESULTS

According to the Army Corp. of Engineers in August 2003, dredging was performed in the past year and sampled per ODCM requirements. Dredge spoils results are on page 57, Section 8.0 of Appendix III. The detectable levels of Cs-137 are attributed to the deposition of atmospheric fallout from the accident at Chernobyl. This is based on the absence of radionuclides normally attributed to effluent streams from an operating reactor, such as Co-60 and Mn-54.

## 10.0 INTERLABORATORY COMPARISON PROGRAM RESULTS

Environmental Incorporated's Interlaboratory Comparison Program Results are presented in Appendix IV.

## 11.0 ERRATA DATA

There is no errata data for 2003.

DRESDEN

APPENDIX I

DATA TABLES AND FIGURES

Table 1.1-1

DRESDEN NUCLEAR POWER STATION  
 UNITS 1, 2 AND 3 RADIOACTIVE EFFLUENT RELEASE REPORT  
 January Through December 2003

DOCKET NUMBERS: 50-010/50-237/50-249

SUMMATION OF ALL GASEOUS RELEASES

	Units	1 <sup>st</sup> Quarter	2 <sup>nd</sup> Quarter	3 <sup>rd</sup> Quarter	4 <sup>th</sup> Quarter	Est. Total Error. %
<b>A. FISSION &amp; ACTIVATION GASES</b>						
1. Total Release	Ci	4.12E+01	6.59E+01	5.17E+01	3.82E+01	18.9%
2. Average Release Rate for the Period	µCi/sec	5.30E+00	8.38E+00	6.50E+00	4.80E+00	
3. Percent of Technical Specification Limit	%	*	*	*	*	
<b>B. IODINES</b>						
1. Total Iodine-131	Ci	1.04E-03	8.43E-04	8.87E-04	2.13E-03	29.8%
2. Average Release Rate of I-131 for the Period	µCi/sec	1.33E-04	1.07E-04	1.12E-04	2.68E-04	
3. Percent of Technical Specification Limit	%	*	*	*	*	
4. Total Iodine-131, Iodine-133 and Iodine-135	Ci	5.55E-03	3.18E-03	3.34E-03	4.66E-03	
<b>C. PARTICULATES</b>						
1. Particulates with half-lives > 8 days	Ci	1.81E-03	1.10E-03	2.20E-03	2.68E-03	28.2%
2. Average Release Rate for the Period	µCi/sec	2.33E-04	1.40E-04	2.77E-04	3.37E-04	
3. Percent of Technical Specification Limit	%	*	*	*	*	
4. Gross Alpha Radioactivity	Ci	1.24E-05	5.24E-06	8.30E-06	<LLD	
<b>D. TRITIUM</b>						
1. Total Release	Ci	2.49E+01	8.16E+00	8.63E+00	4.31E+00	7.63%
2. Average Release Rate for the Period	µCi/sec	3.21E+00	1.04E+00	1.09E+00	5.43E-01	
3. Percent of Technical Specification Limit	%	*	*	*	*	

\*The information is contained in the Radiological Impact on Man section of the report. Total airborne release data are provided which include fission and activation gases, iodines, particulates, and tritium.

Table 1.2-1

DRESDEN NUCLEAR POWER STATION  
 UNITS 1, 2 AND 3 RADIOACTIVE EFFLUENT RELEASE REPORT  
 January Through December 2003

DOCKET NUMBERS: 50-010/50-237/50-249

SUMMATION OF ALL LIQUID RELEASES

	Units	1 <sup>st</sup> Quarter	2 <sup>nd</sup> Quarter	3 <sup>rd</sup> Quarter	4 <sup>th</sup> Quarter	Est. Total Error. %
<b>A. FISSION &amp; ACTIVATION PRODUCTS</b>						
1. Total Release (not including H-3, gases, alpha)	Ci	1.77E-03	<LLD	<LLD	1.23E-04	13.5%
2. Average Diluted Conc. During Period	µCi/ml	6.68E-09	<LLD	<LLD	1.16E-08	
3. Percent of Technical Specification Limit	%	*	*	*	*	
<b>B. TRITIUM</b>						
1. Total Release	Ci	1.40E+01	<LLD	<LLD	2.02E-02	12.1%
2. Average Diluted Conc. During Release	µCi/ml	5.28E-09	<LLD	<LLD	1.91E-06	
3. Percent of Technical Specification Limit	%	*	*	*	*	
<b>C. DISSOLVED AND ENTRAINED GASES</b>						
1. Total Release	Ci	<LLD	<LLD	<LLD	<LLD	20.3%
2. Average Diluted Conc. During Period	µCi/ml	<LLD	<LLD	<LLD	<LLD	
3. Percent of Technical Specification Limit	%	*	*	*	*	
<b>D. GROSS ALPHA ACTIVITY</b>						
1. Total Release	Ci	1.82E-06	<LLD	<LLD	<LLD	5.58%
<b>E. VOLUME OF WASTE RELEASED (prior to dilution)</b>						
	Liters	3.99E+06	4.90E+06	3.59E+06	1.06E+07	1.00%
<b>F. VOLUME OF DILUTION WATER USED DURING PERIOD</b>						
	Liters	2.61E+08	0	0	0	5.00%

\*The information is contained in the Radiological Impact on Man section of the report.




Figure 3.0-1

Estimated Cumulative Gamma Dose (in mrad)  
from the Dresden Station for the period  
January-December 2003



Isopleth Labels

Small figure - multiply by  $10^{-5}$

Large figure - multiply by  $10^{-3}$



SCALE



SCALE




Figure 3.0-2

Estimated Total Concentrations (in pCi/m<sup>3</sup>)  
of Noble Gases from the Dresden Station  
for the period January-December 2003

Isopleth Labels

Small figure - multiply by 10<sup>-2</sup>

Large figure - multiply by 10<sup>0</sup>





Figure 3.0-3

Estimated Total Concentrations (in pCi/m<sup>3</sup>)  
of Iodines from the Dresden Station for  
the period January-December 2003

Isopleth Labels

Small figure - multiply by 10<sup>-7</sup>

Large figure - multiply by 10<sup>-5</sup>




Figure 3.0-4

Estimated Total Concentrations (in pCi/m<sup>3</sup>)  
of Particulates from the Dresden Station  
for the period January-December 2003

Isopleth Labels

Small figure - multiply by 10<sup>-3</sup>

Large figure - multiply by 10<sup>-1</sup>







Table 3.1-1

DRESDEN NUCLEAR POWER STATION  
 UNITS 1, 2 AND 3 RADIOACTIVE EFFLUENT RELEASE REPORT  
 January Through December 2003

RADIOLOGICAL IMPACT ON MAN\*

UNIT 1

1. Airborne Releases

	Maximum Doses from Airborne Releases					Yearly Obj.	Annual Dose
	Quarterly Obj.	1 <sup>st</sup> QTR	2 <sup>nd</sup> QTR	3 <sup>rd</sup> QTR	4 <sup>th</sup> QTR		
Gamma Air (mrad)	5.0 mrad	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	10.0 mrad	0.00E+00 (e)
Beta Air (mrad)	10.0 mrad	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	20.0 mrad	0.00E+00 (e)
Total Body (mrem)	2.5 mrem	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	5.0 mrem	0.00E+00 (e)
Skin (mrem)	7.5 mrem	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	0.00E+00 (e)	15.0 mrem	0.00E+00 (e)
Organ (mrem)	7.5 mrem	1.95E-05 (c)	5.03E-06 (t,a)	4.43E-06 (a)	7.95E-4 (i,c)	15.0 mrem	8.17E-04 (c)
Critical Organ		Lung	GI_LLI	GI_LLI	Liver (i) Bone (c)		Liver

UNIT 2

2. Airborne Releases

	Maximum Doses from Airborne Releases					Yearly Obj.	Annual Dose
	Quarterly Obj.	1 <sup>st</sup> QTR	2 <sup>nd</sup> QTR	3 <sup>rd</sup> QTR	4 <sup>th</sup> QTR		
Gamma Air (mrad)	5.0 mrad	1.80E-04 (e)	2.33E-04 (e)	3.07E-04 (e)	1.10E-04 (e)	10.0 mrad	8.30E-04 (e)
Beta Air (mrad)	10.0 mrad	1.46E-05 (e)	1.91E-05 (e)	2.12E-05 (e)	1.60E-05 (e)	20.0 mrad	6.88E-05 (e)
Total Body (mrem)	2.5 mrem	1.69E-04 (e)	1.76E-04 (e)	2.31E-04 (e)	8.26E-05 (e)	5.0 mrem	6.26E-04 (e)
Skin (mrem)	7.5 mrem	1.52E-04 (e)	1.95E-04 (e)	2.54E-04 (e)	9.38E-05 (e)	15.0 mrem	6.95E-04 (e)
Organ (mrem)	7.5 mrem	3.71E-04 (c)	3.03E-03 (c)	4.14E-03 (c)	3.31E-03 (c)	15.0 mrem	1.09E-02 (c)
Critical Organ		Lung	Thyroid	Thyroid	Thyroid		Thyroid

\* The doses reported include abnormal releases. These doses are the highest among the four analyzed receptors as described in parentheses [(i)=infant, (c)=child, (t)=teenager, (a)=adult, (e)=every receptor has the same value].

Table 3.1-1 (continued)

DRESDEN NUCLEAR POWER STATION  
 UNITS 1, 2 AND 3 RADIOACTIVE EFFLUENT RELEASE REPORT  
 January Through December 2003

RADIOLOGICAL IMPACT ON MAN\*

UNIT 3

3. Airborne Releases

	Maximum Doses from Airborne Releases					Yearly Obj.	Annual Dose
	Quarterly Obj.	1 <sup>st</sup> QTR	2 <sup>nd</sup> QTR	3 <sup>rd</sup> QTR	4 <sup>th</sup> QTR		
Gamma Air (mrad)	5.0 mrad	4.94E-04 (e)	5.27E-04 (e)	4.81E-04 (e)	4.79E-04 (e)	10.0 mrad	1.98E-03 (e)
Beta Air (mrad)	10.0 mrad	4.41E-05 (e)	4.76E-05 (e)	4.23E-05 (e)	5.95E-05 (e)	20.0 mrad	1.89E-04 (e)
Total Body (mrem)	2.5 mrem	3.72E-04 (e)	3.97E-04 (e)	3.63E-04 (e)	3.61E-04 (e)	5.0 mrem	1.49E-03 (e)
Skin (mrem)	7.5 mrem	4.19E-04 (e)	4.44E-04 (e)	4.06E-04 (e)	4.08E-04 (e)	15.0 mrem	1.68E-03 (e)
Organ (mrem)	7.5 mrem	2.16E-03 (c)	7.12E-03 (c)	9.05E-03 (c)	4.75E-03 (c)	15.0 mrem	2.31E-02 (c)
Critical Organ		Thyroid	Thyroid	Thyroid	Thyroid		Thyroid

\* The doses reported include abnormal releases. These doses are the highest among the four analyzed receptors as described in parentheses [(i)=infant, (c)=child, (t)=teenager, (a)=adult, (e)=every receptor has the same value].

Table 3.2-1

DRESDEN NUCLEAR POWER STATION  
 UNITS 1, 2 AND 3 RADIOACTIVE EFFLUENT RELEASE REPORT  
 January Through December 2003

RADIOLOGICAL IMPACT ON MAN\*

UNIT 1

1. Liquid Releases

	Maximum Doses from Aquatic Effluents					Yearly Obj.	Annual Dose
	Quarterly Obj.	1 <sup>st</sup> QTR	2 <sup>nd</sup> QTR	3 <sup>rd</sup> QTR	4 <sup>th</sup> QTR		
Total Body (mrem)	1.5 mrem	None	None	None	None	3.0 mrem	None
Organ (mrem)	5.0 mrem	None	None	None	None	10.0 mrem	None
Critical Organ		None	None	None	None		None

UNIT 2

2. Liquid Releases

	Maximum Doses from Aquatic Effluents					Yearly Obj.	Annual Dose
	Quarterly Obj.	1 <sup>st</sup> QTR	2 <sup>nd</sup> QTR	3 <sup>rd</sup> QTR	4 <sup>th</sup> QTR		
Total Body (mrem)	1.5 mrem	5.58E-05 (a)	0.00E+00 (e)	0.00E+00 (e)	3.86E-09 (c)	3.0 mrem	5.58E-05 (a)
Organ (mrem)	5.0 mrem	7.71E-05 (c)	0.00E+00 (e)	0.00E+00 (e)	2.30E-08 (a)	10.0 mrem	7.71E-05 (c)
Critical Organ		Liver	None	None	GI_LLI		Liver

UNIT 3

3. Liquid Releases

	Maximum Doses from Aquatic Effluents					Yearly Obj.	Annual Dose
	Quarterly Obj.	1 <sup>st</sup> QTR	2 <sup>nd</sup> QTR	3 <sup>rd</sup> QTR	4 <sup>th</sup> QTR		
Total Body (mrem)	1.5 mrem	5.19E-05 (a)	0.00E+00 (e)	0.00E+00 (e)	2.36E-07 (c)	3.0 mrem	5.21E-05 (a)
Organ (mrem)	5.0 mrem	7.14E-05 (c)	0.00E+00 (e)	0.00E+00 (e)	1.65E-06 (a)	10.0 mrem	7.20E-05 (c)
Critical Organ		Liver	None	None	Liver		Liver

\* The doses reported include abnormal releases. These doses are the highest among the four analyzed receptors as described in parentheses [(i)=infant, (c)=child, (t)=teenager, (a)=adult, (e)=every receptor has the same value].

Table 3.3-1

DRESDEN STATION UNIT ONE

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 04/22/04

1. 10 CFR 20.1301 (a) (1) Compliance

Total Effective Dose Equivalent, mrem/yr		8.10E-04
10 CFR 20.1301 (a) (1) limit	mrem/yr	100.0
	% of limit	0.00

Compliance Summary - 10CFR20

	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	% of Limit
TEDE	1.82E-05	4.82E-06	4.26E-06	7.88E-04	0.00

RESULTS BASED UPON: ODCM ANNEX REVISION 1.1 JULY 1994  
 ODCM SOFTWARE VERSION 1.1 January 1995  
 ODCM DATABASE VERSION 1.1 January 1995



Table 3.3-1 (continued)

DRESDEN STATION UNIT ONE

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 04/22/04

2. 10 CFR 20.1301 (d)/40 CFR 190 Compliance

		Dose (mrem)	Limit (mrem)	% of Limit
Whole Body (DDE)	Plume	0.00E+00		
	Skyshine	0.00E+00		
	Ground	7.98E-04		
	Total	7.98E-04	25.0	0.00
Organ Dose (CDE)	Thyroid	1.11E-05	75.0	0.00
	Gonads	1.27E-05	25.0	0.00
	Breast	1.11E-05	25.0	0.00
	Lung	1.24E-05	25.0	0.00
	Marrow	1.18E-05	25.0	0.00
	Bone	1.12E-05	25.0	0.00
	Remainder	1.43E-05	25.0	0.00
	CEDE	1.27E-05		
	TEDE	8.10E-04	100.0	0.00

RESULTS BASED UPON: ODCM ANNEX REVISION 1.1 JULY 1994  
 ODCM SOFTWARE VERSION 1.1 January 1995  
 ODCM DATABASE VERSION 1.1 January 1995

Table 3.3-1 (continued)

DRESDEN STATION UNIT TWO

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 04/22/04

1. 10 CFR 20.1301 (a) (1) Compliance

Total Effective Dose Equivalent, mrem/yr	3.95E+00
10 CFR 20.1301 (a) (1) limit mrem/yr	100.0
% of limit	3.95

Compliance Summary - 10CFR20

	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	% of Limit
TEDE	1.10E+00	1.09E+00	1.10E+00	6.52E-01	3.95

RESULTS BASED UPON: ODCM ANNEX REVISION 1.1 JULY 1994  
 ODCM SOFTWARE VERSION 1.1 January 1995  
 ODCM DATABASE VERSION 1.1 January 1995

Table 3.3-1 (continued)

DRESDEN STATION UNIT TWO

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 04/22/04

2. 10 CFR 20.1301 (d)/40 CFR 190 Compliance

		Dose (mrem)	Limit (mrem)	% of Limit
Whole Body (DDE)	Plume	6.26E-04		
	Skyshine	3.94E+00		
	Ground	2.31E-03		
	Total	3.94E+00	25.0	15.77
Organ Dose (CDE)	Thyroid	3.95E-03	75.0	0.01
	Gonads	2.92E-03	25.0	0.01
	Breast	2.86E-03	25.0	0.01
	Lung	2.93E-03	25.0	0.01
	Marrow	2.88E-03	25.0	0.01
	Bone	2.87E-03	25.0	0.01
	Remainder	3.01E-03	25.0	0.01
	CEDE	2.96E-03		
	TEDE	3.95E+00	100.0	3.95

RESULTS BASED UPON: ODCM ANNEX REVISION 1.1 JULY 1994  
 ODCM SOFTWARE VERSION 1.1 January 1995  
 ODCM DATABASE VERSION 1.1 January 1995

Table 3.3-1 (continued)

DRESDEN STATION UNIT THREE

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 04/22/04

1. 10 CFR 20.1301 (a) (1) Compliance

Total Effective Dose Equivalent, mrem/yr		4.06E+00
10 CFR 20.1301 (a) (1) limit	mrem/yr	100.0
	% of limit	4.06

Compliance Summary - 10CFR20

	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	% of Limit
TEDE	1.07E+00	1.01E+00	1.11E+00	8.78E-01	4.06

RESULTS BASED UPON: ODCM ANNEX REVISION 1.1 JULY 1994  
 ODCM SOFTWARE VERSION 1.1 January 1995  
 ODCM DATABASE VERSION 1.1 January 1995

Table 3.3-1 (continued)

DRESDEN STATION UNIT THREE

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/03 TO 12/31/03

CALCULATED 04/22/04

2. 10 CFR 20.1301 (d)/40 CFR 190 Compliance

		Dose (mrem)	Limit (mrem)	% of Limit
Whole Body (DDE)	Plume	1.49E-03		
	Skyshine	4.05E+00		
	Ground	3.50E-03		
	Total	4.06E+00	25.0	16.23
Organ Dose (CDE)	Thyroid	9.09E-03	75.0	0.01
	Gonads	7.28E-03	25.0	0.03
	Breast	7.21E-03	25.0	0.03
	Lung	7.30E-03	25.0	0.03
	Marrow	7.24E-03	25.0	0.03
	Bone	7.22E-03	25.0	0.03
	Remainder	7.42E-03	25.0	0.03
	CEDE	7.36E-03		
TEDE	4.06E+00	100.0	4.06	

RESULTS BASED UPON: ODCM ANNEX REVISION 1.1 JULY 1994  
 ODCM SOFTWARE VERSION 1.1 January 1995  
 ODCM DATABASE VERSION 1.1 January 1995

Table 3.4-1

Dresden Station - Unit 1

MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES

2003

TYPE OF DOSE	FIRST QUARTER	SECOND QUARTER	THIRD QUARTER	FOURTH QUARTER	ANNUAL
GAMMA AIR (mrad)	0.000E+00( N )	0.000E+00( N )	0.000E+00( N )	0.000E+00( N )	0.000E+00( N )
BETA AIR (mrad)	0.000E+00( N )	0.000E+00( N )	0.000E+00( N )	0.000E+00( N )	0.000E+00( N )
WHOLE BODY (mrem)	3.700E-06(ESE)	1.412E-06(ENE)	7.170E-07(ESE)	2.728E-04( SE)	2.766E-04( SE)
SKIN (mrem)	4.360E-06(ESE)	1.661E-06(ENE)	8.430E-07(ESE)	3.182E-04( SE)	3.226E-04( SE)
ORGAN (mrem)	5.390E-07(ESE)	1.195E-07(SSW)	1.149E-07( N )	4.270E-06(SSE)	4.270E-06(SSE)
CRITICAL PERSON	Teenager	Teenager	Teenager	Child	Child
CRITICAL ORGAN	Lung	Lung	Lung	Bone	Bone

COMPLIANCE STATUS

TYPE OF DOSE	10 CFR 50 APP. I		10 CFR 50 APP. I	
	QUARTERLY OBJECTIVE	% OF APP. I	YEARLY OBJECTIVE	% OF APP. I
GAMMA AIR (mrad)	5.0	0.00	10.0	0.00
BETA AIR (mrad)	10.0	0.00	20.0	0.00
WHOLE BODY (mrem)	2.5	0.01	5.0	0.01
SKIN (mrem)	7.5	0.00	15.0	0.00
ORGAN (mrem)	7.5	0.00	15.0	0.00
CRITICAL PERSON		Child		Child
CRITICAL ORGAN		Bone		Bone

Calculation used release data from the following:

- Unit 1 - Ground
- Unit 1 - Vent
- Unit 1 - Chimney

Date of calculation: 5/ 4/2004

Table 3.4-1 (continued)

Dresden Station - Unit 2

MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES

2003

TYPE OF DOSE	FIRST QUARTER	SECOND QUARTER	THIRD QUARTER	FOURTH QUARTER	ANNUAL
GAMMA AIR (mrad)	3.533E-04(SSE)	5.780E-04(WSW)	5.840E-04( NW)	1.843E-04(NNW)	1.240E-03(WSW)
BETA AIR (mrad)	5.714E-05(ESE)	1.270E-04(WSW)	7.520E-05(WSW)	3.305E-05( SE)	2.295E-04(WSW)
WHOLE BODY (mrem)	2.691E-04(SSE)	1.820E-04( S )	3.229E-04(NNE)	3.848E-04( SE)	9.505E-04( SE)
SKIN (mrem)	3.297E-04(SSE)	2.260E-04( S )	4.225E-04(NNE)	4.591E-04( SE)	1.208E-03(SSE)
ORGAN (mrem)	1.070E-05(ESE)	1.899E-05(WSW)	2.364E-05(NNW)	9.979E-05( N )	1.409E-04( N )
CRITICAL PERSON	Child	Child	Child	Teenager	Teenager
CRITICAL ORGAN	Thyroid	Thyroid	Thyroid	Lung	Lung

COMPLIANCE STATUS

TYPE OF DOSE	10 CFR 50 APP. I		10 CFR 50 APP. I	
	QUARTERLY OBJECTIVE	% OF APP. I	YEARLY OBJECTIVE	% OF APP. I
GAMMA AIR (mrad)	5.0	0.01	10.0	0.01
BETA AIR (mrad)	10.0	0.00	20.0	0.00
WHOLE BODY (mrem)	2.5	0.02	5.0	0.02
SKIN (mrem)	7.5	0.01	15.0	0.01
ORGAN (mrem)	7.5	0.00	15.0	0.00
CRITICAL PERSON			Teenager	Teenager
CRITICAL ORGAN			Lung	Lung

Calculation used release data from the following:

- Unit 2 - Ground
- Unit 2 - Vent
- Unit 2 - Chimney

Date of calculation: 5/ 4/2004

Table 3.4-1 (continued)

Dresden Station - Unit 3

MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES

2003

TYPE OF DOSE	FIRST QUARTER	SECOND QUARTER	THIRD QUARTER	FOURTH QUARTER	ANNUAL
GAMMA AIR (mrad)	9.873E-04(SSE)	1.340E-03(WSW)	9.540E-04( NW)	8.168E-04(NNW)	2.912E-03( N )
BETA AIR (mrad)	1.709E-04(ESE)	3.150E-04(WSW)	1.560E-04(WSW)	1.560E-04( SE)	5.800E-04(WSW)
WHOLE BODY (mrem)	8.936E-04(SSE)	4.190E-04( S )	5.728E-04(NNE)	1.155E-03( SE)	2.602E-03(SSE)
SKIN (mrem)	1.093E-03(SSE)	5.487E-04(SSE)	7.682E-04(NNE)	1.394E-03( SE)	3.324E-03(SSE)
ORGAN (mrem)	9.324E-05(ESE)	6.491E-05(WSW)	5.786E-05( N )	1.009E-04(ESE)	2.161E-04(SSE)
CRITICAL PERSON	Child	Child	Teenager	Teenager	Teenager
CRITICAL ORGAN	Thyroid	Thyroid	Lung	Lung	Lung

COMPLIANCE STATUS

TYPE OF DOSE	10 CFR 50 APP. I		10 CFR 50 APP. I	
	QUARTERLY OBJECTIVE	% OF APP. I	YEARLY OBJECTIVE	% OF APP. I
GAMMA AIR (mrad)	5.0	0.03	10.0	0.03
BETA AIR (mrad)	10.0	0.00	20.0	0.00
WHOLE BODY (mrem)	2.5	0.05	5.0	0.05
SKIN (mrem)	7.5	0.02	15.0	0.02
ORGAN (mrem)	7.5	0.00	15.0	0.00
CRITICAL PERSON		Teenager		Teenager
CRITICAL ORGAN		Lung		Lung

Calculation used release data from the following:

- Unit 3 - Ground
- Unit 3 - Vent
- Unit 3 - Chimney

Maximum Offsite Values (pCi/m3)



Iodine	8.85E-05
Particulate Matter	4.03E-01
Data Recovery (priority parameters)	99.9%

Date of calculation: 5/ 4/2004



Figure 5.0-1

DRESDEN




- Air Sampling Location
- TLD Location
- ◆ Milk

Dresden Station Units 1,2 & 3	
Fixed Air Sampling and TLD Sites, Outer Ring TLD Locations and Milk Location	
D-01 Onsite Station 1	D-12 (C) Lisbon
D-02 Onsite Station 2	D-13 Minooka
D-03 Onsite Station 3	D-14 Channahon
D-04 Collins Road	D-45 McKinley Woods
D-07 Clay Products	D-53 Grudy County Road
D-08 Prairie Parks	D-25 Biros Farm (Milk)
	D-10 Goose Lake Village

Figure 5.0-2

DRESDEN



Dresden Station Units 1,2 & 3	
Inner Ring TLD Locations	
Fish, Water and Sediment Locations	
D-23	Thorsen Well
D-27	Dresden Lock & Dam
D-28	Dresden Pool of Illinois River
D-35	Dresden Lock & Dam
D-46	DesPlaines River, Upstream
D-51	Dresden Lock & Dam
D-52	DesPlaines River
D-54	Kankakee River, Upstream

TABLE 5.0-1

Dresden Station Radiological  
Environmental Monitoring Locations

Air Sampling	TLD	Vegetables	Fish	Milk	Sediments	Surface Water	Well Water
--------------	-----	------------	------	------	-----------	---------------	------------

D-01 Onsite Station 1	<	<	.	.	.	.	.
D-02 Onsite Station 2	<	<	.	.	.	.	.
D-03 Onsite Station 3	<	<	.	.	.	.	.
D-04 Collins Road	<	<	.	.	.	.	.
D-07 Clay Products	<	<	.	.	.	.	.
D-08 Prairie Parks	<	<	.	.	.	.	.
D-10 Goose Lake Village	<	<	.	.	.	.	.
D-12 Lisbon	<	<	.	.	.	.	.
D-13 Minooka	<	<	.	.	.	.	.
D-14 Channahon	<	<	.	.	.	.	.
D-23 Thorsen Well	.	.	.	.	.	.	<
D-25 Vince Biros Farm	.	.	.	<	.	.	.
D-27 Dresden Lock & Dam	.	.	.	.	<	.	.
D-28 Dresden Pool at Illinois River	.	.	.	<	.	.	.
D-35 Dresden Lock & Dam	.	.	.	.	.	.	<
D-46 DesPlaines River, Upstream	.	.	.	<	.	.	.
D-45 McKinley Woods Road	<	<	.	.	.	.	.
D-51 Dresden Lock & Dam	.	.	.	.	.	<	.
D-52 DesPlaines River.	.	.	.	.	.	<	.
D-53 Grundy County Road	<	<	.	.	.	<	.
D-54 Kankakee River	.	.	.	.	.	<	.
D-Quad 1	.	.	<	.	.	.	.
D-Quad 2	.	.	<	.	.	.	.
D-Quad 3	.	.	<	.	.	.	.
D-Quad 4	.	.	<	.	.	.	.
D-Control	.	.	<	.	.	.	.

CENSUS  
Dairy  
Residence  
Cattle

TABLE 5.0-2

## DRESDEN STATION

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM, SAMPLING LOCATIONS

1. AIR SAMPLERS

<u>Site Code</u> <sup>a</sup>	<u>Location</u>	<u>Distance</u> <u>(miles)</u>	<u>Direction</u>	<u>Sector</u>
D-01	Onsite Station 1	0.6	NW	Q
D-02	Onsite Station 2	0.3	NE	C
D-03	Onsite Station 3	0.4	S	J
D-04	Collins Road	0.9	W	N
D-07	Clay Products	2.0	S	J
D-08	Prairie Parks	4.0	SW	L
D-10	Goose Lake Village	3.8	SSW	K
D-12 (C)	Lisbon	10.0	NW	Q
D-13	Minooka	4.5	N	A
D-14	Channahon	3.5	NE	C
D-45	McKinley Woods Road	1.5	ENE	D
D-53	Grundy County Road	2.1	SSE	H

2. TLDs

a. Same as No. 1.

## b. Special TLD Locations

<u>Site Code</u>	<u>Distance</u> <u>(miles)</u>	<u>Direction</u>	<u>Sector</u>
Inner Ring			
D-101-1,2	1.0	N	A
D-102-1,2	1.3	NNE	B
D-103-1,2	1.2	NE	C
D-104-1,2	1.5	ENE	D
D-105-1,2	1.4	E	E
D-106-1,2	0.9	ESE	F
D-107-1,2	1.3	SE	G
D-108-1,2	1.9	SSE	H
D-109-1,2	0.8	S	J
D-110-3,4	0.8	SSW	K
D-111-1,2	0.6	SW	L

<sup>a</sup> Control (reference) locations are denoted by a "C" after site code. All other locations are indicators.

TABLE 5.0-2 (continued)

## DRESDEN STATION

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM, SAMPLING LOCATIONS

2. TLDs (cont.)

## b. Special TLD Locations (continued)

<u>Site Code</u>	<u>Distance (miles)</u>	<u>Direction</u>	<u>Sector</u>
Inner Ring (continued)			
D-112a-1,2	0.8	WSW	M
D-113-1,2	0.9	W	N
D-114-1,2	1.0	WNW	P
D-115-1,2	0.8	NW	Q
D-116-1,2	1.0	NNW	R
Outer Ring			
D-201-1,2	4.5	N	A
D-202-1,2	5.0	NNE	B
D-203-1,2	4.5	NE	C
D-204-1,2	5.0	ENE	D
D-205-1,2	4.2	E	E
D-206-1,2	3.5	ESE	F
D-207-1,2	4.5	SE	G
D-208-1,2	5.0	SSE	H
D-209-1,2	5.0	S	J
D-210-1,2	4.8	SSW	K
D-211-1,2	5.0	SW	L
D-212-3,4	6.0	WSW	M
D-213-1,2	4.5	W	N
D-214-1,2	4.5	WNW	P
D-215-1,2	5.1	NW	Q
D-216-1,2	4.8	NNW	R

3. MILK

<u>Site Code</u> <sup>a</sup>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction</u>	<u>Sector</u>
D-25 (C)	Vince Biros Farm	11.5	SW	L

<sup>a</sup> Control (reference) locations are denoted by a "C" after site code. All other locations are indicators.

TABLE 5.0-2 (continued)

## DRESDEN STATION

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM, SAMPLING LOCATIONS

4. GROUND/WELL WATER

<u>Site Code</u> <sup>a</sup>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction</u>	<u>Sector</u>
D-23	Thorsen Well	0.7	S	J
D-35	Dresden Lock & Dam	0.5	NW	Q

5. SURFACE WATER

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction</u>	<u>Sector</u>
D-51	Dresden Lock & Dam	0.5	NW	Q
D-52 (C)	DesPlaines River	0.9	ESE	F
D-54 (C)	Kankakee River	8.5	SE	G

6. FISH

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction</u>	<u>Sector</u>
D-28	Dresden Pool of Illinois River	0.5	NW	Q
DSP-46(C)	DesPlaines River, Upstream	0.9	E	E

7. SEDIMENT

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction</u>	<u>Sector</u>
D-27	Dresden Lock & Dam	0.5	NW	Q

8. VEGETATION

<u>Site Code</u>	<u>Location</u>	<u>Distance (miles)</u>	<u>Direction</u>	<u>Sector</u>
Quad 1	Chris Locknar	2.8	NE	C
Quad 2	Robert Pagliano	3.2	SSE	H
Quad 3	Jim Bloom	3.9	SSW	K
Quad 4	J.D.Carmichael	1.6	NNW	R
Control (C)	Glasscock Farm	12.8	ENE	D

<sup>a</sup> Control (reference) locations are denoted by a "C" after site code. All other locations are indicators.

TABLE 5.0-2 (continued)

DRESDEN STATION  
RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM, SAMPLE COLLECTION AND ANALYSES

Sample Media	Location		Collection Frequency	Type of Analysis	Frequency of Analysis
	Code <sup>a</sup>	Site			
1. Airborne Particulates	Onsite, Nearfield and Control		Filter exchange weekly	Gross Beta Gamma Isot.	Weekly Quarterly Composite (or if weekly gross beta in a sample exceeds 5X the average concentration of preceding calendar quarter).
	D-01	Onsite 1			
	D-02	Onsite 2			
	D-03	Onsite 3			
	D-04	Collins Road			
	D-07	Clay Products			
	D-12 (C)	Lisbon			
	D-45	McKinley Woods Road			
	D-53	Grundy County Road			
	Far Field				
	D-08	Prairie Parks			
	D-10	Goose Lake Village			
	D-13	Minooka			
	D-14	Channahon			
2. Airborne Iodine	Same as 1.		Canister exchange biweekly	I-131	Biweekly
3. Air Sampling Train	Same as 1.			Test and Maintenance	Weekly
4. TLDs	a. Same as 1. (two TLDs per location)		Quarterly	Gamma	Quarterly
	b. D-101-1,2 Inner Ring				
	102-1,2				
	103-1,2				
	104-1,2				
	105-1,2				
	106-1,2				
	107-1,2				
	108-1,2				
	109-1,2				
	110-3,4				
	111-1,2				
	112a-1,2				
	113-1,2				
	114-1,2				
	115-1,2				
	116-1,2				
	c. D-201-1,2 Outer Ring				
	202-1,2				
	203-1,2				
204-1,2					
205-1,2					
206-1,2					
207-1,2					

<sup>a</sup> Control (background) locations are denoted by a "C" in this column. All other location are indicators.

TABLE 5.0-2 (continued)

DRESDEN STATION  
RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM, SAMPLE COLLECTION AND ANALYSES

Sample Media	Location		Collection Frequency	Type of Analysis	Frequency of Analysis
	Code <sup>a</sup>	Site			
4. TLDs (continued)					
	D-208-1,2	Outer Ring	Quarterly	Gamma	Quarterly
	209-1,2				
	210-1,2				
	211-1,2				
	212-3,4				
	213-1,2				
	214-1,2				
	215-1,2				
	216-1,2				
5. Milk	D-25	Biros Farm	Biweekly: May-October Monthly: November-April	I-131 Gamma Isot.	Biweekly: May-October Monthly: November-April
6. Vegetables	Quad 1	Chris Locknar	Annually - two varieties from each location as available at harvest.	Gamma Isot.	Annually
	Quad 2	Robert Pagliano		I-131	Annually
	Quad 3	Jim Bloom			
	Quad 4	J.D. Carmichael			
	Control	Glasscock Farm			
7. Ground/Well Water	D-23	Thorsen Well	Quarterly	Gamma Isot.	Quarterly
	D-35	Dresden Lock & Dam		Tritium	
8. Surface Water	D-51	Dresden Lock & Dam	Weekly	Gross Beta Gamma Isot.	Monthly composite. Monthly composite.
	D-52 (C)	DesPlaines River, Upstream		Tritium	Quarterly composite.
	D-54 (C)	Kankakee River, Upstream			
9. Fish (at least two species)	D-28	Dresden Pool of Illinois River	Two times/year	Gamma Isot.	Two times/year on edible portions only.
	D-46 (C)	DesPlaines River, Upstream			
10. Sediments	D-27	Dresden Lock & Dam	Semiannually	Gamma Isot.	Semiannually
11. Land Use Census					
		Milch Animals			
		a. Site Boundary to 2 miles		a. Enumeration by a door to door or equivalent counting technique.	Annually during grazing season.

<sup>a</sup> Control (background) locations are denoted by a "C" in this column. All other location are indicators.



TABLE 5.0-2 (continued)

DRESDEN STATION  
 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM, SAMPLE COLLECTION AND ANALYSES

Sample Media	Location		Collection Frequency	Type of Analysis	Frequency of Analysis
	Code <sup>a</sup>	Site			
11. Land Use Census (continued)					
	b.	2 miles to 6.2 miles	-	b. Using referenced information from county agricultural agents or other reliable sources.	
	c.	At dairies listed in Item 5.	-	c. Inquire as to feeding practices: 1. Pasture only. 2. Feed and chop only. 3. Pasture and feed: if both, ask farmer to estimate fraction of food from pasture: <25%, 25-50%, 50-75%, or >75%.	Annually during grazing season.
Nearest Residence		In all sectors up to 6.2 miles.	-		Annually during grazing season.

<sup>a</sup> Control (background) locations are denoted by a "C" in this column. All other location are indicators.

Table 5.0-3

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Dresden Nuclear Power Station Docket No. 50-10, 50-237, 50-249  
 Location of Facility Grundy, Illinois Reporting Period 1st Quarter 2003  
 (County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean	Highest Mean <sup>a</sup> Range	Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results				
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta 95	0.01	0.029 (82/82) (0.013-0.043)	D-02, Onsite Station 2 0.3 mi. NE, Sector C	.033 (4/4) 0.027-0.039)	0.031 (13/13) (0.021-0.047)	0				
	Gamma Spec. 8										
	Cs-134	0.05	<LLD					-	-	<LLD	0
	Cs-137	0.06	<LLD					-	-	<LLD	0
	Other Gammas	0.01-0.04	<LLD					-	-	<LLD	0
Airborne Iodine (pCi/m <sup>3</sup> )	I-131 52	0.07	<LLD	-	-	<LLD	0				
Milk (pCi/L)	I-131 3	1	None	-	-	<LLD	0				
	Gamma Spec. 3										
	Cs-134	15	None	-	-	<LLD	0				
	Cs-137	18	None	-	-	<LLD	0				
	Ba-140	60	None	-	-	<LLD	0				
	La-140	15	None	-	-	<LLD	0				
	Other Gammas	10-15	None	-	-	<LLD	0				
Surface Water (pCi/L)	Gross Beta 6	4	6.4 (3/3) (6.0-6.9)	D-52, DesPlaines River, 0.9 mi. ESE Sector F	10.7 (3/3) (9.0-13.6)	10.7 (3/3) (9.0-13.6)	0				
	Gamma Spec. 6										
	Cs-134	15	<LLD					-	-	<LLD	0
	Cs-137	18	<LLD					-	-	<LLD	0
	Other ODCM-Required Gammas	15-60	<LLD					-	-	<LLD	0
	Tritium 2	200	1,626 (1/1)					D-51, Dresden Lock & Dam, 0.5 mi. NW Sector Q	1,626 (1/1)	230 (1/1)	0
Well Water (pCi/L)	Tritium 2	200	609 (1/2)	D-23 Thorsen Well 0.7 mi. S, Sector J	609 (1/1)	None	0				
	Gamma Spec. 2										
	Cs-134	15	<LLD					-	-	None	0
	Cs-137	18	<LLD					-	-	None	0
	Other ODCM-Required Gammas	15-60	<LLD					-	-	None	0
Gamma Background (TLDs) (mR/Qtr.)	Gamma Dose 87	9.7	25.8 (85/85) (19.0-32.0)	D-201-2, 4.5 mi. N Sector A	32.0 (1/1)	23.5 (2/2) (21.0-26.0)	0				

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-4

**RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM QUARTERLY SUMMARY**  
 Name of Facility Dresden Nuclear Power Station Docket No. 50-10, 50-237, 50-249  
 Location of Facility Grundy, Illinois Reporting Period 2nd Quarter 2003  
 (County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean	Highest Mean <sup>a</sup> Range	Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta 91	0.01	0.018 (78/78) (0.010-0.028)	D-12, Lisbon, 10 mi. NW, Sector Q	0.020 (13/13) (0.014-0.023)	0.020 (13/13) (0.014-0.023)	0
	Gamma Spec. 7						
	Cs-134	0.05	<LLD	-	-	<LLD	0
	Cs-137	0.06	<LLD	-	-	<LLD	0
	Other Gammas	0.01-0.04	<LLD	-	-	<LLD	0
Airborne Iodine (pCi/m <sup>3</sup> )	I-131 48	0.07	<LLD	-	-	<LLD	0
Milk (pCi/L)	I-131 6	1	None	-	-	<LLD	0
	Gamma Spec. 6						
	Cs-134	15	None	-	-	<LLD	0
	Cs-137	18	None	-	-	<LLD	0
	Ba-140	60	None	-	-	<LLD	0
	La-140	15	None	-	-	<LLD	0
	Other Gammas	10-15	None	-	-	<LLD	0
Fish (pCi/g wet)	Gamma Spec. 4						
	Cs-134	0.13	<LLD	-	-	<LLD	0
	Cs-137	0.15	<LLD	-	-	<LLD	0
	Other ODCM-Required Gammas	0.13-0.26	<LLD	-	-	<LLD	0
	Other Gammas	0.20-0.30	<LLD	-	-	<LLD	0
Bottom Sediments (pCi/g dry)	Gamma Spec. 1						
	Cs-134	0.15	<LLD	-	-	None	0
	Cs-137	0.18	<LLD	-	-	None	0
	Other Gammas	0.10-0.60	<LLD	-	-	None	0

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-4 (continued)

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Dresden Nuclear Power Station Docket No. 50-10, 50-237, 50-249  
 Location of Facility Grundy, Illinois Reporting Period 2nd Quarter 2003  
 (County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean	Highest Mean <sup>a</sup> Range	Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results
Surface Water (pCi/L)	Gross Beta 9	4	5.2 (3/3) (4.0-5.9)	D-52, DesPlaines River, 0.9 mi. ESE, Sector F	6.9 (3/3) (5.2-8.1)	6.9 (3/6) (5.2-8.1)	0
	Gamma Spec. 9						
	Cs-134 15	<LLD	-		-	<LLD	0
	Cs-137 18	<LLD	-		-	<LLD	0
	Other ODCM-Required Gammas 15-60	<LLD	-	-	<LLD	0	
Tritium 2	200	294 (1/1)	D-51, Dresden Lock and Dam, 0.5 mi NW, Sector Q	294 (1/1)	<LLD	0	
Well Water (pCi/L)	Tritium 2	200	729 (1/2)	D-23, Thorsen Well 0.7 mi. S, Sector J	729 (1/1)	None	0
	Gamma Spec. 2						
	Cs-134 15	<LLD	-	-	None	0	
	Cs-137 18	<LLD	-	-	None	0	
	Other ODCM-Required Gammas 15-60	<LLD	-	-	None	0	
Gamma Background (TLDs) (mR/Qtr.)	Gamma Dose 88	9.7	22.8 (86/86) (18.0-29.0)	D-110-4, 0.8 mi SSW, Sector K	29.0 (1/1)	19.0 (2/2) (19.0-19.0)	0

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-5

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Dresden Nuclear Power Station Docket No. 50-10, 50-237, 50-249Location of Facility Grundy, Illinois Reporting Period 3rd Quarter 2003  
(County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean	Highest Mean <sup>a</sup> Range	Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results			
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta 91	0.01	0.025 (89/91) (0.011-0.049)	D-12, Lisbon 10 mi. NW, Sector Q	0.029 (13/13) (0.020-0.050)	0.029 (13/13) (0.020-0.050)	0			
	Gamma Spec. 7									
	Cs-134	0.05	<LLD					-	<LLD	0
	Cs-137	0.06	<LLD					-	<LLD	0
	Other Gammas	0.01-0.04	<LLD					-	<LLD	0
Airborne Iodine (pCi/m <sup>3</sup> )	I-131 56	0.07	<LLD	-	-	<LLD	0			
Milk (pCi/L)	I-131 6	1	None	-	-	<LLD	0			
	Gamma Spec. 6									
	Cs-134	15	None	-	-	<LLD	0			
	Cs-137	18	None	-	-	<LLD	0			
	Ba -140	60	None	-	-	<LLD	0			
	La-140	15	None	-	-	<LLD	0			
Other Gammas	10-15									
Vegetation (pCi/g wet)	I-131 11	0.06	<LLD	-	-	<LLD	0			
	Gamma Spec. 11									
	Cs-134	0.06	<LLD	-	-	<LLD	0			
	Cs-137	0.08	<LLD	-	-	<LLD	0			
	Other Gammas	0.01-0.10	<LLD	-	-	<LLD	0			
Surface Water (pCi/L)	Gross Beta 6	4	5.0 (3/3) (4.7-5.5)	D-52 DesPlaines River 0.9 mi. ESE, Sector F	6.1 (3/3) (5.8-6.7)	5.3 (5/6) (4.0-6.7)	0			
	Gamma Spec. 6									
	Cs-134	15	<LLD					-	<LLD	0
	Cs-137	18	<LLD					-	<LLD	0
	Other ODCM-Required Gammas	15-60	<LLD					-	<LLD	0
	Tritium 2	200	662 (1/1)					D-51, Dresden Lock & Dam, 0.5 mi. NW, Sector Q	662 (1/1)	<LLD

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-5 (continued)

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Dresden Nuclear Power Station Docket No. 50-10, 50-237, 50-249  
 Location of Facility Grundy, Illinois Reporting Period 3rd Quarter 2003  
 (County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean	Highest Mean <sup>a</sup> Range	Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results	
Well Water (pCi/L)	Tritium 2	200	839 (1/2)	D-23, Thorsen Well 0.7 mi. S, Sector J	839 (1/1)	None	0	
	Gamma Spec. 2							
	Cs-134 15		<LLD		-	None		0
	Cs-137 18		<LLD		-	None		0
	Other ODCM-Required Gammas 15-60		<LLD		-	None		0
Gamma Background (TLDs) (mR/Qtr.)	Gamma Dose 88	9.7	22.7 (86/86) (18.0-29.0)	D-214-2, 4.5 mi. WNW, Sector P	29.0 (1/1)	21.5 (2/2) (21.0-22.0)	0	

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-6

## RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Dresden Nuclear Power Station Docket No. 50-10, 50-237, 50-249  
 Location of Facility Grundy, Illinois Reporting Period 4th Quarter 2003  
 (County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean	Highest Mean <sup>a</sup> Range	Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results				
Air Particulates (pCi/m <sup>3</sup> )	Gross Beta 90	0.01	0.027 (77/77) (0.013-0.041)	D-03, Onsite Station 3, 0.6 miS, Sector J	0.029 (13/13) (0.019-0.041)	0.028 (13/13) (0.015-0.042)	0				
	Gamma Spec. 8										
	Cs-134	0.05	<LLD					-	-	<LLD	0
	Cs-137	0.06	<LLD					-	-	<LLD	0
	Other Gammas	0.01-0.04	<LLD					-	-	<LLD	0
Airborne Iodine (pCi/m <sup>3</sup> )	I-131 42	0.07	<LLD	-	-	<LLD	0				
Milk (pCi/L)	I-131 5	1	None	-	-	<LLD	0				
	Gamma Spec. 5										
	Cs-134	15	None	-	-	<LLD	0				
	Cs-137	18	None	-	-	<LLD	0				
	Ba-140	60	None	-	-	<LLD	0				
	La-140	15	None	-	-	<LLD	0				
	Other Gammas	10-15	None	-	-	<LLD	0				
Fish (pCi/g wet)	Gamma Spec. 4										
	Cs-134	0.13	<LLD	-	-	<LLD	0				
	Cs-137	0.15	<LLD	-	-	<LLD	0				
	Other ODCM-Required Gammas	0.13-0.26	<LLD	-	-	<LLD	0				
	Other Gammas	0.20-0.30	<LLD	-	-	<LLD	0				
Bottom Sediments (pCi/g dry)	Gamma Spec. 1										
	Cs-134	0.15	<LLD	-	-	None	0				
	Cs-137	0.18	<LLD	-	-	None	0				
	Other Gammas	0.10-0.60	<LLD	-	-	None	0				

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-6 (continued)

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM QUARTERLY SUMMARY

Name of Facility Dresden Nuclear Power Station Docket No. 50-10, 50-237, 50-249  
 Location of Facility Grundy, Illinois Reporting Period 4th Quarter 2003  
 (County, State)

Sample Type (Units)	Type and Number of Analyses	LLD	Indicator Locations Mean <sup>a</sup> Range	Location with Highest Quarterly Mean	Highest Mean <sup>a</sup> Range	Control Locations Mean <sup>a</sup> Range	Number of Non-routine Results	
Surface Water (pCi/L)	Gross Beta 6	4	5.6 (2/3) (5.0-6.2)	D-51, Dresden Lock & Dam, 0.5 mi. NW, Sector Q	5.6 (2/3) (5.0-6.2)	5.3 (3/6) (4.8-5.6)	0	
	Gamma Spec. 6							
	Cs-134 15		<LLD		-	-	<LLD	0
	Cs-137 18		<LLD		-	-	<LLD	0
	Other ODCM-Required Gammas 15-60		<LLD		-	-	<LLD	0
Tritium 2	200	277 (1/1)	D-51, Dresden Lock & Dam, 0.5 mi. NW, Sector Q	277 (1/1)	<LLD	0		
Well Water (pCi/L)	Gamma Spec. 2							
	Cs-134 15		<LLD	-	-	None	0	
	Cs-137 18		<LLD	-	-	None	0	
	Other ODCM-Required Gammas 15-60		<LLD	-	-	None	0	
	Tritium 2	200	711 (1/2)	D-23, Thorsen Well, 0.7 mi. S, Sector J	711 (1/1)	None	0	
Gamma Background (TLDs) (mR/Qt.)	Gamma Dose 88	9.7	26.4 (86/86) (21.0-33.0)	D-214.1, 4.5 mi. WNW, Sector P	33.0 (1/1)	23.5 (2/2) (23.0-24.0)	0	

<sup>a</sup> Mean and range based on detectable measurements only. Fractions indicated in parentheses.  
<sup>b</sup> Locations D-214-1,2 had identical means of 33 mR. Only D-214-1 is detailed in this summary.



DRESDEN

APPENDIX II

METEOROLOGICAL DATA

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Extremely Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	2	0	0	0	3
NNE	0	0	2	0	0	0	2
NE	0	2	8	1	0	0	11
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	1	0	0	0	1
SW	0	0	0	3	3	0	6
WSW	0	0	0	4	0	0	4
W	0	0	4	9	0	0	13
WNW	0	1	8	15	0	0	24
NW	0	1	14	3	0	0	18
NNW	0	6	4	0	0	0	10
Variable	0	0	0	0	0	0	0
Total	0	11	43	35	3	0	92

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Moderately Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	0	0	0	2
NNE	0	1	2	0	0	0	3
NE	0	0	1	0	0	0	1
ENE	0	1	0	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	1	0	0	0	1
SE	0	0	1	0	0	0	1
SSE	0	0	0	0	0	0	0
S	0	0	1	0	0	0	1
SSW	0	0	2	4	1	0	7
SW	0	0	2	1	0	0	3
WSW	0	1	2	0	0	0	3
W	0	1	1	2	0	0	4
WNW	0	0	6	2	0	0	8
NW	0	2	10	0	0	0	12
NNW	0	2	1	1	0	0	4
Variable	0	0	0	0	0	0	0
Total	0	8	32	10	1	0	51

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Slightly Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	0	0	0	0	2
NNE	0	0	1	0	0	0	1
NE	0	2	0	2	0	0	4
ENE	0	2	0	0	0	0	2
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	1	1	0	0	0	2
SSE	0	0	0	1	0	0	1
S	0	0	1	1	0	0	2
SSW	0	0	1	4	0	0	5
SW	0	2	3	5	1	0	11
WSW	0	1	4	4	0	0	9
W	0	0	4	1	0	0	5
WNW	0	1	5	9	0	0	15
NW	0	4	4	1	0	0	9
NNW	0	1	4	2	0	0	7
Variable	0	0	0	0	0	0	0
Total	0	16	28	30	1	0	75

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Neutral - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	22	19	11	0	0	55
NNE	1	17	19	11	0	0	48
NE	1	13	40	28	0	0	82
ENE	0	12	15	0	0	0	27
E	1	4	21	0	0	0	26
ESE	0	12	4	2	0	0	18
SE	0	8	5	3	0	0	16
SSE	2	11	16	10	5	0	44
S	2	11	38	9	0	0	60
SSW	2	8	26	11	2	0	49
SW	2	9	18	28	2	0	59
WSW	2	10	11	15	0	0	38
W	6	19	25	12	0	0	62
WNW	4	23	27	26	1	0	81
NW	6	29	26	1	0	0	62
NNW	5	26	48	9	0	0	88
Variable	0	0	0	0	0	0	0
Total	37	234	358	176	10	0	815

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Slightly Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	15	9	0	0	0	25
NNE	5	12	3	1	0	0	21
NE	5	11	15	9	0	0	40
ENE	7	12	0	0	0	0	19
E	5	29	7	3	0	0	44
ESE	9	19	16	0	0	0	44
SE	6	5	7	3	0	0	21
SSE	7	28	14	12	0	0	61
S	1	31	30	21	1	0	84
SSW	4	18	21	10	0	0	53
SW	4	17	17	9	1	0	48
WSW	6	11	15	4	0	0	36
W	9	38	72	9	1	0	129
WNW	10	51	57	13	0	0	131
NW	11	46	45	1	1	0	104
NNW	9	33	42	1	0	0	85
Variable	0	0	0	0	0	0	0
Total	99	376	370	96	4	0	945

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Moderately Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	2	0	0	0	0	0	2
NE	0	1	0	0	0	0	1
ENE	1	1	0	0	0	0	2
E	1	8	0	0	0	0	9
ESE	2	6	0	0	0	0	8
SE	2	13	0	0	0	0	15
SSE	1	18	0	0	0	0	19
S	4	11	1	0	0	0	16
SSW	5	20	1	0	0	0	26
SW	2	6	4	0	0	0	12
WSW	5	6	0	0	0	0	11
W	3	5	1	0	0	0	9
WNW	3	5	0	0	0	0	8
NW	3	4	0	0	0	0	7
NNW	1	1	0	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	36	105	7	0	0	0	148

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Extremely Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	1	1	0	0	0	0	2
ESE	2	2	0	0	0	0	4
SE	0	0	0	0	0	0	0
SSE	2	1	0	0	0	0	3
S	0	1	0	0	0	0	1
SSW	2	3	0	0	0	0	5
SW	2	3	0	0	0	0	5
WSW	0	1	0	0	0	0	1
W	3	0	0	0	0	0	3
WNW	1	0	0	0	0	0	1
NW	0	1	0	0	0	0	1
NNW	1	0	0	0	0	0	1
Variable	0	0	0	0	0	0	0
Total	15	13	0	0	0	0	28

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0



Dresden Nuclear Station

Period of Record: January - March 2003

Stability Class - Extremely Unstable - 300Ft-35Ft Delta-T (F)  
Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	5	0	0	5
ENE	0	0	1	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	1	1	1	0	3
WNW	0	0	0	2	5	0	7
NW	0	0	0	0	4	0	4
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	0	2	8	10	0	20

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 1

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Moderately Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	1	2	2	1	0	6
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	1	0	0	0	0	1
S	0	0	0	0	0	0	0
SSW	0	0	0	1	3	0	4
SW	0	0	0	1	2	2	5
WSW	0	1	2	0	2	1	6
W	0	0	1	2	3	1	7
WNW	0	0	4	3	5	3	15
NW	0	0	5	3	2	0	10
NNW	0	0	4	2	0	0	6
Variable	0	0	0	0	0	0	0
Total	0	3	19	14	18	7	61

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 1

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Slightly Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	2	2	0	0	5
NNE	0	0	0	3	1	0	4
NE	0	0	1	2	0	0	3
ENE	0	2	1	0	0	0	3
E	0	0	0	0	0	0	0
ESE	0	1	0	0	0	0	1
SE	0	1	1	0	0	0	2
SSE	0	0	2	0	1	2	5
S	0	0	3	0	0	0	3
SSW	0	0	0	6	1	0	7
SW	0	1	1	5	3	2	12
WSW	0	2	2	1	3	0	8
W	0	2	1	2	1	1	7
WNW	0	1	3	9	4	2	19
NW	0	2	3	8	0	0	13
NNW	0	1	7	4	3	0	15
Variable	0	0	0	0	0	0	0
Total	0	14	27	42	17	7	107

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 1

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Neutral - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	10	13	34	11	5	75
NNE	2	3	21	13	19	8	66
NE	0	8	17	25	42	4	96
ENE	1	7	23	26	1	0	58
E	1	5	11	12	5	0	34
ESE	0	5	4	2	6	0	17
SE	0	15	9	5	3	0	32
SSE	0	4	7	16	8	2	37
S	1	10	31	31	17	1	91
SSW	1	3	23	30	4	1	62
SW	1	4	18	34	25	3	85
WSW	1	7	9	14	22	3	56
W	1	14	23	29	10	4	81
WNW	3	12	25	47	46	15	148
NW	1	11	26	49	11	6	104
NNW	2	14	33	67	19	2	137
Variable	0	0	0	0	0	0	0
Total	17	132	293	434	249	54	1179

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 1

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Slightly Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	1	9	12	1	0	25
NNE	0	0	1	4	1	0	6
NE	1	2	9	8	0	0	20
ENE	3	8	4	1	0	0	16
E	3	6	3	6	2	0	20
ESE	2	3	11	9	2	0	27
SE	1	11	16	18	4	0	50
SSE	0	5	13	7	2	0	27
S	1	2	21	16	7	9	56
SSW	0	2	15	18	14	1	50
SW	0	4	7	19	7	4	41
WSW	0	2	5	17	8	1	33
W	0	4	11	15	14	10	54
WNW	1	5	10	44	31	3	94
NW	0	4	17	45	5	0	71
NNW	1	3	10	31	11	0	56
Variable	0	0	0	0	0	0	0
Total	15	62	162	270	109	28	646

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 1

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Moderately Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	0	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	1	0	0	0	0	1
ENE	1	2	0	0	0	0	3
E	0	0	1	2	0	0	3
ESE	0	1	1	0	0	0	2
SE	0	0	1	6	0	0	7
SSE	0	0	2	6	1	0	9
S	1	2	3	6	6	0	18
SSW	0	0	5	15	2	0	22
SW	0	2	1	6	0	0	9
WSW	0	2	10	6	0	0	18
W	2	3	3	5	0	0	13
WNW	0	0	6	3	0	0	9
NW	0	1	5	4	1	0	11
NNW	0	1	1	2	0	0	4
Variable	0	0	0	0	0	0	0
Total	4	16	39	61	10	0	130

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 2  
 Hours of missing stability measurements in all stability classes: 1

Dresden Nuclear Station

Period of Record: January - March 2003  
 Stability Class - Extremely Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	1	0	0	0	0	1
ESE	0	1	0	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	1	0	0	0	1
S	0	1	0	0	0	0	1
SSW	0	0	2	4	0	0	6
SW	0	0	0	1	0	0	1
WSW	0	0	0	0	0	0	0
W	0	1	0	0	0	0	1
WNW	0	0	1	0	0	0	1
NW	0	0	0	0	1	0	1
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	4	4	5	1	0	14

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 1

Dresden Nuclear Station

Period of Record: April - June 2003  
 Stability Class - Extremely Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	5	6	0	0	0	11
NNE	0	8	15	0	0	0	23
NE	0	32	25	0	0	0	57
ENE	0	28	5	0	0	0	33
E	0	4	3	2	0	0	9
ESE	0	3	0	0	0	0	3
SE	0	1	0	0	0	0	1
SSE	0	4	0	0	0	0	4
S	0	0	2	1	0	0	3
SSW	1	1	8	3	1	0	14
SW	0	1	1	2	1	0	5
WSW	1	2	8	9	0	0	20
W	1	0	1	1	0	0	3
WNW	0	2	2	8	0	0	12
NW	0	5	6	0	0	0	11
NNW	0	10	10	1	0	0	21
Variable	0	0	0	0	0	0	0
Total	3	106	92	27	2	0	230

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0



Dresden Nuclear Station

Period of Record: April - June 2003

Stability Class - Moderately Unstable - 150Ft-35Ft Delta-T (F)

Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	0	0	0	2
NNE	0	3	2	0	0	0	5
NE	0	12	3	0	0	0	15
ENE	0	9	2	0	0	0	11
E	1	2	3	1	0	0	7
ESE	0	2	1	1	0	0	4
SE	0	0	0	0	0	0	0
SSE	0	1	1	0	0	0	2
S	0	1	2	3	0	0	6
SSW	0	0	5	5	0	0	10
SW	0	0	0	3	1	0	4
WSW	0	1	5	1	0	0	7
W	0	1	1	0	0	0	2
WNW	0	2	0	3	0	0	5
NW	0	2	3	0	0	0	5
NNW	0	0	4	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	1	36	34	17	1	0	89

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: April - June 2003  
 Stability Class - Slightly Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	3	0	0	0	0	4
NNE	2	3	0	0	0	0	5
NE	1	9	6	0	0	0	16
ENE	0	5	4	0	0	0	9
E	0	1	2	0	0	0	3
ESE	0	2	1	0	0	0	3
SE	0	0	0	0	0	0	0
SSE	0	1	2	0	0	0	3
S	0	0	1	1	0	0	2
SSW	0	1	3	2	1	0	7
SW	0	1	2	1	0	0	4
WSW	1	1	2	2	0	0	6
W	0	1	3	0	0	0	4
WNW	0	2	1	1	0	0	4
NW	0	1	0	0	0	0	1
NNW	0	0	6	0	0	0	6
Variable	0	0	0	0	0	0	0
Total	5	31	33	7	1	0	77

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: April - June 2003

Stability Class - Neutral - 150Ft-35Ft Delta-T (F)

Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	8	25	7	0	0	0	40
NNE	11	41	21	0	0	0	73
NE	8	58	35	0	0	0	101
ENE	4	26	22	1	0	0	53
E	6	20	34	7	0	0	67
ESE	3	16	15	9	0	0	43
SE	4	6	5	4	0	0	19
SSE	3	9	15	3	0	0	30
S	2	4	8	8	0	0	22
SSW	4	5	8	16	7	0	40
SW	3	4	3	6	4	0	20
WSW	2	10	12	11	1	7	43
W	4	15	6	3	7	2	37
WNW	3	14	12	6	0	0	35
NW	2	6	11	1	0	0	20
NNW	14	14	7	0	0	0	35
Variable	0	0	0	0	0	0	0
Total	81	273	221	75	19	9	678

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: April - June 2003  
 Stability Class - Slightly Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	22	15	4	0	0	0	41
NNE	24	41	1	0	0	0	66
NE	13	79	15	1	0	0	108
ENE	3	48	20	1	0	0	72
E	3	49	27	2	0	0	81
ESE	0	27	15	6	0	0	48
SE	6	6	9	2	0	0	23
SSE	6	15	23	4	0	0	48
S	8	22	17	14	3	1	65
SSW	4	13	12	10	7	0	46
SW	6	17	11	4	1	0	39
WSW	6	9	10	0	4	0	29
W	3	20	7	2	0	0	32
WNW	6	10	6	3	0	0	25
NW	6	8	7	0	0	0	21
NNW	17	16	7	0	0	0	40
Variable	0	0	0	0	0	0	0
Total	133	395	191	49	15	1	784

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: April - June 2003  
 Stability Class - Moderately Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	20	3	0	0	0	0	23
NNE	12	6	0	0	0	0	18
NE	2	2	0	0	0	0	4
ENE	5	1	0	0	0	0	6
E	5	2	1	0	0	0	8
ESE	6	11	2	0	0	0	19
SE	1	4	0	0	0	0	5
SSE	8	12	1	0	0	0	21
S	10	15	2	0	0	0	27
SSW	3	10	2	0	0	0	15
SW	4	13	6	0	0	0	23
WSW	3	2	0	0	0	0	5
W	2	2	0	0	0	0	4
WNW	7	12	0	0	0	0	19
NW	18	1	0	0	0	0	19
NNW	17	1	0	0	0	0	18
Variable	0	0	0	0	0	0	0
Total	123	97	14	0	0	0	234

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: April - June 2003

Stability Class - Extremely Stable - 150Ft-35Ft Delta-T (F)

Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	1	0	0	0	0	0	1
NE	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	2	0	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	5	2	0	0	0	0	7
SSE	3	0	0	0	0	0	3
S	6	0	0	0	0	0	6
SSW	1	2	0	0	0	0	3
SW	9	5	0	0	0	0	14
WSW	6	0	0	0	0	0	6
W	6	0	0	0	0	0	6
WNW	3	1	0	0	0	0	4
NW	14	0	0	0	0	0	14
NNW	13	0	0	0	0	0	13
Variable	0	0	0	0	0	0	0
Total	68	13	0	0	0	0	81

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: April - June 2003

Stability Class - Extremely Unstable - 300Ft-35Ft Delta-T (F)

Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	3	0	0	5
NNE	0	0	1	6	5	0	12
NE	0	1	10	7	3	0	21
ENE	0	4	2	1	0	0	7
E	0	1	3	1	0	0	5
ESE	0	1	0	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	1	2	0	1	4
SW	0	0	0	0	1	0	1
WSW	0	0	0	4	2	0	6
W	1	0	0	0	1	0	2
WNW	0	0	0	1	4	2	7
NW	0	0	0	1	0	0	1
NNW	0	1	2	3	3	1	10
Variable	0	0	0	0	0	0	0
Total	1	8	21	29	19	4	82

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 2

Dresden Nuclear Station

Period of Record: April - June 2003  
 Stability Class - Moderately Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	1	2	0	0	3
NNE	0	1	3	4	2	0	10
NE	0	3	6	4	2	0	15
ENE	0	6	17	0	0	0	23
E	0	4	1	3	0	0	8
ESE	0	1	2	0	0	0	3
SE	0	0	0	0	0	0	0
SSE	0	3	0	1	0	0	4
S	0	0	0	1	0	0	1
SSW	0	0	2	7	1	0	10
SW	1	0	0	1	0	0	2
WSW	1	1	3	4	3	2	14
W	0	1	1	0	1	0	3
WNW	0	0	0	0	0	3	3
NW	0	0	4	0	0	0	4
NNW	0	2	4	2	2	0	10
Variable	0	0	0	0	0	0	0
Total	2	22	44	29	11	5	113

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 2



Dresden Nuclear Station

Period of Record: April - June 2003

Stability Class - Slightly Unstable - 300Ft-35Ft Delta-T (F)

Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	3	6	0	0	9
NNE	0	3	3	3	1	2	12
NE	0	4	12	3	1	0	20
ENE	0	16	12	0	0	0	28
E	0	2	8	5	1	0	16
ESE	0	1	1	0	0	0	2
SE	0	3	0	2	0	0	5
SSE	1	2	1	5	0	0	9
S	0	0	0	3	1	0	4
SSW	0	0	1	9	4	2	16
SW	0	0	0	3	4	3	10
WSW	0	1	5	2	5	0	13
W	0	0	3	2	0	0	5
WNW	0	1	5	0	0	2	8
NW	0	2	5	7	0	1	15
NNW	0	2	1	1	0	0	4
Variable	0	0	0	0	0	0	0
Total	1	37	60	51	17	10	176

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 2

Dresden Nuclear Station

Period of Record: April - June 2003

Stability Class - Neutral - 300Ft-35Ft Delta-T (F)

Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	12	20	10	7	0	50
NNE	2	14	28	36	9	1	90
NE	0	14	64	45	7	0	130
ENE	2	29	74	22	3	0	130
E	2	14	23	43	15	2	99
ESE	1	7	17	16	14	3	58
SE	1	8	10	12	5	2	38
SSE	1	10	12	11	2	0	36
S	3	2	3	14	4	3	29
SSW	0	4	7	15	11	14	51
SW	2	3	2	6	10	7	30
WSW	1	4	6	12	10	14	47
W	0	6	16	9	6	9	46
WNW	0	6	8	9	8	9	40
NW	0	4	4	8	17	1	34
NNW	1	7	6	14	7	0	35
Variable	0	0	0	0	0	0	0
Total	17	144	300	282	135	65	943

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 2

Dresden Nuclear Station

Period of Record: April - June 2003

Stability Class - Slightly Stable - 300Ft-35Ft Delta-T (F)

Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	11	12	3	0	27
NNE	0	4	24	36	3	0	67
NE	1	8	43	33	1	0	86
ENE	1	25	32	1	0	1	60
E	2	7	21	21	3	0	54
ESE	0	1	6	15	1	0	23
SE	1	4	6	7	3	0	21
SSE	1	2	6	2	8	1	20
S	3	2	7	16	18	9	55
SSW	0	2	11	20	15	11	59
SW	0	2	8	22	10	0	42
WSW	0	5	10	6	2	1	24
W	0	6	8	13	0	0	27
WNW	0	1	8	9	0	0	18
NW	1	1	1	9	4	0	16
NNW	0	3	0	8	0	0	11
Variable	0	0	0	0	0	0	0
Total	10	74	202	230	71	23	610

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 2

Dresden Nuclear Station

Period of Record: April - June 2003  
 Stability Class - Moderately Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	3	3	11	0	0	18
NNE	0	4	6	7	0	0	17
NE	1	0	14	9	1	0	25
ENE	4	1	0	0	0	0	5
E	1	3	5	0	0	0	9
ESE	1	0	1	7	0	0	9
SE	0	1	11	6	4	0	22
SSE	0	2	7	5	0	0	14
S	0	1	4	6	6	0	17
SSW	0	1	1	5	4	0	11
SW	1	2	9	11	7	0	30
WSW	0	1	4	5	0	0	10
W	0	5	3	4	0	0	12
WNW	0	1	1	4	2	0	8
NW	0	3	1	3	3	0	10
NNW	0	5	2	0	0	0	7
Variable	0	0	0	0	0	0	0
Total	9	33	72	83	27	0	224

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 1  
 Hours of missing stability measurements in all stability classes: 2

Dresden Nuclear Station

Period of Record: April - June 2003  
 Stability Class - Extremely Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	2	0	0	0	2
NNE	0	0	0	0	1	0	1
NE	0	0	1	2	0	0	3
ENE	0	0	0	0	0	0	0
E	0	0	1	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	1	2	1	0	0	4
S	0	0	0	0	0	0	0
SSW	0	0	1	0	0	0	1
SW	0	0	4	0	0	0	4
WSW	0	3	2	2	0	0	7
W	0	1	1	1	0	0	3
WNW	0	0	1	0	0	0	1
NW	1	0	1	2	0	0	4
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	1	5	16	8	1	0	31

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 2  
 Hours of missing stability measurements in all stability classes: 2

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Extremely Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	19	0	0	0	0	21
NNE	0	16	0	0	0	0	16
NE	1	13	10	0	0	0	24
ENE	0	19	8	0	0	0	27
E	0	6	5	0	0	0	11
ESE	0	7	2	0	0	0	9
SE	0	7	5	0	0	0	12
SSE	2	2	5	3	0	0	12
S	0	3	4	0	0	0	7
SSW	0	4	16	8	0	0	28
SW	0	4	9	6	0	0	19
WSW	1	3	15	0	0	0	19
W	0	5	9	1	0	0	15
WNW	0	13	19	0	0	0	32
NW	0	7	4	0	0	0	11
NNW	2	19	1	0	0	0	22
Variable	0	0	0	0	0	0	0
Total	8	147	112	18	0	0	285

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Moderately Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	2	0	0	0	0	5
NNE	1	2	0	0	0	0	3
NE	0	5	1	0	0	0	6
ENE	1	1	1	0	0	0	3
E	1	2	3	0	0	0	6
ESE	0	0	2	0	0	0	2
SE	0	5	3	0	0	0	8
SSE	1	3	7	1	0	0	12
S	0	1	5	0	0	0	6
SSW	0	4	2	2	0	0	8
SW	0	4	0	0	0	0	4
WSW	0	4	5	0	0	0	9
W	0	5	4	0	0	0	9
WNW	1	2	6	0	0	0	9
NW	2	4	3	0	0	0	9
NNW	2	4	0	0	0	0	6
Variable	0	0	0	0	0	0	0
Total	12	48	42	3	0	0	105

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Slightly Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	3	1	0	0	0	0	4
NNE	0	3	0	0	0	0	3
NE	1	4	2	0	0	0	7
ENE	0	1	1	0	0	0	2
E	1	7	0	0	0	0	8
ESE	1	2	0	0	0	0	3
SE	0	4	0	0	0	0	4
SSE	0	3	3	1	0	0	7
S	0	4	4	1	0	0	9
SSW	1	3	5	0	0	0	9
SW	0	4	2	2	0	0	8
WSW	0	6	3	0	0	0	9
W	0	3	7	0	0	0	10
WNW	0	3	4	0	0	0	7
NW	0	5	0	0	0	0	5
NNW	0	1	1	0	0	0	2
Variable	0	0	0	0	0	0	0
Total	7	54	32	4	0	0	97

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0



Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Neutral - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	8	5	0	0	0	0	13
NNE	4	8	0	0	0	0	12
NE	4	38	3	0	0	0	45
ENE	3	23	7	0	0	0	33
E	5	17	2	0	0	0	24
ESE	2	14	8	0	0	0	24
SE	0	8	14	0	0	0	22
SSE	3	9	17	1	0	0	30
S	6	11	15	2	0	0	34
SSW	5	11	18	6	0	0	40
SW	5	15	18	0	0	0	38
WSW	10	23	12	0	0	0	45
W	3	22	21	5	0	0	51
WNW	3	18	14	0	0	0	35
NW	8	6	5	0	0	0	19
NNW	7	9	1	0	0	0	17
Variable	0	0	0	0	0	0	0
Total	76	237	155	14	0	0	482

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Slightly Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	19	10	1	0	0	0	30
NNE	20	14	1	0	0	0	35
NE	10	37	3	0	0	0	50
ENE	4	50	0	0	0	0	54
E	7	26	6	0	0	0	39
ESE	4	30	9	0	0	0	43
SE	2	29	18	0	0	0	49
SSE	9	29	14	0	0	0	52
S	14	35	21	4	0	0	74
SSW	11	34	16	0	0	0	61
SW	14	28	5	0	0	0	47
WSW	8	18	1	0	0	0	27
W	16	33	19	0	0	0	68
WNW	17	39	4	0	0	0	60
NW	18	16	3	0	0	0	37
NNW	27	18	1	0	0	0	46
Variable	0	0	0	0	0	0	0
<b>Total</b>	<b>200</b>	<b>446</b>	<b>122</b>	<b>4</b>	<b>0</b>	<b>0</b>	<b>772</b>

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: July - September 2003

Stability Class - Moderately Stable - 150Ft-35Ft Delta-T (F)

Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	8	1	0	0	0	0	9
NNE	7	1	0	0	0	0	8
NE	2	5	0	0	0	0	7
ENE	3	0	0	0	0	0	3
E	4	3	1	0	0	0	8
ESE	7	19	0	0	0	0	26
SE	8	16	4	0	0	0	28
SSE	25	16	0	0	0	0	41
S	15	11	0	0	0	0	26
SSW	14	13	2	0	0	0	29
SW	14	24	1	0	0	0	39
WSW	14	6	1	0	0	0	21
W	14	7	1	0	0	0	22
WNW	10	6	0	0	0	0	16
NW	15	5	1	0	0	0	21
NNW	15	1	0	0	0	0	16
Variable	0	0	0	0	0	0	0
Total	175	134	11	0	0	0	320

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Extremely Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	4	0	0	0	0	0	4
NNE	0	0	0	0	0	0	0
NE	1	0	0	0	0	0	1
ENE	2	0	0	0	0	0	2
E	3	0	0	0	0	0	3
ESE	1	4	1	0	0	0	6
SE	3	3	0	0	0	0	6
SSE	5	3	0	0	0	0	8
S	11	2	0	0	0	0	13
SSW	7	3	0	0	0	0	10
SW	12	11	0	0	0	0	23
WSW	11	0	0	0	0	0	11
W	3	0	0	0	0	0	3
WNW	3	1	0	1	0	0	5
NW	14	0	0	0	0	0	14
NNW	6	1	0	0	0	0	7
Variable	0	0	0	0	0	0	0
Total	86	28	1	1	0	0	116

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Extremely Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	5	3	0	0	8
NNE	0	0	3	3	0	0	6
NE	0	0	0	1	0	0	1
ENE	0	0	2	0	0	0	2
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	1	0	0	0	1
S	0	0	0	0	0	0	0
SSW	0	0	2	0	0	0	2
SW	0	0	1	1	0	0	2
WSW	0	0	0	3	0	0	3
W	0	0	0	1	0	0	1
WNW	0	0	2	1	3	0	6
NW	0	0	1	0	0	0	1
NNW	0	1	2	0	0	0	3
Variable	0	0	0	0	0	0	0
Total	0	1	19	13	3	0	36

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 4

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Moderately Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	6	3	1	0	0	10
NNE	0	2	3	2	0	0	7
NE	0	2	6	6	0	0	14
ENE	0	0	6	0	0	0	6
E	0	0	3	3	0	0	6
ESE	0	1	4	0	0	0	5
SE	0	4	3	0	0	0	7
SSE	0	0	2	1	2	0	5
S	0	0	1	1	0	0	2
SSW	0	1	3	5	0	0	9
SW	0	1	1	3	1	0	6
WSW	0	1	2	3	1	0	7
W	0	2	1	3	0	0	6
WNW	0	1	8	4	4	0	17
NW	0	0	1	1	0	0	2
NNW	0	5	1	1	0	0	7
Variable	0	0	0	0	0	0	0
Total	0	26	48	34	8	0	116

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 4

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Slightly Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	8	0	0	0	10
NNE	1	6	4	3	0	0	14
NE	0	1	3	4	0	0	8
ENE	0	5	8	0	0	0	13
E	1	4	9	1	0	0	15
ESE	0	5	2	0	0	0	7
SE	0	6	5	3	0	0	14
SSE	0	2	8	3	2	0	15
S	0	1	4	2	1	0	8
SSW	0	6	3	12	0	1	22
SW	0	2	3	4	1	1	11
WSW	0	3	5	7	0	0	15
W	0	0	6	4	1	0	11
WNW	0	4	8	5	1	0	18
NW	0	2	2	3	0	0	7
NNW	2	8	0	1	1	0	12
Variable	0	0	0	0	0	0	0
Total	4	57	78	52	7	2	200

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 4

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Neutral - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	8	10	5	1	0	26
NNE	1	8	19	14	0	0	42
NE	0	5	25	18	0	0	48
ENE	3	22	41	2	0	0	68
E	1	16	15	8	1	0	41
ESE	2	4	14	5	0	0	25
SE	4	12	11	9	0	0	36
SSE	1	9	16	14	1	0	41
S	5	10	11	25	1	1	53
SSW	6	8	14	16	5	0	49
SW	5	13	8	16	4	0	46
WSW	4	20	18	19	2	0	63
W	2	17	17	17	8	0	61
WNW	2	8	13	26	6	1	56
NW	2	8	7	8	3	1	29
NNW	2	7	4	3	0	0	16
Variable	0	0	0	0	0	0	0
Total	42	175	243	205	32	3	700

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 1  
 Hours of missing stability measurements in all stability classes: 4



Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Slightly Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	12	16	1	1	33
NNE	0	2	14	13	0	0	29
NE	3	6	23	11	0	0	43
ENE	2	17	32	0	0	0	51
E	1	8	13	8	2	0	32
ESE	0	4	11	12	6	0	33
SE	0	7	19	27	1	0	54
SSE	2	6	15	23	2	0	48
S	1	6	17	42	6	2	74
SSW	2	8	23	29	10	1	73
SW	1	6	14	25	2	0	48
WSW	0	10	11	15	0	0	36
W	3	12	15	26	9	0	65
WNW	0	7	11	29	4	0	51
NW	3	5	14	15	4	0	41
NNW	1	4	9	13	5	0	32
Variable	0	0	0	0	0	0	0
Total	19	111	253	304	52	4	743

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 4

Dresden Nuclear Station

Period of Record: July - September 2003

Stability Class - Moderately Stable - 300Ft-35Ft Delta-T (F)

Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	4	4	5	0	0	13
NNE	0	2	8	6	1	0	17
NE	1	1	2	5	0	0	9
ENE	0	6	4	0	0	0	10
E	1	3	0	2	0	0	6
ESE	1	9	3	3	2	0	18
SE	2	4	12	15	2	0	35
SSE	0	6	16	17	0	0	39
S	1	4	17	6	5	0	33
SSW	1	3	10	20	1	0	35
SW	6	10	11	11	4	0	42
WSW	1	6	8	10	0	0	25
W	2	4	9	7	0	1	23
WNW	3	6	6	6	0	0	21
NW	1	7	6	10	0	0	24
NNW	0	2	1	0	1	0	4
Variable	0	0	0	0	0	0	0
Total	20	77	117	123	16	1	354

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 1  
 Hours of missing stability measurements in all stability classes: 4

Dresden Nuclear Station

Period of Record: July - September 2003  
 Stability Class - Extremely Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	1	0	0	0	0	1
NNE	0	1	1	0	0	0	2
NE	0	3	3	1	0	0	7
ENE	0	1	0	0	0	0	1
E	0	1	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	1	0	2	0	0	3
SSE	0	1	2	2	0	0	5
S	0	0	0	4	0	0	4
SSW	0	0	1	1	1	0	3
SW	1	0	3	2	2	0	8
WSW	0	0	2	2	0	0	4
W	0	0	9	1	0	0	10
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	1	3	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	1	10	24	15	3	0	53

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 4

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Extremely Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	11	0	0	0	0	12
NNE	0	1	0	0	0	0	1
NE	0	4	4	0	0	0	8
ENE	1	6	0	0	0	0	7
E	0	4	2	0	0	0	6
ESE	0	4	1	0	0	0	5
SE	0	2	2	0	0	0	4
SSE	0	1	0	0	0	0	1
S	0	0	6	3	0	0	9
SSW	0	0	3	7	0	0	10
SW	0	0	7	2	2	0	11
WSW	0	3	11	3	1	0	18
W	0	4	7	6	0	0	17
WNW	0	3	28	3	0	0	34
NW	0	2	7	6	0	0	15
NNW	0	10	5	0	0	0	15
Variable	0	0	0	0	0	0	0
Total	2	55	83	30	3	0	173

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Moderately Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	0	0	0	0	2
NNE	0	0	0	0	0	0	0
NE	1	1	1	0	0	0	3
ENE	0	1	1	0	0	0	2
E	0	1	1	0	0	0	2
ESE	0	3	0	0	0	0	3
SE	1	2	2	0	0	0	5
SSE	0	0	2	0	0	0	2
S	0	0	4	3	1	0	8
SSW	0	0	2	1	1	0	4
SW	0	1	0	2	3	0	6
WSW	0	1	3	1	0	0	5
W	0	3	4	0	1	0	8
WNW	0	0	4	1	0	0	5
NW	0	1	5	1	0	0	7
NNW	0	3	1	0	0	0	4
Variable	0	0	0	0	0	0	0
Total	2	19	30	9	6	0	66

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Slightly Unstable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	2	0	0	0	0	3
NNE	0	0	1	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	2	0	0	0	0	2
E	0	0	1	0	0	0	1
ESE	0	2	2	0	0	0	4
SE	0	2	0	0	0	0	2
SSE	0	3	2	1	0	0	6
S	0	1	2	3	1	0	7
SSW	0	0	2	1	0	0	3
SW	0	0	1	3	0	0	4
WSW	0	1	1	0	0	0	2
W	0	5	5	1	1	0	12
WNW	0	4	3	0	0	0	7
NW	2	4	2	1	0	0	9
NNW	1	0	1	1	0	0	3
Variable	0	0	0	0	0	0	0
Total	4	26	23	11	2	0	66

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Neutral - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	12	2	0	0	0	15
NNE	4	5	4	3	0	0	16
NE	2	9	8	0	0	0	19
ENE	1	12	1	0	0	0	14
E	0	39	23	1	0	0	63
ESE	2	22	24	2	0	0	50
SE	2	9	14	5	0	0	30
SSE	4	17	30	20	1	0	72
S	1	13	34	24	12	0	84
SSW	1	10	32	26	4	0	73
SW	2	10	17	7	1	0	37
WSW	2	15	6	3	1	0	27
W	2	25	35	26	0	2	90
WNW	4	23	49	19	4	1	100
NW	7	26	57	18	0	0	108
NNW	5	25	15	9	0	0	54
Variable	0	0	0	0	0	0	0
Total	40	272	351	163	23	3	852

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Slightly Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	6	16	3	0	0	0	25
NNE	8	5	4	0	0	0	17
NE	12	14	0	0	0	0	26
ENE	6	13	0	0	0	0	19
E	5	34	11	0	0	0	50
ESE	6	34	16	0	0	0	56
SE	2	17	8	2	0	0	29
SSE	4	19	26	10	6	0	65
S	5	9	28	18	4	0	64
SSW	7	19	36	12	6	0	80
SW	3	19	16	5	0	0	43
WSW	7	14	11	5	0	0	37
W	11	31	5	1	0	0	48
WNW	16	36	29	12	0	0	93
NW	17	44	26	1	0	0	88
NNW	7	25	7	0	0	0	39
Variable	0	0	0	0	0	0	0
Total	122	349	226	66	16	0	779

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0



Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Moderately Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	2	1	0	0	0	0	3
NNE	1	0	0	0	0	0	1
NE	4	0	0	0	0	0	4
ENE	2	0	0	0	0	0	2
E	1	1	0	0	0	0	2
ESE	3	22	0	0	0	0	25
SE	5	16	3	0	0	0	24
SSE	7	4	0	0	0	0	11
S	8	5	0	0	0	0	13
SSW	4	4	0	0	0	0	8
SW	4	9	2	0	0	0	15
WSW	5	5	2	0	0	0	12
W	6	12	0	0	0	0	18
WNW	8	16	0	0	0	0	24
NW	7	1	0	0	0	0	8
NNW	11	3	0	0	0	0	14
Variable	0	0	0	0	0	0	0
Total	78	99	7	0	0	0	184

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Extremely Stable - 150Ft-35Ft Delta-T (F)  
 Winds Measured at 35 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	0	0	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	1	1	0	0	0	0	2
ESE	2	5	0	0	0	0	7
SE	2	0	0	0	0	0	2
SSE	0	0	0	0	0	0	0
S	4	0	0	0	0	0	4
SSW	9	1	0	0	0	0	10
SW	10	6	0	0	0	0	16
WSW	2	1	0	0	0	0	3
W	1	1	0	0	0	0	2
WNW	0	0	0	0	0	0	0
NW	3	1	0	0	0	0	4
NNW	6	0	0	0	0	0	6
Variable	0	0	0	0	0	0	0
Total	41	16	0	0	0	0	57

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 0

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Extremely Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	0	0	0	0
NNE	0	1	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	1
E	0	0	0	1	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	1	0	0	1
WSW	0	0	1	1	0	0	2
W	0	0	0	0	0	0	0
WNW	0	0	0	8	1	0	9
NW	0	0	0	0	1	1	2
NNW	0	0	0	0	0	0	0
Variable	0	0	0	0	0	0	0
Total	0	2	1	11	2	1	17

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 3

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Moderately Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	5	0	0	0	5
NNE	0	0	0	0	0	0	0
NE	0	3	0	2	0	0	5
ENE	0	2	0	0	0	0	2
E	0	0	2	0	0	0	2
ESE	0	0	3	0	0	0	3
SE	0	0	2	0	0	0	2
SSE	0	0	0	0	0	0	0
S	0	0	0	3	1	0	4
SSW	0	0	1	0	0	0	1
SW	0	0	1	1	0	1	3
WSW	0	0	0	3	2	0	5
W	0	0	3	2	1	0	6
WNW	0	1	3	9	1	1	15
NW	0	0	0	1	2	2	5
NNW	0	2	5	2	0	0	9
Variable	0	0	0	0	0	0	0
Total	0	8	25	23	7	4	67

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 3

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Slightly Unstable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	3	2	0	0	0	5
NNE	0	1	0	0	0	0	1
NE	0	1	0	2	0	0	3
ENE	0	1	0	0	0	0	1
E	0	0	2	0	0	0	2
ESE	0	1	3	0	0	0	4
SE	0	2	2	0	0	0	4
SSE	0	0	1	1	1	0	3
S	0	0	0	5	2	0	7
SSW	0	0	5	1	4	0	10
SW	0	0	4	0	0	1	5
WSW	0	0	3	4	0	2	9
W	0	0	1	2	2	2	7
WNW	0	0	4	8	0	0	12
NW	0	1	2	2	2	0	7
NNW	0	4	1	0	0	0	5
Variable	0	0	0	0	0	0	0
Total	0	14	30	25	11	5	85

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 1  
 Hours of missing stability measurements in all stability classes: 3

Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Neutral - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	8	8	3	2	0	21
NNE	1	4	4	2	4	3	18
NE	1	8	5	7	2	0	23
ENE	0	12	17	1	0	0	30
E	0	12	36	26	7	0	81
ESE	0	10	12	27	4	0	53
SE	2	12	11	6	10	2	43
SSE	1	6	23	39	26	6	101
S	0	4	12	30	23	21	90
SSW	1	4	18	20	31	11	85
SW	1	6	5	22	9	6	49
WSW	0	7	15	7	3	8	40
W	2	13	28	29	24	23	119
WNW	1	10	20	42	26	8	107
NW	3	14	27	57	37	5	143
NNW	1	11	24	17	10	3	66
Variable	0	0	0	0	0	0	0
Total	14	141	265	335	218	96	1069

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 3

Dresden Nuclear Station

Period of Record: October - December 2003

Stability Class - Slightly Stable - 300Ft-35Ft Delta-T (F)

Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	1	2	9	12	3	0	27
NNE	1	5	0	13	6	0	25
NE	0	2	11	2	0	0	15
ENE	2	8	12	0	0	0	22
E	0	6	9	8	0	0	23
ESE	2	4	11	15	7	0	39
SE	0	9	12	20	2	1	44
SSE	0	3	21	14	5	8	51
S	3	3	1	16	23	18	64
SSW	0	4	9	22	35	8	78
SW	1	8	9	25	10	1	54
WSW	1	7	11	14	10	0	43
W	0	5	21	19	4	1	50
WNW	1	6	13	24	25	9	78
NW	1	5	16	37	13	1	73
NNW	0	5	5	20	3	0	33
Variable	0	0	0	0	0	0	0
Total	13	82	170	261	146	47	719

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 2

Hours of missing stability measurements in all stability classes: 3

Dresden Nuclear Station

Period of Record: October - December 2003

Stability Class - Moderately Stable - 300Ft-35Ft Delta-T (F)

Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	2	2	7	3	0	14
NNE	0	1	2	1	0	0	4
NE	0	1	2	1	0	0	4
ENE	0	3	0	0	0	0	3
E	1	1	2	0	0	0	4
ESE	0	0	2	5	0	0	7
SE	0	0	1	13	1	0	15
SSE	0	0	10	15	1	0	26
S	0	1	3	6	4	0	14
SSW	0	1	2	2	2	0	7
SW	0	3	4	5	1	0	13
WSW	0	0	7	6	1	0	14
W	0	2	6	5	1	0	14
WNW	0	1	3	20	6	0	30
NW	0	0	1	7	0	0	8
NNW	0	1	3	3	1	0	8
Variable	0	0	0	0	0	0	0
Total	1	17	50	96	21	0	185

Hours of calm in this stability class: 0

Hours of missing wind measurements in this stability class: 0

Hours of missing stability measurements in all stability classes: 3



Dresden Nuclear Station

Period of Record: October - December 2003  
 Stability Class - Extremely Stable - 300Ft-35Ft Delta-T (F)  
 Winds Measured at 300 Feet

Wind Direction	Wind Speed (in mph)						Total
	1-3	4-7	8-12	13-18	19-24	> 24	
N	0	0	0	6	0	0	6
NNE	0	0	0	7	0	0	7
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	1	0	0	0	1
ESE	0	1	0	0	0	0	1
SE	0	0	0	1	1	0	2
SSE	0	0	1	1	0	0	2
S	0	0	0	1	0	0	1
SSW	0	0	1	2	2	0	5
SW	0	0	7	8	1	0	16
WSW	0	3	5	7	0	0	15
W	0	2	0	0	0	0	2
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	2	0	0	2
Variable	0	0	0	0	0	0	0
Total	0	6	15	35	4	0	60

Hours of calm in this stability class: 0  
 Hours of missing wind measurements in this stability class: 0  
 Hours of missing stability measurements in all stability classes: 3

DRESDEN

APPENDIX III

2003 REMP SAMPLE RESULTS

DRESDEN

TABLE OF CONTENTS

List of Tables .....III-3

1.0 INTRODUCTION .....III-4

2.0 LISTING OF MISSED SAMPLES .....III-5

3.0 LISTING OF SAMPLE ANOMALIES.....III-6

4.0 2003 ANALYSES DATA TABLES .....III-7

5.0 LAND USE CENSUS .....III-37

6.0 TLD DATA.....III-41

7.0 GRAPHS OF DATA TRENDS .....III-45

8.0 DREDGE SPOILS RESULTS .....III-55

DRESDEN

LIST OF TABLES

<u>No.</u>	<u>Title</u>	<u>Page</u>
1	Airborne Particulates and Iodine-131 .....	III-8
2	Airborne Particulates, Quarterly Composites .....	III-16
3	Milk .....	III-20
4	Fish, Edible Portions .....	III-23
5	Bottom Sediments .....	III-25
6	Vegetables .....	III-26
7	Surface Water .....	III-29
8	Well Water .....	III-36

# DRESDEN

## 1.0 INTRODUCTION

The following constitutes the 2003 Progress Report for the Radiological Environmental Monitoring Program conducted at the Dresden Nuclear Power Station, Morris, Illinois. Results of completed analyses are presented in the attached tables.

Data obtained in the program are well within the ranges previously encountered in the program and to be expected in the environmental media sampled.

For all gamma isotopic analyses, spectrum is computer scanned from 80 to 2048 keV. Specifically included are Mn-54, Fe-59, Co-58, Co-60, Zn-65, Zr-95, Nb-95, I-131, Ba-140, La-140, Cs-134 and Cs-137. Naturally occurring gamma-emitters, such as K-40 and Ra daughters, are frequently detected but not listed here. The data is reported in the format of  $x \pm 2s; 2TPU$ , where "x" is the significant result, "s" is the one standard deviation counting uncertainty, and TPU is the total propagated uncertainty at the one sigma confidence level.

Locations denoted by a "(C)" after site code refer to control locations.

All concentrations, except gross beta, are decay corrected to the time of collection.

TLD data is provided by Exelon Generation Company.

### Deviations from Scheduled Sampling and Corrective Actions Taken

All samples were collected within the scheduled period unless noted otherwise in the Listing of Missed Samples.

### Unusual Environmental Measurements

None for 2003.

---

Sample Type	Location Code	Collection Date	Comments
-------------	---------------	-----------------	----------

---

DRESDEN

2.0 LISTING OF MISSED SAMPLES

Sample Type	Location Code	Expected Collection Date	Reason
A/I	D-02	01-31-03	No AP sample; power outage. Charcoal runtime = 1 week plus 28.3 hours. Station Point of Contact notified.
A	D-02	02-07-03 to 12-26-03	No sample; no electricity. Unable to field check pump.
TLD	OTHER	03-07-03	TLD found missing during monthly visual check; placed Spare #D2031955 ARE.
A/I	D-07	10-10-03	No particulate sample due to blown fuse; runtime of 16.5 hours does not support viable air sample. Charcoal volume based on one week plus 16.5 hours.

DRESDEN

3.0 LISTING OF TABLE ANOMALIES

Sample Type	Location Code	Collection Date	Reason
A	D-04	03-21-03	Low reading of 164.6 hours possibly due to storms in area.
TLD	OTHER	05-02-03	Collector moved TLDs D-203-1 & 2 to new utility poles after road widening.
A/I	D-07	05-09-03	Low reading of 80.4 hours due to power outage. Station Point of Contact notified.
A	D-07	05-16-03	Low reading of 153.9 hours due to recent power restoration.
A	D-01	07-11-03	Low meter reading of 140.6 hours possibly due to storms in area.
A	D-03	07-11-03	Low meter reading of 120.0 hours possibly due to storms in area.
A	D-04	07-11-03	Low meter reading of 125.0 hours possibly due to storms in area.
A	D-07	07-18-03	Estimated timer reading; collector placed new timer.
A	D-07	07-25-03	No apparent reason for low timer reading of 160.8 hours.
A	D-07	10-10-03	No electricity due to blown fuse; collector replaced fuse.

DRESDEN

4.0 ANALYSES DATA TABLES



DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-01 Onsite Station 1							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	279	4.0 ± 0.5; 0.9	-0.3 ± 0.3; 0.3	07-04-03	289	2.6 ± 0.3; 0.6	-1.0 ± 0.4; 0.4
01-10-03	287	2.5 ± 0.4; 0.6	-	07-11-03	238 <sup>b</sup>	2.2 ± 0.3; 0.5	-
01-17-03	283	2.2 ± 0.3; 0.5	0.5 ± 0.3; 0.3	07-18-03	283	1.5 ± 0.3; 0.4	0.9 ± 0.3; 0.4
01-24-03	285	3.0 ± 0.4; 0.7	-	07-25-03	284	1.7 ± 0.3; 0.4	-
01-31-03	285	3.3 ± 0.4; 0.7	0.8 ± 0.5; 0.5	08-01-03	283	1.8 ± 0.3; 0.5	0.2 ± 0.3; 0.3
02-07-03	285	3.0 ± 0.4; 0.7	-	08-08-03	300	2.0 ± 0.3; 0.5	-
02-14-03	284	2.1 ± 0.4; 0.5	0.7 ± 0.4; 0.4	08-15-03	284	2.0 ± 0.3; 0.5	-0.5 ± 0.3; 0.3
02-21-03	283	1.5 ± 0.4; 0.5	-	08-22-03	275	3.1 ± 0.4; 0.7	-
02-28-03	284	2.9 ± 0.4; 0.7	0.1 ± 0.4; 0.4	08-29-03	284	3.9 ± 0.4; 0.8	0.4 ± 0.3; 0.4
03-07-03	288	3.2 ± 0.4; 0.7	-	09-05-03	285	1.6 ± 0.3; 0.4	-
03-14-03	284	3.8 ± 0.4; 0.8	-0.1 ± 0.4; 0.4	09-12-03	285	4.1 ± 0.4; 0.9	-0.0 ± 0.3; 0.3
03-21-03	284	2.3 ± 0.3; 0.5	-	09-19-03	283	3.1 ± 0.4; 0.7	-
03-28-03	283	1.8 ± 0.4; 0.5	-0.3 ± 0.3; 0.4	09-26-03	287	2.0 ± 0.4; 0.5	-0.1 ± 0.3; 0.3
1st Qtr. Mean±s.d.		2.7 ± 0.7	0.2 ± 0.5	3rd Qtr. Mean±s.d.		2.4 ± 0.9	-0.0 ± 0.6
04-04-03	298	1.7 ± 0.3; 0.5	-	10-03-03	291	1.5 ± 0.3; 0.4	-
04-11-03	275	1.6 ± 0.4; 0.5	-0.0 ± 0.3; 0.3	10-10-03	281	3.5 ± 0.4; 0.8	-0.3 ± 0.3; 0.3
04-18-03	283	2.5 ± 0.4; 0.6	-	10-17-03	282	2.4 ± 0.4; 0.6	-
04-25-03	283	1.6 ± 0.4; 0.5	0.0 ± 0.3; 0.3	10-24-03	284	3.2 ± 0.4; 0.7	1.2 ± 0.3; 0.4
05-02-03	285	2.1 ± 0.3; 0.5	-	10-31-03	287	2.0 ± 0.4; 0.5	-
05-09-03	287	1.0 ± 0.3; 0.3	0.2 ± 0.4; 0.4	11-07-03	285	2.5 ± 0.4; 0.6	0.7 ± 0.3; 0.3
05-16-03	282	1.6 ± 0.3; 0.4	-	11-14-03	287	2.6 ± 0.3; 0.6	-
05-23-03	287	1.2 ± 0.3; 0.3	0.6 ± 0.4; 0.4	11-21-03	284	2.2 ± 0.3; 0.5	0.5 ± 0.4; 0.4
05-30-03	280	1.7 ± 0.3; 0.4	-	11-28-03	284	2.4 ± 0.4; 0.6	-
06-06-03	291	2.0 ± 0.3; 0.5	0.1 ± 0.3; 0.3	12-05-03	285	2.6 ± 0.4; 0.6	0.1 ± 0.3; 0.3
06-12-03	244	1.2 ± 0.4; 0.4	-	12-12-03	285	2.2 ± 0.4; 0.5	-
06-20-03	336	1.8 ± 0.3; 0.4	0.3 ± 0.4; 0.4	12-19-03	284	2.7 ± 0.4; 0.6	0.3 ± 0.4; 0.4
06-27-03	275	1.9 ± 0.3; 0.5	-	12-26-03	285	3.0 ± 0.4; 0.7	-
2nd Qtr. Mean±s.d.		1.7 ± 0.4	0.2 ± 0.2	4th Qtr. Mean±s.d.		2.5 ± 0.5	0.4 ± 0.5

<sup>a</sup> Volume based on a two week collection period.

<sup>b</sup> Volume low; possibly due to storms in area.

DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-02 Onsite Station 2							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	286	3.8 ± 0.4 ; 0.8	-0.1 ± 0.5 ; 0.5	07-04-03	NS <sup>c</sup>	-	-
01-10-03	290	2.9 ± 0.4 ; 0.7	-	07-11-03	NS <sup>c</sup>	-	-
01-17-03	283	2.7 ± 0.4 ; 0.6	0.0 ± 0.4 ; 0.4	07-18-03	NS <sup>c</sup>	-	-
01-24-03	294	3.9 ± 0.4 ; 0.8	-	07-25-03	NS <sup>c</sup>	-	-
01-31-03	NS <sup>b</sup>	-	0.4 ± 0.7 ; 0.7	08-01-03	NS <sup>c</sup>	-	-
02-07-03	NS <sup>c</sup>	-	-	08-08-03	NS <sup>c</sup>	-	-
02-14-03	NS <sup>c</sup>	-	-	08-15-03	NS <sup>c</sup>	-	-
02-21-03	NS <sup>c</sup>	-	-	08-22-03	NS <sup>c</sup>	-	-
02-28-03	NS <sup>c</sup>	-	-	08-29-03	NS <sup>c</sup>	-	-
03-07-03	NS <sup>c</sup>	-	-	09-05-03	NS <sup>c</sup>	-	-
03-14-03	NS <sup>c</sup>	-	-	09-12-03	NS <sup>c</sup>	-	-
03-21-03	NS <sup>c</sup>	-	-	09-19-03	NS <sup>c</sup>	-	-
03-28-03	NS <sup>c</sup>	-	-	09-26-03	NS <sup>c</sup>	-	-
1st Qtr. Mean±s.d.		3.3 0.6	0.1± 0.2	3rd Qtr. Mean±s.d.			±
04-04-03	NS <sup>c</sup>	-	-	10-03-03	NS <sup>c</sup>	-	-
04-11-03	NS <sup>c</sup>	-	-	10-10-03	NS <sup>c</sup>	-	-
04-18-03	NS <sup>c</sup>	-	-	10-17-03	NS <sup>c</sup>	-	-
04-25-03	NS <sup>c</sup>	-	-	10-24-03	NS <sup>c</sup>	-	-
05-02-03	NS <sup>c</sup>	-	-	10-31-03	NS <sup>c</sup>	-	-
05-09-03	NS <sup>c</sup>	-	-	11-07-03	NS <sup>c</sup>	-	-
05-16-03	NS <sup>c</sup>	-	-	11-14-03	NS <sup>c</sup>	-	-
05-23-03	NS <sup>c</sup>	-	-	11-21-03	NS <sup>c</sup>	-	-
05-30-03	NS <sup>c</sup>	-	-	11-28-03	NS <sup>c</sup>	-	-
06-06-03	NS <sup>c</sup>	-	-	12-05-03	NS <sup>c</sup>	-	-
06-12-03	NS <sup>c</sup>	-	-	12-12-03	NS <sup>c</sup>	-	-
06-20-03	NS <sup>c</sup>	-	-	12-19-03	NS <sup>c</sup>	-	-
06-27-03	NS <sup>c</sup>	-	-	12-26-03	NS <sup>c</sup>	-	-
2nd Qtr. Mean±s.d.			±	4th Qtr. Mean±s.d.			±

<sup>a</sup> Volume based on a two week collection period.

<sup>b</sup> "NS" = No sample; electricity off; not enough run time (28.3 hrs.) for viable air filter sample; charcoal volume based on one week plus 28.3 hours.

<sup>c</sup> "NS" = No sample; electricity off.

DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-03 Onsite Station 3							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	281	4.3 ± 0.5 ; 0.9	0.2 ± 0.4 ; 0.4	07-04-03	288	2.8 ± 0.3 ; 0.6	0.4 ± 0.4 ; 0.4
01-10-03	286	2.9 ± 0.4 ; 0.7	-	07-11-03	203 <sup>b</sup>	0.9 ± 0.3 ; 0.3	-
01-17-03	284	2.3 ± 0.3 ; 0.5	0.0 ± 0.3 ; 0.3	07-18-03	284	1.1 ± 0.3 ; 0.4	0.5 ± 0.4 ; 0.4
01-24-03	286	3.3 ± 0.4 ; 0.7	-	07-25-03	285	1.8 ± 0.3 ; 0.4	-
01-31-03	286	3.9 ± 0.4 ; 0.8	0.9 ± 0.4 ; 0.4	08-01-03	283	2.5 ± 0.3 ; 0.6	0.8 ± 0.3 ; 0.3
02-07-03	285	3.7 ± 0.4 ; 0.8	-	08-08-03	300	2.2 ± 0.3 ; 0.5	-
02-14-03	284	2.2 ± 0.4 ; 0.6	0.5 ± 0.4 ; 0.4	08-15-03	284	2.4 ± 0.3 ; 0.5	0.0 ± 0.3 ; 0.3
02-21-03	283	1.5 ± 0.4 ; 0.5	-	08-22-03	274	3.7 ± 0.4 ; 0.8	-
02-28-03	284	2.8 ± 0.4 ; 0.7	0.2 ± 0.3 ; 0.3	08-29-03	284	3.9 ± 0.4 ; 0.8	0.0 ± 0.4 ; 0.4
03-07-03	283	2.8 ± 0.4 ; 0.6	-	09-05-03	285	1.6 ± 0.3 ; 0.5	-
03-14-03	286	3.3 ± 0.4 ; 0.7	0.1 ± 0.4 ; 0.4	09-12-03	285	4.9 ± 0.5 ; 1.0	-1.0 ± 0.3 ; 0.4
03-21-03	285	1.9 ± 0.3 ; 0.5	-	09-19-03	283	3.6 ± 0.4 ; 0.8	-
03-28-03	283	2.1 ± 0.4 ; 0.5	-0.1 ± 0.3 ; 0.3	09-26-03	287	2.5 ± 0.4 ; 0.6	1.0 ± 0.3 ; 0.4
1st Qtr. Mean±s.d.		2.9 ± 0.8	0.3 ± 0.3	3rd Qtr. Mean±s.d.		2.6 ± 1.2	0.3 ± 0.7
04-04-03	298	2.3 ± 0.4 ; 0.5	-	10-03-03	290	1.9 ± 0.3 ; 0.5	-
04-11-03	275	1.6 ± 0.4 ; 0.5	-0.2 ± 0.4 ; 0.4	10-10-03	282	4.1 ± 0.4 ; 0.9	0.4 ± 0.4 ; 0.4
04-18-03	283	2.7 ± 0.4 ; 0.6	-	10-17-03	282	2.4 ± 0.4 ; 0.6	-
04-25-03	283	1.7 ± 0.4 ; 0.5	0.4 ± 0.4 ; 0.4	10-24-03	284	3.6 ± 0.4 ; 0.8	0.3 ± 0.3 ; 0.3
05-02-03	285	1.9 ± 0.3 ; 0.4	-	10-31-03	282	2.2 ± 0.4 ; 0.5	-
05-09-03	287	1.4 ± 0.3 ; 0.4	0.2 ± 0.4 ; 0.4	11-07-03	290	2.9 ± 0.4 ; 0.7	0.3 ± 0.3 ; 0.3
05-16-03	282	1.8 ± 0.3 ; 0.5	-	11-14-03	286	3.2 ± 0.4 ; 0.7	-
05-23-03	286	1.4 ± 0.3 ; 0.4	0.0 ± 0.4 ; 0.4	11-21-03	280	2.3 ± 0.3 ; 0.5	-0.3 ± 0.4 ; 0.4
05-30-03	284	1.7 ± 0.3 ; 0.4	-	11-28-03	284	2.9 ± 0.4 ; 0.7	-
06-06-03	282	2.0 ± 0.3 ; 0.5	-0.2 ± 0.4 ; 0.4	12-05-03	285	2.5 ± 0.4 ; 0.6	0.8 ± 0.3 ; 0.4
06-12-03	246	1.1 ± 0.4 ; 0.4	-	12-12-03	285	2.8 ± 0.4 ; 0.6	-
06-20-03	336	1.8 ± 0.3 ; 0.4	-0.3 ± 0.3 ; 0.3	12-19-03	285	2.9 ± 0.4 ; 0.7	-0.6 ± 0.3 ; 0.3
06-27-03	272	2.2 ± 0.4 ; 0.5	-	12-26-03	285	3.6 ± 0.4 ; 0.8	-
2nd Qtr. Mean±s.d.		1.8 ± 0.4	-0.0 ± 0.3	4th Qtr. Mean±s.d.		2.9 ± 0.6	0.2 ± 0.5

<sup>a</sup> Volume based on a two week collection period.  
<sup>b</sup> Volume low; possibly due to storms in area.

DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-04 Collins Road							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	279	4.3 ± 0.5 ; 0.9	-0.4 ± 0.5 ; 0.5	07-04-03	289	2.8 ± 0.3 ; 0.6	-0.7 ± 0.4 ; 0.4
01-10-03	287	3.1 ± 0.4 ; 0.7	-	07-11-03	212 <sup>b</sup>	2.0 ± 0.4 ; 0.5	-
01-17-03	283	2.8 ± 0.4 ; 0.6	-0.1 ± 0.3 ; 0.3	07-18-03	282	1.7 ± 0.3 ; 0.5	-0.3 ± 0.4 ; 0.4
01-24-03	285	3.3 ± 0.4 ; 0.7	-	07-25-03	285	1.8 ± 0.3 ; 0.4	-
01-31-03	286	3.6 ± 0.4 ; 0.7	0.5 ± 0.4 ; 0.4	08-01-03	284	1.8 ± 0.3 ; 0.5	-0.1 ± 0.3 ; 0.3
02-07-03	285	3.0 ± 0.4 ; 0.6	-	08-08-03	300	2.1 ± 0.3 ; 0.5	-
02-14-03	284	2.5 ± 0.4 ; 0.6	0.2 ± 0.4 ; 0.4	08-15-03	275	2.0 ± 0.3 ; 0.5	0.1 ± 0.3 ; 0.3
02-21-03	279	1.6 ± 0.4 ; 0.5	-	08-22-03	274	3.7 ± 0.4 ; 0.8	-
02-28-03	284	3.4 ± 0.4 ; 0.7	0.3 ± 0.3 ; 0.3	08-29-03	294	3.9 ± 0.4 ; 0.8	0.0 ± 0.4 ; 0.4
03-07-03	285	3.6 ± 0.4 ; 0.8	-	09-05-03	285	1.5 ± 0.3 ; 0.4	-
03-14-03	288	4.0 ± 0.4 ; 0.8	-0.0 ± 0.3 ; 0.3	09-12-03	285	4.4 ± 0.5 ; 0.9	0.4 ± 0.3 ; 0.3
03-21-03	279 <sup>b</sup>	2.3 ± 0.3 ; 0.5	-	09-19-03	283	3.4 ± 0.4 ; 0.7	-
03-28-03	283	1.9 ± 0.4 ; 0.5	0.4 ± 0.4 ; 0.4	09-26-03	287	2.1 ± 0.4 ; 0.5	-0.5 ± 0.4 ; 0.4
1st Qtr. Mean±s.d.		3.0 ± 0.8	0.1 ± 0.3	3rd Qtr. Mean±s.d.		2.6 ± 1.0	-0.2 ± 0.4
04-04-03	298	1.9 ± 0.3 ; 0.5	-	10-03-03	291	1.3 ± 0.3 ; 0.4	-
04-11-03	275	2.0 ± 0.4 ; 0.5	0.1 ± 0.3 ; 0.3	10-10-03	280	3.9 ± 0.4 ; 0.8	0.4 ± 0.3 ; 0.3
04-18-03	283	2.5 ± 0.4 ; 0.6	-	10-17-03	282	2.9 ± 0.4 ; 0.6	-
04-25-03	283	2.1 ± 0.4 ; 0.5	-0.1 ± 0.3 ; 0.3	10-24-03	284	3.3 ± 0.4 ; 0.7	-0.1 ± 0.3 ; 0.3
05-02-03	285	2.3 ± 0.3 ; 0.5	-	10-31-03	287	2.2 ± 0.4 ; 0.5	-
05-09-03	287	1.6 ± 0.3 ; 0.4	0.0 ± 0.4 ; 0.4	11-07-03	290	2.2 ± 0.4 ; 0.5	0.3 ± 0.4 ; 0.4
05-16-03	282	2.2 ± 0.4 ; 0.5	-	11-14-03	287	2.8 ± 0.4 ; 0.6	-
05-23-03	286	1.6 ± 0.3 ; 0.4	-0.4 ± 0.4 ; 0.4	11-21-03	284	2.4 ± 0.3 ; 0.6	-0.1 ± 0.3 ; 0.3
05-30-03	281	1.8 ± 0.3 ; 0.5	-	11-28-03	284	2.7 ± 0.4 ; 0.6	-
06-06-03	287	2.1 ± 0.3 ; 0.5	0.1 ± 0.4 ; 0.4	12-05-03	285	2.4 ± 0.4 ; 0.6	0.4 ± 0.3 ; 0.3
06-12-03	245	1.3 ± 0.4 ; 0.4	-	12-12-03	285	2.5 ± 0.4 ; 0.6	-
06-20-03	336	1.8 ± 0.3 ; 0.4	-0.2 ± 0.3 ; 0.3	12-19-03	284	2.8 ± 0.4 ; 0.6	0.2 ± 0.4 ; 0.4
06-27-03	275	2.2 ± 0.4 ; 0.5	-	12-26-03	285	3.4 ± 0.4 ; 0.7	-
2nd Qtr. Mean±s.d.		1.9 ± 0.3	-0.1 ± 0.2	4th Qtr. Mean±s.d.		2.7 ± 0.6	0.2 ± 0.2

<sup>a</sup> Volume based on a two week collection period.

<sup>b</sup> Volume slightly low, lower timer reading of 164.6 hours possibly due to storms in area.

<sup>c</sup> Volume low; possibly due to storms in area.

DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-07 Clay Products							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	283	4.3 ± 0.5 ; 0.9	0.1 ± 0.3 ; 0.3	07-04-03	290	2.5 ± 0.3 ; 0.6	0.4 ± 0.3 ; 0.3
01-10-03	285	3.1 ± 0.4 ; 0.7	-	07-11-03	280	1.6 ± 0.3 ; 0.4	-
01-17-03	285	2.5 ± 0.3 ; 0.6	-0.5 ± 0.4 ; 0.4	07-18-03	285 <sup>d</sup>	1.8 ± 0.3 ; 0.5	0.6 ± 0.3 ; 0.4
01-24-03	284	3.1 ± 0.4 ; 0.7	-	07-25-03	273 <sup>e</sup>	2.3 ± 0.3 ; 0.5	-
01-31-03	285	3.6 ± 0.4 ; 0.8	0.6 ± 0.4 ; 0.5	08-01-03	285	2.0 ± 0.3 ; 0.5	-0.3 ± 0.3 ; 0.4
02-07-03	287	3.8 ± 0.4 ; 0.8	-	08-08-03	297	1.9 ± 0.3 ; 0.5	-
02-14-03	282	1.9 ± 0.4 ; 0.5	0.2 ± 0.3 ; 0.3	08-15-03	264	2.1 ± 0.3 ; 0.5	-0.7 ± 0.3 ; 0.4
02-21-03	285	1.5 ± 0.4 ; 0.5	-	08-22-03	271	3.5 ± 0.4 ; 0.8	-
02-28-03	284	2.8 ± 0.4 ; 0.7	0.6 ± 0.3 ; 0.3	08-29-03	284	3.8 ± 0.4 ; 0.8	0.7 ± 0.4 ; 0.4
03-07-03	286	2.8 ± 0.3 ; 0.6	-	09-05-03	288	1.4 ± 0.3 ; 0.4	-
03-14-03	285	3.8 ± 0.4 ; 0.8	0.3 ± 0.4 ; 0.4	09-12-03	282	3.8 ± 0.4 ; 0.8	-0.1 ± 0.3 ; 0.3
03-21-03	285	1.9 ± 0.3 ; 0.5	-	09-19-03	284	3.4 ± 0.4 ; 0.7	-
03-28-03	283	2.1 ± 0.4 ; 0.5	-0.2 ± 0.4 ; 0.4	09-26-03	285	2.4 ± 0.4 ; 0.6	0.3 ± 0.3 ; 0.3
1st Qtr. Mean±s.d.		2.9 ± 0.9	0.1 ± 0.4	3rd Qtr. Mean±s.d.		2.5 ± 0.8	0.1 ± 0.5
04-04-03	293	2.0 ± 0.4 ; 0.5	-	10-03-03	291	1.4 ± 0.3 ; 0.4	-
04-11-03	271	1.7 ± 0.4 ; 0.5	0.4 ± 0.3 ; 0.3	10-10-03	NS <sup>f</sup>	-	0.4 ± 0.6 ; 0.6
04-18-03	287	2.4 ± 0.4 ; 0.6	-	10-17-03	284	2.4 ± 0.4 ; 0.6	-
04-25-03	283	1.9 ± 0.4 ; 0.5	-0.3 ± 0.4 ; 0.4	10-24-03	284	3.1 ± 0.4 ; 0.7	0.2 ± 0.3 ; 0.3
05-02-03	287	2.2 ± 0.3 ; 0.5	-	10-31-03	282	2.2 ± 0.4 ; 0.5	-
05-09-03	136 <sup>b</sup>	1.9 ± 0.6 ; 0.7	-0.3 ± 0.5 ; 0.5	11-07-03	287	2.4 ± 0.4 ; 0.6	0.4 ± 0.3 ; 0.3
05-16-03	261 <sup>c</sup>	1.8 ± 0.4 ; 0.5	-	11-14-03	285	3.4 ± 0.4 ; 0.7	-
05-23-03	288	1.4 ± 0.3 ; 0.4	0.6 ± 0.4 ; 0.4	11-21-03	284	2.6 ± 0.4 ; 0.6	-0.2 ± 0.4 ; 0.4
05-30-03	283	1.4 ± 0.3 ; 0.4	-	11-28-03	283	3.0 ± 0.4 ; 0.7	-
06-06-03	288	2.0 ± 0.3 ; 0.5	0.1 ± 0.4 ; 0.4	12-05-03	286	2.5 ± 0.4 ; 0.6	-0.0 ± 0.4 ; 0.4
06-12-03	241	1.7 ± 0.4 ; 0.5	-	12-12-03	284	3.0 ± 0.4 ; 0.7	-
06-20-03	337	1.7 ± 0.3 ; 0.4	-0.1 ± 0.3 ; 0.3	12-19-03	287	3.4 ± 0.4 ; 0.7	-0.2 ± 0.3 ; 0.3
06-27-03	276	2.1 ± 0.4 ; 0.5	-	12-26-03	285	3.3 ± 0.4 ; 0.7	-
2nd Qtr. Mean±s.d.		1.9 ± 0.3	0.1 ± 0.4	4th Qtr. Mean±s.d.		2.7 ± 0.6	0.1 ± 0.3

<sup>a</sup> Volume based on a two week collection period.

<sup>b</sup> Volume low due to power outage.

<sup>c</sup> Volume low due to recent power restoration.

<sup>d</sup> Timer reading estimated; collector placed new timer.

<sup>e</sup> Volume low; no apparent reason for low timer reading of 160.8 hours.

<sup>f</sup> No particulate sample due to blown fuse; runtime (16.5 hrs.) does not support viable air particulate sample; charcoal volume = 320m<sup>3</sup> - 1 week + 16.5 hrs.

DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-12 (C) Lisbon							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	282	4.7 ± 0.5 ; 1.0	0.2 ± 0.4 ; 0.4	07-04-03	285	2.2 ± 0.3 ; 0.5	-0.7 ± 0.4 ; 0.4
01-10-03	285	2.7 ± 0.4 ; 0.6	-	07-11-03	273	3.8 ± 0.4 ; 0.8	-
01-17-03	285	2.9 ± 0.4 ; 0.6	-0.1 ± 0.3 ; 0.3	07-18-03	285	2.1 ± 0.3 ; 0.5	0.0 ± 0.3 ; 0.3
01-24-03	285	3.4 ± 0.4 ; 0.7	-	07-25-03	285	2.0 ± 0.3 ; 0.5	-
01-31-03	275	3.4 ± 0.4 ; 0.7	0.4 ± 0.4 ; 0.4	08-01-03	285	2.4 ± 0.3 ; 0.5	0.4 ± 0.3 ; 0.3
02-07-03	288	3.8 ± 0.4 ; 0.8	-	08-08-03	300	2.1 ± 0.3 ; 0.5	-
02-14-03	282	2.5 ± 0.4 ; 0.6	-0.5 ± 0.4 ; 0.4	08-15-03	275	2.1 ± 0.3 ; 0.5	0.0 ± 0.4 ; 0.4
02-21-03	285	2.1 ± 0.4 ; 0.5	-	08-22-03	271	3.9 ± 0.5 ; 0.8	-
02-28-03	285	3.5 ± 0.4 ; 0.8	0.1 ± 0.4 ; 0.4	08-29-03	284	4.0 ± 0.4 ; 0.8	-0.7 ± 0.4 ; 0.4
03-07-03	286	2.8 ± 0.3 ; 0.6	-	09-05-03	288	2.0 ± 0.4 ; 0.5	-
03-14-03	290	3.6 ± 0.4 ; 0.8	-0.1 ± 0.3 ; 0.3	09-12-03	282	5.0 ± 0.5 ; 1.0	0.5 ± 0.4 ; 0.4
03-21-03	285	2.3 ± 0.3 ; 0.5	-	09-19-03	285	3.4 ± 0.4 ; 0.7	-
03-28-03	279	2.3 ± 0.4 ; 0.6	0.0 ± 0.3 ; 0.3	09-26-03	285	2.6 ± 0.4 ; 0.6	-0.3 ± 0.4 ; 0.4
1st Qtr. Mean±s.d.		3.1 ± 0.7	0.0 ± 0.3	3rd Qtr. Mean±s.d.		2.9 ± 1.0	-0.1 ± 0.5
04-04-03	288	2.1 ± 0.4 ; 0.5	-	10-03-03	290	1.5 ± 0.3 ; 0.4	-
04-11-03	280	2.1 ± 0.4 ; 0.5	-0.0 ± 0.3 ; 0.3	10-10-03	281	4.2 ± 0.5 ; 0.9	-1.0 ± 0.4 ; 0.4
04-18-03	287	2.3 ± 0.4 ; 0.6	-	10-17-03	284	2.7 ± 0.4 ; 0.6	-
04-25-03	283	2.0 ± 0.4 ; 0.5	0.0 ± 0.4 ; 0.4	10-24-03	284	3.1 ± 0.4 ; 0.7	0.9 ± 0.3 ; 0.3
05-02-03	287	2.1 ± 0.3 ; 0.5	-	10-31-03	287	2.0 ± 0.4 ; 0.5	-
05-09-03	285	1.6 ± 0.3 ; 0.4	0.2 ± 0.4 ; 0.4	11-07-03	287	2.7 ± 0.4 ; 0.6	-0.8 ± 0.3 ; 0.4
05-16-03	283	2.3 ± 0.4 ; 0.6	-	11-14-03	285	3.2 ± 0.4 ; 0.7	-
05-23-03	287	1.5 ± 0.3 ; 0.4	0.0 ± 0.3 ; 0.3	11-21-03	286	2.4 ± 0.3 ; 0.6	0.0 ± 0.3 ; 0.3
05-30-03	278	2.1 ± 0.3 ; 0.5	-	11-28-03	283	3.1 ± 0.4 ; 0.7	-
06-06-03	286	2.2 ± 0.4 ; 0.5	-0.2 ± 0.4 ; 0.4	12-05-03	286	2.6 ± 0.4 ; 0.6	0.3 ± 0.3 ; 0.3
06-12-03	243	1.4 ± 0.4 ; 0.5	-	12-12-03	284	2.7 ± 0.4 ; 0.6	-
06-20-03	337	1.9 ± 0.3 ; 0.4	0.3 ± 0.4 ; 0.4	12-19-03	287	3.0 ± 0.4 ; 0.7	-0.0 ± 0.3 ; 0.3
06-27-03	273	2.1 ± 0.4 ; 0.5	-	12-26-03	285	3.8 ± 0.4 ; 0.8	-
2nd Qtr. Mean±s.d.		2.0 ± 0.3	0.1 ± 0.2	4th Qtr. Mean±s.d.		2.8 ± 0.7	-0.1 ± 0.7

<sup>a</sup> Volume based on a two week collection period.

DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-45 McKinley Woods Road							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	282	4.0 ± 0.5; 0.8	-0.1 ± 0.5; 0.5	07-04-03	284	2.5 ± 0.3; 0.6	0.1 ± 0.4; 0.4
01-10-03	285	2.8 ± 0.4; 0.6	-	07-11-03	285	1.8 ± 0.3; 0.4	-
01-17-03	285	2.0 ± 0.3; 0.5	-0.5 ± 0.4; 0.4	07-18-03	285	1.7 ± 0.3; 0.4	0.4 ± 0.3; 0.3
01-24-03	285	3.1 ± 0.4; 0.7	-	07-25-03	285	2.2 ± 0.3; 0.5	-
01-31-03	285	3.1 ± 0.4; 0.7	0.6 ± 0.4; 0.4	08-01-03	290	2.1 ± 0.3; 0.5	0.8 ± 0.3; 0.4
02-07-03	288	3.2 ± 0.4; 0.7	-	08-08-03	300	2.3 ± 0.3; 0.5	-
02-14-03	287	2.3 ± 0.4; 0.6	-0.3 ± 0.4; 0.4	08-15-03	285	1.7 ± 0.3; 0.4	-1.3 ± 0.3; 0.4
02-21-03	285	1.3 ± 0.4; 0.4	-	08-22-03	270	3.4 ± 0.4; 0.8	-
02-28-03	285	3.1 ± 0.4; 0.7	-0.7 ± 0.4; 0.4	08-29-03	275	3.8 ± 0.4; 0.8	0.8 ± 0.4; 0.4
03-07-03	286	3.3 ± 0.4; 0.7	-	09-05-03	285	1.7 ± 0.3; 0.5	-
03-14-03	284	3.1 ± 0.4; 0.7	-0.1 ± 0.4; 0.4	09-12-03	285	4.0 ± 0.4; 0.8	-0.6 ± 0.4; 0.4
03-21-03	285	2.3 ± 0.3; 0.5	-	09-19-03	290	3.4 ± 0.4; 0.7	-
03-28-03	279	1.9 ± 0.4; 0.5	0.3 ± 0.4; 0.4	09-26-03	280	2.2 ± 0.4; 0.5	0.0 ± 0.3; 0.3
1st Qtr. Mean±s.d.		2.7 ± 0.7	-0.1 ± 0.4	3rd Qtr. Mean±s.d.		2.5 ± 0.8	0.0 ± 0.8
04-04-03	289	1.9 ± 0.4; 0.5	-	10-03-03	288	1.6 ± 0.3; 0.4	-
04-11-03	285	1.5 ± 0.3; 0.4	-0.4 ± 0.3; 0.3	10-10-03	283	3.8 ± 0.4; 0.8	0.1 ± 0.3; 0.3
04-18-03	287	2.4 ± 0.4; 0.6	-	10-17-03	284	2.4 ± 0.4; 0.6	-
04-25-03	283	1.6 ± 0.4; 0.5	0.2 ± 0.4; 0.4	10-24-03	284	3.2 ± 0.4; 0.7	0.9 ± 0.3; 0.4
05-02-03	287	1.8 ± 0.3; 0.4	-	10-31-03	287	2.1 ± 0.4; 0.5	-
05-09-03	281	1.2 ± 0.3; 0.4	0.1 ± 0.4; 0.4	11-07-03	287	2.3 ± 0.4; 0.6	0.3 ± 0.4; 0.4
05-16-03	287	2.1 ± 0.3; 0.5	-	11-14-03	285	2.9 ± 0.4; 0.6	-
05-23-03	287	1.3 ± 0.3; 0.4	-0.5 ± 0.4; 0.4	11-21-03	285	2.3 ± 0.3; 0.5	-0.1 ± 0.3; 0.3
05-30-03	283	2.0 ± 0.3; 0.5	-	11-28-03	288	3.0 ± 0.4; 0.7	-
06-06-03	286	2.0 ± 0.3; 0.5	0.2 ± 0.3; 0.3	12-05-03	291	2.9 ± 0.4; 0.6	-0.6 ± 0.3; 0.3
06-12-03	243	1.5 ± 0.4; 0.5	-	12-12-03	289	2.6 ± 0.4; 0.6	-
06-20-03	338	1.8 ± 0.3; 0.4	0.1 ± 0.4; 0.4	12-19-03	291	3.0 ± 0.4; 0.7	0.3 ± 0.3; 0.3
06-27-03	273	1.9 ± 0.3; 0.5	-	12-26-03	285	3.8 ± 0.4; 0.8	-
2nd Qtr. Mean±s.d.		1.8 ± 0.3	-0.0 ± 0.3	4th Qtr. Mean±s.d.		2.8 ± 0.6	0.1 ± 0.5

<sup>a</sup> Volume based on a two week collection period.

DRESDEN

Table 1. Airborne Particulates and Iodine Cartridges  
 Collection: Airborne Particulates - Continuous; weekly exchange  
 Iodine cartridges - Continuous; biweekly exchange  
 Required LLD: Gross Beta = 0.01, I-131 = 0.07 pCi/m<sup>3</sup>  
 Units: 10<sup>-2</sup> pCi/m<sup>3</sup>

D-53 Grundy County Road							
Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>	Date Collected	Volume (m <sup>3</sup> )	Gross Beta	I-131 <sup>a</sup>
01-03-03	279	3.9 ± 0.5; 0.8	0.1 ± 0.4; 0.4	07-04-03	290	2.8 ± 0.3; 0.6	0.1 ± 0.4; 0.4
01-10-03	287	2.3 ± 0.4; 0.6	-	07-11-03	281	2.4 ± 0.3; 0.5	-
01-17-03	283	2.5 ± 0.3; 0.6	0.0 ± 0.4; 0.4	07-18-03	282	1.8 ± 0.3; 0.5	-0.5 ± 0.3; 0.3
01-24-03	285	3.1 ± 0.4; 0.7	-	07-25-03	285	1.9 ± 0.3; 0.4	-
01-31-03	286	3.3 ± 0.4; 0.7	0.2 ± 0.4; 0.4	08-01-03	284	2.2 ± 0.3; 0.5	0.2 ± 0.3; 0.3
02-07-03	285	3.4 ± 0.4; 0.7	-	08-08-03	300	2.5 ± 0.3; 0.6	-
02-14-03	284	2.0 ± 0.4; 0.5	0.1 ± 0.4; 0.4	08-15-03	294	2.2 ± 0.3; 0.5	-0.4 ± 0.3; 0.3
02-21-03	283	1.5 ± 0.4; 0.5	-	08-22-03	275	4.1 ± 0.5; 0.9	-
02-28-03	284	2.9 ± 0.4; 0.7	0.1 ± 0.3; 0.3	08-29-03	284	3.8 ± 0.4; 0.8	-1.0 ± 0.4; 0.4
03-07-03	292	3.0 ± 0.4; 0.7	-	09-05-03	280	0.8 ± 0.3; 0.3	-
03-14-03	281	4.1 ± 0.4; 0.9	0.1 ± 0.4; 0.4	09-12-03	284	2.0 ± 0.4; 0.5	-0.6 ± 0.3; 0.3
03-21-03	284	2.2 ± 0.3; 0.5	-	09-19-03	288	2.5 ± 0.4; 0.6	-
03-28-03	283	2.3 ± 0.4; 0.6	0.3 ± 0.3; 0.4	09-26-03	281	2.4 ± 0.4; 0.6	-0.4 ± 0.4; 0.4
1st Qtr. Mean±s.d.		2.8 ± 0.8	0.1 ± 0.1	3rd Qtr. Mean±s.d.		2.4 ± 0.8	-0.4 ± 0.4
04-04-03	298	2.0 ± 0.3; 0.5	-	10-03-03	292	1.6 ± 0.3; 0.4	-
04-11-03	276	1.8 ± 0.4; 0.5	-0.6 ± 0.4; 0.4	10-10-03	280	3.9 ± 0.4; 0.8	-0.1 ± 0.4; 0.4
04-18-03	282	2.8 ± 0.4; 0.6	-	10-17-03	282	2.4 ± 0.4; 0.6	-
04-25-03	283	1.6 ± 0.4; 0.5	0.0 ± 0.4; 0.4	10-24-03	284	3.4 ± 0.4; 0.7	-0.1 ± 0.4; 0.4
05-02-03	291	1.8 ± 0.3; 0.4	-	10-31-03	287	2.0 ± 0.4; 0.5	-
05-09-03	282	1.4 ± 0.3; 0.4	-0.2 ± 0.4; 0.4	11-07-03	285	2.5 ± 0.4; 0.6	0.4 ± 0.3; 0.3
05-16-03	283	1.8 ± 0.3; 0.5	-	11-14-03	286	3.4 ± 0.4; 0.7	-
05-23-03	286	1.4 ± 0.3; 0.4	-0.1 ± 0.4; 0.4	11-21-03	284	2.5 ± 0.4; 0.6	0.9 ± 0.3; 0.4
05-30-03	278	1.8 ± 0.3; 0.5	-	11-28-03	284	2.9 ± 0.4; 0.6	-
06-06-03	296	2.1 ± 0.3; 0.5	0.1 ± 0.3; 0.3	12-05-03	285	2.5 ± 0.4; 0.6	0.9 ± 0.3; 0.3
06-12-03	249	1.7 ± 0.4; 0.5	-	12-12-03	285	3.0 ± 0.4; 0.7	-
06-20-03	334	1.8 ± 0.3; 0.4	0.1 ± 0.4; 0.4	12-19-03	284	3.1 ± 0.4; 0.7	-0.1 ± 0.3; 0.3
06-27-03	275	2.6 ± 0.4; 0.6	-	12-26-03	285	3.2 ± 0.4; 0.7	-
2nd Qtr. Mean±s.d.		1.9 ± 0.4	-0.1 ± 0.3	4th Qtr. Mean±s.d.		2.8 ± 0.6	0.3 ± 0.5

<sup>a</sup> Volume based on a two week collection period.



DRESDEN

Table 2. Airborne Particulates

Collection: Quarterly composites of weekly collections  
 ODCM-  
 Required LLDs: Cs-134 = 0.05, Cs-137 = 0.06 pCi/m<sup>3</sup>  
 Other LLDs: Mn-54 = 0.01; Fe-59 = 0.015; Co-58, Co-60 = 0.01; Zn-65 = 0.04; Zr/Nb-95 = 0.01;  
 Ba/La-140 = 0.025 pCi/m<sup>3</sup>  
 Units: 10<sup>-4</sup> pCi/m<sup>3</sup>

Sample Description and Concentration

D-01 Onsite Station 1

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2123	CDAP-4161	CDAP-6466	CDAP-8023
Volume	3,703	3,715	3,666	3,712
Mn-54	-1.5 ± 5.3 ; 5.3	-0.9 ± 5.4 ; 5.4	-7.3 ± 6.9 ; 7.0	4.2 ± 4.5 ; 4.6
Fe-59	-7.8 ± 8.6 ; 8.7	-6.5 ± 6.8 ; 6.9	5.6 ± 7.1 ; 7.1	-7.7 ± 8.6 ; 8.7
Co-58	-2.2 ± 4.7 ; 4.8	-1.3 ± 4.3 ; 4.3	3.5 ± 4.6 ; 4.6	1.0 ± 4.7 ; 4.7
Co-60	-1.5 ± 5.4 ; 5.4	-0.6 ± 5.6 ; 5.6	-1.3 ± 6.9 ; 6.9	3.7 ± 5.4 ; 5.4
Zn-65	1.6 ± 9.6 ; 9.6	14.3 ± 8.6 ; 8.9	-4.8 ± 12.0 ; 12.0	-8.0 ± 14.3 ; 14.3
Nb/Zr-95	-5.7 ± 6.0 ; 6.1	1.0 ± 5.4 ; 5.4	-1.6 ± 6.4 ; 6.4	-3.1 ± 4.9 ; 5.0
Cs-134	2.9 ± 5.2 ; 5.2	2.7 ± 6.3 ; 6.3	3.6 ± 5.4 ; 5.5	4.8 ± 5.6 ; 5.7
Cs-137	1.7 ± 5.3 ; 5.3	-6.2 ± 5.9 ; 6.0	6.3 ± 4.8 ; 4.9	-1.9 ± 6.6 ; 6.7
Ba/La-140	-24.3 ± 6.6 ; 7.9	25.5 ± 6.9 ; 8.2	22.1 ± 3.7 ; 5.4	-9.5 ± 7.3 ; 7.4

D-02 Onsite Station 2

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2124	NS *	NS *	NS *
Volume	1,156			
Mn-54	-1.8 ± 10.8 ; 10.8	-	-	-
Fe-59	39.7 ± 11.1 ; 13.2	-	-	-
Co-58	-1.7 ± 8.7 ; 8.7	-	-	-
Co-60	-6.2 ± 12.3 ; 12.3	-	-	-
Zn-65	20.0 ± 19.5 ; 19.8	-	-	-
Nb/Zr-95	-15.6 ± 8.9 ; 9.3	-	-	-
Cs-134	4.2 ± 10.5 ; 10.6	-	-	-
Cs-137	5.1 ± 10.5 ; 10.6	-	-	-
Ba/La-140	-793.6 ± 12.0 ; 141.8	-	-	-

\* "NS" = No sample; power out.

DRESDEN

Table 2. Airborne Particulates

Collection: Quarterly composites of weekly collections  
 ODCM-  
 Required LLDs: Cs-134 = 0.05, Cs-137 = 0.06 pCi/m<sup>3</sup>  
 Other LLDs: Mn-54 = 0.01; Fe-59 = 0.015; Co-58, Co-60 = 0.01; Zn-65 = 0.04; Zr/Nb-95 = 0.01;  
 Ba/La-140 = 0.025 pCi/m<sup>3</sup>  
 Units: 10<sup>-4</sup> pCi/m<sup>3</sup>

Sample Description and Concentration

D-03 Onsite Station 3

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2125	CDAP-4162	CDAP-6467	CDAP-8024
Volume	3,703	3,706	3,633	3,707
Mn-54	2.4 ± 6.5 ; 6.5	1.8 ± 4.0 ; 4.0	-0.6 ± 5.0 ; 5.0	2.7 ± 6.0 ; 6.1
Fe-59	-3.3 ± 9.4 ; 9.4	-11.9 ± 7.9 ; 8.2	3.4 ± 6.6 ; 6.7	8.8 ± 9.5 ; 9.7
Co-58	-2.3 ± 5.2 ; 5.2	-2.3 ± 5.2 ; 5.2	2.5 ± 5.6 ; 5.6	5.8 ± 4.9 ; 5.0
Co-60	6.4 ± 7.4 ; 7.5	0.1 ± 4.2 ; 4.2	3.6 ± 3.5 ; 3.6	5.3 ± 4.2 ; 4.3
Zn-65	-3.2 ± 8.2 ; 8.2	7.1 ± 8.8 ; 8.9	-6.5 ± 11.8 ; 11.8	-13.6 ± 11.5 ; 11.8
Nb/Zr-95	7.5 ± 5.5 ; 5.6	-8.7 ± 6.0 ; 6.2	-16.4 ± 5.1 ; 5.8	-8.7 ± 5.6 ; 5.8
Cs-134	-5.4 ± 6.4 ; 6.4	12.2 ± 5.9 ; 6.3	1.6 ± 5.0 ; 5.0	-3.3 ± 6.3 ; 6.3
Cs-137	-5.9 ± 6.8 ; 6.9	2.0 ± 6.2 ; 6.2	-0.7 ± 6.3 ; 6.3	-1.1 ± 5.2 ; 5.2
Ba/La-140	36.9 ± 4.8 ; 8.1	5.6 ± 5.8 ; 5.9	67.1 ± 6.6 ; 13.6	27.4 ± 6.9 ; 8.4

D-04 Collins Road

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2126	CDAP-4163	CDAP-6468	CDAP-8025
Volume	3,695	3,711	3,641	3,717
Mn-54	2.1 ± 6.0 ; 6.0	-0.9 ± 5.4 ; 5.4	0.3 ± 6.8 ; 6.8	6.0 ± 4.9 ; 5.0
Fe-59	1.1 ± 10.1 ; 10.1	2.2 ± 8.5 ; 8.5	1.1 ± 10.3 ; 10.3	-16.8 ± 13.2 ; 13.6
Co-58	-0.6 ± 5.0 ; 5.0	3.5 ± 4.0 ; 4.0	-9.6 ± 4.7 ; 5.0	0.9 ± 5.2 ; 5.2
Co-60	-9.0 ± 7.3 ; 7.4	-4.8 ± 5.8 ; 5.9	7.3 ± 6.5 ; 6.6	2.6 ± 3.0 ; 3.0
Zn-65	-4.8 ± 11.9 ; 11.9	4.0 ± 13.6 ; 13.6	3.3 ± 10.2 ; 10.2	-3.2 ± 12.2 ; 12.2
Nb/Zr-95	3.3 ± 5.2 ; 5.2	-5.5 ± 6.0 ; 6.0	-2.8 ± 4.0 ; 4.0	6.3 ± 5.8 ; 5.9
Cs-134	-6.3 ± 7.3 ; 7.4	4.3 ± 4.8 ; 4.9	1.3 ± 6.7 ; 6.7	0.1 ± 5.8 ; 5.8
Cs-137	5.6 ± 5.1 ; 5.2	-7.0 ± 6.8 ; 7.0	4.6 ± 5.0 ; 5.0	2.2 ± 5.3 ; 5.4
Ba/La-140	-24.7 ± 6.6 ; 7.9	-7.8 ± 4.9 ; 5.1	5.0 ± 8.0 ; 8.1	91.8 ± 7.2 ; 17.9

DRESDEN

Table 2. Airborne Particulates

Collection: Quarterly composites of weekly collections  
 ODCM-  
 Required LLDs: Cs-134 = 0.05, Cs-137 = 0.06 pCi/m<sup>3</sup>  
 Other LLDs: Mn-54 = 0.01; Fe-59 = 0.015; Co-58, Co-60 = 0.01; Zn-65 = 0.04; Zr/Nb-95 = 0.01;  
 Ba/La-140 = 0.025 pCi/m<sup>3</sup>  
 Units: 10<sup>-4</sup> pCi/m<sup>3</sup>

Sample Description and Concentration

D-07 Clay Products

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2127	CDAP-4164	CDAP-6469	CDAP-8026
Volume	3,708	3,537	3,673	3,430
Mn-54	-2.4 ± 6.7 ; 6.7	1.9 ± 5.6 ; 5.6	-3.7 ± 5.5 ; 5.5	-9.5 ± 6.7 ; 6.9
Fe-59	-15.6 ± 12.2 ; 12.5	-12.5 ± 11.8 ; 12.0	-3.4 ± 9.5 ; 9.5	3.6 ± 7.0 ; 7.1
Co-58	3.6 ± 4.0 ; 4.0	5.4 ± 3.8 ; 3.9	3.2 ± 5.6 ; 5.6	2.9 ± 4.8 ; 4.8
Co-60	3.8 ± 6.8 ; 6.9	3.8 ± 5.7 ; 5.7	-0.6 ± 5.7 ; 5.7	2.2 ± 6.9 ; 6.9
Zn-65	-2.4 ± 10.6 ; 10.6	2.5 ± 12.3 ; 12.3	6.4 ± 10.8 ; 10.9	3.5 ± 14.6 ; 14.6
Nb/Zr-95	0.3 ± 4.3 ; 4.3	-7.3 ± 5.6 ; 5.8	9.1 ± 4.3 ; 4.6	-3.8 ± 6.2 ; 6.3
Cs-134	-2.9 ± 7.3 ; 7.3	2.8 ± 6.6 ; 6.6	-4.1 ± 6.7 ; 6.8	-0.6 ± 6.2 ; 6.2
Cs-137	3.8 ± 5.6 ; 5.7	3.7 ± 7.1 ; 7.2	2.3 ± 5.0 ; 5.0	-5.1 ± 7.1 ; 7.2
Ba/La-140	7.4 ± 2.2 ; 2.5	35.2 ± 5.0 ; 8.0	-24.7 ± 6.6 ; 8.0	-44.4 ± 6.2 ; 10.1

D-12 (C) Lisbon

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2128,9	CDAP-4165	CDAP-6470	CDAP-8027
Volume	3,699	3,704	3,690	3,716
Mn-54	3.8 ± 3.9 ; 3.9	0.6 ± 6.2 ; 6.2	8.5 ± 5.3 ; 5.6	0.9 ± 5.7 ; 5.7
Fe-59	-2.8 ± 7.3 ; 7.3	5.4 ± 10.7 ; 10.8	5.6 ± 10.8 ; 10.8	-11.2 ± 9.9 ; 10.1
Co-58	-1.6 ± 3.9 ; 4.0	-7.0 ± 5.0 ; 5.2	-1.4 ± 4.9 ; 4.9	-6.6 ± 5.9 ; 6.1
Co-60	2.1 ± 4.5 ; 4.5	-2.2 ± 6.6 ; 6.6	7.2 ± 6.4 ; 6.5	-3.9 ± 6.1 ; 6.1
Zn-65	-4.4 ± 7.8 ; 7.9	19.1 ± 11.0 ; 11.5	4.0 ± 7.9 ; 7.9	-6.4 ± 11.5 ; 11.6
Nb/Zr-95	-11.8 ± 4.0 ; 4.5	2.5 ± 4.1 ; 4.1	5.4 ± 5.4 ; 5.5	4.4 ± 5.2 ; 5.3
Cs-134	-0.2 ± 4.1 ; 4.1	-3.9 ± 5.6 ; 5.6	-1.1 ± 5.0 ; 5.0	-1.1 ± 4.9 ; 4.9
Cs-137	0.1 ± 4.4 ; 4.4	1.6 ± 5.7 ; 5.7	-3.8 ± 5.1 ; 5.2	3.8 ± 5.6 ; 5.7
Ba/La-140	-21.9 ± 5.5 ; 6.7	-23.6 ± 8.5 ; 9.5	-63.0 ± 7.0 ; 13.2	38.5 ± 4.7 ; 8.3

DRESDEN

Table 2. Airborne Particulates

Collection: Quarterly composites of weekly collections  
 ODCM-  
 Required LLDs: Cs-134 = 0.05, Cs-137 = 0.06 pCi/m<sup>3</sup>  
 Other LLDs: Mn-54 = 0.01; Fe-59 = 0.015; Co-58, Co-60 = 0.01; Zn-65 = 0.04; Zr/Nb-95 = 0.01;  
 Ba/La-140 = 0.025 pCi/m<sup>3</sup>  
 Units: 10<sup>-4</sup> pCi/m<sup>3</sup>

Sample Description and Concentration

D-45 McKinley Woods Road

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2130	CDAP-4166	CDAP-6471	CDAP-8028
Volume	3,707	3,715	3,706	3,734
Mn-54	-12.4 ± 6.4 ; 6.8	-2.1 ± 5.2 ; 5.2	0.3 ± 5.6 ; 5.6	-0.3 ± 4.2 ; 4.2
Fe-59	4.5 ± 12.0 ; 12.0	7.6 ± 7.4 ; 7.6	-20.0 ± 11.6 ; 12.1	-5.6 ± 9.0 ; 9.0
Co-58	6.6 ± 5.0 ; 5.2	-0.3 ± 3.2 ; 3.2	6.8 ± 4.0 ; 4.1	-3.2 ± 5.5 ; 5.6
Co-60	6.1 ± 4.5 ; 4.6	1.0 ± 4.5 ; 4.5	1.9 ± 4.8 ; 4.9	2.2 ± 7.6 ; 7.6
Zn-65	-12.8 ± 13.4 ; 13.6	0.8 ± 6.8 ; 6.8	4.8 ± 10.4 ; 10.4	-1.6 ± 12.5 ; 12.5
Nb/Zr-95	-12.2 ± 5.8 ; 6.2	9.2 ± 5.7 ; 5.9	-5.4 ± 5.2 ; 5.3	-7.9 ± 5.7 ; 5.9
Cs-134	3.2 ± 6.9 ; 7.0	-4.1 ± 6.6 ; 6.7	5.0 ± 5.0 ; 5.1	2.6 ± 6.8 ; 6.8
Cs-137	2.7 ± 5.5 ; 5.5	-1.0 ± 4.7 ; 4.7	-0.5 ± 5.3 ; 5.3	-0.4 ± 4.8 ; 4.8
Ba/La-140	-65.9 ± 10.3 ; 15.6	5.6 ± 5.8 ; 5.9	21.0 ± 6.5 ; 7.5	15.4 ± 3.0 ; 4.1

D-53 Grundy County Road

2003 Collection Period	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Lab Code	CDAP-2131	CDAP-4167	CDAP-6472	CDAP-8029
Volume	3,704	3,720	3,714	3,712
Mn-54	-5.1 ± 5.7 ; 5.8	-0.3 ± 5.5 ; 5.5	3.3 ± 5.0 ; 5.1	9.4 ± 5.0 ; 5.3
Fe-59	-15.6 ± 12.2 ; 12.5	18.5 ± 9.3 ; 9.9	-1.1 ± 9.7 ; 9.7	-12.4 ± 11.3 ; 11.5
Co-58	-2.1 ± 4.2 ; 4.2	-0.5 ± 4.4 ; 4.4	-8.1 ± 5.7 ; 5.9	-5.6 ± 5.2 ; 5.3
Co-60	1.3 ± 7.4 ; 7.4	2.9 ± 6.6 ; 6.6	-2.2 ± 6.6 ; 6.6	8.0 ± 6.7 ; 6.8
Zn-65	-3.2 ± 12.3 ; 12.3	12.7 ± 8.1 ; 8.4	-12.8 ± 13.4 ; 13.6	-12.0 ± 14.9 ; 15.1
Nb/Zr-95	2.3 ± 5.0 ; 5.1	-16.2 ± 6.1 ; 6.7	-9.0 ± 6.0 ; 6.2	0.9 ± 5.8 ; 5.8
Cs-134	0.9 ± 5.4 ; 5.4	-2.6 ± 5.8 ; 5.9	0.6 ± 6.5 ; 6.5	0.1 ± 5.8 ; 5.8
Cs-137	-1.6 ± 5.1 ; 5.1	-1.1 ± 5.6 ; 5.6	-7.7 ± 5.2 ; 5.4	1.2 ± 7.1 ; 7.2
Ba/La-140	-32.5 ± 6.2 ; 8.5	-16.0 ± 6.9 ; 7.5	-32.1 ± 6.2 ; 8.4	-9.1 ± 4.9 ; 5.1

DRESDEN

Table 3. Milk

Collection: Biweekly (May - October)  
 Monthly (November - April)

ODCM-Required LLDs: I-131 = 1, Cs-134 = 15; Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L

Other LLDs: Mn-54 = 10; Fe-59 = 15; Co-58, Co-60 = 10; Zn-65 = 15; Zr/Nb-95 = 10 pCi/L

Units: pCi/L

Sample Description and Concentration

D-25 (C) Vince Biros Farm

Date Collected	01-02-03	02-06-03	03-06-03	04-03-03
Lab Code	CDMI-30	CDMI-538	CDMI-967	CDMI-1514
I-131	-0.10 ± 0.21 ; 0.21	-0.03 ± 0.16 ; 0.16	0.04 ± 0.17 ; 0.17	-0.10 ± 0.19 ; 0.19
Mn-54	0.1 ± 2.9 ; 2.9	-3.0 ± 4.2 ; 4.3	0.8 ± 2.4 ; 2.4	0.6 ± 1.8 ; 1.8
Fe-59	-3.6 ± 6.1 ; 6.2	-1.3 ± 9.3 ; 9.3	-2.5 ± 5.3 ; 5.3	-0.4 ± 4.3 ; 4.3
Co-58	1.0 ± 3.1 ; 3.1	0.5 ± 4.6 ; 4.6	2.9 ± 2.6 ; 2.6	0.5 ± 2.0 ; 2.0
Co-60	2.0 ± 3.1 ; 3.1	3.1 ± 4.3 ; 4.3	1.1 ± 2.4 ; 2.4	1.2 ± 2.3 ; 2.3
Zn-65	-1.9 ± 6.5 ; 6.5	1.6 ± 10.5 ; 10.5	2.4 ± 5.1 ; 5.1	0.4 ± 5.6 ; 5.6
Zr/Nb-95	1.6 ± 2.4 ; 2.4	4.4 ± 3.9 ; 4.0	-0.2 ± 2.5 ; 2.5	0.7 ± 1.9 ; 1.9
Cs-134	1.2 ± 3.2 ; 3.2	-4.2 ± 5.1 ; 5.1	1.2 ± 2.9 ; 2.9	0.1 ± 2.1 ; 2.1
Cs-137	3.7 ± 3.1 ; 3.1	-1.5 ± 4.2 ; 4.2	-3.1 ± 2.9 ; 2.9	-0.8 ± 2.1 ; 2.1
Ba-140	1.9 ± 9.0 ; 9.0	-10.0 ± 13.7 ; 13.8	11.3 ± 8.8 ; 9.0	-7.9 ± 7.3 ; 7.4
La-140	-4.6 ± 3.8 ; 3.9	2.6 ± 3.6 ; 3.6	-1.0 ± 2.0 ; 2.0	-1.5 ± 2.0 ; 2.0
Date Collected	05-01-03	05-15-03	05-29-03	06-11-03
Lab Code	CDMI-2178	CDMI-2622,3	CDMI-2830	CDMI-3187
I-131	0.00 ± 0.16 ; 0.16	0.11 ± 0.14 ; 0.14	0.08 ± 0.18 ; 0.18	0.10 ± 0.19 ; 0.19
Mn-54	1.5 ± 3.5 ; 3.5	0.7 ± 2.3 ; 2.3	-1.0 ± 3.9 ; 3.9	2.1 ± 2.3 ; 2.3
Fe-59	0.5 ± 7.1 ; 7.1	0.0 ± 4.6 ; 4.6	0.6 ± 7.4 ; 7.4	1.9 ± 3.7 ; 3.7
Co-58	1.7 ± 3.4 ; 3.4	2.7 ± 2.2 ; 2.2	-1.4 ± 3.9 ; 3.9	-0.4 ± 2.0 ; 2.0
Co-60	0.4 ± 3.5 ; 3.5	1.5 ± 3.1 ; 3.1	-0.4 ± 3.7 ; 3.7	0.2 ± 2.3 ; 2.3
Zn-65	3.1 ± 8.9 ; 8.9	0.2 ± 5.1 ; 5.1	-1.0 ± 10.0 ; 10.0	-2.4 ± 5.7 ; 5.7
Nb/Zr-95	1.5 ± 3.7 ; 3.7	0.1 ± 1.9 ; 1.9	0.1 ± 3.9 ; 3.9	0.3 ± 2.1 ; 2.1
Cs-134	-0.1 ± 4.1 ; 4.1	0.7 ± 2.2 ; 2.2	2.6 ± 4.0 ; 4.1	1.5 ± 2.4 ; 2.4
Cs-137	3.2 ± 3.9 ; 3.9	1.7 ± 2.2 ; 2.2	3.3 ± 3.8 ; 3.8	0.2 ± 2.3 ; 2.3
Ba-140	-8.7 ± 12.0 ; 12.1	-9.1 ± 7.6 ; 7.7	-0.8 ± 11.0 ; 11.0	3.2 ± 7.2 ; 7.2
La-140	-6.2 ± 4.3 ; 4.4	-2.5 ± 2.1 ; 2.1	0.8 ± 4.7 ; 4.7	0.7 ± 2.5 ; 2.5

## DRESDEN

Table 3.	Milk	
Collection:	Biweekly (May - October)	
	Monthly (November - April)	
ODCM- Required LLDs:	I-131 = 1, Cs-134 = 15; Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L	
Other LLDs:	Mn-54 = 10; Fe-59 = 15; Co-58, Co-60 = 10; Zn-65 = 15; Zr/Nb-95 = 10 pCi/L	
Units:	pCi/L	

## Sample Description and Concentration

D-25 (C) Vince Biros Farm

Date Collected	06-26-03	07-10-03	07-24-03	08-06-03
Lab Code	CDMI-3452	CDMI-3815	CDMI-4178	CDMI-4569
I-131	-0.08 ± 0.15 ; 0.15	0.04 ± 0.22 ; 0.22	-0.01 ± 0.16 ; 0.16	-0.06 ± 0.21 ; 0.21
Mn-54	-0.7 ± 2.1 ; 2.1	2.5 ± 2.2 ; 2.2	-0.6 ± 4.1 ; 4.1	-0.2 ± 1.7 ; 1.7
Fe-59	-4.7 ± 5.1 ; 5.2	-1.1 ± 5.1 ; 5.1	3.8 ± 9.3 ; 9.3	-0.4 ± 5.1 ; 5.1
Co-58	-2.2 ± 1.9 ; 2.0	-1.4 ± 2.1 ; 2.1	-1.9 ± 3.7 ; 3.7	-0.4 ± 2.0 ; 2.0
Co-60	-0.5 ± 1.8 ; 1.8	1.3 ± 2.3 ; 2.3	-0.2 ± 5.0 ; 5.0	1.6 ± 2.3 ; 2.3
Zn-65	1.8 ± 5.5 ; 5.5	-5.7 ± 6.2 ; 6.3	4.1 ± 8.3 ; 8.3	4.0 ± 5.2 ; 5.3
Nb/Zr-95	-2.0 ± 1.8 ; 1.8	-3.0 ± 2.3 ; 2.4	-0.3 ± 3.5 ; 3.5	-1.5 ± 2.2 ; 2.2
Cs-134	2.1 ± 2.4 ; 2.4	0.9 ± 2.8 ; 2.8	-4.6 ± 5.2 ; 5.2	0.4 ± 2.3 ; 2.3
Cs-137	-1.9 ± 2.7 ; 2.7	-0.4 ± 2.1 ; 2.1	-1.4 ± 4.0 ; 4.0	1.1 ± 2.2 ; 2.2
Ba-140	-2.3 ± 7.2 ; 7.2	-2.8 ± 7.4 ; 7.4	0.2 ± 11.6 ; 11.6	-0.1 ± 7.8 ; 7.8
La-140	-3.2 ± 2.4 ; 2.5	0.9 ± 1.9 ; 1.9	-2.3 ± 3.7 ; 3.7	-3.5 ± 2.3 ; 2.3
Date Collected	08-21-03	09-04-03	09-18-03	10-02-03
Lab Code	CDMI-4789	CDMI-5044	CDMI-5346	CDMI-5655
I-131	0.05 ± 0.20 ; 0.20	0.00 ± 0.13 ; 0.13	0.03 ± 0.15 ; 0.15	-0.00 ± 0.17 ; 0.17
Mn-54	-3.1 ± 3.4 ; 3.4	-0.1 ± 2.8 ; 2.8	-0.9 ± 2.2 ; 2.2	-0.6 ± 1.9 ; 1.9
Fe-59	-4.3 ± 6.7 ; 6.8	-11.6 ± 6.3 ; 6.5	-4.1 ± 4.8 ; 4.8	2.7 ± 3.8 ; 3.8
Co-58	-1.4 ± 3.3 ; 3.3	-1.0 ± 2.9 ; 2.9	-0.1 ± 2.1 ; 2.1	0.2 ± 1.8 ; 1.8
Co-60	-0.2 ± 4.4 ; 4.4	2.0 ± 3.5 ; 3.5	1.0 ± 2.5 ; 2.5	-2.5 ± 2.3 ; 2.3
Zn-65	-0.7 ± 8.3 ; 8.3	-5.1 ± 7.4 ; 7.5	-4.7 ± 6.8 ; 6.9	4.0 ± 5.9 ; 5.9
Zr/Nb-95	3.6 ± 3.2 ; 3.2	-0.0 ± 2.7 ; 2.7	0.9 ± 2.1 ; 2.1	1.2 ± 1.9 ; 2.0
Cs-134	2.5 ± 3.5 ; 3.6	-0.8 ± 3.4 ; 3.4	-0.9 ± 2.5 ; 2.5	-0.7 ± 2.4 ; 2.4
Cs-137	1.4 ± 3.6 ; 3.6	0.8 ± 2.8 ; 2.8	0.1 ± 2.2 ; 2.2	-1.8 ± 2.2 ; 2.3
Ba-140	14.4 ± 10.0 ; 10.2	0.1 ± 9.8 ; 9.8	5.8 ± 8.1 ; 8.1	2.0 ± 7.1 ; 7.1
La-140	2.2 ± 4.0 ; 4.1	-2.8 ± 3.0 ; 3.1	1.8 ± 1.9 ; 1.9	-0.2 ± 1.6 ; 1.6

## DRESDEN

Table 3.	Milk	
	Collection:	Biweekly (May - October) Monthly (November - April)
	ODCM- Required LLDs:	I-131 = 1, Cs-134 = 15; Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L
	Other LLDs:	Mn-54 = 10; Fe-59 = 15; Co-58, Co-60 = 10; Zn-65 = 15; Zr/Nb-95 = 10 pCi/L
	Units:	pCi/L

## Sample Description and Concentration

D-25 (C) Vince Biros Farm

Date Collected	10-16-03	10-30-03	11-13-03	12-04-03
Lab Code	CDMI-6127	CDMI-6532	CDMI-6887	CDMI-7260
I-131	0.16 ± 0.16 ; 0.16	-0.10 ± 0.22 ; 0.22	0.18 ± 0.22 ; 0.22	-0.04 ± 0.16 ; 0.16
Mn-54	-1.7 ± 3.2 ; 3.2	-2.6 ± 3.5 ; 3.5	-1.8 ± 2.5 ; 2.5	-0.4 ± 3.7 ; 3.7
Fe-59	-1.9 ± 7.4 ; 7.5	1.3 ± 7.3 ; 7.3	0.4 ± 5.0 ; 5.0	-7.0 ± 7.7 ; 7.8
Co-58	-2.1 ± 3.0 ; 3.0	0.6 ± 3.1 ; 3.1	0.8 ± 2.3 ; 2.3	-1.7 ± 2.6 ; 2.6
Co-60	1.4 ± 3.5 ; 3.5	1.3 ± 4.2 ; 4.2	1.6 ± 1.5 ; 1.5	3.1 ± 4.9 ; 5.0
Zn-65	0.7 ± 8.5 ; 8.5	1.0 ± 9.0 ; 9.0	1.5 ± 6.0 ; 6.0	-7.2 ± 7.6 ; 7.7
Zr-Nb-95	-0.9 ± 3.2 ; 3.2	-0.3 ± 3.2 ; 3.2	-0.6 ± 2.2 ; 2.2	1.3 ± 3.6 ; 3.6
Cs-134	-1.4 ± 3.4 ; 3.4	-2.5 ± 4.0 ; 4.0	-0.3 ± 2.3 ; 2.3	4.2 ± 3.0 ; 3.0
Cs-137	1.4 ± 3.4 ; 3.4	-0.7 ± 3.4 ; 3.4	0.4 ± 2.2 ; 2.2	1.7 ± 3.8 ; 3.8
Ba-140	4.1 ± 9.1 ; 9.2	-2.5 ± 11.6 ; 11.6	-5.6 ± 7.9 ; 8.0	2.1 ± 12.7 ; 12.7
La-140	-1.5 ± 4.1 ; 4.1	2.3 ± 2.8 ; 2.9	-0.5 ± 2.5 ; 2.5	3.9 ± 3.7 ; 3.7

## DRESDEN

Table 4. Fish, Edible Portions

Collection: Semiannually

Required LLDs: Mn = 0.13; Fe -59 = 0.26; Co-58,60 = 0.13; Zn-65 = 0.26; Cs-134 = 0.13;  
Cs-137 = 0.15 pCi/g wet weightUnits:  $10^{-3}$  pCi/g wet weight

## Sample Description and Concentration

D-28 Dresden Pool of Illinois River

Date Collected	05-07-03	05-07-03	10-07-03	10-07-03
Lab Code	CDF-2357	CDF-2358	CDF-5808	CDF-5809
Type	Freshwater Drum	Largemouth Bass	Largemouth Bass	Channel Catfish
Mn-54	0.1 ± 0.7 ; 0.7	0.2 ± 0.5 ; 0.5	0.3 ± 0.9 ; 0.9	-0.2 ± 0.9 ; 0.9
Fe-59	1.3 ± 1.7 ; 1.7	-0.3 ± 1.4 ; 1.4	0.2 ± 1.8 ; 1.8	-0.6 ± 2.2 ; 2.2
Co-58	0.3 ± 0.8 ; 0.8	-0.3 ± 0.5 ; 0.5	0.3 ± 0.8 ; 0.8	-0.2 ± 0.8 ; 0.8
Co-60	-0.2 ± 0.8 ; 0.8	0.4 ± 0.6 ; 0.6	0.3 ± 1.0 ; 1.0	-1.0 ± 1.5 ; 1.5
Zn-65	-1.7 ± 1.6 ; 1.6	-1.1 ± 1.5 ; 1.5	-0.4 ± 2.2 ; 2.2	-0.4 ± 2.4 ; 2.4
Nb/Zr-95	-0.4 ± 0.5 ; 0.5	-0.1 ± 0.6 ; 0.6	-0.3 ± 0.7 ; 0.7	0.7 ± 0.8 ; 0.8
Cs-134	0.4 ± 0.6 ; 0.6	-0.1 ± 0.7 ; 0.7	0.5 ± 0.8 ; 0.8	0.4 ± 0.9 ; 0.9
Cs-137	0.1 ± 0.9 ; 0.9	0.2 ± 0.6 ; 0.6	0.6 ± 0.9 ; 0.9	-0.2 ± 0.9 ; 0.9
Ba/La-140	-0.5 ± 1.0 ; 1.0	0.0 ± 0.3 ; 0.3	-0.3 ± 0.9 ; 0.9	-2.8 ± 1.1 ; 1.2



DRESDEN

Table 4. Fish, Edible Portions

Collection: Semiannually

Required LLDs: Mn = 0.13; Fe -59 = 0.26; Co-58,60 = 0.13; Zn-65 = 0.26; Cs-134 = 0.13;  
Cs-137 = 0.15 pCi/g wet weight

Units:  $10^{-2}$  pCi/g wet weight

Sample Description and Concentration

D-46 (C) Des Plaines River, Upstream

Date Collected	05-07-03	05-07-03	10-07-03	10-07-03
Lab Code	CDF-2355	CDF-2356	CDF-5806	CDF-5807
Type	Channel Catfish	Largemouth Bass	Largemouth Bass	Common Carp
Mn-54	-0.2 ± 0.7 ; 0.7	-0.0 ± 1.2 ; 1.2	0.2 ± 0.9 ; 0.9	0.6 ± 0.8 ; 0.8
Fe-59	-0.5 ± 2.0 ; 2.0	0.1 ± 2.8 ; 2.8	0.3 ± 2.1 ; 2.1	0.4 ± 2.0 ; 2.0
Co-58	-0.6 ± 0.7 ; 0.7	0.8 ± 0.8 ; 0.8	0.4 ± 0.7 ; 0.7	-0.2 ± 0.7 ; 0.7
Co-60	0.2 ± 0.9 ; 0.9	0.7 ± 1.7 ; 1.7	0.7 ± 1.0 ; 1.0	-0.6 ± 1.2 ; 1.2
Zn-65	-0.4 ± 2.0 ; 2.0	-1.1 ± 2.8 ; 2.8	-0.9 ± 2.2 ; 2.2	-0.3 ± 2.1 ; 2.1
Nb/Zr-95	0.2 ± 0.7 ; 0.7	0.5 ± 1.0 ; 1.0	0.5 ± 0.8 ; 0.8	-0.4 ± 0.7 ; 0.7
Cs-134	0.1 ± 0.7 ; 0.7	0.4 ± 1.3 ; 1.3	0.0 ± 1.0 ; 1.0	0.1 ± 0.9 ; 0.9
Cs-137	0.2 ± 0.9 ; 0.9	-0.6 ± 1.2 ; 1.2	-0.4 ± 0.8 ; 0.8	0.2 ± 1.0 ; 1.0
Ba/La-140	0.1 ± 0.8 ; 0.8	0.7 ± 1.3 ; 1.3	0.7 ± 0.9 ; 0.9	1.6 ± 0.7 ; 0.7

DRESDEN

Table 5. Bottom Sediments

Collection: Semiannually  
 ODCM-  
 Required LLDs: Cs-134 = 0.15, Cs-137 = 0.18 pCi/g dry weight  
 Other LLDs: Mn-54 = 0.15; Fe-59 = 0.60; Co-58, Co-60 = 0.10; Zn-65 = 0.60; Zr/Nb-95 = 0.20;  
 Ba/La = 0.60 g dry weight  
 Units:  $10^{-2}$  pCi/g dry weight

Sample Description and Concentration

D-27 Dresden Lock & Dam

Date Collected	05-16-03	10-03-03
Lab Code	CDBS-2615	CDBS-5700
Mn-54	0.3 ± 1.5 ; 1.5	0.9 ± 1.6 ; 1.6
Fe-59	-1.3 ± 2.9 ; 2.9	-11.3 ± 3.7 ; 4.0
Co-58	0.4 ± 1.3 ; 1.3	2.1 ± 1.3 ; 1.4
Co-60	1.3 ± 1.5 ; 1.5	-0.1 ± 1.8 ; 1.8
Zn-65	-2.0 ± 3.4 ; 3.4	-4.4 ± 4.5 ; 4.5
Nb/Zr-95	-1.2 ± 1.5 ; 1.5	-14.6 ± 2.2 ; 2.9
Cs-134	1.1 ± 1.5 ; 1.5	3.7 ± 2.3 ; 2.3
Cs-137	3.2 ± 1.7 ; 1.8	44.3 ± 4.8 ; 7.7
Ba/La-140	-0.9 ± 1.4 ; 1.4	-70.7 ± 1.6 ; 9.8

## DRESDEN

Table 6.	Vegetation	
	Collection:	Annually
	ODCM-	
	Required LLDs:	I-131=0.06, Cs-134=0.06, Cs-137=0.08 pCi/g wet weight
	Other LLDs:	Mn-54 = 0.05; Fe-59 = 0.10; Co-58, Co-60, Zn-65 = 0.05; Zr/Nb-95 = 0.01; Ba/La-140 = 0.02 pCi/g wet weight
	Units:	10 <sup>-2</sup> pCi/g wet weight

## Sample Description and Concentration

D-Control Glasscock Farm

Date Collected	09-06-03	09-06-03
Lab Code	CDVE-5130	CDVE-5131
Type	Lettuce	Onions
Mn-54	0.1 ± 0.6 ; 0.6	-0.3 ± 0.5 ; 0.5
Fe-59	-0.9 ± 1.6 ; 1.6	-0.8 ± 1.5 ; 1.5
Co-58	-0.0 ± 0.6 ; 0.6	0.3 ± 0.7 ; 0.7
Co-60	-0.5 ± 0.9 ; 0.9	-0.1 ± 1.0 ; 1.0
Zn-65	-1.6 ± 1.6 ; 1.6	0.5 ± 1.8 ; 1.8
Nb/Zr-95	-0.2 ± 0.7 ; 0.7	-0.2 ± 0.6 ; 0.6
I-131	0.9 ± 0.6 ; 0.6	0.0 ± 0.5 ; 0.5
Cs-134	0.3 ± 0.8 ; 0.8	-0.9 ± 0.8 ; 0.9
Cs-137	1.0 ± 0.9 ; 0.9	-0.2 ± 0.7 ; 0.7
Ba/La-140	-0.2 ± 0.6 ; 0.6	0.4 ± 0.7 ; 0.7

D-Quad 1 Chris Locknar

Date Collected	09-06-03	09-06-03
Lab Code	CDVE-5122	CDVE-5248
Type	Potates	Cabbage
Mn-54	0.4 ± 0.5 ; 0.5	0.3 ± 0.6 ; 0.6
Fe-59	0.3 ± 1.2 ; 1.2	-1.7 ± 1.3 ; 1.4
Co-58	0.4 ± 0.4 ; 0.4	0.1 ± 0.7 ; 0.7
Co-60	0.2 ± 0.7 ; 0.7	0.8 ± 0.7 ; 0.7
Zn-65	0.7 ± 1.5 ; 1.5	0.1 ± 1.9 ; 1.9
Nb/Zr-95	0.1 ± 0.4 ; 0.4	-0.6 ± 0.7 ; 0.7
I-131	-0.2 ± 0.5 ; 0.5	-0.8 ± 0.5 ; 0.6
Cs-134	0.2 ± 0.6 ; 0.6	0.2 ± 0.6 ; 0.6
Cs-137	0.2 ± 0.5 ; 0.5	0.3 ± 0.6 ; 0.6
Ba/La-140	0.1 ± 0.5 ; 0.5	-0.1 ± 0.8 ; 0.8

DRESDEN

Table 6. Vegetation  
 Collection: Annually  
 ODCM-  
 Required LLDs: I-131=0.06, Cs-134=0.06, Cs-137=0.08 pCi/g wet weight  
 Other LLDs: Mn-54 = 0.05; Fe-59 = 0.10; Co-58, Co-60, Zn-65 = 0.05; Zr/Nb-95 = 0.01;  
 Ba/La-140 = 0.02 pCi/g wet weight  
 Units: 10<sup>-3</sup> pCi/g wet weight

Sample Description and Concentration

D-Quad 2 Robert Pagliano

Date Collected	09-05-03	09-05-03
Lab Code	CDVE-5123	CDVE-5124
Type	Carrots	Carrots tops
Mn-54	-0.4 ± 0.6 ; 0.6	-0.5 ± 0.8 ; 0.8
Fe-59	-0.6 ± 1.4 ; 1.4	-0.4 ± 2.0 ; 2.0
Co-58	0.2 ± 0.5 ; 0.5	0.2 ± 0.8 ; 0.8
Co-60	0.0 ± 0.6 ; 0.6	0.4 ± 0.9 ; 0.9
Zn-65	-0.2 ± 1.6 ; 1.6	-0.2 ± 2.2 ; 2.2
Nb/Zr-95	0.2 ± 0.6 ; 0.6	-0.9 ± 0.7 ; 0.7
I-131	0.4 ± 0.5 ; 0.5	0.2 ± 0.9 ; 0.9
Cs-134	-0.6 ± 0.6 ; 0.6	0.2 ± 0.9 ; 0.9
Cs-137	-0.1 ± 0.6 ; 0.6	1.2 ± 0.9 ; 0.9
Ba/La-140	0.1 ± 0.7 ; 0.7	-0.1 ± 0.8 ; 0.8
Date Collected	09-05-03	
Lab Code	CDVE-5125	
Type	Greens	
Mn-54	0.2 ± 1.2 ; 1.2	
Fe-59	-3.8 ± 2.7 ; 2.8	
Co-58	0.6 ± 1.2 ; 1.2	
Co-60	0.3 ± 0.6 ; 0.6	
Zn-65	1.9 ± 2.5 ; 2.6	
Nb/Zr-95	0.4 ± 1.0 ; 1.0	
I-131	-1.0 ± 1.1 ; 1.2	
Cs-134	-0.7 ± 1.3 ; 1.3	
Cs-137	0.3 ± 1.1 ; 1.1	
Ba/La-140	-0.3 ± 1.3 ; 1.3	

DRESDEN

Table 6. Vegetation

Collection: Annually  
 ODCM-  
 Required LLDs: I-131=0.06, Cs-134=0.06, Cs-137=0.08 pCi/g wet weight  
 Other LLDs: Mn-54 = 0.05; Fe-59 = 0.10; Co-58, Co-60, Zn-65 = 0.05; Zr/Nb-95 = 0.01;  
 Ba/La-140 = 0.02 pCi/g wet weight  
 Units:  $10^{-2}$  pCi/g wet weight

Sample Description and Concentration

D-Quad 3 Jim Bloom

Date Collected	09-06-03	09-06-03
Lab Code	CDVE-5126	CDVE-5127
Type	Cabbage	Onions
Mn-54	0.1 ± 0.9 ; 0.9	0.1 ± 0.5 ; 0.5
Fe-59	-0.1 ± 1.9 ; 1.9	0.4 ± 1.1 ; 1.1
Co-58	0.2 ± 0.8 ; 0.8	0.5 ± 0.4 ; 0.4
Co-60	-0.3 ± 1.1 ; 1.1	-0.6 ± 0.6 ; 0.7
Zn-65	0.2 ± 1.9 ; 1.9	-0.9 ± 1.2 ; 1.3
Nb/Zr-95	0.2 ± 0.7 ; 0.7	0.0 ± 0.5 ; 0.5
I-131	-1.1 ± 0.8 ; 0.8	-0.7 ± 0.5 ; 0.6
Cs-134	-0.5 ± 0.9 ; 0.9	0.7 ± 0.6 ; 0.6
Cs-137	-0.2 ± 0.7 ; 0.7	0.1 ± 0.6 ; 0.6
Ba/La-140	-0.7 ± 0.6 ; 0.6	-0.9 ± 0.7 ; 0.7

D-Quad 4 J.D. Carmichael

Date Collected	09-06-03	09-06-03
Lab Code	CDVE-5128	CDVE-5129
Type	Beet tops	Beets
Mn-54	0.5 ± 0.9 ; 0.9	0.3 ± 0.6 ; 0.6
Fe-59	-1.2 ± 1.8 ; 1.8	0.6 ± 1.0 ; 1.0
Co-58	-0.1 ± 0.7 ; 0.7	-0.3 ± 0.5 ; 0.5
Co-60	-1.1 ± 1.0 ; 1.0	-0.0 ± 0.6 ; 0.6
Zn-65	-0.2 ± 2.1 ; 2.1	1.1 ± 1.3 ; 1.3
Nb/Zr-95	-0.3 ± 0.8 ; 0.8	0.3 ± 0.6 ; 0.6
I-131	-0.2 ± 0.7 ; 0.7	0.2 ± 0.6 ; 0.6
Cs-134	-0.2 ± 1.0 ; 1.0	-0.0 ± 0.7 ; 0.7
Cs-137	1.1 ± 1.1 ; 1.1	-0.3 ± 0.7 ; 0.7
Ba/La-140	0.4 ± 0.7 ; 0.7	-0.9 ± 0.8 ; 0.8

DRESDEN

Table 7. Surface Water

Collection: Monthly composites of weekly collections

ODCM- Gross Beta = 4, Mn-54 = 15, Fe-59 = 30, Co-58 = 15, Co-60 = 15, Zn-65 = 30, Zr-95 = 30,  
 Required LLDs: Nb-95 = 15, Cs-134 = 15, Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L

Units: pCi/L

Sample Description and Concentration			
<u>D-51 Dresden Lock &amp; Dam</u>			
2003 Collection Period	January	February	March
Lab Code	CDSW-505	CDSW-987	CDSW-1482
Gross Beta	6.2 ± 1.4 ; 1.7	6.0 ± 1.2 ; 1.5	6.9 ± 1.5 ; 1.8
Mn-54	-2.1 ± 3.2 ; 3.2	0.9 ± 3.3 ; 3.3	-0.9 ± 1.8 ; 1.8
Fe-59	4.1 ± 5.2 ; 5.3	3.4 ± 4.7 ; 4.7	1.2 ± 3.2 ; 3.2
Co-58	1.5 ± 2.8 ; 2.9	4.8 ± 3.8 ; 3.9	1.1 ± 1.6 ; 1.6
Co-60	-1.9 ± 2.4 ; 2.4	-0.9 ± 3.8 ; 3.8	0.2 ± 1.6 ; 1.6
Zn-65	1.2 ± 5.7 ; 5.7	-5.6 ± 8.0 ; 8.1	-1.0 ± 3.8 ; 3.8
Zr-95	-2.6 ± 5.4 ; 5.4	5.5 ± 8.0 ; 8.0	-3.7 ± 4.0 ; 4.0
Nb-95	-1.1 ± 3.0 ; 3.0	-0.8 ± 3.5 ; 3.5	0.8 ± 1.7 ; 1.7
Cs-134	1.7 ± 2.8 ; 2.8	-0.8 ± 3.9 ; 3.9	1.0 ± 2.1 ; 2.1
Cs-137	1.1 ± 3.4 ; 3.4	-3.4 ± 3.8 ; 3.9	0.9 ± 1.9 ; 1.9
Ba-140	6.9 ± 9.7 ; 9.8	7.9 ± 11.7 ; 11.8	-4.6 ± 6.3 ; 6.3
La-140	-2.2 ± 4.0 ; 4.0	-4.1 ± 3.4 ; 3.4	-1.7 ± 1.8 ; 1.8
2003 Collection Period	April	May	June
Lab Code	CDSW-2495	CDSW-3030	CDSW-3513
Gross Beta	5.7 ± 1.2 ; 1.4	4.0 ± 1.0 ; 1.2	5.9 ± 1.1 ; 1.4
Mn-54	-0.2 ± 2.3 ; 2.3	1.0 ± 2.1 ; 2.1	-1.4 ± 1.2 ; 1.2
Fe-59	1.3 ± 4.6 ; 4.6	-0.7 ± 4.5 ; 4.5	1.1 ± 3.4 ; 3.4
Co-58	1.2 ± 2.6 ; 2.6	-1.8 ± 2.2 ; 2.2	-0.1 ± 1.9 ; 1.9
Co-60	1.2 ± 2.6 ; 2.6	-3.2 ± 2.4 ; 2.4	-0.3 ± 1.6 ; 1.6
Zn-65	-1.5 ± 4.9 ; 4.9	-0.7 ± 5.0 ; 5.0	-0.4 ± 4.0 ; 4.0
Zr-95	3.5 ± 4.5 ; 4.6	2.6 ± 5.5 ; 5.5	0.6 ± 4.3 ; 4.3
Nb-95	-0.9 ± 2.1 ; 2.1	1.1 ± 2.2 ; 2.2	-2.7 ± 1.9 ; 1.9
Cs-134	-1.1 ± 2.7 ; 2.7	-0.2 ± 3.1 ; 3.1	-1.5 ± 2.2 ; 2.2
Cs-137	-0.8 ± 3.0 ; 3.0	0.0 ± 3.0 ; 3.0	2.0 ± 2.2 ; 2.2
Ba-140	-1.6 ± 7.5 ; 7.5	-9.8 ± 7.7 ; 7.8	-0.9 ± 7.3 ; 7.3
La-140	-3.7 ± 2.7 ; 2.7	-6.1 ± 2.7 ; 2.8	-1.1 ± 2.2 ; 2.2

DRESDEN

Table 7. Surface Water  
 Collection: Monthly composites of weekly collections  
 ODCM- Gross Beta = 4, Mn-54 = 15, Fe-59 = 30, Co-58 = 15, Co-60 = 15, Zn-65 = 30, Zr-95 = 30,  
 Required LLDs: Nb-95 = 15, Cs-134 = 15, Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L  
 Units: pCi/L

Sample Description and Concentration			
<u>D-51 Dresden Lock &amp; Dam</u>			
2003 Collection Period	July	August	September
Lab Code	CDSW-4353	CDSW-5076	CDSW-5764
Gross Beta	4.8 ± 1.5 ; 1.6	4.5 ± 1.1 ; 1.3	5.6 ± 1.2 ; 1.5
Mn-54	1.3 ± 1.9 ; 1.9	1.2 ± 1.4 ; 1.4	1.9 ± 2.7 ; 2.7
Fe-59	1.1 ± 3.2 ; 3.2	0.8 ± 3.3 ; 3.3	1.0 ± 4.9 ; 4.9
Co-58	-0.4 ± 1.7 ; 1.7	-0.8 ± 1.2 ; 1.2	0.5 ± 1.7 ; 1.7
Co-60	0.6 ± 1.7 ; 1.7	-1.9 ± 1.6 ; 1.6	-0.4 ± 3.0 ; 3.0
Zn-65	-2.2 ± 4.3 ; 4.3	2.2 ± 3.2 ; 3.2	-2.0 ± 6.6 ; 6.6
Zr-95	-1.2 ± 4.5 ; 4.5	0.2 ± 3.3 ; 3.3	-3.7 ± 6.4 ; 6.4
Nb-95	-1.1 ± 1.8 ; 1.8	0.5 ± 1.6 ; 1.6	-1.2 ± 3.0 ; 3.0
Cs-134	-0.3 ± 1.7 ; 1.7	1.0 ± 1.7 ; 1.7	0.7 ± 3.7 ; 3.7
Cs-137	-0.3 ± 2.2 ; 2.2	0.7 ± 1.6 ; 1.6	-2.0 ± 2.5 ; 2.5
Ba-140	-1.5 ± 7.2 ; 7.2	9.0 ± 6.3 ; 6.4	3.8 ± 8.6 ; 8.7
La-140	-3.8 ± 2.3 ; 2.4	0.3 ± 1.8 ; 1.8	-1.6 ± 3.1 ; 3.1
2003 Collection Period	October	November	December
Lab Code	CDSW-6694	CDSW-7355	CDSW-7786
Gross Beta	6.2 ± 1.4 ; 1.7	5.0 ± 1.1 ; 1.3	2.6 ± 1.3 ; 1.4
Mn-54	2.3 ± 2.7 ; 2.7	0.7 ± 1.8 ; 1.8	1.1 ± 1.7 ; 1.7
Fe-59	-3.8 ± 6.0 ; 6.0	1.8 ± 3.1 ; 3.1	-1.2 ± 3.5 ; 3.5
Co-58	2.0 ± 2.7 ; 2.7	1.9 ± 1.7 ; 1.7	-0.9 ± 1.6 ; 1.6
Co-60	-0.9 ± 2.9 ; 2.9	1.1 ± 1.8 ; 1.8	-0.3 ± 2.1 ; 2.1
Zn-65	-2.1 ± 4.0 ; 4.0	-2.2 ± 3.7 ; 3.7	-2.6 ± 4.8 ; 4.8
Zr-95	-0.1 ± 5.1 ; 5.1	-0.3 ± 4.6 ; 4.6	-1.8 ± 4.5 ; 4.5
Nb-95	0.3 ± 2.4 ; 2.4	-0.8 ± 1.8 ; 1.8	2.8 ± 2.0 ; 2.1
Cs-134	3.5 ± 2.4 ; 2.5	1.1 ± 2.2 ; 2.2	-0.1 ± 2.2 ; 2.2
Cs-137	2.6 ± 3.1 ; 3.1	1.1 ± 2.2 ; 2.2	1.2 ± 2.1 ; 2.1
Ba-140	1.5 ± 9.2 ; 9.2	6.8 ± 6.8 ; 6.8	5.1 ± 7.4 ; 7.5
La-140	-7.6 ± 3.4 ; 3.6	-3.1 ± 2.3 ; 2.4	3.1 ± 2.2 ; 2.3

DRESDEN

Table 7. Surface Water  
 Collection: Monthly composites of weekly collections  
 ODCM- Gross Beta = 4, Mn-54 = 15, Fe-59 = 30, Co-58 = 15, Co-60 = 15, Zn-65 = 30, Zr-95 = 30,  
 Required LLDs: Nb-95 = 15, Cs-134 = 15, Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L  
 Units: pCi/L

Sample Description and Concentration				
<u>D-52 (C) DesPlaines River</u>				
2003 Collection Period	January	February	March	
Lab Code	CDSW-506	CDSW-988	CDSW-1483	
Gross Beta	13.6 ± 1.6 ; 2.7 <sup>a</sup>	9.0 ± 1.3 ; 1.9	9.6 ± 1.4 ; 2.0	
Mn-54	-0.1 ± 2.1 ; 2.1	-1.9 ± 2.4 ; 2.4	1.0 ± 3.1 ; 3.1	
Fe-59	1.2 ± 3.8 ; 3.8	-1.1 ± 2.8 ; 2.8	0.8 ± 5.1 ; 5.1	
Co-58	0.1 ± 2.1 ; 2.1	1.1 ± 2.3 ; 2.3	-0.5 ± 2.7 ; 2.7	
Co-60	1.2 ± 1.9 ; 1.9	1.6 ± 2.5 ; 2.5	-0.2 ± 1.9 ; 1.9	
Zn-65	1.8 ± 2.8 ; 2.8	1.8 ± 3.6 ; 3.6	3.4 ± 5.6 ; 5.6	
Zr-95	-4.1 ± 4.0 ; 4.0	-3.5 ± 4.7 ; 4.7	-1.9 ± 5.8 ; 5.8	
Nb-95	0.2 ± 1.8 ; 1.8	0.4 ± 2.5 ; 2.5	-0.6 ± 2.8 ; 2.8	
Cs-134	3.4 ± 2.1 ; 2.1	1.9 ± 3.2 ; 3.2	2.4 ± 3.1 ; 3.1	
Cs-137	-0.5 ± 2.2 ; 2.2	0.1 ± 2.4 ; 2.4	-1.5 ± 2.1 ; 2.1	
Ba-140	-3.3 ± 7.3 ; 7.3	-13.2 ± 9.7 ; 9.9	-9.9 ± 7.8 ; 8.0	
La-140	0.3 ± 2.1 ; 2.1	4.9 ± 2.8 ; 2.9	4.1 ± 2.5 ; 2.5	
2003 Collection Period	April	May	June	
Lab Code	CDSW-2496	CDSW-3031	CDSW-3514	
Gross Beta	8.1 ± 1.3 ; 1.8	5.2 ± 1.1 ; 1.4	7.4 ± 1.2 ; 1.7	
Mn-54	-0.1 ± 1.0 ; 1.0	-0.4 ± 1.9 ; 1.9	-1.0 ± 1.7 ; 1.7	
Fe-59	1.7 ± 1.8 ; 1.8	1.3 ± 3.7 ; 3.7	1.8 ± 2.7 ; 2.8	
Co-58	-0.1 ± 0.8 ; 0.8	0.6 ± 1.5 ; 1.5	0.3 ± 1.3 ; 1.3	
Co-60	0.4 ± 1.0 ; 1.0	0.8 ± 1.6 ; 1.6	-0.4 ± 1.8 ; 1.8	
Zn-65	0.8 ± 2.2 ; 2.2	-1.2 ± 4.1 ; 4.1	1.0 ± 4.1 ; 4.1	
Zr-95	1.4 ± 2.1 ; 2.1	0.6 ± 4.0 ; 4.0	-0.8 ± 4.3 ; 4.3	
Nb-95	0.3 ± 1.0 ; 1.0	0.6 ± 1.7 ; 1.7	-2.3 ± 1.7 ; 1.7	
Cs-134	-0.1 ± 1.1 ; 1.1	1.9 ± 2.1 ; 2.2	0.7 ± 1.9 ; 1.9	
Cs-137	-0.4 ± 1.1 ; 1.1	-1.2 ± 2.1 ; 2.1	1.9 ± 1.8 ; 1.8	
Ba-140	-2.1 ± 3.9 ; 3.9	-6.9 ± 6.6 ; 6.7	-1.9 ± 5.9 ; 5.9	
La-140	1.1 ± 1.1 ; 1.1	0.3 ± 2.2 ; 2.2	-0.3 ± 1.8 ; 1.8	

<sup>a</sup>Repeat result; original gross beta = 13.6 ± 1.6; recount = 13.5 ± 2.3 pCi/L.



DRESDEN

Table 7. Surface Water  
 Collection: Monthly composites of weekly collections  
 ODCM- Gross Beta = 4, Mn-54 = 15, Fe-59 = 30, Co-58 = 15, Co-60 = 15, Zn-65 = 30, Zr-95 = 30,  
 Required LLDs: Nb-95 = 15, Cs-134 = 15, Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L  
 Units: pCi/L

Sample Description and Concentration			
<u>D-52 (C) DesPlaines River</u>			
2003 Collection Period	July	August	September
Lab Code	CDSW-4354	CDSW-5077	CDSW-5765
Gross Beta	5.8 ± 1.5 ; 1.8	5.9 ± 1.1 ; 1.4	6.7 ± 1.3 ; 1.6
Mn-54	0.1 ± 1.9 ; 1.9	-2.1 ± 2.7 ; 2.7	1.1 ± 1.5 ; 1.5
Fe-59	-1.8 ± 3.5 ; 3.5	3.1 ± 4.8 ; 4.8	-1.1 ± 3.5 ; 3.5
Co-58	0.7 ± 1.7 ; 1.7	-0.2 ± 3.1 ; 3.1	-0.2 ± 2.1 ; 2.1
Co-60	-0.2 ± 1.8 ; 1.8	-2.8 ± 2.6 ; 2.6	0.5 ± 1.7 ; 1.7
Zn-65	0.4 ± 4.5 ; 4.5	-6.8 ± 6.5 ; 6.6	-2.3 ± 4.6 ; 4.6
Zr-95	-2.1 ± 4.4 ; 4.4	4.2 ± 5.0 ; 5.0	-0.4 ± 4.2 ; 4.2
Nb-95	0.4 ± 2.1 ; 2.1	-2.3 ± 2.5 ; 2.5	-1.3 ± 2.1 ; 2.1
Cs-134	0.8 ± 2.1 ; 2.1	1.6 ± 3.4 ; 3.4	-0.8 ± 2.0 ; 2.0
Cs-137	0.8 ± 2.1 ; 2.1	-0.8 ± 2.8 ; 2.8	-1.3 ± 2.2 ; 2.2
Ba-140	-8.3 ± 7.1 ; 7.2	12.2 ± 8.5 ; 8.7	-1.3 ± 7.4 ; 7.4
La-140	-4.9 ± 2.1 ; 2.2	-1.6 ± 3.2 ; 3.2	1.0 ± 2.5 ; 2.5
2003 Collection Period	October	November	December
Lab Code	CDSW-6696	CDSW-7356	CDSW-7787
Gross Beta	5.6 ± 1.3 ; 1.5	4.8 ± 1.1 ; 1.3	3.3 ± 0.6 ; 0.8
Mn-54	0.6 ± 1.9 ; 1.9	-0.1 ± 1.8 ; 1.8	0.5 ± 1.6 ; 1.6
Fe-59	2.0 ± 3.3 ; 3.3	1.1 ± 3.3 ; 3.3	-3.7 ± 3.5 ; 3.5
Co-58	1.5 ± 1.6 ; 1.6	0.8 ± 1.7 ; 1.7	0.7 ± 1.5 ; 1.6
Co-60	0.7 ± 1.3 ; 1.4	0.2 ± 1.4 ; 1.4	0.9 ± 2.0 ; 2.0
Zn-65	-0.2 ± 4.4 ; 4.4	5.3 ± 3.4 ; 3.5	0.2 ± 3.6 ; 3.6
Zr-95	0.8 ± 4.1 ; 4.1	-1.2 ± 3.8 ; 3.8	-3.1 ± 4.5 ; 4.5
Nb-95	1.8 ± 1.9 ; 1.9	0.1 ± 1.6 ; 1.6	0.2 ± 1.9 ; 1.9
Cs-134	0.2 ± 1.9 ; 1.9	1.3 ± 1.8 ; 1.8	-2.1 ± 2.3 ; 2.3
Cs-137	1.2 ± 2.2 ; 2.2	1.9 ± 1.8 ; 1.8	-1.2 ± 2.0 ; 2.0
Ba-140	-2.0 ± 7.2 ; 7.2	-1.2 ± 6.8 ; 6.8	4.7 ± 5.7 ; 5.7
La-140	0.7 ± 1.9 ; 1.9	-1.8 ± 2.3 ; 2.3	0.5 ± 2.3 ; 2.3

DRESDEN

Table 7. Surface Water  
 Collection: Monthly composites of weekly collections  
 ODCM- Gross Beta = 4, Mn-54 = 15, Fe-59 = 30, Co-58 = 15, Co-60 = 15, Zn-65 = 30, Zr-95 = 30,  
 Required LLDs: Nb-95 = 15, Cs-134 = 15, Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L  
 Units: pCi/L

Sample Description and Concentration			
<u>D-54 (C) Kankakee River</u>			
2003 Collection Period	January	February	March
Lab Code	CDSW-503	CDSW-908	CDSW-1478
Gross Beta	2.4 ± 1.0 ; 1.0	4.0 ± 1.1 ; 1.3	4.6 ± 1.3 ; 1.5
Mn-54	-0.1 ± 1.9 ; 1.9	1.8 ± 1.8 ; 1.8	-3.4 ± 3.3 ; 3.3
Fe-59	0.2 ± 3.3 ; 3.3	3.2 ± 4.0 ; 4.0	-2.7 ± 6.6 ; 6.6
Co-58	-0.6 ± 2.1 ; 2.1	-0.4 ± 2.1 ; 2.1	-2.7 ± 3.1 ; 3.1
Co-60	-2.6 ± 2.6 ; 2.6	-1.5 ± 2.5 ; 2.5	-0.4 ± 3.6 ; 3.6
Zn-65	2.0 ± 4.4 ; 4.4	-6.4 ± 4.4 ; 4.5	2.0 ± 7.6 ; 7.6
Zr-95	-1.5 ± 4.4 ; 4.4	-0.8 ± 4.7 ; 4.7	3.0 ± 5.5 ; 5.5
Nb-95	-1.7 ± 2.1 ; 2.2	0.8 ± 2.0 ; 2.0	1.5 ± 3.0 ; 3.0
Cs-134	-2.1 ± 2.5 ; 2.5	-1.5 ± 2.1 ; 2.1	0.9 ± 3.8 ; 3.8
Cs-137	-1.8 ± 2.3 ; 2.3	0.6 ± 2.2 ; 2.2	-0.5 ± 3.2 ; 3.2
Ba-140	1.7 ± 8.9 ; 8.9	-1.7 ± 8.0 ; 8.0	-15.7 ± 11.0 ; 11.2
La-140	2.6 ± 2.0 ; 2.0	-2.2 ± 2.4 ; 2.4	-4.5 ± 4.4 ; 4.4
2003 Collection Period	April	May	June
Lab Code	CDSW-2491	CDSW-2874	CDSW-3860
Gross Beta	3.6 ± 1.0 ; 1.2	2.5 ± 1.1 ; 1.1	2.8 ± 1.1 ; 1.2
Mn-54	-0.2 ± 1.1 ; 1.1	0.1 ± 1.6 ; 1.6	0.4 ± 0.6 ; 0.6
Fe-59	-0.6 ± 2.2 ; 2.2	0.7 ± 2.6 ; 2.6	0.5 ± 1.2 ; 1.2
Co-58	0.0 ± 1.0 ; 1.0	0.9 ± 1.6 ; 1.6	0.9 ± 0.6 ; 0.6
Co-60	1.0 ± 1.1 ; 1.2	1.4 ± 2.0 ; 2.0	0.7 ± 0.7 ; 0.7
Zn-65	-0.1 ± 2.0 ; 2.0	-0.2 ± 4.1 ; 4.1	-0.9 ± 1.5 ; 1.5
Zr-95	-2.7 ± 2.2 ; 2.3	-0.6 ± 3.7 ; 3.7	-0.8 ± 1.4 ; 1.4
Nb-95	-0.2 ± 1.1 ; 1.1	-1.0 ± 1.8 ; 1.8	0.4 ± 0.6 ; 0.6
Cs-134	-0.6 ± 1.4 ; 1.4	1.2 ± 1.3 ; 1.3	0.3 ± 0.7 ; 0.7
Cs-137	-0.9 ± 1.2 ; 1.2	-0.2 ± 2.0 ; 2.0	0.0 ± 0.7 ; 0.7
Ba-140	-2.4 ± 4.2 ; 4.3	2.0 ± 7.1 ; 7.1	5.9 ± 2.5 ; 2.6
La-140	-1.3 ± 1.2 ; 1.3	-1.4 ± 1.9 ; 1.9	-1.8 ± 0.9 ; 0.9

\* Location added by station request; data shared with Braidwood Station, location 10.

DRESDEN

Table 7. Surface Water  
 Collection: Monthly composites of weekly collections  
 ODCM- Gross Beta = 4, Mn-54 = 15, Fe-59 = 30, Co-58 = 15, Co-60 = 15, Zn-65 = 30, Zr-95 = 30,  
 Required LLDs: Nb-95 = 15, Cs-134 = 15, Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L  
 Units: pCi/L

Sample Description and Concentration			
<u>D-54 (C) Kankakee River</u>			
2003 Collection Period	July	August	September
Lab Code	CDSW-4364	CDSW-5066	CDSW-5566
Gross Beta	4.0 ± 1.4 ; 1.6	2.9 ± 1.1 ; 1.2	4.0 ± 1.2 ; 1.3
Mn-54	0.6 ± 3.5 ; 3.5	0.3 ± 2.3 ; 2.3	-1.0 ± 1.7 ; 1.7
Fe-59	4.9 ± 6.5 ; 6.5	1.9 ± 4.6 ; 4.6	0.2 ± 3.2 ; 3.2
Co-58	2.5 ± 3.6 ; 3.6	-0.4 ± 2.4 ; 2.4	-0.1 ± 1.4 ; 1.4
Co-60	1.7 ± 4.1 ; 4.1	-1.1 ± 1.9 ; 1.9	-0.3 ± 1.7 ; 1.7
Zn-65	-6.7 ± 7.5 ; 7.6	2.1 ± 4.1 ; 4.1	2.2 ± 4.0 ; 4.0
Zr-95	-2.4 ± 7.1 ; 7.1	3.0 ± 6.3 ; 6.3	-1.9 ± 4.1 ; 4.1
Nb-95	3.9 ± 3.1 ; 3.1	1.0 ± 2.4 ; 2.4	-3.5 ± 1.8 ; 1.9
Cs-134	-2.4 ± 3.9 ; 3.9	-1.2 ± 2.9 ; 3.0	-0.6 ± 1.9 ; 1.9
Cs-137	2.7 ± 2.8 ; 2.8	1.0 ± 2.9 ; 3.0	0.4 ± 2.2 ; 2.2
Ba-140	-4.0 ± 11.2 ; 11.2	-3.8 ± 8.3 ; 8.3	-7.1 ± 7.1 ; 7.2
La-140	-0.1 ± 4.7 ; 4.7	-0.5 ± 3.2 ; 3.2	-1.3 ± 2.4 ; 2.4
2003 Collection Period	October	November	December
Lab Code	CDSW-6707	CDSW-7305	CDSW-7767
Gross Beta	3.4 ± 1.0 ; 1.1	5.5 ± 1.1 ; 1.4	2.0 ± 0.9 ; 1.0
Mn-54	-1.6 ± 2.0 ; 2.0	-0.7 ± 3.4 ; 3.4	-0.5 ± 1.6 ; 1.6
Fe-59	-6.1 ± 3.7 ; 3.8	-0.4 ± 5.3 ; 5.3	-3.5 ± 3.7 ; 3.7
Co-58	1.5 ± 1.8 ; 1.9	2.2 ± 3.6 ; 3.7	0.3 ± 1.8 ; 1.8
Co-60	0.7 ± 1.8 ; 1.8	-3.0 ± 4.0 ; 4.0	-0.9 ± 2.0 ; 2.0
Zn-65	-1.6 ± 4.3 ; 4.3	-3.4 ± 7.4 ; 7.4	-1.8 ± 4.5 ; 4.5
Zr-95	2.0 ± 3.9 ; 3.9	-6.0 ± 8.1 ; 8.2	-6.7 ± 4.7 ; 4.8
Nb-95	2.1 ± 1.9 ; 1.9	-1.5 ± 3.7 ; 3.7	0.3 ± 1.5 ; 1.5
Cs-134	-1.3 ± 2.1 ; 2.1	-1.5 ± 3.5 ; 3.5	0.4 ± 2.0 ; 2.0
Cs-137	0.6 ± 2.0 ; 2.0	1.1 ± 3.0 ; 3.0	-0.8 ± 2.0 ; 2.0
Ba-140	1.5 ± 8.2 ; 8.2	1.4 ± 10.6 ; 10.6	-1.8 ± 7.2 ; 7.2
La-140	1.9 ± 2.6 ; 2.6	-5.6 ± 4.7 ; 4.8	-0.3 ± 1.7 ; 1.7

\* Location added by station request; data shared with Braidwood Station, location 10.

DRESDEN

Table 7. Surface Water  
 Collection: Quarterly composites of weekly collections  
 Required LLD: H-3 = 200 pCi/L  
 Units: pCi/L

2003 Collection Period	<u>Sample Description and Concentration</u>	Tritium
<u>D-51 Dresden Lock &amp; Dam</u>		
1st Quarter	CDSW - 1468	1,626 ± 125 ; 254
2nd Quarter	CDSW - 3516	294 ± 93 ; 102
3rd Quarter	CDSW - 5591	662 ± 112 ; 144
4th Quarter	CDSW - 7783	277 ± 92 ; 100
<u>D-52 (C) DesPlaines River</u>		
1st Quarter	CDSW - 1469	230 ± 75 ; 81
2nd Quarter	CDSW - 3517	12 ± 81 ; 81
3rd Quarter	CDSW - 5592	102 ± 90 ; 91
4th Quarter	CDSW - 7784,5	53 ± 58 ; 58
<u>D-54 (C) Kankakee River</u>		
1st Quarter	CDSW - 1465	134 ± 70 ; 72
2nd Quarter	CDSW - 3642	18 ± 84 ; 84
3rd Quarter	CDSW - 5589	61 ± 94 ; 94
4th Quarter	CDSW - 7770	10 ± 80 ; 80

\* Location added by station request; data shared with Braidwood Station, location 10.

DRESDEN

Table 8. Well Water  
 Collection: Quarterly  
 ODCM-  
 Required LLDs: H-3 = 200, Mn-54 = 15, Fe-59 = 30, Co-58 = 15, Co-60 = 15, Zn-65 = 30,  
 Zr-95 = 30, Nb-95 = 15, Cs-134 = 15, Cs-137 = 18, Ba-140 = 60, La-140 = 15 pCi/L  
 Units: pCi/L

Sample Description and Concentration				
<u>D-23 Thorsen Well</u>				
Date Collected	01-10-03	04-11-03	07-11-03	10-10-03
Lab Code	CDWW-159	CDWW-1787	CDWW-3881	CDWW-5896
H-3	609 ± 93 ; 124	729 ± 96 ; 138	839 ± 115 ; 162	711 ± 110 ; 147
Mn-54	-1.0 ± 3.1 ; 3.1	-2.4 ± 2.0 ; 2.0	1.5 ± 1.6 ; 1.6	2.0 ± 3.1 ; 3.1
Fe-59	-5.6 ± 5.0 ; 5.1	-5.8 ± 4.5 ; 4.6	0.7 ± 2.9 ; 2.9	-1.8 ± 5.6 ; 5.6
Co-58	-0.8 ± 3.1 ; 3.5	0.4 ± 2.3 ; 3.0	0.2 ± 1.6 ; 1.2	-3.3 ± 2.4 ; 2.6
Co-60	-1.0 ± 3.5 ; 3.1	-0.3 ± 3.0 ; 2.3	0.4 ± 1.2 ; 1.6	-2.4 ± 2.6 ; 2.4
Zn-65	-3.6 ± 4.5 ; 4.6	1.4 ± 4.2 ; 4.2	-0.6 ± 3.8 ; 3.8	-0.7 ± 5.6 ; 5.6
Zr-95	-2.1 ± 6.1 ; 6.1	0.6 ± 5.6 ; 5.6	-2.5 ± 3.4 ; 3.4	4.3 ± 6.0 ; 6.0
Nb-95	-0.5 ± 2.9 ; 2.9	-1.0 ± 2.9 ; 2.9	0.6 ± 1.8 ; 1.8	-1.8 ± 3.1 ; 3.1
Cs-134	-3.1 ± 4.1 ; 4.1	-1.2 ± 3.9 ; 3.9	0.1 ± 1.7 ; 1.7	-0.5 ± 3.1 ; 3.1
Cs-137	-1.4 ± 3.4 ; 3.4	-0.7 ± 3.5 ; 3.5	0.9 ± 1.8 ; 1.8	2.8 ± 3.3 ; 3.4
Ba-140	17.1 ± 9.7 ; 10.0	7.8 ± 8.3 ; 8.4	-3.2 ± 6.7 ; 6.7	1.5 ± 9.0 ; 9.0
La-140	-1.7 ± 3.2 ; 3.2	1.2 ± 2.6 ; 2.6	-3.0 ± 2.3 ; 2.3	0.9 ± 3.0 ; 3.0
<u>D-35 Dresden Lock &amp; Dam</u>				
Date Collected	01-10-03	04-11-03	07-11-03	10-10-03
Lab Code	CDWW-160	CDWW-1788	CDWW-3882	CDWW-5897
H-3	-61 ± 62 ; 62	16 ± 64 ; 64	12 ± 74 ; 74	0 ± 81 ; 81
Mn-54	1.3 ± 1.4 ; 1.4	1.2 ± 3.3 ; 3.3	0.7 ± 3.4 ; 3.4	0.5 ± 1.4 ; 1.4
Fe-59	-2.1 ± 3.2 ; 3.2	-2.2 ± 4.8 ; 4.8	-2.5 ± 6.3 ; 6.3	0.4 ± 3.2 ; 3.2
Co-58	0.6 ± 1.6 ; 1.5	2.6 ± 3.0 ; 4.3	1.5 ± 2.7 ; 4.2	1.1 ± 1.6 ; 1.7
Co-60	-0.1 ± 1.5 ; 1.6	0.4 ± 4.3 ; 3.0	-1.3 ± 4.2 ; 2.7	-1.1 ± 1.6 ; 1.6
Zn-65	-2.3 ± 4.3 ; 4.3	1.8 ± 7.6 ; 7.6	-0.4 ± 6.6 ; 6.6	-1.1 ± 3.3 ; 3.3
Zr-95	-0.8 ± 3.8 ; 3.8	-2.9 ± 8.1 ; 8.2	3.0 ± 5.0 ; 5.0	0.8 ± 4.0 ; 4.0
Nb-95	0.2 ± 1.4 ; 1.4	2.0 ± 3.4 ; 3.4	-0.6 ± 2.8 ; 2.8	-0.7 ± 1.8 ; 1.8
Cs-134	3.0 ± 1.8 ; 1.9	-0.1 ± 3.8 ; 3.8	-0.6 ± 3.4 ; 3.4	-0.5 ± 1.7 ; 1.7
Cs-137	-0.5 ± 1.6 ; 1.6	0.6 ± 3.8 ; 3.8	1.0 ± 3.3 ; 3.3	-0.6 ± 1.7 ; 1.7
Ba-140	0.3 ± 6.6 ; 6.6	2.1 ± 9.5 ; 9.5	4.8 ± 11.3 ; 11.3	-1.4 ± 7.4 ; 7.4
La-140	-1.1 ± 2.0 ; 2.0	0.3 ± 4.3 ; 4.3	-4.9 ± 4.7 ; 4.8	-0.6 ± 1.8 ; 1.8

DRESDEN

5.0 MILCH ANIMALS, NEAREST LIVESTOCK AND  
NEAREST RESIDENCES CENSUS

DRESDEN

MILCH ANIMALS CENSUS, 2003

Cows Being Milked

Halpin's Dairy Farm

16.0 miles, Sector J

55

10% or less for pasture

25% ground grain

65% green chop, hay or silage

D-25

V. Biros Dairy Farm

11.4 miles, Sector L

94

25% pasture

25% ground grain

50% green chop

Census conducted by A.D. Lewis on August 27, 2003

DRESDEN

NEAREST LIVESTOCK CENSUS, 2003

Nearest livestock of the Dresden Station within a 6.2 mile radius.

<u>Sector</u>	<u>Direction</u>	<u>Distance</u>
A	N	1.4 miles
B	NNE	6.0 miles
C	NE	2.5 miles
D	ENE	4.7 miles
E	E	None
F	ESE	None
G	SE	None
H	SSE	None
J	S	None
K	SSW	None
L	SW	None
M	WSW	None
N	W	0.5 miles
P	WNW	0.5 miles
Q	NW	0.5 miles
R	NNW	1.0 miles

Census conducted by A.D. Lewis on August 27, 2003



DRESDEN

NEAREST RESIDENCE CENSUS, 2003

Nearest resident of the Dresden Station within a 6.2 mile radius.

<u>Sector</u>	<u>Direction</u>	<u>Distance</u>
A	N	2.3 miles
B	NNE	0.8 miles
C	NE	0.8 miles
D	ENE	0.7 miles
E	E	1.1 miles
F	ESE	1.0 miles
G	SE	0.6 miles
H	SSE	0.5 miles
J	S	0.5 miles
K	SSW	3.3 miles
L	SW	3.6 miles
M	WSW	5.8 miles
N	W	3.5 miles
P	WNW	3.7 miles
Q	NW	2.6 miles
R	NNW	0.8 miles

Census conducted by A.D. Lewis on August 27, 2003

DRESDEN

6.0 TLD DATA\*

\* TLD Data provided by Exelon Generation Company.

Exelon Nuclear  
Environmental Site Report for Dresden

Site	Description	Gamma Radiation Measured in mR by TLDs			
		Quarter 1 2003	Quarter 2 2003	Quarter 3 2003	Quarter 4 2003
<b>I. INDICATOR LOCATIONS</b>					
<b>a. Air Samplers</b>					
D-01-1	ONSITE STATION 1	27.0	25.0	24.0	28.0
D-01-2	ONSITE STATION 1	24.0	20.0	20.0	25.0
D-02-1	ONSITE STATION 2	25.0	22.0	20.0	25.0
D-02-2	ONSITE STATION 2	26.0	22.0	20.0	26.0
D-03-1	ONSITE STATION 3	24.0	21.0	19.0	22.0
D-03-2	ONSITE STATION 3	25.0	21.0	21.0	22.0
D-04-1	COLLINS ROAD	27.0	25.0	25.0	30.0
D-04-2	COLLINS ROAD	28.0	24.0	24.0	26.0
D-07-1	CLAY PRODUCTS	26.0	23.0	22.0	28.0
D-07-2	CLAY PRODUCTS	24.0	22.0	19.0	27.0
D-08-1	PRAIRIE PARK	24.0	23.0	24.0	26.0
D-08-2	PRAIRIE PARK	29.0	23.0	24.0	27.0
D-10-1	GOOSE LAKE VILLAGE	28.0	22.0	24.0	29.0
D-10-2	GOOSE LAKE VILLAGE	28.0	23.0	23.0	28.0
D-13-1	MINOOKA	25.0	19.0	20.0	26.0
D-13-2	MINOOKA	24.0	21.0	20.0	26.0
D-14-1	CHANNAHON	24.0	21.0	19.0	25.0
D-14-2	CHANNAHON	21.0	23.0	21.0	23.0
D-45-1	MCKINLEY WOODS ROAD	27.0	24.0	25.0	28.0
D-45-2	MCKINLEY WOODS ROAD	30.0	25.0	24.0	30.0
D-53-1	GRUNDY COUNTY LINE ROAD	21.0	19.0	18.0	21.0
D-53-2	GRUNDY COUNTY LINE ROAD	23.0	19.0	19.0	21.0
	Air Sampler Mean ± S. D.	25.5 ±2.4	22.1 ±1.9	21.6 ±2.3	25.9 ±2.7
	Annual Air Sampler Mean ± S.D.				23.8 ±2.8
<b>b. Inner Ring (100 Series)</b>					
D-101-1		28.0	25.0	24.0	30.0
D-101-2		25.0	22.0	22.0	24.0
D-102-1		29.0	25.0	23.0	31.0
D-102-2		28.0	25.0	24.0	29.0
D-103-1			24.0	23.0	24.0
D-103-2		25.0	22.0	26.0	28.0
D-104-1		28.0	25.0	26.0	29.0
D-104-2		29.0	25.0	23.0	27.0
D-105-1		27.0	22.0	22.0	25.0
D-105-2		28.0	25.0	22.0	31.0
D-106-1		25.0	23.0	23.0	24.0
D-106-2		23.0	21.0	19.0	22.0
D-107-1		23.0	18.0	20.0	26.0
D-107-2		23.0	21.0	20.0	21.0
D-108-1		28.0	25.0	27.0	26.0
D-108-2		26.0	20.0	22.0	28.0

Exelon Nuclear  
Environmental Site Report for Dresden

Gamma Radiation Measured in mR by TLDs

Site	Description	Quarter 1 2003	Quarter 2 2003	Quarter 3 2003	Quarter 4 2003
<b>b. Inner Ring (100 Series)</b>					
D-109-1		28.0	26.0	25.0	28.0
D-109-2		28.0	25.0	27.0	27.0
D-110-3		27.0	25.0	26.0	32.0
D-110-4		30.0	29.0	28.0	31.0
D-111-1		28.0	24.0	24.0	30.0
D-111-2		26.0	24.0	24.0	29.0
D-112A-1		22.0	24.0	22.0	28.0
D-112A-2		25.0	23.0	23.0	24.0
D-113-1		20.0	19.0	21.0	23.0
D-113-2		23.0	23.0	23.0	24.0
D-114-1		24.0	21.0	22.0	23.0
D-114-2		25.0	21.0	22.0	24.0
D-115-1		26.0	23.0	23.0	27.0
D-115-2		27.0	22.0	24.0	29.0
D-116-1		29.0	24.0	25.0	29.0
D-116-2		29.0	25.0	25.0	31.0
Inner Ring Mean ± S.D.		26.2 ±2.5	23.3 ±2.2	23.4 ±2.1	27.0 ±3.0
					Annual Inner Ring Mean ± S.D.
					25.0 ±3.0
<b>c. Outer Ring (200 Series)</b>					
D-201-1		30.0	28.0	27.0	28.0
D-201-2		32.0	28.0	25.0	30.0
D-202-1		27.0	24.0	22.0	28.0
D-202-2		28.0	25.0	24.0	31.0
D-203-1		19.0	20.0	19.0	22.0
D-203-2		27.0	23.0	22.0	24.0
D-204-1		28.0	24.0	23.0	25.0
D-204-2		22.0	21.0	22.0	23.0
D-205-1		24.0	23.0	22.0	29.0
D-205-2		24.0	20.0	21.0	27.0
D-206-1		27.0	22.0	23.0	26.0
D-206-2		25.0	24.0	20.0	25.0
D-207-1		26.0	21.0	22.0	23.0
D-207-2		26.0	22.0	22.0	23.0
D-208-1		21.0	21.0	21.0	22.0
D-208-2		21.0	19.0	18.0	22.0
D-209-1		23.0	19.0	21.0	21.0
D-209-2		23.0	18.0	19.0	22.0
D-210-1		26.0	22.0	23.0	25.0
D-210-2		27.0	26.0	24.0	26.0
D-211-1		28.0	24.0	25.0	29.0
D-211-2		28.0	23.0	26.0	30.0



Exelon Nuclear  
Environmental Site Report for Dresden

Site	Description	Gamma Radiation Measured in mR by TLDs			
		Quarter 1 2003	Quarter 2 2003	Quarter 3 2003	Quarter 4 2003
Outer Ring (200 Series)					
D-212-3		24.0	20.0	22.0	23.0
D-212-4		24.0	21.0	20.0	26.0
D-213-1		20.0	19.0	18.0	22.0
D-213-2		20.0	18.0	20.0	22.0
D-214-1		30.0	27.0	26.0	33.0
D-214-2		31.0	25.0	29.0	33.0
D-215-1		30.0	26.0	26.0	32.0
D-215-2		29.0	25.0	26.0	28.0
D-216-1		27.0	24.0	24.0	26.0
D-216-2		28.0	25.0	24.0	32.0
	Outer Ring Mean ± S.D.	25.8 ±3.4	22.7 ±2.8	22.7 ±2.7	26.2 ±3.7
	Annual Outer Ring Mean ± S.D.				24.3 ±3.6
	INDICATOR LOCATION MEAN ± S.D.	25.8 ±2.8	22.8 ±2.4	22.7 ±2.5	26.4 ±3.2
	Annual INDICATOR MEAN ± S.D.				24.4 ±3.2
II. CONTROL LOCATIONS					
D-12-1	LISBON	26.0	19.0	22.0	23.0
D-12-2	LISBON	21.0	19.0	21.0	24.0
	CONTROL LOCATION MEAN ± S.D.	23.5 ±3.5	19.0 ±0.0	21.5 ±0.7	23.5 ±0.7
	Annual CONTROL LOCATION MEAN ± S.D.				21.9 ±2.4



DRESDEN

7.0 GRAPHS OF DATA TRENDS

# Air Particulates - Gross Beta





# Air Particulates - Gross Beta









# Air Particulates - Gross Beta




# Air Particulates - Gross Beta



# Surface Water-Gross Beta



# Surface Water-Gross Beta



# Surface Water-Tritium

## D-51 Dresden Lock & Dam




Figure 11. Quarterly composite of weekly collection.

## D-52 Des Plaines River







Figure 12. Quarterly composite of weekly collection.

# Surface Water-Tritium



# Well Water-Tritium



DRESDEN

8.0 2003 DREDGE SPOILS RESULTS



## Dresden Station: Special Sampling Points

## Dredge Spoils

Analysis: Gamma Isotopic

Required LLDs: Mn-54 = 0.15; Fe-59 = 0.60; Co-58, 60 = 0.10; Zn-65 = 0.60;

Units:  $10^{-02}$  pCi/g dry

Zr/Nb-95 = 0.20; Cs-134 = 0.15; Cs-137 = 0.18; Ba/La-140 = 0.60 pCi/g dry

Location	D-T-01 Shallow	D-T-01 Deep	D-S-01 North Side Shallow	D-S-01 North Side Deep
Lab Code	CDSO-5375	CDSO-5376	CDSO-5377	CDSO-5378
Date Collected	9/19/2003	9/19/2003	9/19/2003	9/19/2003
Mn-54	2.2 ± 2.1	-0.4 ± 1.7	0.7 ± 1.9	0.9 ± 1.3
Fe-59	1.5 ± 4.2	-6.6 ± 3.4	-6.6 ± 3.9	0.1 ± 2.3
Co-58	-3.1 ± 1.9	-0.8 ± 1.7	0.3 ± 1.6	2.0 ± 1.1
Co-60	1.0 ± 2.4	3.0 ± 2.2	-1.2 ± 2.4	1.5 ± 1.5
Zn-65	-14.3 ± 5.4	-1.0 ± 4.4	-9.6 ± 4.9	-36.7 ± 4.6
Nb/Zr-95	-6.3 ± 2.0	-29.8 ± 2.8	-13.2 ± 2.3	-10.7 ± 1.9
Cs-134	4.5 ± 2.4	2.0 ± 2.3	6.1 ± 2.1	1.5 ± 1.7
Cs-137	63.9 ± 4.6	44.1 ± 5.3	12.5 ± 5.5	21.5 ± 2.5
Ba/La-140	-17.2 ± 2.5	-16.2 ± 1.9	-20.3 ± 2.4	-14.0 ± 1.7

Location	D-S-02 East Side Shallow	D-S-02 East Side Deep	D-S-03 South Side Shallow	D-S-03 South Side Deep
Lab Code	CDSO-5379	CDSO-5380	CDSO-5381	CDSO-5382
Date Collected	9/19/2003	9/19/2003	9/19/2003	9/19/2003
Mn-54	1.3 ± 1.5	-1.3 ± 1.7	1.6 ± 1.7	1.5 ± 1.9
Fe-59	-2.5 ± 2.9	-1.2 ± 3.1	-5.3 ± 3.2	-10.4 ± 3.6
Co-58	-0.1 ± 1.4	1.4 ± 1.5	0.2 ± 1.5	-1.2 ± 1.7
Co-60	1.1 ± 1.7	1.6 ± 1.8	-0.6 ± 2.0	1.4 ± 1.9
Zn-65	-4.9 ± 3.7	-2.3 ± 3.6	-39.2 ± 5.6	-2.3 ± 4.1
Nb/Zr-95	-12.1 ± 1.8	-17.1 ± 2.4	-7.9 ± 2.2	-11.9 ± 2.2
Cs-134	4.1 ± 1.7	2.9 ± 1.9	1.9 ± 2.1	1.2 ± 2.5
Cs-137	28.8 ± 2.8	24.6 ± 2.8	42.4 ± 6.2	30.9 ± 5.8
Ba/La-140	-7.4 ± 1.7	-14.6 ± 2.1	-2.1 ± 1.6	-1.3 ± 2.5

Location	D-S-04 West Side Shallow	D-S-04 West Side Deep	Duplicate of 5384
Lab Code	CDSO-5383	CDSO-5384	CDSO-5385
Date Collected	9/19/2003	9/19/2003	9/19/2003
Mn-54	0.9 ± 1.6	-1.9 ± 2.1	-0.6 ± 1.8
Fe-59	-1.5 ± 3.5	3.6 ± 3.6	-10.6 ± 3.5
Co-58	-0.7 ± 1.4	2.7 ± 1.6	-1.1 ± 1.5
Co-60	2.2 ± 2.1	0.2 ± 2.3	0.5 ± 2.0
Zn-65	-28.1 ± 5.1	-3.6 ± 4.0	-2.2 ± 4.4
Nb/Zr-95	-14.2 ± 2.0	-15.9 ± 2.3	-12.9 ± 2.2
Cs-134	3.4 ± 1.9	5.2 ± 2.4	4.9 ± 2.1
Cs-137	32.7 ± 3.1	53.6 ± 6.2	54.3 ± 4.3
Ba/La-140	-1.5 ± 2.1	-66.8 ± 2.2	2.5 ± 1.8

## Dresden Station: Special Sampling Points

## Dredge Spoils

Analysis: Gamma Isotopic

Units:  $10^{-02}$  pCi/g dryRequired LLDs: Mn-54 = 0.15; Fe-59 = 0.60; Co-58, 60 = 0.10; Zn-65 = 0.60;  
Zr/Nb-95 = 0.20; Cs-134 = 0.15; Cs-137 = 0.18; Ba/La-140 = 0.60 pCi/g dry

Location	D-T-02 Shallow	D-T-02 Deep	D-S-05 North Side Shallow	D-S-05 North Side Deep
Lab Code	CDSO-5386	CDSO-5387	CDSO-5388	CDSO-5389
Date Collected	9/19/2003	9/19/2003	9/19/2003	9/19/2003
Mn-54	0.0 ± 1.2	1.1 ± 1.1	0.2 ± 1.7	0.2 ± 1.7
Fe-59	-4.2 ± 2.7	-3.3 ± 2.3	3.0 ± 3.3	0.9 ± 3.6
Co-58	-1.9 ± 1.1	-0.7 ± 1.0	-0.3 ± 1.5	-0.7 ± 1.5
Co-60	2.1 ± 1.3	1.7 ± 1.3	-0.2 ± 2.1	0.1 ± 2.0
Zn-65	-5.5 ± 3.2	-11.2 ± 3.2	-15.7 ± 4.6	-0.3 ± 4.4
Nb/Zr-95	-6.7 ± 1.5	-6.8 ± 1.4	-7.4 ± 1.9	-30.2 ± 2.8
Cs-134	3.5 ± 1.5	2.2 ± 1.4	2.7 ± 2.0	0.9 ± 2.4
Cs-137	55.9 ± 5.0	60.2 ± 3.2	41.6 ± 3.2	50.0 ± 5.6
Ba/La-140	-6.4 ± 1.4	-9.2 ± 1.3	-18.4 ± 2.0	-4.4 ± 2.3


Location	D-S-06 East Side Shallow	D-S-06 East Side Deep	D-S-07 South Side Shallow	D-S-07 South Side Deep
Lab Code	CDSO-5390	CDSO-5391	CDSO-5392	CDSO-5393
Date Collected	9/19/2003	9/19/2003	9/19/2003	9/19/2003
Mn-54	0.2 ± 1.7	1.1 ± 1.7	0.6 ± 1.7	0.9 ± 1.5
Fe-59	-1.0 ± 3.2	2.6 ± 3.6	-4.0 ± 3.7	-4.9 ± 3.7
Co-58	-3.9 ± 1.6	-1.5 ± 1.5	1.1 ± 1.5	-1.4 ± 1.5
Co-60	0.1 ± 2.1	-0.5 ± 2.0	1.1 ± 2.0	-0.5 ± 2.0
Zn-65	-3.2 ± 4.2	3.4 ± 3.4	-3.9 ± 4.4	0.5 ± 3.8
Nb/Zr-95	-3.8 ± 2.1	-21.5 ± 2.3	-2.3 ± 1.9	-11.2 ± 2.2
Cs-134	3.4 ± 2.0	3.6 ± 2.1	2.4 ± 2.1	-0.5 ± 2.1
Cs-137	56.0 ± 5.0	63.9 ± 6.1	51.9 ± 4.5	58.3 ± 5.6
Ba/La-140	-20.2 ± 2.2	-3.3 ± 1.8	-6.3 ± 1.9	-7.9 ± 1.8

Location	D-S-08 West Side Shallow	D-S-08 West Side Deep
Lab Code	CDSO-5394	CDSO-5395
Date Collected	9/19/2003	9/19/2003
Mn-54	-0.4 ± 1.9	0.4 ± 2.0
Fe-59	4.2 ± 3.4	-4.2 ± 4.3
Co-58	-0.4 ± 1.5	0.0 ± 1.7
Co-60	1.9 ± 1.9	0.6 ± 2.6
Zn-65	-4.3 ± 3.9	-30.1 ± 6.5
Nb/Zr-95	-10.0 ± 2.0	0.1 ± 2.3
Cs-134	-1.2 ± 1.4	-1.8 ± 2.3
Cs-137	32.3 ± 3.4	47.0 ± 5.1
Ba/La-140	-42.6 ± 1.9	-18.9 ± 2.5

DRESDEN

APPENDIX IV

INTERLABORATORY COMPARISON PROGRAM RESULTS



**Environmental, Inc.**  
Midwest Laboratory  
an Allegheny Technologies Co.

700 Landwehr Road - Northbrook, IL 60062-2  
(847) 564-0700 Fax (847) 564-4317

#### APPENDIX IV

#### INTERLABORATORY COMPARISON PROGRAM RESULTS

**NOTE:** Environmental Inc., Midwest Laboratory participates in intercomparison studies administered by Environmental Resources Associates, and serves as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada. Results are reported in Appendix A. TLD Intercomparison results, in-house spikes, blanks, duplicates and mixed analyte performance evaluation program results are also reported. Appendix A is updated four times a year; the complete Appendix is included in March, June, September and December monthly progress reports only.

January, 2003 through December, 2003

## Appendix A

### Interlaboratory Comparison Program Results

Environmental, Inc., Midwest Laboratory, formerly Teledyne Brown Engineering Environmental Services Midwest Laboratory has participated in interlaboratory comparison (crosscheck) programs since the formulation of its quality control program in December 1971. These programs are operated by agencies which supply environmental type samples containing concentrations of radionuclides known to the issuing agency but not to participant laboratories. The purpose of such a program is to provide an independent check on a laboratory's analytical procedures and to alert it of any possible problems.

Participant laboratories measure the concentration of specified radionuclides and report them to the issuing agency. Several months later, the agency reports the known values to the participant laboratories and specifies control limits. Results consistently higher or lower than the known values or outside the control limits indicate a need to check the instruments or procedures used.

Results in Table IV-1 were obtained through participation in the environmental sample crosscheck program administered by Environmental Resources Associates, serving as a replacement for studies conducted previously by the U.S. EPA Environmental Monitoring Systems Laboratory, Las Vegas, Nevada.

The results in Table IV-2 were obtained for Thermoluminescent Dosimeters (TLDs), via International Intercomparison of Environmental Dosimeters under the sponsorships listed in Table A-2. Results of internal laboratory testing is also listed.

Table IV-3 lists results of the analyses on in-house "spiked" samples for the past twelve months. All samples are prepared using NIST traceable sources. Data for previous years available upon request.

Table IV-4 lists results of the analyses on in-house "blank" samples for the past twelve months. Data for previous years available upon request.

Table IV-5 list results of the in-house "duplicate" program for the past twelve months. Acceptance is based on the difference of the results being less than the sum of the errors. Data for previous years available upon request.

The results in Table IV-6 were obtained through participation in the Mixed Analyte Performance Evaluation Program.

The results in Table IV-7 were obtained through participation in the Environmental Measurement Laboratory Quality Assessment Program.

Attachment A lists acceptance criteria for "spiked" samples.

Out-of-limit results are explained directly below the result.

Attachment A

ACCEPTANCE CRITERIA FOR "SPIKED" SAMPLES

LABORATORY PRECISION: ONE STANDARD DEVIATION VALUES FOR VARIOUS ANALYSES<sup>a</sup>

Analysis	Level	One standard deviation for single determination
Gamma Emitters	5 to 100 pCi/liter or kg > 100 pCi/liter or kg	5.0 pCi/liter 5% of known value
Strontium-89 <sup>b</sup>	5 to 50 pCi/liter or kg > 50 pCi/liter or kg	5.0 pCi/liter 10% of known value
Strontium-90 <sup>b</sup>	2 to 30 pCi/liter or kg > 30 pCi/liter or kg	5.0 pCi/liter 10% of known value
Potassium-40	> 0.1 g/liter or kg	5% of known value
Gross alpha	20 pCi/liter > 20 pCi/liter	5.0 pCi/liter 25% of known value
Gross beta	100 pCi/liter > 100 pCi/liter	5.0 pCi/liter 5% of known value
Tritium	4,000 pCi/liter > 4,000 pCi/liter	1s = (pCi/liter) = 169.85 x (known) <sup>0.0933</sup> 10% of known value
Radium-226,-228	0.1 pCi/liter	15% of known value
Plutonium	0.1 pCi/liter, gram, or sample	10% of known value
Iodine-131, Iodine-129 <sup>b</sup>	55 pCi/liter > 55 pCi/liter	6.0 pCi/liter 10% of known value
Uranium-238, Nickel-63 <sup>b</sup> Technetium-99 <sup>b</sup>	35 pCi/liter > 35 pCi/liter	6.0 pCi/liter 15% of known value
Iron-55 <sup>b</sup>	50 to 100 pCi/liter > 100 pCi/liter	10 pCi/liter 10% of known value
Others <sup>b</sup>	--	20% of known value

<sup>a</sup> From EPA publication, "Environmental Radioactivity Laboratory Intercomparison Studies Program, Fiscal Year, 1981-1982, EPA-600/4-81-004.

<sup>b</sup> Laboratory limit.

TABLE IV-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)<sup>3</sup>.

Lab Code	Date	Analysis	Concentration (pCi/L)		
			Laboratory Result <sup>b</sup>	ERA Result <sup>c</sup>	Control Limits
STW-973	02/17/03	Sr-89	17.0 ± 0.5	15.9 ± 5.0	7.2 - 24.6
STW-973	02/17/03	Sr-90	8.9 ± 0.3	9.0 ± 5.0	0.4 - 17.7
STW-974	02/17/03	Ba-133	14.5 ± 0.9	19.5 ± 5.0	10.8 - 28.2
STW-974	02/17/03	Co-60	37.5 ± 0.9	37.4 ± 5.0	28.7 - 46.1
STW-974	02/17/03	Cs-134	18.2 ± 0.6	17.8 ± 5.0	9.1 - 26.5
STW-974	02/17/03	Cs-137	42.7 ± 1.0	44.2 ± 5.0	35.5 - 52.9
STW-974	02/17/03	Zn-65	56.8 ± 2.2	60.3 ± 6.0	49.9 - 70.7
STW-975 <sup>d</sup>	02/17/03	Gr. Alpha	18.4 ± 0.3	37.6 ± 9.4	21.3 - 53.9
STW-975	02/17/03	Gr. Beta	11.7 ± 0.5	8.6 ± 5.0	0.0 - 17.2
STW-976	02/17/03	Ra-226	4.1 ± 0.1	4.7 ± 0.7	3.5 - 6.0
STW-976	02/17/03	Ra-228	7.6 ± 0.5	6.5 ± 1.6	3.7 - 9.3
STW-976	02/17/03	Uranium	52.9 ± 1.9	53.7 ± 5.4	44.4 - 63.0
STW-983	05/19/03	H-3	1290.0 ± 25.0	1250.0 ± 331.0	678.0 - 1820.0
STW-984	05/19/03	I-131	19.7 ± 1.3	20.8 ± 3.0	15.6 - 26.0
STW-985	05/19/03	Gr. Alpha	54.4 ± 3.0	70.3 ± 17.6	39.9 - 101.0
STW-985	05/19/03	Ra-226	14.9 ± 0.2	16.5 ± 2.5	12.2 - 20.8
STW-985	05/19/03	Ra-228	13.1 ± 0.6	10.3 ± 2.6	5.8 - 14.8
STW-985	05/19/03	Uranium	14.5 ± 0.4	15.1 ± 3.0	9.9 - 20.3
STW-986	05/19/03	Co-60	56.9 ± 8.6	63.8 ± 5.0	55.1 - 72.5
STW-986 <sup>e</sup>	05/19/03	Cs-134	61.6 ± 6.6	75.7 ± 5.0	67.0 - 84.4
STW-986	05/19/03	Cs-137	143.0 ± 1.2	150.0 ± 7.5	137.0 - 163.0
STW-986	05/19/03	Gr. Beta	309.0 ± 2.7	363.0 ± 54.5	269.0 - 457.0
STW-986	05/19/03	Sr-89	33.1 ± 0.2	31.3 ± 5.0	22.6 - 40.0
STW-986	05/19/03	Sr-90	28.8 ± 1.3	27.4 ± 5.0	18.7 - 36.1
STW-988	08/18/03	Ra-226	13.3 ± 1.1	13.4 ± 2.0	9.9 - 16.9
STW-988	08/18/03	Ra-228	11.5 ± 1.0	12.5 ± 3.1	7.1 - 17.9
STW-988	08/18/03	Uranium	12.3 ± 0.4	11.4 ± 3.0	6.2 - 16.6
STW-989	08/18/03	Ba-133	18.1 ± 1.9	20.7 ± 5.0	12.0 - 29.4
STW-989	08/18/03	Co-60	35.9 ± 1.3	37.4 ± 5.0	28.7 - 46.1
STW-989	08/18/03	Cs-134	32.6 ± 1.8	32.6 ± 5.0	23.9 - 41.3
STW-989	08/18/03	Cs-137	48.3 ± 0.6	44.3 ± 5.0	35.6 - 53.0
STW-989	08/18/03	Zn-65	58.9 ± 2.1	60.2 ± 6.0	49.8 - 70.6
STW-990	08/18/03	Gr. Alpha	41.8 ± 3.4	56.2 ± 16.3	36.9 - 93.3
STW-990 <sup>f</sup>	08/18/03	Gr. Beta	51.3 ± 3.0	31.6 ± 5.0	22.9 - 40.3
STW-991	08/18/03	Sr-89	57.2 ± 4.3	58.8 ± 5.0	50.1 - 67.5
STW-991	08/18/03	Sr-90	21.2 ± 0.9	20.6 ± 5.0	11.9 - 29.3

TABLE IV-1. Interlaboratory Comparison Crosscheck program, Environmental Resource Associates (ERA)<sup>a</sup>.

Lab Code	Date	Analysis	Concentration (pCi/L)		
			Laboratory Result <sup>b</sup>	ERA Result <sup>c</sup>	Control Limits
STW-997	11/18/03	Gr. Alpha	37.0 ± 2.0	29.5 ± 7.4	16.7 - 42.3
STW-997	11/18/03	Gr. Beta	26.5 ± 0.8	26.3 ± 5.0	17.6 - 35.0
STW-998	11/18/03	I-131	14.8 ± 0.3	16.5 ± 3.0	11.3 - 21.7
STW-999	11/18/03	Ra-226	17.2 ± 1.1	17.8 ± 2.7	13.2 - 22.4
STW-999	11/18/03	Ra-228	6.6 ± 0.3	6.8 ± 1.7	3.8 - 9.7
STW-999	11/18/03	Uranium	11.7 ± 0.3	11.7 ± 3.0	6.5 - 16.9
STW-1000	11/18/03	H-3	15900.0 ± 174.0	14300.0 ± 1430.0	11800.0 - 16800.0
STW-1001	11/18/03	Gr. Alpha	32.9 ± 0.3	54.2 ± 3.0	30.7 - 77.7
STW-1001	11/18/03	Ra-226	16.5 ± 0.9	16.1 ± 2.4	11.9 - 20.3
STW-1001	11/18/03	Ra-228	6.2 ± 0.5	5.5 ± 1.4	3.1 - 7.9
STW-1001	11/18/03	Uranium	9.7 ± 1.5	9.3 ± 13.6	4.1 - 14.5
STW-1002	11/18/03	Co-60	27.7 ± 1.9	27.7 ± 5.0	19.0 - 36.4
STW-1002	11/18/03	Cs-134	21.5 ± 1.1	23.4 ± 5.0	17.6 - 29.2
STW-1002	11/18/03	Cs-137	66.3 ± 2.8	64.2 ± 5.0	55.5 - 72.9
STW-1002	11/18/03	Gr. Beta	159.0 ± 2.5	168.0 ± 5.0	124.0 - 212.0
STW-1002	11/18/03	Sr-89	48.5 ± 0.4	50.4 ± 5.0	41.7 - 59.1
STW-1002	11/18/03	Sr-90	10.1 ± 3.0	10.2 ± 25.2	1.5 - 18.9

<sup>a</sup> Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the environmental samples crosscheck program operated by Environmental Resources Associates (ERA).

<sup>b</sup> Unless otherwise indicated, the laboratory result is given as the mean ± standard deviation for three determinations.

<sup>c</sup> Results are presented as the known values, expected laboratory precision (1 sigma, 1 determination) and control limits as provided by ERA.

<sup>d</sup> Recount of the original sample still low. The ERA blank was spiked in the lab; known value of 20.1 pCi/L, measured 21.5 ± 1.1 pCi/L. No explanation for ERA test failure.

<sup>e</sup> Lower bias observed for gamma spectroscopic analysis. The undiluted sample was reanalyzed; Results of reanalysis, Co-60: 62.3 pCi/L., Cs-134: 69.2 pCi/L., Cs-137: 152.3 pCi/L.

<sup>f</sup> Reason for deviation unknown. A recount of the original planchets averaged 43.4 pCi/L. Cs-137 activity by gamma spectroscopy; 28.3 pCi/L. Result of reanalysis; 29.3 pCi/L.



TABLE IV-2. Crosscheck program results; Thermoluminescent Dosimetry, (TLDs).

Lab Code	TLD Type	Date	Description	Known Value	mR	
					Lab Result $\pm 2$ sigma	Control Limits
<u>Environmental, Inc.</u>						
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 120	4.69	4.74 $\pm$ 0.54	3.28 - 6.10
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 150	3.00	3.02 $\pm$ 0.20	2.10 - 3.90
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 180	2.08	1.89 $\pm$ 0.45	1.46 - 2.70
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 180	2.08	2.11 $\pm$ 0.22	1.46 - 2.70
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 30	75.00	84.40 $\pm$ 4.87	52.50 - 97.50
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 60	18.75	19.11 $\pm$ 1.86	13.13 - 24.38
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 60	18.75	22.82 $\pm$ 5.41	13.13 - 24.38
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 90	8.33	9.05 $\pm$ 1.17	5.83 - 10.83
2003-1	CaSO4: Dy Cards	8/8/2003	Reader 1, 90	8.33	7.60 $\pm$ 1.08	5.83 - 10.83
<u>Environmental, Inc.</u>						
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 30	61.96	73.50 $\pm$ 2.58	43.37 - 80.55
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 60	15.49	19.70 $\pm$ 0.51	10.84 - 20.14
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 60	15.49	16.93 $\pm$ 1.37	10.84 - 20.14
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 90	6.88	8.06 $\pm$ 0.60	4.82 - 8.94
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 90	6.88	6.64 $\pm$ 0.58	4.82 - 8.94
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 120	3.87	4.39 $\pm$ 0.17	2.71 - 5.03
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 150	2.48	2.34 $\pm$ 0.18	1.74 - 3.22
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 150	2.48	2.51 $\pm$ 0.16	1.74 - 3.22
2003-2	CaSO4: Dy Cards	1/12/2004	Reader 1, 180	1.72	2.01 $\pm$ 0.13	1.20 - 2.24

TABLE IV-3. In-House "Spike" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		
				Laboratory results 2s, n=1 <sup>b</sup>	Known Activity	Control Limits <sup>c</sup>
SPW-356	water	1/2/2003	Sr-90	34.04 ± 1.57	30.93	24.74 - 37.12
W-10303	water	1/3/2003	Gr. Beta	63.24 ± 1.20	63.90	53.90 - 73.90
W-11303	water	1/13/2003	Gr. Beta	59.75 ± 1.10	63.90	53.90 - 73.90
W-12103	water	1/21/2003	Gr. Beta	61.56 ± 1.59	63.99	53.99 - 73.99
SPAP-446	Air Filter	1/31/2003	Gr. Beta	1.49 ± 0.02	1.52	-8.48 - 11.52
SPW-468	water	1/31/2003	H-3	95982.00 ± 865.00	89607.00	71685.60 - 107528.40
W-20703	water	2/7/2003	Fe-55	9095.00 ± 114.00	10587.00	8469.60 - 12704.40
SPU-1347	Urine	3/1/2003	H-3	1724.00 ± 412.00	1784.33	1101.27 - 2467.39
DW-30303	water	3/3/2003	Gr. Beta	65.44 ± 0.59	63.90	53.90 - 73.90
SPCH-964	Charcoal	3/8/2003	I-131(G)	73.37 ± 0.28	69.45	59.45 - 79.45
SPMI-1086	Milk	3/13/2003	Cs-137	57.18 ± 8.03	49.50	39.50 - 59.50
SPMI-1086	Milk	3/13/2003	I-131	75.13 ± 12.01	67.60	54.08 - 81.12
SPMI-1086	Milk	3/13/2003	I-131(G)	65.81 ± 1.06	67.56	57.56 - 77.56
SPW-1088	water	3/13/2003	Co-60	27.16 ± 4.79	28.20	18.20 - 38.20
SPW-1088	water	3/13/2003	Cs-137	51.74 ± 9.15	49.50	39.50 - 59.50
SPW-1088	water	3/13/2003	I-131(G)	68.14 ± 12.92	67.60	57.60 - 77.60
SPW-1088	water	3/13/2003	I-131	76.94 ± 1.13	67.56	54.05 - 81.07
SPVE-1110	Vegetation	3/14/2003	I-131(G)	122.80 ± 16.80	124.00	111.60 - 136.40
SPW-1194	water	3/21/2003	Co-60	31.09 ± 6.28	28.15	18.15 - 38.15
SPW-1194	water	3/21/2003	Cs-137	55.11 ± 0.13	49.50	39.50 - 59.50
SPW-1194	water	3/21/2003	I-131(G)	66.17 ± 9.15	67.60	57.60 - 77.60
W-32103	water	3/21/2003	C-14	5201.00 ± 16.60	4966.00	2979.60 - 6952.40
SPCH-1429	Charcoal	4/1/2003	I-131(G)	8.83 ± 0.11	9.18	-0.82 - 19.18
W-40103	water	4/1/2003	Gr. Beta	67.74 ± 0.52	63.39	53.39 - 73.39
SPF-1407	Fish	4/2/2003	Cs-134	0.58 ± 0.03	0.59	0.35 - 0.83
SPF-1407	Fish	4/2/2003	Cs-137	1.29 ± 0.06	1.32	0.79 - 1.85
SPAP-1409	Air Filter	4/2/2003	Gr. Beta	1.44 ± 0.02	1.51	-8.49 - 11.51
SPU-41203	Urine	4/12/2003	H-3	1798.50 ± 409.30	1784.33	1101.27 - 2467.39
SPU-41703	Urine	4/17/2003	H-3	1625.10 ± 401.30	1784.33	1101.27 - 2467.39
SPW-2022	water	4/25/2003	H-3	89007.00 ± 798.00	88463.00	70770.40 - 106155.60
SPW-2053	water	4/28/2003	Cs-137	45.70 ± 9.44	49.35	39.35 - 59.35
SPW-2053	water	4/28/2003	Sr-90	47.51 ± 1.87	44.47	35.58 - 53.36
SPMI-2055	Milk	4/28/2003	Cs-137	61.65 ± 7.17	65.80	55.80 - 75.80
SPMI-2055	Milk	4/28/2003	Sr-90	38.45 ± 1.59	44.74	35.79 - 53.69
W-50603	water	5/6/2003	Gr. Beta	70.95 ± 0.53	63.39	53.39 - 73.39
W-60303	water	6/3/2003	Gr. Beta	63.00 ± 0.51	65.73	55.73 - 75.73
SPW-3960	water	7/15/2003	H-3	88700.00 ± 822.00	87369.00	69895.20 - 104842.80
SPMI-4019	Milk	7/18/2003	Cs-137	47.17 ± 7.22	49.11	39.11 - 59.11
SPMI-4019	Milk	7/18/2003	Sr-89	40.95 ± 4.88	49.49	39.49 - 59.49
SPMI-4019	Milk	7/18/2003	Sr-90	45.30 ± 1.73	44.24	35.39 - 53.09
SPW-4023	water	7/18/2003	Cs-137	51.92 ± 6.24	49.11	39.11 - 59.11
SPW-4023	water	7/18/2003	Sr-89	42.49 ± 10.23	49.49	39.49 - 59.49
SPW-4023	water	7/18/2003	Sr-90	49.69 ± 3.04	44.24	35.39 - 53.09
SPW-4518	water	8/8/2003	Fe-55	8176.00 ± 107.00	9330.00	7464.00 - 11196.00

TABLE IV-3. In-House "Spike" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L)		
				Laboratory results 2s, n=1 <sup>b</sup>	Known Activity	Control Limits <sup>c</sup>
SPW-6197	water	10/16/2003	Tc-99	540.14 ± 54.00	539.73	377.81 - 701.65
SPAP-3958	Air Filter	10/28/2003	Gr. Beta	1.45 ± 0.02	1.50	-8.50 - 11.50
SPW-6401	water	10/28/2003	H-3	84867.00 ± 826.00	85984.00	68787.20 - 103180.80
SPAP-6403	Air Filter	10/28/2003	Gr. Beta	1.71 ± 0.02	1.49	-8.51 - 11.49
SPF-6418	Fish	10/28/2003	Cs-134	0.50 ± 0.02	0.49	0.29 - 0.69
SPF-6418	Fish	10/28/2003	Cs-137	1.37 ± 0.05	1.30	0.78 - 1.82
SPW-6421	water	10/28/2003	Fe-55	104.18 ± 1.26	88.18	68.18 - 108.18
SPMI-7459	Milk	12/12/2003	Cs-134	41.06 ± 2.45	41.88	31.88 - 51.88
SPMI-7459	Milk	12/12/2003	Cs-137	48.48 ± 4.99	48.64	38.64 - 58.64
SPMI-7459	Milk	12/12/2003	Sr-89	55.94 ± 4.12	65.80	52.64 - 78.96
SPMI-7459	Milk	12/12/2003	Sr-90	41.86 ± 1.57	43.80	35.04 - 52.56
SPW-7461	water	12/12/2003	Cs-134	44.07 ± 1.49	41.88	31.88 - 51.88
SPW-7461	water	12/12/2003	Cs-137	50.26 ± 2.67	48.64	38.64 - 58.64
SPW-7461	water	12/12/2003	Sr-89	56.41 ± 4.87	65.80	52.64 - 78.96
SPW-7461	water	12/12/2003	Sr-90	48.44 ± 1.84	43.80	35.04 - 52.56

<sup>c</sup> Control limits are based on Attachment A, Page A2 of this report.

NOTE: For fish, Jello is used for the Spike matrix. For Vegetation, cabbage is used for the Spike matrix.

TABLE IV-4. In-House "Blank" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		
				Laboratory results (4.66σ)		Acceptance Criteria (4.66 σ)
				LLD	Activity <sup>b</sup>	
SPW-357	water	1/2/2003	Sr-90	0.50	0.12 ± 0.25	1
W-10303	water	1/3/2003	Gr. Beta	0.12	0.022 ± 0.10	3.2
W-11303	water	1/13/2003	Gr. Beta	0.14	0.035 ± 0.10	3.2
W-12103	water	1/21/2003	Gr. Beta	0.12	0.029 ± 0.09	3.2
SPAP-447	Air Filter	1/31/2003	Gr. Beta	0.00	-0.0034 ± 0.00	3.2
SPW-469	water	1/31/2003	H-3	160.20	19.3 ± 80.30	200
W-20103	water	2/1/2003	Gr. Beta	0.17	0.0 ± 0.12	3.2
W-20703	water	2/7/2003	Fe-55	802.00	149 ± 498.00	1000
DW-30303		3/3/2003	Gr. Beta	0.15	0.007 ± 0.11	3.2
SPCH-965	Charcoal Cani:	3/8/2003	I-131(G)	0.01		9.6
SPMI-1087	Milk	3/13/2003	Cs-134	7.49		10
SPMI-1087	Milk	3/13/2003	Cs-137	7.90		10
SPMI-1087	Milk	3/13/2003	I-131	0.33	-0.013 ± 0.18	0.5
SPMI-1087	Milk	3/13/2003	I-131(G)	7.76		20
SPW-1089	water	3/13/2003	Co-60	4.48		10
SPW-1089	water	3/13/2003	Cs-134	5.60		10
SPW-1089	water	3/13/2003	Cs-137	4.32		10
SPW-1089	water	3/13/2003	I-131	0.29	-0.050 ± 0.16	0.5
SPVE-1111	Vegetation	3/14/2003	I-131(G)	7.53		20
W-32103	water	3/21/2003	C-14	17.50	-0.4 ± 9.200	200
SPCH-1430	Charcoal Cani:	4/1/2003	I-131(G)	0.01		9.6
W-40103	water	4/1/2003	Gr. Beta	0.14	-0.11 ± 0.100	3.2
SPF-1408	Fish	4/2/2003	Cs-134	0.01		100
SPF-1408	Fish	4/2/2003	Cs-137	0.01		100
SPAP-1410	Air Filter	4/2/2003	Gr. Beta	0.00	-0.0029 ± 0.002	3.2
SPU-41203	Urine	4/12/2003	H-3	653.99	542.28 ± 364.780	200
SPU-41703	Urine	4/17/2003	H-3	648.35	100.1 ± 344.800	200
SPW-2054	water	4/28/2003	Cs-137	3.16		10
SPW-2054	water	4/28/2003	Sr-89	0.55	0.45 ± 0.50	5
SPW-2054	water	4/28/2003	Sr-90	0.55	0.072 ± 0.260	1
SPMI-2056 <sup>c</sup>	Milk	4/28/2003	Sr-90	0.77	0.66 ± 0.430	1
SPMI-2056	Milk	4/28/2003	Cs-137	2.74		10
SPMI-2056	Milk	4/28/2003	I-131(G)	3.54		20
W-50603	water	5/6/2003	Gr. Beta	0.12	0 ± 0.090	3.2
W-60303	water	6/3/2003	Gr. Beta	0.14	-0.035 ± 0.095	3.2
SPW-3960	water	7/15/2003	H-3	156.60	53.4 ± 80.200	200
SPMI-4018	Milk	7/18/2003	Cs-137	4.10		10
SPMI-4018	Milk	7/18/2003	Sr-89	0.73	0.39 ± 0.880	5
SPMI-4018 <sup>c</sup>	Milk	7/18/2003	Sr-90	0.51	0.93 ± 0.340	1
SPW-4024	water	7/18/2003	Sr-89	0.83	0.21 ± 0.730	5
SPW-4024	water	7/18/2003	Sr-90	0.62	0.09 ± 0.300	1
SPW-4519	water	8/8/2003	Fe-55	527.00	87 ± 369.000	1000
SPW-6401	water	10/28/2003	H-3	163.80	-23.8 ± 85.000	200

TABLE IV-4. In-House "Blank" Samples

Lab Code	Sample Type	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		
				Laboratory results (4.66σ)		Acceptance Criteria (4.66 σ)
				LLD	Activity <sup>b</sup>	
SPAP-6404	Air Filter	10/28/2003	Gr. Beta	0.87	-0.99 ± 0.440	3.2
SPF-6419	Fish	10/28/2003	Cs-134	0.01		100
SPF-6419	Fish	10/28/2003	Cs-137	0.01		100
SPMI-7460	Milk	12/12/2003	Cs-134	4.52		10
SPMI-7460	Milk	12/12/2003	Cs-137	5.77		10
SPMI-7460 <sup>c</sup>	Milk	12/12/2003	Sr-90	0.50	1.26 ± 0.370	1

<sup>a</sup> Liquid sample results are reported in pCi/Liter, air filters (pCi/filter), charcoal (pCi/charcoal canister), and solid samples (pCi/kg).

<sup>b</sup> The activity reported is the net activity result.

<sup>c</sup> Low levels of Sr-90 are still detected in the environment. A concentration of (1-5 pCi/L) in milk is not unusual.

TABLE IV-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		Averaged Result
			First Result	Second Result	
MI-24, 25	1/2/2003	K-40	1362.00 ± 117.00	1377.00 ± 188.00	1369.50 ± 110.72
MI-24, 25	1/2/2003	Sr-90	1.45 ± 0.40	2.21 ± 0.50	1.83 ± 0.32
CF-47, 48	1/2/2003	Gr. Beta	2.72 ± 0.10	2.84 ± 0.10	2.78 ± 0.07
CF-47, 48	1/2/2003	K-40	2.61 ± 0.31	2.32 ± 0.12	2.47 ± 0.17
AP-8827, 8828	1/2/2003	Be-7	0.06 ± 0.01	0.05 ± 0.02	0.05 ± 0.01
AP-8869, 8870	1/2/2003	Be-7	0.04 ± 0.02	0.05 ± 0.02	0.05 ± 0.01
MI-119, 120	1/8/2003	K-40	1351.90 ± 116.10	1234.70 ± 108.70	1293.30 ± 79.52
MI-119, 120	1/8/2003	Sr-90	2.22 ± 0.43	1.88 ± 0.40	2.05 ± 0.30
MI-213, 214	1/14/2003	K-40	1372.30 ± 104.80	1303.80 ± 109.10	1338.05 ± 75.64
MI-213, 214	1/14/2003	Sr-90	1.81 ± 0.41	2.29 ± 0.45	2.05 ± 0.31
MI-262, 263	1/15/2003	K-40	1399.20 ± 200.70	1347.70 ± 126.40	1373.45 ± 118.59
S-696, 697	1/29/2003	Gr. Alpha	24.70 ± 4.89	23.23 ± 4.64	23.97 ± 3.37
S-696, 697	1/29/2003	Gr. Beta	22.89 ± 2.67	22.71 ± 2.73	22.80 ± 1.91
MI-448, 449	2/3/2003	K-40	1159.70 ± 157.90	1396.40 ± 106.20	1278.05 ± 95.15
SW-470, 471	2/3/2003	Gr. Beta	13.62 ± 1.23	15.21 ± 1.21	14.42 ± 0.86
SW-470, 471	2/3/2003	K-40 (ICP)	5.10 ± 0.51	5.20 ± 0.52	5.15 ± 0.36
SW-470, 471	2/3/2003	K-40	5.80 ± 0.51	5.90 ± 0.52	5.85 ± 0.36
MI-517, 518	2/4/2003	K-40	1437.70 ± 125.50	1357.70 ± 188.00	1397.70 ± 113.02
MI-541, 542	2/5/2003	K-40	1443.00 ± 194.80	1385.20 ± 190.10	1414.10 ± 136.09
MI-620, 621	2/11/2003	K-40	1294.70 ± 115.10	1234.10 ± 165.10	1264.40 ± 100.63
DW-922, 923	3/4/2003	I-131	0.67 ± 0.16	0.79 ± 0.16	0.73 ± 0.11
CF-1048, 1049 <sup>b</sup>	3/10/2003	K-40	3.09 ± 0.12	2.67 ± 0.07	2.88 ± 0.07
LW-1152, 1153	3/13/2003	H-3	1147.26 ± 122.56	1094.42 ± 120.92	1120.84 ± 86.09
F-1120, 1121	3/14/2003	Cs-137	0.04 ± 0.02	0.05 ± 0.01	0.05 ± 0.01
F-1120, 1121	3/14/2003	Gr. Beta	2.04 ± 0.06	2.11 ± 0.06	2.08 ± 0.04
F-1120, 1121	3/14/2003	K-40	1.93 ± 0.38	1.89 ± 0.25	1.91 ± 0.23
DW-1278, 1279	3/25/2003	I-131	0.37 ± 0.22	0.34 ± 0.29	0.36 ± 0.18
SO-1380, 1381	3/25/2003	Gr. Beta	18.60 ± 2.68	20.53 ± 2.83	19.57 ± 1.95
LW-1299, 1300	3/27/2003	Gr. Beta	2.35 ± 0.55	2.48 ± 0.56	2.42 ± 0.39
LW-1320, 1321	3/27/2003	H-3	487.12 ± 104.43	422.00 ± 102.00	454.56 ± 72.99
W-1403, 1404	3/31/2003	Sr-90	0.96 ± 0.32	1.10 ± 0.42	1.03 ± 0.26
AP-2019, 2020	3/31/2003	Be-7	0.07 ± 0.01	0.08 ± 0.01	0.07 ± 0.01
MI-1422, 1423	4/1/2003	K-40	1410.00 ± 176.00	1340.00 ± 114.00	1375.00 ± 104.85
MI-2170, 2171	4/1/2003	K-40	1452.30 ± 129.10	1472.50 ± 191.00	1462.40 ± 115.27
MI-1422, 1423	4/2/2003	Sr-90	1.84 ± 0.42	1.15 ± 0.39	1.50 ± 0.29
AP-1633, 1634	4/2/2003	Be-7	0.05 ± 0.01	0.06 ± 0.01	0.06 ± 0.01
AP-1871, 1872	4/2/2003	Be-7	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
AP-1974, 1975	4/2/2003	Be-7	0.08 ± 0.02	0.07 ± 0.02	0.08 ± 0.01
LW-1828, 1829	4/11/2003	Gr. Beta	2.49 ± 0.58	3.42 ± 0.63	2.96 ± 0.43
S-1544, 1545	4/15/2003	K-40	15.84 ± 2.36	15.41 ± 2.02	15.63 ± 1.55
DW-1913, 1914	4/15/2003	I-131	0.29 ± 0.21	0.42 ± 0.19	0.36 ± 0.14
MI-1996, 1997	4/21/2003	Sr-90	2.05 ± 0.74	3.25 ± 0.91	2.65 ± 0.58
MI-1996, 1997	4/22/2003	K-40	1580.20 ± 118.90	1602.10 ± 120.40	1591.15 ± 84.61

TABLE IV-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		Averaged Result
			First Result	Second Result	
LW-2063, 2064	4/28/2003	Gr. Beta	2.33 ± 0.66	2.68 ± 0.60	2.51 ± 0.45
SWU-2275, 2276	4/28/2003	Gr. Beta	3.62 ± 0.67	4.60 ± 0.71	4.11 ± 0.49
G-2149, 2150	4/30/2003	Be-7	0.71 ± 0.19	0.69 ± 0.20	0.70 ± 0.14
TD-2339, 2340	5/1/2003	H-3	221.00 ± 91.00	161.00 ± 88.00	191.00 ± 63.29
SO-2381, 2382	5/1/2003	Cs-137	0.11 ± 0.03	0.10 ± 0.02	0.10 ± 0.02
SO-2381, 2382	5/1/2003	Gr. Alpha	11.14 ± 5.15	10.39 ± 5.60	10.77 ± 3.80
SO-2381, 2382	5/1/2003	Gr. Beta	35.18 ± 4.69	39.66 ± 5.24	37.42 ± 3.52
SO-2381, 2382	5/1/2003	K-40	18.29 ± 0.84	17.83 ± 0.84	18.06 ± 0.59
SO-2381, 2382	5/1/2003	Sr-90	0.06 ± 0.02	0.10 ± 0.02	0.08 ± 0.01
DW-2317, 2318	5/6/2003	I-131	1.77 ± 0.27	1.47 ± 0.26	1.62 ± 0.19
BS-2595, 2596	5/6/2003	Cs-137	0.06 ± 0.02	0.06 ± 0.02	0.06 ± 0.02
BS-2595, 2596	5/6/2003	K-40	13.74 ± 0.62	14.10 ± 0.73	13.92 ± 0.48
U-2484, 2485	5/9/2003	H-3	512.00 ± 100.00	370.00 ± 95.00	441.00 ± 68.97
SO-2645, 2646	5/14/2003	Be-7	1.18 ± 0.42	1.21 ± 0.35	1.19 ± 0.27
SO-2645, 2646	5/14/2003	Cs-137	0.11 ± 0.04	0.09 ± 0.05	0.10 ± 0.03
SO-2645, 2646	5/14/2003	K-40	16.50 ± 1.13	15.33 ± 1.09	15.91 ± 0.79
MI-2696, 2697	5/19/2003	K-40	1320.40 ± 124.50	1394.10 ± 113.00	1357.25 ± 84.07
MI-2696, 2697	5/19/2003	Sr-90	1.49 ± 0.47	2.01 ± 0.45	1.75 ± 0.32
SO-2787, 2788	5/28/2003	Cs-137	0.27 ± 0.04	0.23 ± 0.04	0.25 ± 0.03
SO-2787, 2788	5/28/2003	Gr. Beta	19.62 ± 1.73	20.81 ± 1.72	20.21 ± 1.22
SO-2787, 2788	5/28/2003	K-40	14.77 ± 1.02	14.41 ± 1.00	14.59 ± 0.71
MI-2840, 2841	5/28/2003	K-40	1179.50 ± 167.80	1401.70 ± 120.20	1290.60 ± 103.20
SWU-2864, 2865	5/28/2003	Gr. Beta	3.39 ± 0.59	3.41 ± 0.64	3.40 ± 0.43
BS-2888, 2889	5/29/2003	Cs-137	0.05 ± 0.02	0.07 ± 0.04	0.06 ± 0.02
BS-2888, 2889	5/29/2003	K-40	9.70 ± 0.83	10.17 ± 0.87	9.93 ± 0.60
W-3230, 3231	5/30/2003	Gr. Beta	4.33 ± 1.00	3.28 ± 1.22	3.81 ± 0.79
TD-3036, 3037	6/2/2003	H-3	529.50 ± 100.00	585.50 ± 102.00	557.50 ± 71.42
SL-2909, 2910 <sup>b</sup>	6/3/2003	Gr. Beta	7.10 ± 0.15	7.60 ± 0.16	7.35 ± 0.11
SL-2909, 2910	6/3/2003	K-40	3.90 ± 0.67	3.49 ± 0.52	3.70 ± 0.42
SW-3080, 3081	6/10/2003	Gr. Alpha	4.63 ± 1.90	4.47 ± 1.71	4.55 ± 1.28
SW-3080, 3081	6/10/2003	Gr. Beta	9.07 ± 1.29	8.98 ± 1.28	9.02 ± 0.91
VE-3172, 3173	6/11/2003	K-40	2.62 ± 0.35	3.17 ± 0.58	2.90 ± 0.34
F-3742, 3743	6/11/2003	Gr. Beta	3.47 ± 0.13	3.71 ± 0.14	3.59 ± 0.10
F-3742, 3743	6/11/2003	K-40	2.94 ± 0.39	2.70 ± 0.40	2.82 ± 0.28
SO-3325, 3326	6/13/2003	Gr. Beta	20.95 ± 1.88	19.97 ± 2.01	20.46 ± 1.38
MI-3253, 3254	6/17/2003	K-40	1329.40 ± 121.80	1417.60 ± 130.90	1373.50 ± 89.40
MI-3297, 3298	6/17/2003	Sr-90	2.14 ± 0.57	2.27 ± 0.50	2.21 ± 0.38
WW-3380, 3381	6/23/2003	Gr. Beta	5.58 ± 0.69	5.03 ± 0.69	5.31 ± 0.49
SWT-3403, 3404	6/24/2003	Gr. Beta	2.80 ± 0.56	2.63 ± 0.55	2.72 ± 0.39
MI-3424, 3425	6/24/2003	K-40	1422.80 ± 185.40	1216.20 ± 170.10	1319.50 ± 125.80
SW-3862, 3863	6/24/2003	Gr. Beta	3.66 ± 1.18	3.70 ± 1.22	3.68 ± 0.85
G-3479, 3480	6/25/2003	Be-7	1.52 ± 0.25	1.43 ± 0.28	1.47 ± 0.19
G-3479, 3480	6/25/2003	K-40	5.02 ± 0.45	5.10 ± 0.48	5.06 ± 0.33
LW-3809, 3810	6/30/2003	Gr. Beta	2.12 ± 0.76	2.39 ± 0.72	2.25 ± 0.52

TABLE IV-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		Averaged Result
			First Result	Second Result	
LW-3809, 3810	6/30/2003	H-3	2814.09 ± 167.99	2812.17 ± 167.94	2813.13 ± 118.77
AP-4105, 4106	6/30/2003	Be-7	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
G-3572, 3573	7/1/2003	Be-7	0.91 ± 0.24	0.81 ± 0.28	0.86 ± 0.18
G-3572, 3573	7/1/2003	Gr. Beta	6.35 ± 0.15	6.35 ± 0.15	6.35 ± 0.11
G-3572, 3573	7/1/2003	K-40	5.44 ± 0.55	5.68 ± 0.28	5.56 ± 0.31
G-3572, 3573	7/1/2003	Sr-90	0.01 ± 0.00	0.02 ± 0.00	0.01 ± 0.00
MI-3601, 3602	7/1/2003	K-40	1318.60 ± 117.40	1435.10 ± 117.80	1376.85 ± 83.16
MI-3601, 3602	7/1/2003	Sr-90	0.86 ± 0.51	1.74 ± 0.60	1.30 ± 0.39
AP-3933, 3934	7/1/2003	Be-7	0.07 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
AP-4061, 4062	7/2/2003	Be-7	0.07 ± 0.01	0.08 ± 0.01	0.08 ± 0.01
AP-4147, 4148	7/2/2003	Be-7	0.08 ± 0.01	0.07 ± 0.01	0.07 ± 0.01
AP-4084, 4085	7/3/2003	Be-7	0.09 ± 0.02	0.08 ± 0.02	0.08 ± 0.01
LW-3786, 3787	7/9/2003	Gr. Beta	2.13 ± 0.56	2.93 ± 0.62	2.53 ± 0.42
WW-4168, 4169	7/11/2003	Gr. Beta	3.79 ± 1.87	4.48 ± 1.98	4.14 ± 1.36
CF-3975, 3976	7/14/2003	Be-7	1.64 ± 0.81	1.66 ± 0.57	1.65 ± 0.50
CF-3975, 3976	7/14/2003	K-40	6.54 ± 0.75	6.19 ± 0.50	6.36 ± 0.45
MI-4020, 4021	7/16/2003	K-40	1350.90 ± 174.90	1199.80 ± 153.20	1275.35 ± 116.25
DW-4272, 4273	7/29/2003	Gr. Beta	2.35 ± 0.92	2.29 ± 0.89	2.32 ± 0.64
SWU-4461, 4462	7/30/2003	Gr. Beta	2.28 ± 0.44	1.93 ± 0.43	2.10 ± 0.31
SL-4398, 4399	8/4/2003	Be-7	4.55 ± 1.05	4.50 ± 1.10	4.53 ± 0.76
SL-4398, 4399 b	8/4/2003	Gr. Beta	3.41 ± 0.12	3.12 ± 0.11	3.27 ± 0.08
SL-4398, 4399	8/4/2003	K-40	2.47 ± 0.67	2.44 ± 0.87	2.46 ± 0.55
G-4419, 4420	8/4/2003	Be-7	3.98 ± 0.63	3.93 ± 0.57	3.96 ± 0.42
G-4419, 4420	8/4/2003	Gr. Beta	5.38 ± 0.14	5.35 ± 0.16	5.37 ± 0.11
G-4419, 4420	8/4/2003	K-40	4.42 ± 0.66	4.32 ± 0.74	4.37 ± 0.50
TD-4550, 4551	8/4/2003	H-3	327.30 ± 95.10	390.20 ± 92.10	358.75 ± 66.19
MI-4482, 4483	8/6/2003	K-40	1301.40 ± 115.20	1370.30 ± 116.80	1335.85 ± 82.03
MI-4482, 4483	8/6/2003	Sr-90	0.81 ± 0.30	0.85 ± 0.31	0.83 ± 0.21
G-4526, 4527	8/6/2003	Be-7	1.47 ± 0.29	1.42 ± 0.28	1.45 ± 0.20
G-4526, 4527	8/6/2003	K-40	5.42 ± 0.56	5.21 ± 0.63	5.31 ± 0.42
SWU-4609, 4610	8/6/2003	Gr. Beta	3.22 ± 0.63	2.67 ± 0.64	2.95 ± 0.45
CW-4694, 4695	8/6/2003	Gr. Beta	1.48 ± 0.34	1.09 ± 0.34	1.29 ± 0.24
CW-4694, 4695	8/6/2003	H-3	22776.41 ± 428.73	21831.75 ± 420.10	22304.08 ± 300.12
LW-4673, 4674	8/13/2003	Gr. Beta	2.86 ± 0.65	3.75 ± 0.71	3.30 ± 0.48
MI-4735, 4736	8/19/2003	K-40	1396.30 ± 127.90	1410.10 ± 120.20	1403.20 ± 87.76
MI-4756, 4757	8/19/2003	Sr-90	1.66 ± 0.47	1.53 ± 0.44	1.60 ± 0.32
VE-4832, 4833	8/20/2003	K-40	1.96 ± 0.50	1.43 ± 0.47	1.70 ± 0.34
MI-4860, 4861	8/26/2003	K-40	1312.10 ± 191.80	1307.80 ± 109.30	1309.95 ± 110.38
SO-5082, 5083	8/28/2003	Cs-137	0.01 ± 0.00	0.01 ± 0.00	0.01 ± 0.00
SO-5082, 5083	8/28/2003	Gr. Beta	20.02 ± 1.84	20.92 ± 2.03	20.47 ± 1.37
CW-5349, 5350	8/31/2003	Gr. Beta	1.45 ± 0.39	1.55 ± 0.45	1.50 ± 0.30
CW-5349, 5350	8/31/2003	H-3	24429.50 ± 444.42	24744.25 ± 447.18	24586.88 ± 315.23
ME-4968, 4969	9/2/2003	Gr. Beta	4.90 ± 0.23	5.18 ± 0.24	5.04 ± 0.17
ME-4968, 4969	9/2/2003	K-40	2.46 ± 0.41	2.68 ± 0.37	2.57 ± 0.28



TABLE IV-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		
			First Result	Second Result	Averaged Result
DW-4989, 4990	9/2/2003	Gr. Beta	2.20 ± 1.04	3.19 ± 1.14	2.70 ± 0.77
MI-5154, 5155	9/8/2003	K-40	1365.50 ± 116.70	1456.70 ± 119.10	1411.10 ± 83.37
MI-5154, 5155	9/8/2003	Sr-90	1.19 ± 0.39	1.39 ± 0.39	1.29 ± 0.28
AP-6177, 6178	9/29/2003	Be-7	0.07 ± 0.01	0.06 ± 0.01	0.06 ± 0.01
SWU-5773, 5774	9/30/2003	Gr. Beta	2.55 ± 0.63	2.83 ± 0.60	2.69 ± 0.44
AP-6102, 6103	9/30/2003	Be-7	0.07 ± 0.01	0.05 ± 0.01	0.06 ± 0.01
G-5631, 5632	10/1/2003	Be-7	1.88 ± 0.48	2.21 ± 0.40	2.05 ± 0.31
G-5631, 5632	10/1/2003	Gr. Beta	5.87 ± 0.09	5.85 ± 0.08	5.86 ± 0.06
G-5631, 5632	10/1/2003	K-40	5.24 ± 0.77	5.26 ± 0.58	5.25 ± 0.48
SO-5660, 5661	10/1/2003	Cs-137	0.15 ± 0.04	0.16 ± 0.05	0.16 ± 0.03
SO-5660, 5661	10/1/2003	Gr. Alpha	12.72 ± 3.72	14.86 ± 3.88	13.79 ± 2.69
SO-5660, 5661	10/1/2003	Gr. Beta	32.42 ± 3.09	33.60 ± 3.04	33.01 ± 2.17
SO-5660, 5661	10/1/2003	K-40	18.93 ± 0.87	18.25 ± 1.19	18.59 ± 0.74
SO-5660, 5661	10/1/2003	Sr-90	0.03 ± 0.01	0.03 ± 0.01	0.03 ± 0.01
AP-6334, 6335	10/1/2003	Be-7	0.06 ± 0.01	0.06 ± 0.01	0.06 ± 0.01
AP-6363, 6364	10/2/2003	Be-7	0.07 ± 0.02	0.07 ± 0.02	0.07 ± 0.01
MI-5794, 5795	10/6/2003	Sr-90	1.37 ± 0.37	1.02 ± 0.37	1.19 ± 0.26
MI-5838, 5839	10/8/2003	K-40	1364.30 ± 124.10	1414.40 ± 110.40	1389.35 ± 83.05
MI-5838, 5839	10/8/2003	Sr-90	0.76 ± 0.30	1.00 ± 0.34	0.88 ± 0.23
BS-5938, 5939	10/8/2003	Cs-137	0.18 ± 0.03	0.20 ± 0.05	0.19 ± 0.03
BS-5938, 5939	10/8/2003	K-40	15.59 ± 0.70	16.69 ± 0.80	16.14 ± 0.53
SS-5959, 5960	10/13/2003	K-40	7.49 ± 0.42	7.29 ± 0.63	7.39 ± 0.38
MI-6011, 6012	10/13/2003	K-40	1165.20 ± 118.70	1191.20 ± 99.50	1178.20 ± 77.44
MI-6034, 6035	10/14/2003	Sr-90	0.86 ± 0.33	0.90 ± 0.34	0.88 ± 0.24
VE-6055, 6056	10/15/2003	Gr. Beta	5.18 ± 0.18	5.33 ± 0.18	5.25 ± 0.13
VE-6055, 6056	10/15/2003	K-40	5.31 ± 0.57	4.52 ± 0.51	4.92 ± 0.38
MI-6291, 6292	10/21/2003	K-40	1935.60 ± 147.70	1936.10 ± 116.50	1935.85 ± 94.06
MI-6291, 6292	10/21/2003	Sr-90	1.22 ± 0.39	1.41 ± 0.37	1.31 ± 0.27
SS-6435, 6436	10/21/2003	Cs-137	0.05 ± 0.02	0.05 ± 0.03	0.05 ± 0.02
SS-6435, 6436	10/21/2003	K-40	14.08 ± 0.54	14.28 ± 0.80	14.18 ± 0.48
CF-6313, 6314	10/22/2003	K-40	14.56 ± 0.45	14.70 ± 0.95	14.63 ± 0.53
SO-6528, 6529	10/22/2003	Cs-137	0.15 ± 0.03	0.16 ± 0.05	0.16 ± 0.03
SO-6528, 6529	10/22/2003	K-40	17.46 ± 0.69	17.90 ± 1.05	17.68 ± 0.63
SO-6393, 6394	10/25/2003	Cs-137	0.09 ± 0.03	0.10 ± 0.04	0.10 ± 0.03
SO-6393, 6394	10/25/2003	Gr. Beta	23.21 ± 1.98	21.76 ± 1.91	22.48 ± 1.38
SO-6393, 6394	10/25/2003	K-40	13.98 ± 0.80	14.57 ± 0.86	14.27 ± 0.59
SWT-6507, 6508	10/28/2003	Gr. Beta	2.64 ± 0.52	2.63 ± 0.53	2.63 ± 0.37
DW-6647, 6648	10/31/2003	I-131	0.46 ± 0.27	0.61 ± 0.31	0.53 ± 0.21
BS-6603, 6604	11/3/2003	Cs-137	9.03 ± 0.82	8.60 ± 1.13	8.82 ± 0.70
BS-6603, 6604	11/3/2003	Gr. Beta	26.83 ± 1.94	27.18 ± 1.95	27.01 ± 1.38
SO-6670, 6671	11/5/2003	Cs-137	0.15 ± 0.04	0.13 ± 0.04	0.14 ± 0.03
SO-6670, 6671	11/5/2003	K-40	12.96 ± 0.66	12.95 ± 0.72	12.96 ± 0.49
S-7067, 7068	11/10/2003	Cs-137	0.21 ± 0.05	0.19 ± 0.08	0.20 ± 0.05
MI-6818, 6819	11/11/2003	K-40	1695.50 ± 129.80	1709.40 ± 143.00	1702.45 ± 96.56

TABLE IV-5. In-House "Duplicate" Samples

Lab Code	Date	Analysis	Concentration (pCi/L) <sup>a</sup>		Averaged Result
			First Result	Second Result	
MI-6818, 6819	11/11/2003	Sr-90	2.01 ± 0.41	1.59 ± 0.39	1.80 ± 0.28
WL-6987, 6988	11/17/2003	Fe-55	603.49 ± 53.32	619.65 ± 53.97	611.57 ± 37.93
SO-7156, 7157	11/21/2003	Cs-137	0.74 ± 0.08	0.77 ± 0.07	0.76 ± 0.06
SO-7156, 7157	11/21/2003	Gr. Alpha	14.90 ± 4.24	19.25 ± 4.45	17.07 ± 3.07
SO-7156, 7157	11/21/2003	Gr. Beta	22.97 ± 3.12	25.51 ± 2.98	24.24 ± 2.16
SO-7156, 7157	11/21/2003	K-40	12.51 ± 1.06	12.94 ± 1.07	12.73 ± 0.75
S-7281, 7282	11/24/2003	Cs-137	0.82 ± 0.15	1.16 ± 0.20	0.99 ± 0.12
SWU-7198, 7199	11/25/2003	Gr. Beta	2.60 ± 0.53	2.54 ± 0.55	2.57 ± 0.38
DW-7221, 7222	11/25/2003	Gr. Beta	12.32 ± 1.40	12.38 ± 1.43	12.35 ± 1.00
SW-7133, 7134	12/1/2003	Gr. Beta	2.10 ± 0.23	2.46 ± 0.23	2.28 ± 0.16
SW-7133, 7134	12/1/2003	K-40	1.50 ± 0.15	1.40 ± 0.14	1.45 ± 0.10
W-7519, 7520	12/1/2003	Fe-55	3.03 ± 0.65	3.12 ± 0.64	3.08 ± 0.46
SW-7805, 7806	12/1/2003	Sr-90	0.59 ± 0.32	0.56 ± 0.33	0.58 ± 0.23
VE-7399, 7400	12/9/2003	Gr. Beta	4.99 ± 0.15	5.24 ± 0.15	5.11 ± 0.11
VE-7399, 7400	12/9/2003	K-40	5.04 ± 0.46	5.34 ± 0.74	5.19 ± 0.43
SW-7540, 7541	12/9/2003	Gr. Alpha	2.64 ± 1.36	2.10 ± 1.19	2.37 ± 0.91
SW-7540, 7541	12/9/2003	Gr. Beta	6.62 ± 1.22	5.89 ± 1.35	6.25 ± 0.91
LW-7736, 7737	12/26/2003	Gr. Beta	2.62 ± 0.54	2.83 ± 0.56	2.73 ± 0.39
AP-7868, 7869	12/30/2003	Be-7	0.05 ± 0.01	0.04 ± 0.01	0.04 ± 0.01
AP-7952, 7953	12/30/2003	Be-7	0.04 ± 0.01	0.04 ± 0.01	0.04 ± 0.01
AP-7994, 7995	12/31/2003	Be-7	0.05 ± 0.02	0.05 ± 0.01	0.05 ± 0.01

Note: Duplicate analyses are performed on every twentieth sample received in-house. Results are not listed for those analyses with activities that measure below the LLD.

<sup>a</sup> Results are reported in units of pCi/L, except for air filters (pCi/Filter), food products, vegetation, soil, sediment (pCi/g).

<sup>b</sup> 200 minute count time or longer, resulting in lower error.

TABLE IV-6. Department of Energy's Mixed Analyte Performance Evaluation Program (MAPEP)<sup>a</sup>.

Lab Code	Type	Date	Analysis	Concentration <sup>b</sup>		
				Laboratory result	Known Activity	Control Limits <sup>c</sup>
STW-972	water	12/01/02	Am-241	0.56 ± 0.06	0.58 ± 0.09	0.40 - 0.75
STW-972	water	12/01/02	Co-57	57.10 ± 1.90	57.00 ± 5.70	39.90 - 74.10
STW-972	water	12/01/02	Co-60	38.30 ± 0.60	38.20 ± 3.82	26.74 - 49.66
STW-972	water	12/01/02	Cs-134	395.30 ± 10.10	421.00 ± 42.10	294.70 - 547.30
STW-972	water	12/01/02	Cs-137	316.40 ± 5.30	329.00 ± 32.90	230.30 - 427.70
STW-972	water	12/01/02	Fe-55	94.90 ± 24.50	96.00 ± 9.60	67.20 - 124.80
STW-972	water	12/01/02	Mn-54	33.40 ± 0.10	32.90 ± 3.29	23.03 - 42.77
STW-972	water	12/01/02	Ni-63	123.80 ± 5.50	136.50 ± 13.70	95.55 - 177.45
STW-972	water	12/01/02	Pu-238	0.66 ± 0.06	0.83 ± 0.08	0.58 - 1.08
STW-972	water	12/01/02	Pu-239/40	0.001 ± 0.001	0.000 ± 0.000	0.000 - 0.005
STW-972	water	12/01/02	Sr-90	13.80 ± 1.00	12.31 ± 1.23	8.62 - 16.00
STW-972	water	12/01/02	Tc-99	128.10 ± 3.80	132.00 ± 13.20	92.40 - 171.60
STW-972	water	12/01/02	U-233/4	1.60 ± 0.09	1.54 ± 0.15	1.08 - 2.00
STW-972	water	12/01/02	U-238	1.64 ± 0.09	1.60 ± 0.16	1.12 - 2.08
STW-972	water	12/01/02	Zn-65	540.40 ± 9.90	516.00 ± 51.60	361.20 - 670.80
STSO-987	soil	01/01/03	Co-57	534.36 ± 2.61	530.00 ± 53.00	371.00 - 689.00
STSO-987	soil	01/01/03	Co-60	442.16 ± 2.31	420.00 ± 42.00	294.00 - 546.00
STSO-987	soil	01/01/03	Cs-134	211.00 ± 2.30	238.00 ± 23.80	166.60 - 309.40
STSO-987	soil	01/01/03	Cs-137	849.50 ± 3.30	832.00 ± 83.20	582.40 - 1081.60
STSO-987	soil	01/01/03	K-40	716.50 ± 12.80	652.00 ± 65.20	456.40 - 847.60
STSO-987	soil	01/01/03	Mn-54	148.76 ± 2.84	137.00 ± 13.70	95.90 - 178.10
STSO-987	soil	01/01/03	Ni-63	597.10 ± 23.50	770.00 ± 77.00	539.00 - 1001.00
STSO-987	soil	01/01/03	Pu-238	67.05 ± 3.10	66.90 ± 6.70	46.83 - 86.97
STSO-987	soil	01/01/03	Pu-239/40	52.80 ± 3.60	52.70 ± 5.30	36.90 - 68.50
STSO-987	soil	01/01/03	Sr-90	609.50 ± 9.80	714.00 ± 71.40	499.80 - 928.20
STSO-987	soil	01/01/03	U-233/4	99.50 ± 7.60	89.00 ± 8.90	62.30 - 115.70
STSO-987	soil	01/01/03	U-238	508.60 ± 42.20	421.00 ± 42.10	294.70 - 547.30
STSO-987	soil	01/01/03	Zn-65	492.70 ± 28.10	490.00 ± 49.00	343.00 - 637.00

<sup>a</sup> Results obtained by Environmental, Inc., Midwest Laboratory as a participant in the Department of Energy's Mixed Analyte Performance Evaluation Program, Idaho Operations office, Idaho Falls, Idaho

<sup>b</sup> All results are in Bq/kg or Bq/L as requested by the Department of Energy.

<sup>c</sup> MAPEP results are presented as the known values and expected laboratory precision (1 sigma, 1 determination) and control limits as defined by the MAPEP.

TABLE IV-7. Environmental Measurements Laboratory Quality Assessment Program (EML)

Lab Code	Type	Date	Analysis	Concentration <sup>a</sup>		
				Laboratory results	EML Result <sup>b</sup>	Control Limits <sup>c</sup>
STW-977	water	03/01/03	Gr. Alpha	304.30 ± 53.10	377.50	0.58 - 1.29
STW-977	water	03/01/03	Gr. Beta	615.80 ± 14.70	627.50	0.61 - 1.43
STW-978	water	03/01/03	Am-241	2.00 ± 0.10	2.13	0.79 - 1.41
STW-978	water	03/01/03	Co-60	221.30 ± 1.20	234.00	0.80 - 1.20
STW-978 <sup>d</sup>	water	03/01/03	Cs-134	23.30 ± 1.10	30.50	0.80 - 1.30
STW-978	water	03/01/03	Cs-137	61.40 ± 0.60	63.80	0.80 - 1.22
STW-978 <sup>e</sup>	water	03/01/03	H-3	341.90 ± 22.70	390.00	0.78 - 2.45
STW-978	water	03/01/03	Pu-238	3.70 ± 0.20	3.33	0.74 - 1.20
STW-978	water	03/01/03	Pu-239/40	4.40 ± 0.10	3.92	0.79 - 1.20
STW-978	water	03/01/03	Sr-90	4.60 ± 0.30	4.34	0.69 - 1.34
STW-978	water	03/01/03	Uranium	5.10 ± 0.60	4.29	0.75 - 1.33
STSO-979	soil	03/01/03	Ac-228	55.60 ± 2.50	57.60	0.80 - 1.38
STSO-979	soil	03/01/03	Am-241	12.42 ± 0.90	15.60	0.65 - 2.28
STSO-979	soil	03/01/03	Bi-212	57.70 ± 3.20	60.60	0.50 - 1.34
STSO-979	soil	03/01/03	Bi-214	60.40 ± 3.20	67.00	0.78 - 1.42
STSO-979	soil	03/01/03	Cs-137	1416.80 ± 70.00	1450.00	0.80 - 1.25
STSO-979	soil	03/01/03	K-40	653.80 ± 11.90	636.00	0.80 - 1.32
STSO-979	soil	03/01/03	Pb-212	51.10 ± 5.20	57.90	0.78 - 1.32
STSO-979	soil	03/01/03	Pb-214	64.70 ± 5.10	71.10	0.76 - 1.46
STSO-979	soil	03/01/03	Pu-239/40	24.40 ± 0.30	23.40	0.71 - 1.30
STSO-979	soil	03/01/03	Sr-90	54.50 ± 2.60	64.40	0.67 - 2.90
STSO-979	soil	03/01/03	Uranium	245.00 ± 1.50	249.00	0.71 - 1.32
STVE-980	Vegetation	03/01/03	Am-241	3.10 ± 0.20	3.51	0.73 - 2.02
STVE-980	Vegetation	03/01/03	Cm-244	1.40 ± 0.50	2.01	0.61 - 1.59
STVE-980	Vegetation	03/01/03	Co-60	12.60 ± 0.40	12.10	0.80 - 1.44
STVE-980	Vegetation	03/01/03	Cs-137	449.70 ± 6.20	444.00	0.80 - 1.31
STVE-980	Vegetation	03/01/03	K-40	1159.00 ± 38.60	1120.00	0.79 - 1.39
STVE-980	Vegetation	03/01/03	Pu-239/40	4.80 ± 0.40	5.17	0.69 - 1.31
STVE-980	Vegetation	03/01/03	Sr-90	659.70 ± 50.40	650.00	0.55 - 1.21
STAP-981	Air Filter	03/01/03	Am-241	0.27 ± 0.10	0.34	0.70 - 2.34
STAP-981	Air Filter	03/01/03	Co-60	30.20 ± 0.30	33.50	0.80 - 1.26
STAP-981	Air Filter	03/01/03	Cs-137	90.30 ± 1.30	99.70	0.80 - 1.32
STAP-981	Air Filter	03/01/03	Mn-54	41.80 ± 0.60	43.80	0.80 - 1.35
STAP-981	Air Filter	03/01/03	Pu-238	0.52 ± 0.10	0.52	0.67 - 1.33
STAP-981	Air Filter	03/01/03	Pu-239/40	0.35 ± 0.10	0.33	0.73 - 1.26
STAP-981	Air Filter	03/01/03	Sr-90	2.50 ± 0.10	2.80	0.53 - 1.84
STAP-981	Air Filter	03/01/03	Uranium	0.51 ± 0.10	0.50	0.79 - 2.10
STAP-982	Air Filter	03/01/03	Gr. Alpha	0.90 ± 0.10	1.17	0.73 - 1.43
STAP-982	Air Filter	03/01/03	Gr. Beta	1.50 ± 0.10	1.50	0.76 - 1.36

TABLE IV-7. Environmental Measurements Laboratory Quality Assessment Program (EML)

Lab Code	Type	Date	Analysis	Concentration <sup>a</sup>		
				Laboratory results	EML Result <sup>b</sup>	Control Limits <sup>c</sup>
STW-992	water	09/02/03	Am-241	9.78 ± 0.32	8.76	0.79 - 1.41
The September, 2003 results are preliminary. Control limits used were taken from the March, 2003 data. Control limits may vary slightly when the final study is published.						
STW-992	water	09/02/03	Co-60	468.30 ± 4.10	513.00	0.80 - 1.20
STW-992	water	09/02/03	Cs-134	53.90 ± 0.80	63.00	0.80 - 1.30
STW-992	water	09/02/03	Cs-137	76.10 ± 1.40	80.30	0.80 - 1.22
STW-992	water	09/02/03	H-3	355.20 ± 12.80	446.30	0.78 - 2.45
STW-992	water	09/02/03	Pu-238	1.71 ± 0.07	2.07	0.74 - 1.20
STW-992	water	09/02/03	Pu-239/40	4.24 ± 0.01	4.99	0.79 - 1.20
STW-992	water	09/02/03	Sr-90	6.70 ± 0.50	7.04	0.69 - 1.34
STW-992	water	09/02/03	Uranium	6.03 ± 0.14	5.69	0.75 - 1.33
STW-993	water	09/02/03	Gr. Alpha	688.00 ± 7.60	622.00	0.58 - 1.29
STW-993	water	09/02/03	Gr. Beta	1985.00 ± 111.00	1948.00	0.61 - 1.43
STSO-994	soil	09/02/03	Am-241	19.70 ± 1.50	18.40	0.65 - 2.28
STSO-994	soil	09/02/03	Cs-137	1928.00 ± 19.00	1973.00	0.80 - 1.25
STSO-994	soil	09/02/03	K-40	533.00 ± 79.00	488.00	0.80 - 1.32
STSO-994	soil	09/02/03	Pu-238	15.30 ± 0.80	14.60	0.59 - 2.88
STSO-994	soil	09/02/03	Pu-239/40	32.50 ± 2.30	30.40	0.71 - 1.30
STSO-994	soil	09/02/03	Sr-90	69.80 ± 2.30	80.30	0.67 - 2.90
STSO-994	soil	09/02/03	Uranium	228.30 ± 17.10	259.30	0.71 - 1.32
STAP-995	Air Filter	09/02/03	Am-241	0.64 ± 0.05	0.44	0.70 - 2.34
STAP-995	Air Filter	09/02/03	Co-60	48.50 ± 0.40	55.10	0.80 - 1.26
STAP-995	Air Filter	09/02/03	Cs-137	51.20 ± 1.10	54.80	0.80 - 1.32
STAP-995	Air Filter	09/02/03	Mn-54	53.70 ± 1.10	58.00	0.80 - 1.35
STAP-995	Air Filter	09/02/03	Pu-238	0.24 ± 0.05	0.23	0.67 - 1.33
STAP-995	Air Filter	09/02/03	Pu-239/40	0.41 ± 0.10	0.40	0.73 - 1.26
STAP-995	Air Filter	09/02/03	Sr-90	1.90 ± 0.10	2.06	0.53 - 1.84
STAP-995	Air Filter	09/02/03	Uranium	0.80 ± 0.06	0.82	0.79 - 2.10
STAP-996	Air Filter	09/02/03	Gr. Alpha	3.23 ± 0.07	3.11	0.73 - 1.43
STAP-996	Air Filter	09/02/03	Gr. Beta	4.18 ± 0.03	3.89	0.76 - 1.36

<sup>a</sup> Results are reported in Bq/L with the following exceptions: Air Filters (Bq/Filter), Soil and Vegetation (Bq/kg).

<sup>b</sup> The EML result listed is the mean of replicate determinations for each nuclide ± the standard error of the mean.

<sup>c</sup> Control limits are reported by EML as the ratio of Reported Value / EML value.

<sup>d</sup> A low bias for Cs-134 activity has been observed in the past. No errors have been found in the library or efficiency.

Additional spike analyses will be performed and a correction factored into the calculation.

<sup>e</sup> Reporting error.