



Entergy Operations, Inc.
Waterloo Road
P.O. Box 756
Port Gibson, MS 39150
Tel 601 437 6299

Charles A. Bottemiller
Manager
Plant Licensing

GNRO-2004/00036

May 24, 2004

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Document Control Desk

Subject: Technical Specification Bases Update to the NRC for Period Dated
May 24, 2004

Grand Gulf Nuclear Station
Docket No. 50-416
License No. NPF-29

Ladies and Gentlemen:

Pursuant to Grand Gulf Nuclear Station (GGNS) Technical Specification 5.5.11, Entergy Operations, Inc. hereby submits an update of all changes made to GGNS Technical Specification Bases since the last submittal (GNRO-2004/00014 letter dated February 12, 2004 to the NRC from GGNS). This update is consistent with update frequency listed in 10CFR50.71(e).

This letter does not contain any commitments.

Should you have any questions, please contact Michael Larson at (601) 437-6685.

Yours truly,

A handwritten signature in black ink, appearing to be "CAB".

CAB/MJL
attachment:
cc:

GGNS Technical Specification Bases Revised Pages
(See Next Page)

cc:

Hoeg	T. L.	(GGNS Senior Resident)	(w/a)
Levanway	D. E.	(Wise Carter)	(w/a)
Reynolds	N. S.		(w/a)
Smith	L. J.	(Wise Carter)	(w/a)
Thomas	H. L.		(w/o)

U.S. Nuclear Regulatory Commission ATTN: Mr. Bruce Mallett (w/2) 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011-4005	ALL LETTERS
U.S. Nuclear Regulatory Commission ATTN: Mr. Nageswaran Kalyanam, NRR/DLPM (w/2) ATTN: ADDRESSEE ONLY ATTN: Courier Delivery Only Mail Stop OWFN/7D-1 11555 Rockville Pike Rockville, MD 20852-2378	ALL LETTERS – COURIER DELIVERY (FEDEX, ETC.) ADDRESS ONLY - ****DO NOT USE FOR U.S. POSTAL SERVICE ADDRESS*****

ATTACHMENT to GNRO-2004/00036

Grand Gulf Technical Specification Bases Revised Pages

dated

May 24, 2004

LDC#	BASES PAGES AFFECTED	TOPIC of CHANGE
03025	B 3.7-24	Removal of excessive detail from Bases section to match NUREG 1434 Revision 2 wording.

BASES

ACTIONS B.1, B.2, B.3.1, and B.3.2 (continued)

An alternative to Required Actions B.1 and B.2 is to place the unit in a MODE in which the LCO does not apply. To achieve this status, the unit must be placed in at least MODE 3 within 12 hours and in MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner and without challenging unit systems.

SURVEILLANCE REQUIREMENTS SR 3.7.5.1 and 3.7.5.2

SR 3.7.5.2, on a 31 day Frequency, requires an isotopic analysis of an offgas sample to ensure that the required limits are satisfied. The noble gases to be sampled include Xe-133, Xe-135, Xe-138, Kr-85, Kr-87, and Kr-88. If the measured rate of radioactivity increases significantly (by $\geq 50\%$ after correcting for expected increases due to changes in THERMAL POWER), an isotopic analysis is also performed within 4 hours after the increase is noted as required by SR 3.7.5.1, to ensure that the increase is not indicative of a sustained increase in the radioactivity rate. The 31 day Frequency is adequate in view of other instrumentation that continuously monitor the offgas, and is acceptable based on operating experience.

SR 3.7.5.2 is modified by a Note indicating that the SR is not required to be performed until 31 days after any SJAE is in operation. Only in this condition can radioactive fission gases be in the Main Condenser Offgas System at significant rates.

- REFERENCES
1. UFSAR, Section 15.7.1.
 2. NUREG-0800.
 3. 10 CFR 100.
-