

#

~~SENSITIVE INFORMATION - FOR OFFICIAL USE ONLY~~

DAVIS-BESSE RESTART STATUS

This information is current as of 5:30 pm (EST) on February 19, 2004.

The plant is in Mode 3 maintaining Normal Operating Pressure/Normal Operating Temperature. (NOP/NOT - 532°F/2155 psig). The licensee expects to maintain the plant in these conditions until restart.

The 0350 Panel activities remain focused on restart deliberations. The final SERP was conducted on February 19 for the High Pressure Injection pump Greater than Green issue, with a final significance determination of White. Region III plans to issue the final significance letter and Notice of Violation in the next 2 weeks.

LICENSEE ACTIVITIES PRIOR TO RESTART

The licensee is currently tracking outstanding activities that need to be completed prior to restart [Mode 2/1]. There are approximately 24 restart items.

- Corrective Actions: 7
- Condition Reports: 7
- Field Work: 7
- Post Maintenance Tests: 2
- Surveillance Tests: 1

NRC ACTIVITIES PRIOR TO RESTART

Below is a simplified time line that describes the significant NRC and licensee activities and milestones that are necessary for NRC to authorize restart.

These tentative dates are predicated upon the licensee successfully completing NRC pre-restart activities and demonstrating acceptable operating performance. Key Agency decision points are annotated with asterisks (**) in the timeline below. The outcome of each decision point could materially alter the timing and substance of the rest of the schedule.

The details of these activities are described in three internal NRC documents: the Davis-Besse Oversight Panel Process Plan, the Davis-Besse Restart Communications Plan and the Davis-Besse Restart Punch List.




Panel deliberations on restart decision
Panel briefing for Jim Caldwell, Jim Dyer, and Sam Collins on restart deliberations
Panel issues restart recommendation to Jim Caldwell
Panel briefing for Commissioners' TAs
Jim Caldwell issues draft Order to licensee (for affirmation/hearing declination)
Licensee affirms conditions of Order and declines hearing
Finalize restart authorization letter and Order (letter to be signed by Jim Caldwell; will authorize restart and transmit the Order - Order to be signed by Jim Dyer)

5
1-12

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 5

~~SENSITIVE INFORMATION - FOR OFFICIAL USE ONLY~~

FOIA- 2004-140



SENSITIVE INFORMATION - FOR OFFICIAL USE ONLY

Implement Restart Communications Plan (1-day Enforcement Notification)
Issue restart authorization letter and Order
Implement restart inspection plan

15

CHALLENGES THAT THE LICENSEE IS CURRENTLY ADDRESSING

None at this time.

LICENSEE ACTIVITIES FOLLOWING RESTART AUTHORIZATION

The following sequence of events were taken from a licensee Level 1 schedule.

NRC approval for restart
Enter operational Mode 2 (reactor startup)
Reactor critical - Zero power physics testing
Enter Mode 1 (greater than 5% power)
Readiness and effectiveness review prior to synch to the grid
Synch to the grid
Readiness and effectiveness review prior to exceeding 50% power
Reactor at 100% power

SENSITIVE INFORMATION - FOR OFFICIAL USE ONLY