



NOTES:
1. FOR ADDITIONAL NOTES, SEE FB-27K.

RACK LOCATION (FB-27K)	REQD HALON BOTTLE WEIGHT	TURBINE BLOC LOCATION	DETAIL NUMBER	TANK NO.					CHECK VLV NO.	MANUAL PNEUMATIC ACTUATOR
				1	2	3	4	5		
A1	240	UNIT 1	1	1-FP-TK-101	1-FP-PI-201	1-FP-SOV-456	1-FP-456	1-FP-MVA-456		
A2	240	UNIT 1	2	1-FP-TK-102	1-FP-PI-202	1-FP-SOV-457	1-FP-457	1-FP-MVA-457		
B1	335	UNIT 1	1	1-FP-TK-103	1-FP-PI-203	1-FP-SOV-458	1-FP-458	1-FP-MVA-458		
B2	335	UNIT 1	2	1-FP-TK-104	1-FP-PI-204	1-FP-SOV-459	1-FP-459	1-FP-MVA-459		
B3	335	UNIT 1	3	1-FP-TK-105	1-FP-PI-205	1-FP-SOV-460	1-FP-460	1-FP-MVA-460		
C1	335	UNIT 1	1	1-FP-TK-106	1-FP-PI-206	1-FP-SOV-461	1-FP-461	1-FP-MVA-461		
C2	335	UNIT 1	2	1-FP-TK-107	1-FP-PI-207	1-FP-SOV-462	1-FP-462	1-FP-MVA-462		
C3	335	UNIT 1	3	1-FP-TK-108	1-FP-PI-208	1-FP-SOV-463	1-FP-463	1-FP-MVA-463		
D1	335	UNIT 2	1	2-FP-TK-109	2-FP-PI-209	2-FP-SOV-464	2-FP-464	2-FP-MVA-464		
D2	335	UNIT 2	2	2-FP-TK-110	2-FP-PI-210	2-FP-SOV-465	2-FP-465	2-FP-MVA-465		
D3	335	UNIT 2	3	2-FP-TK-111	2-FP-PI-211	2-FP-SOV-466	2-FP-466	2-FP-MVA-466		
E1	335	UNIT 2	3	2-FP-TK-112	2-FP-PI-212	2-FP-SOV-467	2-FP-467	2-FP-MVA-467		
E2	335	UNIT 2	2	2-FP-TK-113	2-FP-PI-213	2-FP-SOV-468	2-FP-468	2-FP-MVA-468		
E3	335	UNIT 2	1	2-FP-TK-114	2-FP-PI-214	2-FP-SOV-469	2-FP-469	2-FP-MVA-469		
F1	240	UNIT 2	4	2-FP-TK-115	2-FP-PI-215		2-FP-470			
F2	240	UNIT 2	5	2-FP-TK-116	2-FP-PI-216	2-FP-SOV-471	2-FP-471	2-FP-MVA-471		
F3	240	UNIT 2	1	2-FP-TK-117	2-FP-PI-217	2-FP-SOV-472	2-FP-472	2-FP-MVA-472		
G1	N/A	UNIT 1	6	1-FP-TK-118	1-FP-PI-218					
G2	N/A	UNIT 1	6	1-FP-TK-119	1-FP-PI-219					
G3	N/A	UNIT 1	6	1-FP-TK-120	1-FP-PI-220					
G4	N/A	UNIT 1	6	1-FP-TK-121	1-FP-PI-221					
G5	N/A	UNIT 1	6	1-FP-TK-122	1-FP-PI-222					
G6	N/A	UNIT 1	6	1-FP-TK-123	1-FP-PI-223					
G7	N/A	UNIT 1	6	1-FP-TK-124	1-FP-PI-224					
G8	N/A	UNIT 1	6	1-FP-TK-125	1-FP-PI-225					
G9	N/A	UNIT 1	6	1-FP-TK-126	1-FP-PI-226					

D-04

VIRGINIA POWER NORTH CAROLINA POWER
 NUCLEAR ENGINEERING SERVICES
 RICHMOND, VIRGINIA

FIRE PROTECTION SERVICE BUILDING
 SURRY POWER STATION - UNIT 1 & 2

REVISOR: EES SOW
 DATE: 10/19/98
 DRAWN: RPD
 ENGR SUPV: _____
 CAD NO.: C:\usr\dgn\27K106No01
 DRAWING NO.: 11448-FB-27K1
 REV. 1

SCALE: NONE
 UNLESS OTHERWISE NOTED

VERIFY print 24 hrs after 8:30:45 AM 05/06/2004