SH 1 OF 1

DRAWING NO: 11448-FB-27A

REV 16

CALLED NORTH

RELAY ROOM No 1

RELAY ROOM No 2

MECH EQUIP ROOM

PIPE TUNNEL

PLAN - SWITCHGEAR & RELAY ROOMS EL 9'-6"

SECT M-M (E-2)

B - B (G-5)

C - C (H-6 & I-5) (FB-27B, A-3) (FB-27A1, C-5 & D-4)

D - D (G-2)

E - E (A-2)

F - F (H-6)

A - A (C-6)

NOTES

GENERAL NOTES & LEGEND FB-27C

CHILLED WATER LINES TO BE CLASS 151 WITH TYPE 'J' INSULATION

A. FLOOR DRAIN - 4" JOSAM STRAINER & JOSAM FLOOR DRAIN (FLAP TYP)

B. FLOOR DRAIN - 4" FLOAT VV BACKWATER SEWER STOP.

HALON GAS - FIRE PROTECTION - NOTES FB-27K

D-06

VIRGINIA POWER
NORTH CAROLINA POWER
NUCLEAR ENGINEERING SERVICES
RICHMOND, VIRGINIA

PLUMBING & FIRE PROTECTION
SERVICE BUILDING
SURRY POWER STATION - UNIT 1

REVISION DESCRIPTION	CAD NO: C:\usr\dgn\27AHYBt61	
REVISED PER ENGINEERING REVIEW. (DCR 02-0394)	DRAWING NO: 11448-FB-27A	REV 16
DSGN GWB	SCALE: 1/4" = 1'-0" UNLESS OTHERWISE NOTED	SH 1 OF 1

PC-SEF & SP1

VERIFY print 24 hrs after 8:29:59 AM05/06/2004

WAYNE89
29-MAY-2002 09:32
C:\usr\dgn\27AHYBt61

PRIOR TO USING FOR DESIGN WORK CHECK DMIS FOR WORK PENDING