


PLAN - EL. 9'-6"

NOTES

1. FOR GENERAL NOTES SEE NOTES AND REFERENCES SH 1
2. BATTERY RM ROOF SEPARATES BATTERY RM FROM FIRE AREA 3.

1. AUXILIARY SHUTDOWN PANEL - UNIT 1
3. APPENDIX R ISOLATION PANEL - UNIT 1 (1-AS-1)
4. D.C. SWBD 1B
5. D.C. SWBD 1A
6. BKR-15H10 (1-CC-P-1A)
7. BKR-15H11 (1-RH-P-1A)
8. BKR-15J10 (1-CC-P-1B)
9. BKR-15J11 (1-RH-P-1B)
10. "1H" 4KV SWITCHGEAR (1-CH-P-1A, 1-CH-P-1C, & 1-FW-P-3A)
11. "1J" 4KV SWITCHGEAR (1-CH-P-1B, 1-CH-P-1C, & 1-FW-P-3B)
12. BKR-15J3 (DIESEL GENERATOR NO. 3)
13. 480V MCC 1H1-1
14. 480V MCC 1J1-1
15. 480V LOAD CTR 1H
16. 480V LOAD CTR 1J
17. TRANSFORMER 1H-1
18. TRANSFORMER 1J-1
19. UPS 1A-1
20. UPS 1A-2
21. UPS 1B-1
22. UPS 1B-2
23. DC SWBD SUB PNL 1A
24. DC SWBD SUB PNL 1B
25. 1-EE-DIP-ESRH-DIESEL ISOLATION PANEL, INCLUDING EXCORE FLUX MON PWR SUPPLY XFR SWITCH
26. TELECOMMUNICATIONS REMOTE CONTROL STATION
27. TELECOMMUNICATIONS REMOTE ANTENNA
36. VACUUM BREAKER TRIP VALVES (1-IA-1267, -1268, -1269, & -1270)
T. TELECOMMUNICATIONS HANDSET & BACKUP SYSTEM PAGING
31. 01-EPL-BKR-150
32. 01-EPL-BKR-151
33. 01-EPL-CS-100
34. 01-EPL-MCC-1K1

1 - 2 01-FP-FBAR-009ESGR01
2 - 4 01-FP-FBAR-009ESGR02
4 - 5 01-FP-FBAR-013AB02
6 - 7 01-FP-FBAR-013AB09
3 - 4 01-FP-FBAR-009CT01
3 - 8 01-FP-FBAR-009CT02
8 - 9 01-FP-FBAR-009CT03
9 - 10 01-FP-FBAR-009CT04
9 - 11 01-FP-FBAR-009ESGR03
11 - 12 01-FP-FBAR-009ESGR04
12 - 20 01-FP-FBAR-009ESGR05
17 - 20 01-FP-FBAR-009ESGR06
13 - 17 01-FP-FBAR-009ESGR07
14 - 15 01-FP-FBAR-009BTR01
14 - 16 01-FP-FBAR-009BTR02
15 - 17 01-FP-FBAR-009BTR03
16 - 17 01-FP-FBAR-009BTR04
16 - 18 01-FP-FBAR-009BTR05
18 - 19 01-FP-FBAR-009BTR06
17 - 19 01-FP-FBAR-009BTR07
7 - 10 01-FP-FBAR-009CT05
21 01-FP-FBAR-009BTR08
22 01-FP-FBAR-009BTR09

D-10

**VIRGINIA POWER**
**NORTH CAROLINA POWER**
NUCLEAR ENGINEERING SERVICES
RICHMOND, VIRGINIA

EQUIPMENT LOCATION - APPENDIX 'R'
SERVICE BUILDING
PLAN - EL. 9'-6"
SURRY POWER STATION UNIT 1

| REVISION DESCRIPTION (SIGNATURES ON FILE) | CAD NO: C:\usr\dgn\206S07DGNm51 | |
|---|---|---|
| REVISED PER ENGINEERING REVIEW. (DCR 00-2470) | DRAWING NO: 11448-FAR-206 | REV 15 |
| DSGN LML | SCALE: 3/8" = 1'-0" UNLESS OTHERWISE NOTED | SH 7 OF 11 |

PC=MF1 & MP1

VERIFY print 24 hrs after 8:26:11 AM05/06/2004
LUOTOL
29-JAN-2001 14:54
C:\usr\dgn\206S07DGNm51
PRIOR TO USING FOR DESIGN WORK CHECK DMIS FOR WORK PENDING