



PLAN - EL. 9'-6"

NOTES

- FOR GENERAL NOTES SEE NOTES AND REFERENCES SH 1
- BATTERY RM ROOF SEPARATES BATTERY RM FROM FIRE AREA 3.

- △ AUXILIARY SHUTDOWN PANEL - UNIT 1
- △ APPENDIX R ISOLATION PANEL - UNIT 1 (1-AS-1)
- △ D.C. SWBD 1B
- △ D.C. SWBD 1A
- △ BKR-15H10 (1-CC-P-1A)
- △ BKR-15H11 (1-RH-P-1A)
- △ BKR-15J10 (1-CC-P-1B)
- △ BKR-15J11 (1-RH-P-1B)
- △ 11J 4KV SWITCHGEAR (1-CH-P-1A, 1-CH-P-1C, & 1-FW-P-3A)
- △ 11J 4KV SWITCHGEAR (1-CH-P-1B, 1-CH-P-1C, & 1-FW-P-3B)
- △ BKR-15J3 (DIESEL GENERATOR NO. 3)
- △ 480V MCC 1H-1
- △ 480V MCC 1J-1
- △ 480V LOAD CTR 1H
- △ 480V LOAD CTR 1J
- △ TRANSFORMER 1H-1
- △ TRANSFORMER 1J-1
- △ UPS 1A-1
- △ UPS 1A-2
- △ UPS 1B-1
- △ UPS 1B-2
- △ DC SWBD SUB PNL 1A
- △ DC SWBD SUB PNL 1B
- △ 1-EE-DIP-ESRH-DIESEL ISOLATION PANEL, INCLUDING EXCORE FLUX MON PWR SUPPLY XFR SWITCH
- △ TELECOMMUNICATIONS REMOTE CONTROL STATION
- △ TELECOMMUNICATIONS REMOTE ANTENNA
- △ VACUUM BREAKER TRIP VALVES (1-1A-1267, -1268, -1269, & -1270)
- △ TELECOMMUNICATIONS HANSET & BACKUP SYSTEM PAGING
- △ 01-EPL-BKR-150
- △ 01-EPL-BKR-151
- △ 01-EPL-CS-100
- △ 01-EPL-MCC-1K1

- 1 - 2 01-FP-FBAR-009ESGR01
- 2 - 4 01-FP-FBAR-009ESGR02
- 4 - 5 01-FP-FBAR-013AB02
- 6 - 7 01-FP-FBAR-013AB09
- 3 - 4 01-FP-FBAR-009CT01
- 3 - 8 01-FP-FBAR-009CT02
- 8 - 9 01-FP-FBAR-009CT03
- 9 - 10 01-FP-FBAR-009CT04
- 9 - 11 01-FP-FBAR-009ESGR03
- 11 - 12 01-FP-FBAR-009ESGR04
- 12 - 20 01-FP-FBAR-009ESGR05
- 17 - 20 01-FP-FBAR-009ESGR06
- 13 - 17 01-FP-FBAR-009ESGR07
- 14 - 15 01-FP-FBAR-009BTR01
- 14 - 16 01-FP-FBAR-009BTR02
- 15 - 17 01-FP-FBAR-009BTR03
- 16 - 17 01-FP-FBAR-009BTR04
- 16 - 18 01-FP-FBAR-009BTR05
- 18 - 19 01-FP-FBAR-009BTR06
- 17 - 19 01-FP-FBAR-009BTR07
- 7 - 10 01-FP-FBAR-009CT05
- 21 01-FP-FBAR-009BTR08
- 22 01-FP-FBAR-009BTR09

D-10

VIRGINIA POWER NORTH CAROLINA POWER NUCLEAR ENGINEERING SERVICES RICHMOND, VIRGINIA		
EQUIPMENT LOCATION - APPENDIX 'R' SERVICE BUILDING PLAN - EL. 9'-6" SURRY POWER STATION UNIT 1		
REVISION DESCRIPTION (SIGNATURES ON FILE) REVISED PER ENGINEERING REVIEW. (DCR 00-2470)	CAD NO: C:\usr\adgn\20650700\m51 DRAWING NO: 11448-FAR-206	REV 15
DSCR UML SCALE: 3/8" = 1'-0" UNLESS OTHERWISE NOTED SH 7 OF 11		

VERIFY print 24 hrs after 8:26:11 AM 05/06/2004