

s. Primary Coolant Outside Containment (Section 22.2, III.D.1.1)

Prior to exceeding 5 percent power level, TVA is required to complete the leak tests on Unit 2, and results are to be submitted within 30 days from the completion of the testing.

(17) Surveillance Interval Extension

The performance interval for the 36-month surveillance requirements in TS 4.3.2.1.3 shall be extended to May 18, 1996, to coincide with the Cycle 7 refueling outage. The extended interval shall not exceed a total of 50 months for the 36-month surveillances.

(18) Mixed Core DNBR Penalty

TVA will obtain NRC approval prior to startup for any cycle's core that involves a reduction in the departure from nucleate boiling ratio initial transition core penalty below that value stated in TVA's submittal on Framatome fuel conversion dated April 6, 1997.

(19) Steam Generator Replacement Project

During the Unit 1 Cycle 12 refueling and steam generator replacement outage, lifts of heavy loads will be performed in accordance with Table 3.1 of NRC Safety Evaluation dated March 26, 2003.

(20) Control Room Air-Conditioning System Maintenance

TVA commits to the use of a portable chiller package and air-handling unit to provide alternate cooling if both trains of the control room air condition system become inoperable during the maintenance activities to upgrade the compressors and controls or immediately enter Technical Specification 3.0.3.

- D. Exemptions from certain requirements of Appendices G and J to 10 CFR Part 50 are described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplements No. 1 and No. 5. These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. Therefore, these exemptions are hereby granted. The facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission.

A temporary exemption from General Design Criterion 57 found in Appendix A to 10 CFR part 50 is described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplement No. 5, Section 6.2.4. This exemption is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest. The exemption, therefore, is hereby granted and shall remain in effect through the first refueling outage as discussed in Section 6.2.4 of Supplement 5 to the Safety Evaluation Report. The granting of the exemption is authorized with the issuance of the Facility Operating License. The facility will operate, to the extent authorized herein, in conformity with the application as amended, the provisions of the Act, and the regulations of the Commission. Additional Exemptions are listed in Attachment 2.

E. Physical Protection

The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revision to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR

50.90 and 10 CFR 50.54(p). The Safeguards Contingency Plan is incorporated into the Physical Security Plan. The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "Sequoyah Physical Security Plan," with revisions submitted through November 23, 1987; and "Sequoyah Security Personnel Training and Qualification Plan," with revisions submitted through April 16, 1987. Changes made in accordance with 10 CFR 73.55 shall be implemented in accordance with the schedule set forth therein.

F. Reactor Safety Methodology Applications Programs (Section 24.0)

TVA will provide a report prepared by the Kaman Sciences Corporation (KSC) on a full scale nuclear safety and availability analysis within six months from the date of the KSC report.

G. This amended license is subject to the following additional condition for the protection of the environment:

Before engaging in additional construction or operational activities which may result in an environmental impact that was not evaluated by the Commission, Tennessee Valley Authority will prepare and record an environmental evaluation of such activity. When the evaluation indicates that such activity may result in a significant adverse environmental impact that was not evaluated, or that is significantly greater than that evaluated in the Final Environmental Statement prepared by the Tennessee Valley Authority and the Environmental Impact Appraisal prepared by the Commission in May 1979, the Tennessee Valley Authority shall provide a written evaluation of such activities and obtain prior approval from the Director, Office of Nuclear Reactor Regulation.

H. Deleted

I. TVA shall immediately notify the Commission of any accident at this facility which could result in an unplanned release of quantities of fission products in excess of allowable limits for normal operation established by the Commission.

J. TVA shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.

PLANT SYSTEMS

3/4.7.15 CONTROL ROOM AIR-CONDITIONING SYSTEM (CRACS)

LIMITING CONDITION FOR OPERATION

---

3.7.15 Two independent control room air-conditioning systems (CRACS) shall be OPERABLE.

APPLICABILITY: ALL MODES and during movement of irradiated fuel assemblies

ACTION:

MODES 1, 2, 3, or 4

- a. With one CRACS inoperable, restore the inoperable system to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With both CRACS inoperable, immediately enter LCO 3.0.3.\*

MODES 5 or 6, or during movement of irradiated fuel assemblies

- a. With one CRACS inoperable, restore the inoperable system to OPERABLE status within 30 days or initiate and maintain operation of the OPERABLE CRACS  
or  
suspend movement of irradiated fuel assemblies.
- b. With both CRACS inoperable, suspend movement of irradiated fuel assemblies.

SURVEILLANCE REQUIREMENTS

---

4.7.15 Each CRACS shall be demonstrated OPERABLE:

- a. At least once per 18 months by verifying each CRACS train has the capability to remove the assumed heat load.

---

\* An allowance to monitor control room temperature every four hours and verify less than or equal to 90 degrees Fahrenheit is permitted for up to seven days in lieu of the immediate entry into LCO 3.0.3. If control room temperature exceeds 90 degrees Fahrenheit or the duration without a train of CRACS being OPERABLE exceeds seven days, the immediate entry into LCO 3.0.3 will be required. This provision is only applicable during maintenance activities planned for the upgrade of the CRACS compressors and controls and expires on March 31, 2005.