

ACTIONS

-----NOTE-----
 LCO 3.0.4.b is not applicable when entering MODE 4.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. Two centrifugal charging pumps capable of injecting into the RCS.</p> <p><u>OR</u></p> <p>One centrifugal charging pump and one safety injection pump capable of injecting into the RCS.</p> <p><u>OR</u></p> <p>Two safety injection pumps capable of injecting into the RCS.</p>	<p>A.1 -----NOTE----- Two centrifugal charging pumps may be capable of injecting into the RCS during pump swap operation for ≤ 15 minutes. ----- Initiate action to verify a maximum of one centrifugal charging pump or one safety injection pump is capable of injecting into the RCS.</p> <p><u>OR</u></p> <p>A.2.1 Verify RHR suction relief valve is OPERABLE and the suction isolation valves are open.</p> <p><u>AND</u></p> <p>A.2.2.1 Verify RCS cold leg temperature $> 174^{\circ}\text{F}$ (Unit 1) or $> 89^{\circ}\text{F}$ (Unit 2).</p> <p><u>OR</u></p> <p>A.2.2.2 Verify RCS cold leg temperature $> 74^{\circ}\text{F}$ and cooldown rate $< 20^{\circ}\text{F/hr}$ (Unit 1), or $> 74^{\circ}\text{F}$ and cooldown rate $< 60^{\circ}\text{F/hr}$ (Unit 2).</p> <p><u>OR</u></p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p> <p>Immediately</p> <p>(continued)</p>