

ACTIONS

-----NOTE-----  
 LCO 3.0.4.b is not applicable when entering MODE 4.  
 -----

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. Two centrifugal charging pumps capable of injecting into the RCS.</p> <p><u>OR</u></p> <p>One centrifugal charging pump and one safety injection pump capable of injecting into the RCS.</p> <p><u>OR</u></p> <p>Two safety injection pumps capable of injecting into the RCS.</p>	<p>A.1 -----NOTE-----            Two centrifugal charging pumps may be capable of injecting into the RCS during pump swap operation for <math>\leq 15</math> minutes.            -----            Initiate action to verify a maximum of one centrifugal charging pump or one safety injection pump is capable of injecting into the RCS.</p> <p><u>OR</u></p> <p>A.2.1 Verify RHR suction relief valve is OPERABLE and the suction isolation valves are open.</p> <p><u>AND</u></p> <p>A.2.2.1 Verify RCS cold leg temperature <math>&gt; 174^{\circ}\text{F}</math> (Unit 1) or <math>&gt; 89^{\circ}\text{F}</math> (Unit 2).</p> <p><u>OR</u></p> <p>A.2.2.2 Verify RCS cold leg temperature <math>&gt; 74^{\circ}\text{F}</math> and cooldown rate <math>&lt; 20^{\circ}\text{F/hr}</math> (Unit 1), or <math>&gt; 74^{\circ}\text{F}</math> and cooldown rate <math>&lt; 60^{\circ}\text{F/hr}</math> (Unit 2).</p> <p><u>OR</u></p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p> <p>Immediately</p> <p>(continued)</p>