

REACTOR VESSEL HEAD PSV EQUIPMENT PIECE LIST						
P.S.V. NO.	TE	TAH	FT	FAH	FIAH	
01-119 A (NR-28 A)	36-75A (IA01-63)	E319	27	27 A	27 B	
01-119 B (NR-28 B)	36-75B (IA01-68)	E309	28	28 A	28 B	
01-119 C (NR-28 C)	36-75C (IA01-54)	E310	29	29 A	29 B	
01-119 D (NR-28 D)	36-75D (IA01-55)	E311	30	30 A	30 B	
01-119 F (NR-28 F)	36-75F (IA01-57)	E313	32	32 A	32 B	
01-119 G (NR-28 G)	36-75G (IA01-58)	E314	33	33 A	33 B	
01-119 H (NR-28 H)	36-75H (IA01-59)	E315	34	34 A	34 B	
01-119 J (NR-28 J)	36-75J (IA01-60)	E316	35	35 A	35 B	
01-119 M (NR-28 M)	36-75M (IA01-62)	E318	37	37 A	37 B	
			SYS. 01			

ELECTROMATIC P.S.V. EQUIPMENT PIECE LIST			
P.S.V. NO.	FT	FAH	FIAH
01-102A (NR-108A)	19	19A	19B
01-102B (NR-108B)	20	20A	20B
01-102C (NR-108C)	21	21A	21B
01-102D (NR-108D)	22	22A	22B
01-102E (NR-108E)	23	23A	23B
01-102F (NR-108F)	24	24A	24B
	SYS. 66		

REACTOR PROTECTION SYSTEM DEVICES				
DEVICE		CONDITION	SET POINT IND. SCALE	ACTION
COLUMN 11	COLUMN 12			
01-26A,B,C,D	01-26E,F,G,H	MAIN STEAM EXCESS FLOW	<105 PSID	ACTUATE M.S.I.V.

ELECTROMATIC RELIEF VALVE SETTINGS		
01-102A (NR-108A)	01-102D (NR-108D)	1090 PSIG
01-102B (NR-108B)	01-102C (NR-108C)	1095 PSIG
01-102E (NR-108E)	01-102F (NR-108F)	1100 PSIG

SETTINGS ON SAFETY VALVES 01-119
3 SET AT 1218 PSIG
2 SET AT 1227 PSIG
2 SET AT 1236 PSIG
1 SET AT 1245 PSIG
1 SET AT 1254 PSIG

REFERENCE DWG.'S
G.E. 713E812 REV. 6
G.E. 713E812 REV. 3
G.E. 713E812 REV. 4

NOTES:
(1) FOR OPERATION OF MECHANICAL PRESSURE REGULATORS; STOP, CONTROL, AND BYPASS VALVES. SEE G.E. DWG. 186R999, SHEETS 1&2 (GEK-5524)
(2) PERFORMANCE CALCULATION INPUT BY G.E.
(3) REMOVABLE (FOR TEST ONLY)
(4) LOCATED NEAR CONDENSER
(5) ALSO LIMITS MAX. FLOW
(6) TYPICAL FOR VALVES 01-07, 01-08, 01-09, 01-10, 01-11, 01-12 —||— FLG. CONN. FOR PIPE REMOVAL
(7) FURNISHED BY G.E. (SCHENECTADY)
(8) LOCATED ON REHEATER OPERATING PANEL (IN)
(9) DELETED BY DCR N19500ILG056
(10) MOUNTED IN TRANSDUCER CAB #12
(11) LOCATED IN AUX. CONTROL ROOM
(12) FOR INST. AIR AND ASSOCIATED EQUIP. FOR IV 01-03 & 04, SEE DWG. B-22109-C SH.3 (518.8)
(13) SEE TYPICAL DETAIL AT A-6, THIS DWG.
(14) FOR INSTRUMENTATION VALVE SCHEDULE SEE DWG. F-45136-C
(15) FOR INSTRUMENT DIAGRAM, SEE DWG. B-69002-C SH. 1-3 AND A-69002-C SH.4.
(16) POS-01-07A, POS-01-08A, POS-01-09A, POS-01-10A, POS-01-11A AND POS-01-12A ARE RETIRED IN PLACE

LR NOTE: PLEASE REFER TO DRAWING LR-18000-C SHEETS 1 AND 2 FOR LR BOUNDARY DRAWING NOTES, SYMBOLS, AND ACRONYMS.

REV	DATE	BY	REMARKS	CK	APP	MF
0						

...\LR-18002-C_001.dgn 5/16/2004 9:40:06 AM

D 004