

5.5 Programs and Manuals (continued)

5.5.12 Primary Containment Leakage Rate Testing Program

A program shall be established to implement the leakage rate testing of the primary containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be in accordance with the guidelines contained in Regulatory Guide 1.163, "Performance-Based Containment Leak-Test Program," dated September 1995.

The peak calculated primary containment internal pressure for the design basis loss of coolant accident, P_a , is 47.3 psig.

The maximum allowable primary containment leakage rate, L_a , at P_a is 1.2% of primary containment air weight per day.

Leakage rate acceptance criteria are:

- a. Primary containment overall leakage rate acceptance criterion is $\leq 1.0 L_a$. During the first unit startup following testing in accordance with this program, the leakage rate acceptance criteria are $\leq 0.60 L_a$ for the combined Type B and Type C tests, and $\leq 0.75 L_a$ for Type A tests;
- b. Air lock testing acceptance criteria are:
 - 1) Overall air lock leakage rate is $\leq 0.05 L_a$ when tested at $\leq P_a$,
 - 2) For each door, leakage rate is $\leq 0.01 L_a$ when the gap between the door seals is pressurized to ≥ 10 psig for at least 15 minutes.

The provisions of SR 3.0.2 do not apply to the test frequencies specified in the Primary Containment Leakage Rate Testing Program.

(continued)