



LR NOTES:
PLEASE REFER TO DRAWING LR-18000-C SHEETS 1 AND 2 FOR
LR BOUNDARY DRAWING NOTES, SYMBOLS, AND ACRONYMS.

- NOTES:**
- 1) SEE C-18002-C SHEET 3 FOR EP NUMBER.
 - 2) TYPICAL FOR ALL VALVES SO NOTED
 - 3) SEE C-18005-C SHEET 2 FOR EP NUMBERS
 - 4) NEW PIPE (Ø) INSTALLED UP TO FIRST ISOLATION VALVE.
 - 5) VALVES 48-82 AND 48-12 ARE LOCKED OPEN VIA VALVE MOTOR STARTER CIRCUIT BREAKER.
 - 6) VALVE FAILS CLOSED ON LOSS OF POWER.
 - 7) FOR INSTR. AIR AND ASSOCIATED EQUIPMENT FOR IV 81-83 & 81-84, REFER TO DRAWING B-22189-C SHEET 3 (S18.8).
 - 8) FOR INSTRUMENTATION VALVE SCHEDULE, SEE DWG. F-45136-C.
 - 9) FOR INSTRUMENT DIAGRAM, SEE DWG. A-69806-C SH.1-3.
 - 10) POS-81-07A, POS-81-08A, POS-81-09A, POS-81-10A, POS-81-11A AND POS-81-12A ARE RETIRED IN PLACE

NOTE: THIS DRAWING WAS CREATED USING
COMPUTER AIDED DRAFTING
DO NOT MAKE MANUAL CHANGES

| | | | |
|---------------------------------------------------------------|-------|------------------------------------------------|------------|
| | | STA NINE MILE POINT NUCLEAR STATION UNIT NO. 1 | |
| DRYWELL & TORUS ISOLATION VALVES P & I DIAGRAM | | | |
| APP | APP | DATE | INDEX |
| DES | DR | OR | SH |
| REV | SCALE | DWG NO | REV |
| | NONE | LR-18006-C | 3-N2-S18.8 |
| REV | DATE | BY | REMARKS |
| | | | |

D010