



TURBINE BLDG.  
(5,400 CFM)

NOTES:  
(1) THE HVAC FLOW RATES LISTED ON THIS P&I ARE SYSTEM DESIGN TARGET VALUES TO BE USED AS REFERENCE POINTS FOR INITIAL AND/OR PERIODIC FLOW BALANCING AND ARE NOT LIMITING REQUIRED VALUES.

LR NOTE:  
PLEASE REFER TO DRAWING LR-18000-C SHEETS 1 AND 2 FOR LR BOUNDARY DRAWING NOTES, SYMBOLS, AND ACRONYMS.

NOTE: THIS DRAWING WAS CREATED USING COMPUTER AIDED DRAFTING. DO NOT MAKE MANUAL CHANGES.

CONSTELLATION ENERGY GROUP		NINE MILE POINT NUCLEAR STATION UNIT NO. 1	
APP AL/RMC	ET	OFF-GAS BUILDING	
APP LHM	APP CSB	VENTILATION SYSTEMS	
APP	DATE 5-22-74	P & I DIAGRAM	
DES	DFB	DWG NO LR-18021-C	INDEX 3-N2-S10
SCALE	NONE	SHEET 3	REV 0

REV	DATE	BY	REMARKS	CK	APP	MF

D046