

June 3, 2004

Mr. R. T. Ridenoure  
Division Manager - Nuclear Operations  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: CORRECTION OF AMENDMENT NO. 223 TO RENEWED FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. MB7499)

Dear Mr. Ridenoure:

On November 10, 2003, the Commission issued Amendment No. 223 to Renewed Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. The amendment deleted Technical Specification 2.3(2)i) and the corresponding Bases that allows the performance of the surveillance test of Table 3-2, Item 20 (Recirculation Actuation Logic Channel Functional Test) under administrative controls, while components in excess of those allowed by Conditions a, b, d, and e of TS 2.3(2) are inoperable, provided they are returned to operable status within one hour. This amendment was in response to your application dated January 27, 2003, and its supplement dated October 14, 2003.

On November 4, 2003, the Commission issued Renewed Facility Operating License No. DPR-40 along with Appendix A, "Technical Specifications," and Appendix B, "Additional Conditions." The technical specifications (TS) pages that were issued within Amendment No. 223 do not match the TSs that were issued with the renewed facility operating license. Therefore, enclosed are: (1) a revised insert/remove page, and (2) revised TS pages.

We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

Alan Wang, Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosures: 1. Insert/Remove Page  
2. TS Pages 2-3 - Page 3 and 2-3 - Page 7

cc w/encls: See next page

June 3, 2004

Mr. R. T. Ridenoure  
Division Manager - Nuclear Operations  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
Post Office Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: CORRECTION OF AMENDMENT NO. 223 TO RENEWED FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. MB7499)

Dear Mr. Ridenoure:

On November 10, 2003, the Commission issued Amendment No. 223 to Renewed Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. The amendment deleted Technical Specification 2.3(2)i) and the corresponding Bases that allows the performance of the surveillance test of Table 3-2, Item 20 (Recirculation Actuation Logic Channel Functional Test) under administrative controls, while components in excess of those allowed by Conditions a, b, d, and e of TS 2.3(2) are inoperable, provided they are returned to operable status within one hour. This amendment was in response to your application dated January 27, 2003, and its supplement dated October 14, 2003.

On November 4, 2003, the Commission issued Renewed Facility Operating License No. DPR-40 along with Appendix A, "Technical Specifications," and Appendix B, "Additional Conditions." The technical specifications (TS) pages that were issued within Amendment No. 223 do not match the TSs that were issued with the renewed facility operating license. Therefore, enclosed are: (1) a revised insert/remove page, and (2) revised TS pages.

We apologize for any inconvenience this may have caused.

Sincerely,  
/RA/  
Alan Wang, Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosures: 1. Insert/Remove Page  
2. TS Pages 2-3 - Page 3 and 2-3 - Page 7

cc w/encls: See next page

DISTRIBUTION:  
PUBLIC  
PDIV-2 Reading  
RidsNrrDlpmPdiv (HBerkow)  
RidsNrrPMAWang  
RidsNrrLAEPeyton  
RidsOgcRp  
RidsAcrsAcnwMailCenter  
RidsRegion4MailCenter (CJohnson)  
GHill (2)

**ACCESSION NO. ML041550573**

**NRR-058**

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	AWang	EPeyton:esp	MFields for SDembek
DATE	5/26/04	5/26/04	6-3-04

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn  
ATTN: James R. Curtiss, Esq.  
1400 L Street, N.W.  
Washington, DC 20005-3502

Chairman  
Washington County Board of Supervisors  
P.O. Box 466  
Blair, NE 68008

Mr. John Kramer, Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 310  
Fort Calhoun, NE 68023

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Ms. Sue Semerera, Section Administrator  
Nebraska Health and Human Services  
Systems  
Division of Public Health Assurance  
Consumer Services Section  
301 Centennial Mall, South  
P.O. Box 95007  
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager  
Fort Calhoun Station  
Omaha Public Power District  
Fort Calhoun Station FC-1-1 Plant  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

Mr. John B. Herman  
Manager - Nuclear Licensing  
Omaha Public Power District  
Fort Calhoun Station FC-2-4 Adm.  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee  
Bureau of Radiological Health  
Iowa Department of Public Health  
401 SW 7<sup>th</sup> Street, Suite D  
Des Moines, IA 50309

Mr. Richard P. Clemens  
Division Manager - Nuclear Assessments  
Omaha Public Power District  
Fort Calhoun Station  
P.O. Box 550  
Fort Calhoun, NE 68023-0550

ATTACHMENT TO LICENSE AMENDMENT NO. 223  
RENEWED FACILITY OPERATING LICENSE NO. DPR-40  
DOCKET NO. 50-285

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

REMOVE

2.3 - Page 3  
2.3 - Page 7

INSERT

2.3 - Page 3  
2.3 - Page 7