



Codes and Standards to be Applied to the ACR-700 Design in the U.S.

**Al Stretch, Principal Engineer, Safety Concepts
Presentation to US Nuclear Regulatory Commission**

Washington DC

May 25-26, 2004





Application of Codes and Standards

- **U.S. regulations, codes and standards will be applied to the ACR-700 design.**
- **Certain CANDU-specific aspects of the ACR-700 design will necessitate the use of additional requirements (i.e., such as those found in Canadian Standards)**



Background Information

CANDU Nuclear Standards

- **Developed over the last 30 years (National Standards of Canada)**
- **Define acceptable requirements and design methods.**
- **Accepted by regulator as part of standards ballot process.**
- **Applicable to plants built in Canada, to the extent agreed with the regulator.**
- **Used as input to the design, part of the design requirements.**
- **Compliance with the Canadian standards is not necessarily required by regulators in other countries.**



CANDU Nuclear Standards

- **CANDU standards series:**
 - **N285 : Systems and Components (pressure boundary)**
 - **N286 : Quality Assurance**
 - **N287 : Concrete Containment Structures**
 - **N288 : Environmental Radiation Protection**
 - **N289 : Seismic Design**
 - **N290 : Control Systems, Safety Systems, and Instrumentation**
 - **N293 : Fire Protection**



Application of U.S. Codes and Standards

- **Pressure Boundary Systems and Components (N285)**
 - **Code classification** **SRP 3.1, 3.2, RG 1.26, ANSI / ANS 51.1**
 - **Design** **10CFR50.55a, ASME Section III, B31.1, etc.**
 - **Supplemental requirements** **See next presentation**
 - **Metal containment** **ASME Section III**
 - **In-Service Inspection** **ASME Section XI**
 - **Material standards** **ASME Section II, supplemented for
ACR specific components**



Summary

- **The ACR-700 DCD will use U.S. codes and standards**
- **For CANDU-specific aspects of the ACR-700 design not addressed in the U.S. regulations, codes and standards, requirements from CANDU standards may be used**
- **The following presentations provide a detailed discussion of how this can be done for the ACR-700 RCPB**



 **AECL**
TECHNOLOGIES INC.