

~~_____~~ 4/23/97 interview w/

- Uvito, C. Coughlin

- Former QA mgr. -
- no support -

- not encouraging writing problems

✓ design engineering - general ✓

- control room doors - 1992

- heating boiler - 1991

- tried to "bump" him - by assigning him the entire project -

- 95 appraisal - "Don't write DER's"

- DER-ORG ⇒ proper dept ⇒ supervisor ⇒
 ⇒ completion - renewed by same department

12220
 542

(- Ct, under x-ten
 -)

- Speckout - sent most of package to them over time
 - bought issue directly to resident manager -

- progression of issue - over time - not actual
 statement of FOIA D.

Information in this record was deleted
 in accordance with the Freedom of Information
 Act, exemptions 7C
 FOIA- 2001-0107

Portions withheld - Ex 7C E11

Technical Issues - still open

→ Fuel Oil Tank

- 52 bldgs - list of SSCs - PEDB - no component detail - no list of components for "structures" -
- door qualifications 7 1/2 g. doors, with
- RB-Croj - may be more for 10 g. doors, 1/2 g. doors,
economic problem doors,
- ~1991 - roof inspection - 1992
- leak occurred in 1995 -
- Tornado protection for corridor to new S&A bldg
 - door only purchased as a tornado pressure boundary door & not a tornado outside boundary doors -
 - question: - questions veracity of answer, not that they didn't answer question.
- ESW pump room ventilation - dampers not Cat 1
 - pro raised to report - a few days ago
 - should be Cat 1 dampers
 - maybe alternate cooling/air supply to room
 - is this addressed by Fire Protection plan?
 - maybe damper shouldn't be there @ all -
 - question? - possibility of closure based on cause other than fire
 - answer was that a "plume study" was done & pro would not get down to
 - Insulation Procedure -
need IP# or Hot#
- ESW pump room: R.C. 10, 15 floor of S&A bldg
 - not double protected
- Det 97-45 - leftover for Boiler piping in RB
 - not supported & for some time

[- potable water - only supply of dem water]

[- possibility to see same problems w/ other DFLs -
- recent exp on ~~out~~ other DFLs -]

- Reorganization -

J. Erki - heady up 50.54(f) - 1992

- systematically discriminated against -

- "more" dots than every one else -

Speckard - not interested in giving issues to
them anymore - issues go right to
upper level management -

- Hens of long over claim of command - M. Coulomb
- 1992 - telling DFLs to GM is 1st line report -

[- GL 88.14 NMP 2 -]

- Snubbers - 7/8 ~ 10/89
- pulled snubbers list off of a computer
- database showed that was not kosher
- was paid
- reconstituted snubbers database
- agents should have known better