

June 9, 2004

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF MEETING HELD ON MAY 27, 2004, TO DISCUSS PACIFIC GAS AND ELECTRIC COMPANY'S (PG&E) RESPONSE TO THE SAN SIMEON EARTHQUAKE AND RELATED LICENSING BASIS ISSUES

On May 27, 2004, representatives of PG&E met with the NRC staff to make a presentation on their response to the San Simeon earthquake and related licensing basis issues.

The meeting began with PG&E's discussion that their decision for not shutting down the plant was appropriate. The San Simeon earthquake was significantly less than the design earthquake (DE) and did not have the potential to cause damage to the Diablo Canyon Power Plant (DCPP). PG&E further stated that the excursion from the DE vertical response spectra at top of containment was as expected, and the DCPP DE licensing/design basis provides adequate margin for the operating basis earthquake function. Finally, PG&E also discussed that San Simeon earthquake was consistent with the tectonic framework developed in the DCPP long-term seismic program. Following the meeting, the staff expressed its appreciation to PG&E for their presentation.

An attendance list is provided in the attachment. The presentation slides used during the meeting are available in ADAMS under Accession No. ML041490247.

/RA/

Girija S. Shukla, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Attachment: Attendance List

cc w/att: See next page

June 9, 2004

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF MEETING HELD ON MAY 27, 2004, TO DISCUSS PACIFIC GAS AND ELECTRIC COMPANY'S (PG&E) RESPONSE TO THE SAN SIMEON EARTHQUAKE AND RELATED LICENSING BASIS ISSUES

On May 27, 2004, representatives of PG&E met with the NRC staff to make a presentation on their response to the San Simeon earthquake and related licensing basis issues.

The meeting began with PG&E's discussion that their decision for not shutting down the plant was appropriate. The San Simeon earthquake was significantly less than the design earthquake (DE) and did not have the potential to cause damage to the Diablo Canyon Power Plant (DCPP). PG&E further stated that the excursion from the DE vertical response spectra at top of containment was as expected, and the DCPP DE licensing/design basis provides adequate margin for the operating basis earthquake function. Finally, PG&E also discussed that San Simeon earthquake was consistent with the tectonic framework developed in the DCPP long-term seismic program. Following the meeting, the staff expressed its appreciation to PG&E for their presentation.

An attendance list is provided in the attachment. The presentation slides used during the meeting are available in ADAMS under Accession No. ML041490247.

/RA/

Girija S. Shukla, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Attachment: Attendance List

cc w/att: See next page

DISTRIBUTION:

PUBLIC

PDIV-2 Reading

RidsNrrDlpm (LMarsh/ELeeds)

RidsNrrDlpmLpdiv (HBerkow)

RidsNrrPMGShukla

RidsNrrLAEPeyton

RidsOgcMailCenter

RidsAcrcAcnwMailCenter

TMensah (NRR/PMAS)

GImbro

KManoly

GBagchi

YLi

See-Meng Wong

MYoung

DTang

BJones (Region IV)

BTripathi

RHall

RTadessee, EDO

Meeting Notice: ML041270523

ADAMS Accession No.: ML041620315

PKG: ML041620324

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	SDembek for GShukla:mp	EPeyton	SDembek
DATE	6/9/04	6/7/04	6/9/04

OFFICIAL RECORD COPY

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML041620315.wpd

MEETING WITH PACIFIC GAS AND ELECTRIC COMPANY

ATTENDANCE LIST

MAY 27, 2004

PACIFIC GAS & ELECTRIC COMPANY

L. Womack
S. Ketelsen
L. Parker
B. Horstman
N. Jahangir
D. Locke
D. Miklush
L. Cluff
N. Abrahamson
B. Norton
B. Kennedy

NRC

G. Shukla
G. Imbro
K. Manoly
G. Bagchi
Y. Li
S. Wong
M. Young
D. Tang
B. Jones
B. Tripathi
R. Hall

Diablo Canyon Power Plant, Units 1 and 2

cc:

NRC Resident Inspector
Diablo Canyon Power Plant
c/o U.S. Nuclear Regulatory Commission
P.O. Box 369
Avila Beach, CA 93424

Sierra Club San Lucia Chapter
c/o Henriette Groot
1000 Montecito Road
Cayucos, CA 93430

Ms. Nancy Culver
San Luis Obispo
Mothers for Peace
P.O. Box 164
Pismo Beach, CA 93448

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, CA 93408

Mr. Truman Burns
Mr. Robert Kinosian
California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, CA 94102

Diablo Canyon Independent Safety
Committee
ATTN: Robert R. Wellington, Esq.
Legal Counsel
857 Cass Street, Suite D
Monterey, CA 93940

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Richard F. Locke, Esq.
Pacific Gas & Electric Company
P.O. Box 7442
San Francisco, CA 94120

Mr. David H. Oatley, Vice President
and General Manager
Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

City Editor
The Tribune
3825 South Higuera Street
P.O. Box 112
San Luis Obispo, CA 93406-0112

Mr. Ed Bailey, Chief
Radiologic Health Branch
State Department of Health Services
P.O. Box 997414 (MS 7610)
Sacramento, CA 95899-7414

Mr. James D. Boyd, Commissioner
California Energy Commission
1516 Ninth Street (MS 31)
Sacramento, CA 95814

Mr. James R. Becker, Vice President
Diablo Canyon Operations
and Station Director
Diablo Canyon Power Plant
P.O. Box 3
Avila Beach, CA 93424

Mr. Gregory M. Rueger
Senior Vice President, Generation and
Chief Nuclear Officer
Pacific Gas and Electric Company
Diablo Canyon Power Plant
P.O. Box 3
Avila Beach, CA 93424